

PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans
Rulemaking 18-10-007
Data Response

PG&E Data Request No.:	WSD_007-Q03		
PG&E File Name:	WildfireMitigationPlans_DR_WSD_007-Q03		
Request Date:	March 1, 2021	Requester DR No.:	WSD-2021 WMP-02
Date Sent:	March 4, 2021	Requesting Party:	Wildfire Safety Division
PG&E Witness:		Requester:	Ryan Arba

QUESTION 03

Enter the total circuit miles for each category in the following table. HFTD = High Fire Threat District, Tx = Transmission Lines, Dx = Distribution Lines, OH = Overhead, UG = Underground.

Location	Tx-OH	Tx-UG	Dx-OH	Dx-UG	TOTAL
<i>Non-HFTD</i>					
<i>HFTD-Zone 1</i>					
<i>HFTD-Tier 2</i>					
<i>HFTD-Tier 3</i>					
TOTAL					

ANSWER 03

Location	Tx-OH	Tx-UG	Dx-OH	Dx-UG	TOTAL
<i>Non-HFTD</i>	12,609.62	171.50	55,481.68	24,382.51	92,645.31
<i>HFTD-Zone 1</i>	6.13	-	14.83	11.84	32.80
<i>HFTD-Tier 2</i>	4,227.98	10.05	18,278.05	2,022.07	24,538.15
<i>HFTD-Tier 3</i>	1,292.42	0.71	7,062.92	699.60	9,055.65
TOTAL	18,136.15	182.26	80,837.48	27,116.02	126,271.91