

**PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans Discovery 2022
Data Response**

PG&E Data Request No.:	OEIS_007-Q12		
PG&E File Name:	WMP-Discovery2022_DR_OEIS_007-Q12		
Request Date:	March 28, 2022	Requester DR No.:	Data Request OEIS-PG&E-22-007
Date Sent:	March 30, 2022	Requesting Party:	Office of Energy Infrastructure Safety
PG&E Witness:		Requester:	Kevin Miller

SUBJECT: COVERED CONDUCTOR

QUESTION 12

Regarding covered conductor inspections and maintenance.

- a. Provide the following job aids:
 - i. TD-2305M-JA02
 - ii. TD-2305M-JA08
 - iii. TD-2305M-JA12
- b. Provide a description and list of all changes made to inspections and maintenance procedures as it directly relates to covered conductor and all associated equipment.

ANSWER 12

- a.
 - i. Please see attachment "WMP-Discovery2022_DR_OEIS_007-Q12Atch01.pdf".
 - ii. Please see attachment "WMP-Discovery2022_DR_OEIS_007-Q12Atch02.pdf".
 - iii. Please see attachment "WMP-Discovery2022_DR_OEIS_007-Q12Atch03.pdf".
- b. As mentioned on page 439 of the 2022 WMP, "PG&E does not have a separate covered conductor maintenance program. Like bare conductor, covered conductor is inspected for visual concerns as part of our standard GO 165 inspections." There are currently no special maintenance recommendations specifically for covered conductor.