

**PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans Discovery 2023
Data Response**

PG&E Data Request No.:	SPD 003-Q003		
PG&E File Name:	WMP-Discovery2023_DR_SPD_003-Q003		
Request Date:	April 12, 2023	Requester DR No.:	SPD PG&E 2023_003
Date Sent:	April 19, 2023	Requesting Party:	Safety Policy Division
DRU Index #:		Requester:	Kevin Miller

SUBJECT: DATA REQUEST SPD_PG&E_2023_003 DUE 4.19.2023

QUESTION 003

Confirm or revise PG&E’s Butte County OH to UG conversion factor in the 2023-2025 WMP (currently 1.57 in the GRC) based on actual and estimated UG miles for 2023-2026. In the PG&E 2023 GRC Reply Brief (Dec '22) PG&E forecast 2,000 SH UG miles (MAT 08W) and 100 Butte County UG miles (MAT 95F) for 2023-2026.

**TABLE PG&E-8.1.2-1:
OVERALL SYSTEM HARDENING MILEAGE FORECAST**

Year	Estimated Overhead Covered Conductor Miles	Estimated System Hardening Undergrounding Miles	Estimated Line Removal Miles	Overall System Hardening Target	Estimated Butte County Rebuild Undergrounding Miles
2023	110	280	30	420	70
2024	75	380	15	470	70
2025	50	515	15	580	35
2026	50	750	15	815 ^(a)	0
2023-2026	285	1,925	75	2,285	175

(a) The 2023 WMP requires annual targets for 2023-2025. The 2026 miles are provided as a forecast only.

**TABLE 4-2:
SYSTEM HARDENING UNDERGROUND
PG&E'S ADJUSTED UNDERGROUND MILES FORECAST – MAT 08W AND MAT 95F**

PG&E's Forecast Miles	2021	2022	2023	2024	2025	2026	Total 2023- 2026
Adjusted Underground Miles Proposal (MAT 08W)	30	139	308	415	527	750	2,000
Adjusted Underground Miles Proposal (MAT 95F) ^(a)	--	36	42	35	23	0	100
Adjusted Underground Miles - Total	30	175	350	450	550	750	2,100
(a) The number of underground miles tracked in MAT 95F has not been adjusted.							

ANSWER 003

PG&E confirms that our Butte County OH to UG conversion factor for the 2023-2025 WMP is 1.57.