

The following questions relate to PG&E's inspections of transmission towers.

QUESTION 11

- a) How many Priority A corrective tags were issued as a result of work verification or quality control of transmission tower drone inspections in 2020?
- b) How many Priority B corrective tags were issued as a result of work verification or quality control of transmission tower drone inspections in 2020?
- c) Please respond to questions 11(a) through 11(b) for:
 - i. 2018.
 - ii. 2019.

ANSWER 11

AIR inspections include review of images taken by helicopter, drone, or both. It is not possible for me to separate these two techniques, although in general towers of any voltage tend to be drone imagery. Determined by the presence of DI or NN in the description.

Type	Year	A	B
AIR Work Verification	2018	-	-
	2019	-	3
	2020	2	14