

PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans
Rulemaking 18-10-007
Data Response

PG&E Data Request No.:	WSD_010-Q15		
PG&E File Name:	WildfireMitigationPlans_DR_WSD_010-Q15		
Request Date:	March 15, 2021	Requester DR No.:	WSD to PGE – Data Request – 20210315
Date Sent:	March 17, 2021	Requesting Party:	Wildfire Safety Division
PG&E Witness:		Requester:	Ryan Arba

QUESTION 15

Regarding “in-flight” hardening projects:

- a. Are all "in-flight" hardening projects based on the 2018-2020 modeling top CPZ categorization?
- b. How many "in-flight" hardening projects cancelled due to CPZ reprioritization from the 2021 Wildfire Model? Provide both the number of CPZs and the total circuit miles.

ANSWER 15

- a. In-flight hardening projects were selected and scoped based on the 2019-2020 Wildfire Risk Model. These projects, if within the top 20% of the 2021 Wildfire Distribution Risk Model or had “broken ground” (i.e., poles installed), the project was approved to move forward in 2021.
- b. No in-flight projects were officially cancelled at this time due to the risk model change; however, all remaining in-flight projects not identified in subpart (a) have been put on hold and may not proceed in 2021. PG&E continues to meet and discuss additional risks within those projects to determine the possibility to re-allocate that work into future years.