

**PACIFIC GAS AND ELECTRIC COMPANY  
Wildfire Mitigation Plans Discovery 2022  
Data Response**

PG&E Data Request No.:	CalAdvocates_003-Q09		
PG&E File Name:	WMP-Discovery2022_DR_CalAdvocates_003-Q09		
Request Date:	January 25, 2022	Requester DR No.:	003
Date Sent:	February 1, 2022	Requesting Party:	Public Advocates Office
PG&E Witness:		Requester:	Alan Wehrman

The following questions relate to your 2022 WMP Update submission.

If a full response to a given question will be included in your WMP submission, your response to that question of this data request may consist of a citation to the specific page(s) or table(s) of the WMP where the information may be found, a written response to the question, or both.

**QUESTION 09**

Note: this question refers to transmission structures generally, and should not be construed to be limited to 500 kV towers.

- a. How many Priority A corrective tags were issued as a result of work verification or quality control of transmission tower climbing inspections performed in 2021?
- b. How many Priority B corrective tags were issued as a result of work verification or quality control of transmission tower climbing inspections performed in 2021?

**ANSWER 09**

PG&E's search of LC tags issued as a result of both desktop and field Quality Control reviews did not identify any Priority A or Priority B LC tags issued for climbing inspections.