

**PACIFIC GAS AND ELECTRIC COMPANY  
Wildfire Mitigation Plans Discovery 2023  
Data Response**

PG&E Data Request No.:	CalAdvocates_011-Q009		
PG&E File Name:	WMP-Discovery2023_DR_CalAdvocates_011-Q009		
Request Date:	April 5, 2023	Requester DR No.:	CalAdvocates-PGE-2023WMP-11
Date Sent:	April 10, 2023	Requesting Party:	Public Advocates Office
DRU Index #:		Requester:	Pui-Wa LI

The following questions relate to your 2023-2025 WMP submission and also the following documents:

- PG&E's 2022 WMP, Section 7.1.E, Attachment 1 (Attch\_Q3.pdf),
- PG&E's presentation during the 2021 EPIC Symposium (Attch\_Q6\_EPIC\_Presentation.pdf),
- PG&E's Electric Preliminary Statement Part FY (Tariff Sheet No. 52259-E), and
- PG&E's Test Year 2023 GRC, Application 21-06-021, Exhibit PG&E-04 and Exhibit PG&E-17.

**TOPIC: RAPID EARTH FAULT CURRENT LIMITER (REFCL)**

**QUESTION 009**

At which substations, other than the Calistoga substation, has PG&E tested REFCL?

**ANSWER 009**

We have not tested REFCL at any substations other than the Calistoga substation.