

**PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans Discovery 2023
Data Response**

| | | | |
|------------------------|--|-------------------|---------------------------------|
| PG&E Data Request No.: | CalAdvocates_026-Q010 | | |
| PG&E File Name: | WMP-Discovery2023_DR_CalAdvocates_026-Q010 | | |
| Request Date: | July 27, 2023 | Requester DR No.: | No. CalAdvocates-PGE-2023WMP-26 |
| Date Sent: | August 17, 2023 | Requesting Party: | Public Advocates Office |
| PG&E Witness: | | Requester: | Holly Wehrman |

QUESTION 010

Provide updated GIS layers of primary distribution, secondary distribution, and transmission lines, with the following attributes:

- a) Circuit ID Number
- b) Peak load in Amperes observed since January 1, 2014.
- c) Circuit Capacity in Amperes

ANSWER 010

The attachment to this response contains confidential material and is provided pursuant to the accompanying confidentiality declaration.

Please refer to “*WMP-Discovery2023_DR_CalAdvocates_026-Q010Atch01CONF.zip*” for the requested GIS attributes for our primary distribution system. Line section attributes may include additional circuits not shown in the response to Q009. The list of circuits in Q009 includes only those circuits that are studied as part the distribution planning process. Single-customer circuits, tie cables, and idle circuits are not included. Please note, this attachment contains confidential information. Also, we do not model the secondary distribution system, nor record secondary distribution loading.

As agreed to, PG&E will provide a response to the portion of this request relating to transmission lines in a subsequent response by Thursday, August 24th.