

**PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans Discovery 2023
Data Response**

PG&E Data Request No.:	OEIS_003-Q012		
PG&E File Name:	WMP-Discovery2023_DR_OEIS_003-Q012		
Request Date:	April 21, 2023	Requester DR No.:	P-WMP_2023-PG&E-003
Date Sent:	April 26, 2023	Requesting Party:	Office of Energy Infrastructure Safety
DRU Index #:		Requester:	Colin Lang

SUBJECT: REGARDING PG&E’S RESPONSE TO P-WMP_2023-PG&E-002-Q07

QUESTION 012

- a. PG&E states that it is still performing targeted equipment repairs relating to EPSS. Is this a program separate from that described within Section 8.1.7 of its WMP? If so, provide the following:
 - i. Description and procedures in which PG&E uses to decide when and where it will perform EPSS-related targeted equipment repairs.
 - ii. How PG&E reallocates resources to address these EPSS-related targeted equipment repairs (particularly in relation to the program described in Section 8.1.7).
 - iii. The scale of such EPSS-related targeted equipment repairs (i.e., number of work orders, number of CPZs included in this program).
- b. In the attachment “WMP-Discovery2023_DR_OEIS_002-Q009Atch02.xlsx”, targeted equipment repairs are not included as part of the additional mitigations being completed. Why were these not included if PG&E is still using this measure?
- c. Provide a GIS file with the locations of CPZs scoped for additional reliability mitigations based on EPSS impacts.

ANSWER 012

The confidential material is being provided pursuant to the accompanying confidentiality declaration.

- a. (i) (ii) (iii) EPSS targeted equipment repairs are incorporated into the Open Work Orders Tag program as described in Section 8.1.7 of the WMP. EPSS targeted equipment repairs can be either an EC, ER, or CE Notification. Notifications with a potential reliability impact on EPSS circuits receive a priority ranking for visibility during work scheduling to allow them to be scheduled on a priority basis compared to other work. Field Operations uses the priority ranking during scheduling to help in decision-making and subsequent execution. PG&E is currently using the prioritization criteria from 2022 that is based on circuit risk rankings.
- b. EPSS targeted equipment repairs are currently included as a part of attachment “WMP-Discovery2023_DR_OEIS_002-Q009Atch02.xlsx” in column T (Open Work

Tags (Asset)). These Tags may constitute EC, ER, and CE Notifications and may be EPSS targeted equipment repairs or other types of work.

The additional mitigation measures previously included in the attachment are mitigation measures being undertaken from a reliability improvement perspective. These are in addition to the Open Work Orders Tag program.

- c. Please see attached file "*WMP-Discovery2023_DR_OEIS_003-Q012Atch01CONF.kmz*."