



Calling 9-1-1 to Report Ignitions

Reporting Ignitions on the Jobsite

TD-1464S requires that all PG&E work related ignitions must be reported to the fire “Authority Having Jurisdiction” (AHJ). All ignitions, even those that are successfully and completely extinguished by PG&E employees and contract partners, must be reported to the AHJ. The easiest and most effective way to report an ignition is to call 9-1-1.

When fires ignite on the jobsite, work personnel must perform the following actions:

1. Call emergency services (9-1-1) to report the ignition, **even if the fire has been fully extinguished**. Be prepared to report the following information:
 - Incident type and brief description (including impacted assets)
 - Any injuries
 - Location (address/city, cross street-landmark identifiers, latitude and longitude, best access route)
 - Hazards in the area (i.e., bridges or powerlines)
 - Fire size/fuel type (including estimated rate of spread)
2. Take safe, reasonable suppression actions consistent with PG&E training.
3. If necessary, evacuate to a safe location and provide any information possible to first responders when they arrive.
4. After contacting emergency services, the jobsite supervisor must call the Hazard Awareness and Warning Center (HAWC) at 1-800-255-7593 to report the fire. The jobsite supervisor must include the following information, at a minimum:
 - Location (address/city, cross street-landmark identifiers, latitude and longitude, best access route)
 - Source of ignition
 - Impacted assets
5. All jobsite work personnel **must** report incidents to their direct supervisors, and follow any additional reporting procedures, as required (e.g., notify Control Centers).