



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 1

TABLE OF CONTENTS

A.	TABLE OF CONTENTS	1	
B.	APPLICABILITY	15	(T)
1.	APPLICABILITY	15	
2.	DEFINITIONS	15	
3.	APPLICABLE CODES AND STANDARDS	16	
4.	RETAIL CUSTOMER ENERGY STORAGE DEVICES	16	
C.	DEFINITIONS	16	
D.	GENERAL, RULES, RIGHTS AND OBLIGATIONS	34	
1.	AUTHORIZATION REQUIRED TO OPERATE	34	
2.	SEPARATE AGREEMENTS REQUIRED FOR OTHER SERVICES	34	
3.	SERVICES UNDER THIS TARIFF LIMITED TO INTERCONNECTION	35	
4.	COMPLIANCE WITH LAWS, RULES, AND TARIFFS	35	
5.	DESIGN REVIEWS AND INSPECTIONS	36	
6.	RIGHT TO ACCESS	36	
7.	CONFIDENTIALITY	36	
a.	Scope	36	
b.	Limitations on Scope	37	
c.	Disclosure to Commission, FERC, or their respective Staff	38	
d.	Required Disclosure	39	(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 2

TABLE OF CONTENTS (Cont'd.)

D.	GENERAL, RULES, RIGHTS AND OBLIGATIONS (Cont'd.)		
8.	PRUDENT OPERATION AND MAINTENANCE REQUIRED	39	
9.	CURTAILMENT AND DISCONNECTION	40	
10.	LOCAL FURNISHING BONDS	40	
11.	COORDINATION WITH AFFECTED SYSTEMS	41	
12.	TRANSFERABILITY OF INTERCONNECTION REQUEST	41	
13.	SPECIAL PROVISIONS APPLICABLE TO CERTAIN NET ENERGY METERED APPLICANTS	41	
14.	SPECIAL PROVISIONS APPLICABLE TO NON-EXPORT ENERGY STORAGE GENERATING FACILITIES	45	
15.	COMPLIANCE WITH ESTABLISHED TIMELINES	45	
16.	MODIFICATION OF TIMELINES	45	
E.	INTERCONNECTION REQUEST SUBMISSION PROCESS	46	
1.	OPTIONAL STANDARD AND ENHANCED PRE-APPLICATION REPORTS	46	
a.	Standard Pre-Application Report	46	
b.	Enhanced Pre-Application Report	47	
2.	INTERCONNECTION REQUEST PROCESS	51	
a.	Applicant Initiates Contact with Distribution Provider	51	
b.	Applicant Selects a Study Process	52	
c.	Applicant Completes an Interconnection Request	53	
d.	Site Exclusivity	56	
3.	INTERCONNECTION REQUEST FEE AND STUDY DEPOSIT	56	
a.	Detailed Study Deposit	57	(T)

(Continued)



**ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS**

Sheet 3

TABLE OF CONTENTS (Cont'd.)

E.	INTERCONNECTION REQUEST SUBMISSION PROCESS (Cont'd.)		
4.	INTERCONNECTION COST RESPONSIBILITY	62	
a.	Costs of Interconnection and Parallel Operation	62	
b.	Methodology and Timing of Cost Identification	62	
c.	Timing of Cost Identification	63	
d.	Producer Costs During Parallel Operation	63	
e.	Cost Allocation	63	
f.	Summary Tables	65	
5.	INTERCONNECTION REQUEST VALIDATION AND ASSIGNMENT OF QUEUE POSITION	67	
a.	Acknowledgement of Interconnection Request	67	
b.	Deficiencies in Interconnection Request	67	
c.	Assignment of Queue Position	69	
d.	Publication of the Interconnection Queue	70	
Ee.	MODIFICATION TO INTERCONNECTED GENERATING FACILITIES	72	(N)
1.	MODIFICATIONS TO EXISTING EQUIPMENT (D. 19-03-013 - TYPE II)	72	(N)
F.	REVIEW PROCESS FOR INTERCONNECTION REQUESTS	74	(T)
1.	OVERVIEW OF THE INTERCONNECTION REVIEW PROCESS	74	(T)
a.	Valid Interconnection Request	74	(T)
b.	Fast Track Review	75	(T)
c.	Detailed Studies	76	(T)
d.	Compliance with Timelines	76	(T)

(Continued)



**ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS**

Sheet 4

TABLE OF CONTENTS (Cont'd.)

F.	REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.)		
2.	FAST TRACK INTERCONNECTION REVIEW PROCESS	78	
	a. Initial Review	78	
	b. Optional Initial Review Results Meeting	82	
	c. Supplemental Review	83	
	d. Optional Supplemental Review Results Meeting	87	
	e. Execution of the Generator Interconnection Agreement	87	
3.	DETAILED STUDY INTERCONNECTION REVIEW PROCESS	91	
	a. Detailed Study Track Selection Process	91	
	b. Independent Study Process	93	
	c. Distribution Group Study Process	102	
	d. WDT Transmission Cluster Study Process	116	
	e. Generator Interconnection Agreement	118	
	f. Engineering & Procurement (E&P) Agreement	121	
4.	BILL ON ESTIMATE	123	(D) ----- (D) (N)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 5

TABLE OF CONTENTS (Cont'd.)

F.	REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.)		
5.	COMMISSIONING TESTING AND PARALLEL OPERATION	124	(T)
	a. Commissioning Testing	124	
	b. Parallel Operation or Momentary Parallel Operation	124	
6.	WITHDRAWAL	125	
7.	Cost Envelope Option	126	
	a. Eligibility for Cost Envelope Option	126	
	b. Cost Responsibility for Facilities Subject to Cost Envelope	128	
	c. Timing of Applicant's Selection of Cost Envelope and Payment of Deposit	129	
	d. Distribution Provider's Preparation of the Cost Envelope Estimate	131	
	e. Cost Elements Not Subject to Cost Envelope	132	
	f. Modifications	134	
	g. Tender of the Generator Interconnection Agreement Under the Cost Envelope Option	135	
8.	Design and Construction Timeline	135	
G.	ENGINEERING REVIEW DETAILS	136	
1.	INITIAL REVIEW SCREENS	138	
	a. Screen A: Is the PCC on a Networked Secondary System?	139	
	b. Screen B: Is Certified Equipment used?	139	
	c. Screen C: Is the Starting Voltage Drop within acceptable limits?	140	(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 6

TABLE OF CONTENTS (Cont'd.)

G.	ENGINEERING REVIEW DETAILS (Cont'd.)		
1.	INITIAL REVIEW SCREENS (Cont'd.)		
	d. Screen D: Is the transformer or secondary conductor rating exceeded?	141	(T)
	e. Screen E: Does the Single-Phase Generator cause unacceptable imbalance?	141	
	f. Screens F: Is the Short Circuit Current Contribution Ratio within acceptable limits?	141	
	Screen F1: Is the per unit Short Circuit Current contribution under allowable levels?	141	
	g. Screen G: Is the Short Circuit Interrupting Capability Exceeded?	143	
	h. Screen H: Is the line configuration compatible with the Interconnection type?	144	
	i. Screen I: Will power be exported across the PCC?	145	
	j. Screen J: Is the Gross Rating of the Generating Facility 30 kVA or less?	149	
	k. Screen K: Is the Generating Facility a Net Energy Metering (NEM) Generating Facility with nameplate capacity less than or equal to 500kW?	149	
	l. Screen L: Transmission Dependency and Transmission Stability Test	150	
	m. Screen M: Does the Generating Facility pass the ICA as required in G.1.m or is aggregate generation less than 15% of line section peak load for all line sections bounded by automatic sectionalizing devices?	151	(T)

(Continued)



**ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS**

Sheet 7

TABLE OF CONTENTS (Cont'd.)

G.	ENGINEERING REVIEW DETAILS (Cont'd.)		
2.	SUPPLEMENTAL REVIEW SCREENS	152	(T)
a.	Screen N: Penetration Test	152	
b.	Screen O: Power Quality and Voltage Tests	156	
c.	Screen P: Safety and Reliability Tests	157	
3.	DETAILED STUDY SCREENS	159	
a.	Screen Q: Is the Interconnection Request electrically Independent of the Transmission System?	159	
b.	Screen R: Is the Interconnection Request independent of other earlier-queued and yet to be studied interconnection requests interconnecting to the Distribution System?	161	
c.	Independent Study Process and Distribution Group Study Process Interconnection Studies	162	
H.	GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS	166	
1.	GENERAL INTERCONNECTION AND PROTECTIVE FUNCTION REQUIREMENTS	166	
a.	Protective Functions Required	166	
b.	Momentary Paralleling Generating Facilities	167	
c.	Suitable Equipment Required	168	
d.	Visible Disconnect Required	169	
e.	Drawings Required	169	
f.	Generating Facility Conditions Not Identified	170	(T)

(Continued)



**ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS**

Sheet 8

TABLE OF CONTENTS (Cont'd.)

H.	GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS (Cont'd.)		
2.	PREVENTION OF INTERFERENCE	170	(T)
a.	Voltage Regulation	170	
b.	Voltage Trip Setting	171	
c.	Paralleling	174	
d.	Flicker	174	
e.	Integration with Distribution Provider's Distribution System Grounding	175	
f.	Frequency	175	
g.	Harmonics	177	
h.	Direct Current Injection	178	
i.	Power Factor	178	
3.	TECHNOLOGY SPECIFIC REQUIREMENTS	179	
a.	Technology Specific Requirements	179	
b.	Induction Generators	179	
c.	Inverters	180	
d.	Limitations on Inverters Not Classified as Smart Inverters	180	
e.	Non-Export AC/DC Converters	180	(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 9

TABLE OF CONTENTS (Cont'd.)

H.	GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS (Cont'd.)		
4.	SUPPLEMENTAL GENERATING FACILITY REQUIREMENTS	181	(T)
a.	Fault Detection	181	
b.	Transfer Trip	181	
c.	Reclose Blocking	181	
Hh.	SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS	181	
1.	GENERAL INTERCONNECTION AND PROTECTIVE FUNCTION REQUIREMENTS	183	
a.	Protective Functions Required	184	
b.	Momentary Paralleling Generating Facilities	185	
c.	Suitable Equipment Required	185	
d.	Visible Disconnect Required	185	
e.	Drawings Required	187	
f.	Generating Facility Conditions Not Identified	187	
2.	PREVENTION OF INTERFERENCE	188	
a.	Voltage Regulation	188	
b.	Voltage Trip and Ride-Through Settings	188	
c.	Paralleling	191	
d.	Flicker	191	
e.	Integration with Distribution Provider's Distribution System Grounding	191	(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 10

TABLE OF CONTENTS (Cont'd.)

Hh.	SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS (Cont'd.)		
2.	PREVENTION OF INTERFERENCE (Cont'd.)		
	f. Frequency	192	(T)
	g. Harmonics	193	
	h. Direct Current Injection	194	
	i. Fixed Power Factor	194	
	j. Dynamic Volt/VAR Operations	195	
	k. Ramp Rate Requirements	197	
	l. Recommended Frequency-Watt Settings	197	
	m. Smart Inverters	199	
	n. Default Activation States for Phase 1 Functions	201	
	o. Load Shedding or Transfer	201	
	p. Default Activation States for Phase 1 Functions	202	
	q. Phase 3 Function	203	
3.	TECHNOLOGY SPECIFIC REQUIREMENTS	203	
4.	SUPPLEMENTAL SMART INVERTER REQUIREMENTS	204	
	a. Fault Detection	204	
	b. Transfer Trip	204	
	c. Reclose Blocking	204	
5.	COMMUNICATION REQUIREMENTS	205	
	a. Generating Facilities utilizing inverter-based technologies must adhere to all of the following communication protocol requirements:	205	(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 11

TABLE OF CONTENTS (Cont'd.)

Hh.	SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS (Cont'd.)		
5.	COMMUNICATION REQUIREMENTS (Cont'd.)		
	b. Additional communication protocol requirements shall also apply to Generating Facilities utilizing inverter-based technologies as provided in the following documents	206	(T)
	c. Additional communication protocol requirements shall also apply to Generating Facilities utilizing inverter-based technologies as provided in the following documents:	207	
6.	SCHEDULING CAPABILITY REQUIREMENTS	208	
7.	MONITORING AND TELEMETRY REQUIREMENTS	210	
8.	CONTROL THROUGH COMMUNICATION CAPABILITIES	213	
I.	THIRD-PARTY INSTALLATIONS, RESERVATION OF UNUSED FACILITIES, AND REFUND OF SALVAGE VALUE	214	
1.	INTERCONNECTION FACILITIES AND DISTRIBUTION UPGRADES	214	
2.	THIRD-PARTY INSTALLATIONS	214	
3.	RESERVATION OF UNUSED FACILITIES	215	
4.	REFUND OF SALVAGE VALUE	215	
J.	METERING, MONITORING AND TELEMETERING	215	
1.	GENERAL REQUIREMENTS	215	
2.	METERING BY NON-DISTRIBUTION PROVIDER PARTIES	215	
3.	NET GENERATION OUTPUT METERING	216	
4.	POINT OF COMMON COUPLING (PCC) METERING	218	
5.	TELEMETERING	218	
6.	LOCATION	219	
7.	COSTS OF METERING	219	
8.	MULTIPLE TARIFF METERING	219	(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 12

TABLE OF CONTENTS (Cont'd.)

K.	DISPUTE RESOLUTION PROCESS	220	(T)
1.	SCOPE	220	
2.	PROCEDURES	220	
3.	PERFORMANCE DURING DISPUTE	224	
L.	CERTIFICATION AND TESTING CRITERIA	230	
1.	INTRODUCTION	230	
2.	CERTIFIED AND NON-CERTIFIED INTERCONNECTION EQUIPMENT	232	
a.	Certified Equipment	232	
b.	Non-Certified Equipment	233	
3.	TYPE TESTING	234	
a.	Type Tests and Criteria for Interconnection Equipment Certification	234	
b.	Anti-Islanding Test	236	
c.	Non-Export Test	236	
d.	In-rush Current Test	237	
e.	Surge Withstand Capability Test	238	
f.	Synchronization Test	238	
g.	Paralleling Device Withstand Test	239	
h.	Backfeed Test	239	(T)

(Continued)



**ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS**

Sheet 13

TABLE OF CONTENTS (Cont'd.)

L.	CERTIFICATION AND TESTING CRITERIA (Cont'd.)		
4.	PRODUCTION TESTING	239	(T)
5.	COMMISSIONING TESTING	240	
a.	Commissioning Testing	240	
b.	Review, Study, and Additional Commissioning Test Verification Costs	241	
c.	Other Checks and Tests	242	
d.	Certified Equipment	242	
e.	Non-Certified Equipment	243	
f.	Verification of Settings	243	
g.	Trip Tests	244	
h.	In-service Tests	244	
6.	PERIODIC TESTING	245	
7.	TYPE TESTING PROCEDURES NOT DEFINED IN OTHER STANDARDS	245	
a.	Non-Exporting Test Procedures	245	
b.	In-rush Current Test Procedures	256	(T)
M.	INADVERTENT EXPORT	257	(T)/(P)
Mm.	INADVERTENT EXPORT FOR INTERCONNECTION REQUESTS UTILIZING UL-1741 CERTIFIED OR SA LISTED GRID SUPPORT (NONISLANDING) INVERTERS	259	
Mm1.	OPTION 8: Non-Export Utilizing Certified Power Control Systems	263	
Mm2.	OPTION 9: Limited Export Utilizing Certified Power Control Systems	265	
Mm3.	OPTION 10: Non-Export with Inadvertent Export Utilizing Certified Power Control Systems	267	
Mm4.	OPTION 11: Limited Export with Inadvertent Export Utilizing Certified Power Control Systems	269	(T)/(P)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 14

TABLE OF CONTENTS (Cont'd.)

			(P)
N.	EXPEDITED INTERCONNECTION PROCESS FOR NON-EXPORT ENERGY STORAGE GENERATING FACILITIES	271	(T)
	1. ELIGIBILITY REQUIREMENTS	271	
	2. GENERATING FACILITY ELIGIBILITY CRITERIA	272	
O.	AC/DC CONVERTER ELIGIBILITY CRITERIA	273	(T)
P.	SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741 SB INVERTERS	274	(T)/(P)
	1. GENERAL INTERCONNECTION AND PROTECTIVE FUNCTION REQUIRMENTS	275	
	2. PREVENTION OF INTERFERENCE	280	
	3. TECHNOLOGY SPECIFIC REQUIREMENTS	295	
	4. SUPPLEMENTAL SMART INVERTER REQUIREMENTS	296	
	5. COMMUNICATION REQUIREMENTS	297	
	6. SCHEDULING CAPABIITY REQUIREMENTS	301	
	7. MONITORING TELEMETRY REQUIREMENTS	302	
	8. CONTROL THROUGH COMMUNICATION CAPABILITIES	305	(T)/(P)
Appendix A	Forms Associated with Rule 2 Generating Facility Interconnections	307	(T)
Appendix B	Unit Cost Guide	315	(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 16

B. APPLICABILITY (Cont'd)

(L)

1. APPLICABILITY (Cont'd)

Generating Facility interconnections to Distribution Provider's Distribution System that are subject to Federal Energy Regulatory Commission (FERC) jurisdiction shall apply under Distribution Provider's Wholesale Distribution Tariff (WDT) whether they interconnect to Distribution Provider's Distribution or Transmission System.

2. DEFINITIONS

Capitalized terms used in this Rule, and not defined in Distribution Provider's other tariffs shall have the meaning ascribed to such terms in Section C of this Rule. The definitions set forth in Section C of this Rule shall only apply to this Rule, the Interconnection Request, study agreements and Generator Interconnection Agreements, and may not apply to Distribution Provider's other tariffs.

(L)

(Continued)

Advice 6682-E-A
Decision D.22-07-001

Issued by
Meredith Allen
Vice President, Regulatory Affairs

Submitted September 19, 2022
Effective February 28, 2023
Resolution



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 16

B. APPLICABILITY (Cont'd.)

3. APPLICABLE CODES AND STANDARDS

This Rule has been harmonized with the requirements of Institute of Electrical and Electronic Engineers (IEEE) 1547-2018 Standards for Interconnecting Distributed Resources with Electric Power Systems. In some sections, IEEE 1547-2018 language has been adopted directly or by reference. In others, IEEE 1547-2018 requirements were interpreted and this Rule's language was changed to maintain the spirit of both documents.

(T)
(T)
(T)
(T)

(D)
(D)

The language from IEEE 1547-2018 that has been adopted directly or by reference (as opposed to paraphrased language or previous language that was determined to be consistent with IEEE 1547-2018) is followed by a citation that lists the clause from which the language derived. For example, IEEE 1547-2018, 4.1.1 is a reference to Clause 4.1.1.

(T)
|
(T)
(T)

In the event of any conflict between this Rule, any of the standards listed herein, or any other applicable standards or codes, the requirements of this Rule shall take precedence.

4. RETAIL CUSTOMER ENERGY STORAGE DEVICES

For retail customers interconnecting energy storage devices pursuant to this Rule, the load aspects of the storage devices will be treated pursuant to Rules 2, 3, 15, and 16 just like other load, using the incremental net load for non-residential customers, if any, of the storage devices.

5. APPLICABILITY OF IEEE 1547-2018 REQUIREMENTS

(N)

The system's voltage at Point of Interconnection (POI) will determine the required Generating Facility operating requirements. Where voltage at the Point of Interconnection is less than 50 kV, for applicable generation technology, IEEE 1547-2018 and related certification requirements are required. Where POI voltage is greater than or equal to 50 kV, the Distribution Provider's Interconnection Handbook will outline operating and performance requirements consistent with North American Electric Reliability Corporation (NERC) and CAISO operating requirements.

(N)

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 18

C. DEFINITIONS

(P)/(L)

The definitions in this Section C are applicable only to this Rule, the Interconnection Request, Study Agreements and Generator Interconnection Agreements.

(L)

Added Facilities: See Special Facilities.

Affected System: An electric system other than Distribution Provider's Distribution or Transmission System that may be affected by the proposed Interconnection.

Affected System Operator: The entity that operates an Affected System.

Affiliate: With respect to a corporation, partnership or other entity, each such other corporation, partnership or other entity that directly or indirectly, through one or more intermediaries, controls, is controlled by, or is under common control with, such corporation, partnership or other entity.

Allocated Capacity: Existing aggregate generation capacity in megawatts (MW) interconnected to a substation/area bus, bank or circuit (i.e., amount of generation online).

Anti-Islanding: A control scheme installed as part of the Generating or Interconnection Facility that senses and prevents the formation of an Unintended Island.

Applicant: The entity submitting an Interconnection Request pursuant to this Rule.

Application: See Interconnection Request.

Available Capacity: Total Capacity less the sum of Allocated Capacity and Queued Capacity.

Base Case: Data including, but not limited to, base power flow, short circuit and dynamic/stability data bases, underlying load, generation, and transmission facility assumptions, contingency lists, including relevant special protection systems, and transmission diagrams used to perform the Interconnection Studies. The Base Case may include Critical Energy Infrastructure Information (as that term is defined by FERC). (Continued on next page.)

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

C. DEFINITIONS (Cont'd.)

(L)

Base Case (Cont'd): The Base Case shall include (a) transmission facilities as approved by Distribution Provider or CAISO, as applicable, (b) planned Distribution Upgrades that may have an impact on the Interconnection Request, (c) Distribution Upgrades and Network Upgrades associated with generating facilities in (iv) below, and (d) generating facilities that (i) are directly interconnected to the Distribution System or CAISO Controlled Grid; (ii) are interconnected to Affected Systems and may have an impact on the Interconnection Request; (iii) have a pending request to interconnect to the Distribution System or an Affected System; or (iv) are not interconnected to the Distribution System or CAISO Controlled Grid, but are subject to a fully executed Generator Interconnection Agreement (or its equivalent predecessor agreement) or for which an unexecuted Generator Interconnection Agreement (or its equivalent predecessor agreement) has been requested to be filed with FERC.

Business Day: Monday through Friday, excluding Federal and State Holidays.

CAISO Controlled Grid: The system of transmission lines and associated facilities that have been placed under the CAISO's Operational Control.

CAISO Tariff: The California Independent System Operator FERC Electric Tariff.

Calendar Day: Any day, including Saturday, Sunday or a Federal and State Holiday.

Certification Test: A test pursuant to this Rule that verifies conformance of certain equipment with Commission-approved performance standards in order to be classified as Certified Equipment. Certification Tests are performed by Nationally Recognized Test Laboratories (NRTLs).

Certification; Certified; Certificate: The documented results of a successful Certification Testing.

Certified Equipment: Equipment that has passed all required Certification Tests.

Commercial Operation: The status of a Generating Facility that has commenced generating electricity, excluding electricity generated during the period which Producer is engaged in on-site test operations and commissioning of the Generating Facility prior to Commercial Operation.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 20

C. DEFINITIONS (Cont'd.)

(L)

Commercial Operation Date: The date on which a Generator at a Generating Facility commences Commercial Operation, as agreed to by the Parties.

Commission: The Public Utilities Commission of the State of California.

Commissioning Test: A test performed during the commissioning of all or part of a Generating Facility to achieve one or more of the following:

Verify specific aspects of its performance;

Calibrate its instrumentation;

Establish instrument or Protective Function set-points.

Confidential Information: See Section D.7.

Conservation Voltage Regulation (CVR): The CVR program that the Commission directed Distribution Provider to implement as applicable to the operation and design of distribution circuits and related service voltages.

Construction Activities: Actions by Distribution Provider that result in irrevocable financial commitments for the purchase of major electrical equipment or land for Distribution Provider's Interconnection Facilities, Distribution Upgrades, or Network Upgrades assigned to the Interconnection Customer that occur after receipt of all appropriate governmental approvals needed for Distribution Provider's Interconnection Facilities, Distribution Upgrades, or Network Upgrades.

Continuous Operation: The Smart Inverter operates indefinitely without tripping. Any functions that protect the Smart Inverter from damage may operate as needed.

Control Area: As defined in the CAISO Tariff.

Cost Envelope: A cost-certainty framework defined as plus or minus twenty-five (25) percent of the estimated cost of certain Interconnection Facilities and/or Distribution Upgrades identified in the Cost Envelope Estimate that is offered to an Applicant based on actual costs within such twenty-five (25) percent envelope. Applicant's cost responsibility for Interconnection Facilities and/or Distribution Upgrades subject to the Cost Envelope is set forth in Section F.7.b.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 21

C. DEFINITIONS (Cont'd.)

Cost Envelope Option: A five-year pilot option described in Section F.7 applicable to Interconnection Requests for Generating Facilities that are processed under the Fast Track Process or Independent Study Process.

Cost Envelope Estimate: An estimate prepared by the Distribution Provider and delivered to Applicant pursuant to the Cost Envelope Option that contains (i) the estimated cost of Distribution Provider’s required Interconnection Facilities and/or Distribution Upgrades that are offered to Applicant that are subject to the Cost Envelope, and (ii) the estimated costs of related activities and facilities that are excluded from the Cost Envelope and offered on an actual cost basis, both pursuant to Section F.7.

Customer: The entity that receives or is entitled to receive Distribution Service through Distribution Provider’s Distribution System or is a retail Customer of Distribution Provider connected to the Transmission System.

db_{HF}: A single-sided deadband value for high-frequency in Hz used in Section P.

db_{LF}: A single-sided deadband value for low-frequency in Hz used in Section P.

Dedicated Transformer; Dedicated Distribution Transformer: A transformer that provides electricity service to a single Customer. The Customer may or may not have a Generating Facility.

Delivery Network Upgrades: The transmission facilities at or beyond the point where Distribution Provider’s Distribution System interconnects to the CAISO Controlled Grid, other than Reliability Network Upgrades, as defined in the CAISO Tariff.

Detailed Study: An Independent Study, a Distribution Group Study or a WDT Transmission Cluster Study.

Detailed Study Agreement: The agreement entered into by the Interconnection Customer and Distribution Provider which sets forth the Parties’ agreement to perform Interconnection Studies under the Independent Study Process or the Distribution Group Study Process.

Device: A mechanism or piece of equipment designed to serve a purpose or perform a function. The term may be used interchangeably with the terms “equipment” and function without intentional difference in meaning. See also Function and Protective Function.

(L)

(L)
(P)/(L)
(P)/(L)
(L)

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 22

C. DEFINITIONS (Cont'd.)

DGS Phase I Interconnection Study: Distribution Group Study (DGS) Phase I Interconnection Study performed by the Distribution Provider under the Distribution Group Study Process per Section G.3.c.i.

DGS Phase II Interconnection Study: Distribution Group Study (DGS) Phase II Interconnection Study performed by the Distribution provider under the Distribution Group Study Process per Section G.3.c.ii.

Dispute Resolution: See Section K.

Distributed Energy Resource (DER): As defined in IEEE 1547-2018.

DER Interconnection System: As defined by "Interconnection System" in IEEE 1547-2018

Distribution Group Study: An interconnection engineering study of a group comprised of Interconnection Requests that pass Screen Q as a group and fail Screen R demonstrating they are electrically interdependent in accordance with Section F.3.c.

Distribution Group Study Process: The interconnection study process set forth in Section F.3.c.

Distribution Provider: Pacific Gas and Electric Company

Distribution Service: The service of delivering energy over the Distribution System pursuant to the approved tariffs of Distribution Provider other than services directly related to the Interconnection of a Generating Facility under this Rule.

Distribution Study Group: A group comprised of Interconnection Requests that fail Screen R that will be studied pursuant to Section F.3.c because the Screen R results demonstrate they are electrically interdependent.

Distribution System: All electrical wires, equipment, and other facilities owned or provided by Distribution Provider, other than Interconnection Facilities or the Transmission System, by which Distribution Provider provides Distribution Service to its Customers.

Distribution Upgrades: The additions, modifications, and upgrades to Distribution Provider's Distribution System at or beyond the Point of Interconnection to facilitate interconnection of the Generating Facility and render the Distribution Service. Distribution Upgrades do not include Interconnection Facilities.

(L)

(L)
(P)/(L)

(P)/(L)
(L)

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 23

C. DEFINITIONS (Cont'd.)

(L)

Electrical Independence Test: The tests set forth in Section G.3 used to determine eligibility for the Independent Study Process.

Emergency: Whenever in Distribution Provider’s discretion an Unsafe Operating Condition or other hazardous condition exists or whenever access is necessary for emergency service restoration, and such immediate action is necessary to protect persons, Distribution Provider’s facilities or property of others from damage or interference caused by Interconnection Customer’s Generating Facility, or the failure of protective device to operate properly, or a malfunction of any electrical system equipment or a component part thereof.

Energy-Only Deliverability Status: A condition elected by an Interconnection Customer for a Generating Facility interconnected to Distribution System, the result of which is that the Interconnection Customer is responsible only for the costs of Reliability Network Upgrades and is not responsible for the costs of Delivery Network Upgrades, but the Generating Facility will be deemed to have a Net Qualifying Capacity as defined in the CAISO Tariff of zero.

Engineering and Procurement Agreement: An agreement that authorizes Distribution Provider to begin engineering and procurement of long lead-time items necessary for the establishment of the Interconnection in order to advance the implementation of the Interconnection Request.

Expedited Interconnection Dispute Resolution Panel Process (“Expedited Process”): A process authorized by AB 2861 in which the CPUC’s Executive Director issues binding determinations on interconnection disputes within 60 days of receiving the dispute. Determinations are made based on the recommendations of the Interconnection Dispute Resolution Panel, pursuant to Resolution ALJ-347. See Section K.

Exporting Generating Facility: Any Generating Facility other than a Non-Export Generating Facility, NEM Generating Facility, or uncompensated Generating Facility.

Fast Track Process: The interconnection study process set forth in Section F.2.

Federal Energy Regulatory Commission: Referred to herein as FERC.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 24

C. DEFINITIONS (Cont'd.)

(L)

Field Testing: Testing performed in the field to determine whether equipment meets Distribution Provider’s requirements for safe and reliable Interconnection.

Function: Some combination of hardware and software designed to provide specific features or capabilities. Its use, as in Protective Function, is intended to encompass a range of implementations from a single-purpose device to a section of software and specific pieces of hardware within a larger piece of equipment to a collection of devices and software.

Generating Facility: All Generators, electrical wires, equipment, and other facilities, excluding Interconnection Facilities, owned or provided by Producer for the purpose of producing electric power, including storage.

Generating Facility Capacity: The net capacity of the Generating Facility and the aggregate net capacity of the Generating Facility where it includes multiple Generators.

Generation Profile: The active power output of a Generating Facility over a period of time. The Generation Profile may be less than the Gross Nameplate Capacity at certain times, for example when using a typical PV Generation Profile or a Limited Generation Profile.

Generator: A device converting mechanical, chemical, or solar energy into electrical energy, including all of its protective and control functions and structural appurtenances. One or more Generators comprise a Generating Facility.

Generator Interconnection Agreement: An agreement between Distribution Provider and Producer providing for the Interconnection of a Generating Facility that gives certain rights and obligations to effect or end Interconnection. For the purpose of this Rule, Net Energy Metering or power purchase agreements authorized by the Commission are also defined as Generator Interconnection Agreements.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

C. DEFINITIONS (Cont'd.)

(L)

Good Utility Practice: Any of the practices, methods and acts engaged in or approved by a significant portion of the electric utility industry during the relevant time period, or any of the practices, methods and acts which, in the exercise of reasonable judgment in light of the facts known at the time the decision was made, could have been expected to accomplish the desired result at a reasonable cost consistent with good business practices, reliability, safety and expedition. Good Utility Practice is not intended to be limited to the optimum practice, method, or act to the exclusion of all others, but rather to be acceptable practices, methods, or acts generally accepted in the region.

Governmental Authority: Any federal, state, local or other governmental regulatory or administrative agency, court, commission, department, board, or other governmental subdivision, legislature, rulemaking board, tribunal, or other governmental authority having jurisdiction over the Parties, their respective facilities, or the respective services they provide, and exercising or entitled to exercise any administrative, executive, police, or taxing authority or power; provided, however, that such term does not include Interconnection Customer, Distribution Provider, or any Affiliate thereof.

Gross Rating; Gross Nameplate Rating; Gross Capacity or Gross Nameplate Capacity: The total gross generating capacity of a Generator or Generating Facility as designated by the manufacturer(s) of the Generator(s).

Host Load: The electrical power, less the Generator auxiliary load, consumed by the Customer, to which the Generating Facility is connected.

Inadvertent Export: The unscheduled and uncompensated export of real power* from a Generating Facility (GF) for a limited duration as specified in Sections M, Mm and Mm3.

Independent Study Process: The interconnection study process set forth in Section F.3.d.

Initial Review: See Section F.2.a.

In-rush Current: The current determined by the In-rush Current Test.

In-Service Date: The estimated date upon which Applicant reasonably expects it will be ready to begin use of Distribution Provider's Interconnection Facilities.

* For the purpose of Rule 21, real power is the same as active power.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 26

C. DEFINITIONS (Cont'd.)

(L)

Integration Capacity Analysis (ICA) Values: Values which represent the maximum capacity that can be interconnected at a given Point of Interconnection without exceeding Distribution Provider equipment thermal limits or any of the Distribution System voltage, power quality, protection, and operational flexibility (safety) limits, each of which is independently calculated.

Integration Capacity Analysis – Operational Flexibility 576 (ICA-OF 576) Profile: Annual Profile composed of 576 hours where each hour is represented by its ICA-OF Value.

Integration Capacity Analysis – Operational Flexibility (ICA-OF) Values: The minimum ICA value at a given Point of Interconnection from the set of the thermal, voltage, power quality, protection, and operational flexibility ICA Values.

Integration Capacity Analysis – Static Grid 576 (ICA-SG 576) Profile: Annual Profile composed of 576 hours where each hour is represented by its ICA-SG Value.

Integration Capacity Analysis – Static Grid (ICA-SG) Values: The minimum ICA value at a given Point of Interconnection from the set of the thermal, voltage, power quality, and protection ICA Values.

Interconnection; Interconnected: The physical connection of a Generating Facility in accordance with the requirements of this Rule so that Parallel Operation with Distribution Provider’s Distribution or Transmission System can occur (has occurred).

Interconnection Agreement: See Generator Interconnection Agreement.

Interconnection Customer: See Applicant.

Interconnection Facilities: The electrical wires, switches and related equipment that are required in addition to the facilities required to provide electric Distribution Service to a Customer to allow Interconnection. Interconnection Facilities may be located on either side of the Point of Common Coupling as appropriate to their purpose and design. Interconnection Facilities may be integral to a Generating Facility or provided separately. Interconnection Facilities may be owned by either Producer or Distribution Provider.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 27

C. DEFINITIONS (Cont'd.)

Interconnection Facilities Study: A study conducted by Distribution Provider for an Interconnection Customer under the Independent Study Process to determine a list of facilities (including Distribution Provider's Interconnection Facilities, Distribution Upgrades, and Network Upgrades as identified in the Interconnection System Impact Study), the cost of those facilities, and the time required to interconnect the Generating Facility with Distribution Provider's Distribution or Transmission System. The scope of the study is defined in Section G.3.c.

(D)
(D)

Interconnection Request: An Applicant's request to interconnect a new Generating Facility, or to increase the capacity of, or make a Material Modification to the operating characteristics of, an existing Generating Facility that is interconnected with Distribution Provider's Distribution or Transmission System.

Interconnection Study: A study to establish the requirements for Interconnection of a Generating Facility with Distribution Provider's Distribution System or Transmission System, pursuant to this Rule.

Interconnection System Impact Study: An engineering study conducted by Distribution Provider for an Interconnection Customer under the Independent Study Process that evaluates the impact of the proposed interconnection on the safety and reliability of Distribution Provider's Distribution and/or Transmission System and, if applicable, an Affected System. The scope of the study is defined in Section G.3.c.i.

Island; Islanding: A condition on Distribution Provider's Distribution System in which one or more Generating Facilities deliver power to Customers using a portion of Distribution Provider's Distribution System that is electrically isolated from the remainder of Distribution Provider's Distribution System.

k_{of} : The per-unit frequency change corresponding to 1 per-unit power output change (frequency droop), unitless used in Section P.

(P)

k_{uf} : The per-unit frequency change corresponding to 1 per-unit power output change (frequency droop), unitless used in Section P.

(P)

Large Generating Facility: A Generating Facility having a Generating Facility Capacity of more than 20 MW.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 28

C. DEFINITIONS (Cont'd.)

Like for like: For inverters, like-for-like means certified, same nameplate or smaller, same fault current or smaller. For solar panels, like-for-like means certified, same CEC-AC rating of the system or smaller. For batteries, like-for-like means same or less kWh & kW rating and same operating profile. For transformers, like-for-like means same connection type, same or smaller impedance and capacity. (L)

Line Section: That portion of Distribution Provider's Distribution or Transmission System connected to a Customer bounded by automatic sectionalizing devices or the end of the distribution line. (L)

Local DER Generating Facility Communication Interface: Interface at the Generating Facility capable of communicating to support the information exchange requirements specified in this rule and as required in IEEE 1547-2018 for all applicable functions that are in Section P. (P)/(L)

Local Furnishing Bond: Tax-exempt bonds utilized to finance facilities for the local furnishing of electric energy, as described in Internal Revenue Code, 26 U.S.C. § 142(f). (L)

Local Furnishing Distribution Provider: Any Distribution Provider that owns facilities financed by Local Furnishing Bonds.

Mandatory Operation: The Smart Inverter operates at maximum available current without tripping during Distribution Provider's Transmission or Distribution System excursions outside the region of continuous operation. Any functions that protect the Smart Inverter from damage may operate as needed.

Material Modification: Those modifications that have a material impact on cost or timing of any Interconnection Request with a later queue priority date or a change in Point of Interconnection. A Material Modification does not include a change in ownership of a Generating Facility, (ii) a modification described in Table F.1, nor (iii) a modification described in Tables Ee.1, 2 or 3 that does not require a new interconnection request.

Metering: The measurement of electrical power in kilowatts (kW) and/or energy in kilowatt-hours (kWh), and if necessary, reactive power in kVAR at a point, and its display to Distribution Provider, as required by this Rule.

Metering Equipment: All equipment, hardware, software including meter cabinets, conduit, etc., that are necessary for Metering. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 29

C. DEFINITIONS (Cont'd.)

(L)

Momentary Cessation: The Smart Inverter momentarily reduces current output to the Distribution Provider's Transmission or Distribution System to below 10% of the maximum continuous output current rating. The Smart Inverter is allowed to increase current output to the Distribution Provider's Transmission or Distribution System without any intentional reconnection delay once voltage exits the Momentary Cessation region and enters a Permissive Operation region or Continuous Operation region.

Momentary Parallel Operation: The Interconnection of a Generating Facility to the Distribution and Transmission System for one second (60 cycles) or less.

Nationally Recognized Testing Laboratory (NRTL): A laboratory accredited to perform the Certification Testing requirements under this Rule.

Net Energy Metering (NEM): Metering for the receipt and delivery of electricity between Producer and Distribution Provider pursuant to California Public Utilities Code (PUC) sections 2827, 2827.1 (as currently implemented by Commission Decision (D.)16-01-044), 2827.8, or 2827.10.

NEM-1: Refers to Interconnection Requests for service pursuant to Schedules NEM, NEMV, and NEMVMASH.

NEM-2: Refers to Interconnection Requests for service pursuant to Schedules NEM2, NEM2V, NEM2VMSH, and NEM2VSOM.

Net Rating or Net Nameplate Rating: The Gross Rating minus the consumption of electrical power of the auxiliary load.

Network Upgrades: Delivery Network Upgrades and Reliability Network Upgrades.

Networked Secondary System: An AC distribution system where the secondaries of the distribution transformers are connected to a common bus for supplying electricity directly to consumers. There are two types of secondary networks: grid networks (also referred to as area networks or street networks) and Spot Networks. Synonyms: Secondary Network. Refer to IEEE 1547.6 for additional detail.

Non-Emergency: Conditions or situations that are not Emergencies, including but not limited to meter reading, inspection, testing, routine repairs, replacement, and maintenance.

Nominal: Standard frequency and voltage.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 30

C. DEFINITIONS (Cont'd.)

(L)

Non-Export; Non-Exporting: When the Generating Facility is sized and designed such that the Generator output is used for Host Load only and is designed to prevent the transfer of electrical energy from the Generating Facility to Distribution Provider's Distribution or Transmission System.

Non-Export AC/DC Converter: A one-way only device that takes alternating current (AC) power from the Distribution System and converts it into direct current (DC) power for DC loads in the Customer's facility. A Non-Export AC/DC Converter must be certified by a Nationally Recognized Test Lab as non-export, meaning it must be certified to not export power back into the grid (i.e. exports less than 0.5% of its rated current towards the grid under steady-state conditions or after 5 cycles of an induced fault condition) and it must meet IEEE 1547-4.3.3 harmonic requirements. Until a national certification standard is approved and the Non-Export AC/DC Converter can be certified by a NRTL, the requirement can be satisfied through Distribution Provider's interim approval process. An interim approval will apply to devices that complete the Distribution Provider's testing procedure described in Section L.7.a.v. The interim approval will be effective upon the Distribution Provider acknowledging that the test results for a particular model of Non-Export AC/DC Converter confirm satisfactory completion of the testing procedures. Twelve months after the UL 1741 Non-Export Certification Requirement Document (CRD) standard is available, new interconnections requests for non-export using an AC/DC converter must use an NRTL certified non-export converter.

Non-Islanding: Designed to detect and disconnect from a stable Unintended Island with matched load and generation. Reliance solely on under/over voltage and frequency trip is not considered sufficient to qualify as Non-Islanding.

Open Loop Response Time: The duration from a step change in control signal input (reference value) until the output changes to 90 percent of its final change, before any overshoot.

Parallel Operation: The simultaneous operation of a Generator with power delivered or received by Distribution Provider while Interconnected. For the purpose of this Rule, Parallel Operation includes only those Generating Facilities that are Interconnected with Distribution Provider's Distribution or Transmission System for more than 60 cycles (one second).

Paralleling Device: An electrical device, typically a circuit breaker, operating under the control of a synchronization relay or by a qualified operator to connect an energized generator to an energized electric power system or two energized power systems to each other.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 31

C. DEFINITIONS (Cont'd.)

Party, Parties: Applicant or Distribution Provider.

Periodic Test: A test performed on part or all of a Generating Facility/Interconnection Facilities at pre-determined time or operational intervals to achieve one or more of the following: 1) verify specific aspects of its performance; 2) calibrate instrumentation; and 3) verify and re-establish instrument or Protective Function set-points.

Permissive Operation: The Smart Inverter is allowed, but not required, to operate at any current level.

Point of Common Coupling (PCC): The transfer point for electricity between the electrical conductors of Distribution Provider and the electrical conductors of Producer.

Point of Interconnection (POI): The point where the Interconnection Facilities connect with Distribution Provider's Distribution or Transmission System. This may or may not be coincident with the Point of Common Coupling.

Point of Generating Resource Connection (POC): The point where a DER unit is electrically connected in a Generating Facility and meets the requirements of this rule.

Pre-Construction Activities: The actions by Distribution Provider, other than those required by an Engineering and Procurement Agreement under Section F.3.f, undertaken prior to Construction Activities in order to prepare for the construction of Distribution Provider's Interconnection Facilities, Distribution Upgrades, or Network Upgrades assigned to the Interconnection Customer, including, but not limited to, preliminary engineering, permitting activities, environmental analysis, or other activities specifically needed to obtain governmental approvals for Distribution Provider's Interconnection Facilities, Distribution Upgrades, or Network Upgrades.

(L)

(L)

(P)/(L)

(L)

(L)

(P)/(L)

(P)/(L)

(L)

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 32

C. DEFINITIONS (Cont'd.)

(L)

Producer: The entity that executes a Generator Interconnection Agreement with Distribution Provider. Producer may or may not own or operate the Generating Facility, but is responsible for the rights and obligations related to the Generator Interconnection Agreement.

Production Test: A test performed on each device coming off the production line to verify certain aspects of its performance.

Protective Function(s): The equipment, hardware and/or software in a Generating Facility (whether discrete or integrated with other functions) whose purpose is to protect against Unsafe Operating Conditions.

Prudent Electrical Practices: Those practices, methods, and equipment, as changed from time to time, that are commonly used in prudent electrical engineering and operations to design and operate electric equipment lawfully and with safety, dependability, efficiency, and economy.

Queue Position: See Section E.5.C.

Queued Capacity: Aggregate queued generation capacity (in MW) for a substation/area bus, bank or circuit (i.e., amount of generation in the queue).

Reasonable Efforts: With respect to an action required to be attempted or taken by a Party under this Rule, efforts that are timely and consistent with Good Utility Practice and are otherwise substantially equivalent to those a Party would use to protect its own interests.

(L)

Reference Point of Applicability (RPA): The location where the Generating Facility interconnection and interoperability performance requirements shall be met.

(P)/(L)
|
(P)/(L)

Reliability Network Upgrades: The transmission facilities at or beyond the point where Distribution Provider's Distribution System interconnects to the CAISO Controlled Grid, necessary to interconnect one or more Generating Facility(ies) safely and reliably to the CAISO Controlled Grid, as defined in the CAISO Tariff.

(L)

Section 218 Load: Electrical power that is supplied in compliance with California PUC section 218. PUC section 218 defines an "Electric Corporation" and provides conditions under which a transaction involving a Generating Facility would not classify a Producer as an Electric Corporation. These conditions relate to "over-the-fence" sale of electricity from a Generating Facility without using Distribution Provider's Distribution or Transmission System.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 33

C. DEFINITIONS (Cont'd.)

(L)

Short Circuit Contribution Ratio (SCCR): The ratio of the Generating Facility's short circuit contribution to the short circuit contribution provided through Distribution Provider's Distribution System for a three-phase fault at the high voltage side of the distribution transformer connecting the Generating Facility to Distribution Provider's Distribution System.

Single Line Diagram; Single Line Drawing: A schematic drawing, showing the major electric switchgear, Protective Function devices (including relays, current transformer and potential transformer configurations/wiring in addition to circuit breakers/fuses), wires, Generators, transformers, meters and other devices, providing relevant details to communicate to a qualified engineer the essential design and safety of the system being considered.

Site Exclusivity: Documentation reasonably demonstrating: (1) For private land: (a) Ownership of, a leasehold interest in, or a right to develop property upon which the Generating Facility will be located consisting of a minimum of 50% of the acreage reasonably necessary to accommodate the Generating Facility; or (b) an option to purchase or acquire a leasehold interest in property upon which the Generating Facility will be located consisting of a minimum of 50% of the acreage reasonably necessary to accommodate the Generating Facility. (2) For public land, including that controlled or managed by any federal, state or local agency, a final, non-appealable permit, license, or other right to use the property for the purpose of generating electric power and in acreage reasonably necessary to accommodate the Generating Facility, which exclusive right to use public land under the management of the federal Bureau of Land Management shall be in a form specified by the Bureau of Land Management. The demonstration of Site Exclusivity, at a minimum, must be through the Commercial Operation Date of the new Generating Facility or increase in capacity of the existing Generating Facility.

Small Generating Facility: A Generating Facility that has a Generating Facility Capacity of no more than 20 MW.

Smart Inverter: A Generating Facility's inverter that performs functions that, when activated, can autonomously contribute to grid support during excursions from normal operating voltage and frequency system conditions by providing: dynamic reactive/real power support, voltage and frequency ride-through, ramp rate controls, communication systems with ability to accept external commands and other functions.

Special Facilities: As defined in Distribution Provider's Rule 2.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 34

C. DEFINITIONS (Cont'd.)

(L)

Spot Network: For purposes of this Rule, a Spot Network is a type of distribution system found within modern commercial buildings to provide high reliability of service to a single customer.

Starting Voltage Drop: The percentage voltage drop at a specified point resulting from In-rush Current. The Starting Voltage Drop can also be expressed in volts on a particular base voltage, (e.g. 6 volts on a 120-volt base, yielding a 5% drop).

Supplemental Review: See Section F.2.c.

System Integrity: The condition under which Distribution Provider's Distribution and Transmission System is deemed safe and can reliably perform its intended functions in accordance with the safety and reliability rules of Distribution Provider.

Telemetry: The electrical or electronic transmittal of Metering data on a real-time basis to Distribution Provider.

Total Capacity: Capacity (in MW) of substation/area bus, bank or circuit based on normal or operating ratings.

Transfer Trip: A Protective Function that trips a Generating Facility remotely by means of an automated communications link controlled by Distribution Provider.

Transient/Dynamic Stability: The ability of an electrical system to withstand disturbances. Transient/Dynamic Stability studies are performed to ensure power system stability and are time-based simulations that assess the performance of the power system during and shortly following system disturbances.

Transmission Cluster Study Process: The cluster study process as defined in Distribution Provider's Wholesale Distribution Tariff.

Transmission System: Transmission facilities owned by Distribution Provider that have been placed under the CAISO's operational control and are part of the CAISO Controlled Grid, as defined in the CAISO Tariff.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 35

C. DEFINITIONS (Cont'd.)

(L)

Trip: The act of a Generating Facility to cease to energize or disconnect from the Distribution Provider's Transmission or Distribution System automatically due to a Distribution Provider's Transmission or Distribution System disturbance. Following a trip, the Smart Inverter must delay re-energization or reconnection for a preset period of time once the voltage and frequency of the Distribution Provider's Transmission or Distribution System are within normal ranges.

Type Test: A test performed on a sample of a particular model of a device to verify specific aspects of its design, construction and performance.

Unintended Island: The creation of an Island, usually following a loss of a portion of Distribution Provider's Distribution System, without the approval of Distribution Provider.

Unit Cost Guide: A published guide that is not binding for actual facility costs and is provided only for additional cost transparency, developer reference, and Distribution Provider's reference when preparing the study estimate.

Unsafe Operating Conditions: Conditions that, if left uncorrected, could result in harm to personnel, damage to equipment, loss of System Integrity or operation outside pre-established parameters required by the Generator Interconnection Agreement.

Voltage Excursion: Beginning when Distribution Provider's Transmission or Distribution System voltage at the PCC exits the near Nominal magnitude range and ending when voltage re-enters the near Nominal magnitude range.

VRef: The reference voltage or nominal voltage.

VRefOfs: The offset from the reference voltage due to the location of the Smart Inverter system on a distribution feeder. This may be a setting or may be calculated dynamically from local voltage measurements.

Wholesale Distribution Tariff: PG&E's Wholesale Distribution Tariff (WDT)

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 36

D. GENERAL, RULES, RIGHTS AND OBLIGATIONS

(L)

1. AUTHORIZATION REQUIRED TO OPERATE

A Producer must comply with this Rule, execute a Generator Interconnection Agreement with Distribution Provider, and receive Distribution Provider's express written permission before Parallel Operation of its Generating Facility with Distribution Provider's Distribution or Transmission System. Distribution Provider shall apply this Rule in a non-discriminatory manner and shall not unreasonably withhold its permission for Parallel Operation of Producer's Generating Facility with Distribution Provider's Distribution or Transmission System.

2. SEPARATE AGREEMENTS REQUIRED FOR OTHER SERVICES

A Producer requiring other electric services from Distribution Provider including, but not limited to, Distribution Service during periods of curtailment or interruption of Producer's Generating Facility, must enter into agreements with Distribution Provider for such services in accordance with Distribution Provider's Commission-approved tariffs.

3. SERVICES UNDER THIS TARIFF LIMITED TO INTERCONNECTION

Interconnection with Distribution Provider's Distribution or Transmission System under this Rule does not provide a Producer any rights to utilize Distribution Provider's Distribution or Transmission System for the transmission, distribution, or wheeling of electric power, nor does it limit those rights.

4. COMPLIANCE WITH LAWS, RULES, AND TARIFFS

A Producer shall ascertain and comply with applicable Commission-approved tariffs of Distribution Provider; applicable FERC-approved rules, tariffs, and regulations; and any local, state or federal law, statute or regulation which applies to the design, siting, construction, installation, operation, or any other aspect of Producer's Generating Facility and Interconnection Facilities.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 37

D. GENERAL, RULES, RIGHTS AND OBLIGATIONS (Cont'd.) (L)

5. DESIGN REVIEWS AND INSPECTIONS

Distribution Provider shall have the right to review the design of a Producer's Generating and Interconnection Facilities and to inspect a Producer's Generating and/or Interconnection Facilities prior to the commencement of Parallel Operation with Distribution Provider's Distribution or Transmission System. Distribution Provider may require a Producer to make modifications as necessary to comply with the requirements of this Rule. Distribution Provider's review and authorization for Parallel Operation shall not be construed as confirming or endorsing Producer's design or as warranting the Generating Facilities' and/or Interconnection Facilities' safety, durability or reliability. Distribution Provider shall not, by reason of such review or lack of review, be responsible for the strength, adequacy, or capacity of such equipment.

6. RIGHT TO ACCESS

A Producer's Generating Facility and/or Interconnection Facilities shall be reasonably accessible to Distribution Provider personnel as necessary for Distribution Provider to perform its duties and exercise its rights under its tariffs approved by the Commission, and under any Generator Interconnection Agreement between Distribution Provider and Producer.

7. CONFIDENTIALITY

a. Scope

Confidential Information shall include, without limitation, confidential, proprietary or trade secret information relating to the present or planned business of Applicant, Customer, Producer, or Distribution Provider (individually referred to in Section D.7 as Party or collectively as Parties), including all information relating to a Party's technology, research and development, business affairs, and pricing. Distribution Provider shall not use the information contained in the Interconnection Request to propose discounted tariffs to the Customer unless authorized to do so by the Customer or the information is provided to Distribution Provider by the Customer through other means.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 38

D. GENERAL, RULES, RIGHTS AND OBLIGATIONS (Cont'd.) (L)

7. CONFIDENTIALITY (Cont'd)

a. Scope (Cont'd)

Information is Confidential Information only if it is clearly designated or marked in writing as confidential on the face of the document (including electronic materials), or, if the information is conveyed orally or by inspection, if the Party providing the information orally informs the Party receiving the information that the information is confidential. For purposes of this Rule all design, operating specifications, and metering data provided by Applicant shall be deemed Confidential Information regardless of whether it is clearly marked or otherwise designated as such, except as provided in section D.7.b. below.

If requested by either Party, the other Party shall provide in writing, the basis for asserting that the information referred to in this Article warrants confidential treatment, and the requesting Party may disclose such writing to the appropriate Governmental Authority. Each Party shall be responsible for the costs associated with affording confidential treatment to its information.

b. Limitations on Scope

Confidential Information shall not include information pertaining to each Interconnection Request that may be provided in a publicly-posted queue pursuant to Section E.5.d of this Rule.

Confidential Information shall not include information that: (1) is generally available to the public other than as a result of a disclosure by the receiving Party; (2) was in the lawful possession of the receiving Party on a non-confidential basis before receiving it from the disclosing Party; (3) was supplied to the receiving Party without restriction by a third party, who, to the knowledge of the receiving Party after due inquiry, was under no obligation to the disclosing Party to keep such information confidential; (4) was independently developed by the

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 39

D. GENERAL, RULES, RIGHTS AND OBLIGATIONS (Cont'd.)

(L)

7. CONFIDENTIALITY (Cont'd.)

b. Limitations on Scope (Cont'd.)

receiving Party without reference to Confidential Information of the disclosing Party; (5) is, or becomes, publicly known, through no wrongful act or omission of the receiving Party; or (6) is required, in accordance with Section D.7.d, Required Disclosure, to be disclosed by any Governmental Authority or is otherwise required to be disclosed by law or subpoena.

Information designated as Confidential Information will no longer be deemed confidential if the Party that designated the information as confidential notifies the other Party that it no longer is confidential.

c. Disclosure to Commission, FERC, or their respective Staff

Notwithstanding anything in this Section D.7 to the contrary, and pursuant to 18 CFR section 1b.20 in the case of disclosure to FERC, if the Commission, FERC, or their respective staff, during the course of an investigation or otherwise, requests information from one of the Parties that is otherwise required to be maintained in confidence pursuant to this Rule, the Party shall provide the requested information to the Commission, FERC, or their respective staff, within the time provided for in the request for information. In providing the information to the Commission, FERC, or their respective staff, the Party shall, pursuant to PUC section 583 and General Order 66-D in the case of disclosure to the Commission, and consistent with 18 CFR section 388.112 in the case of disclosure to FERC, request that the information be treated as confidential and non-public by the Commission, FERC, and their respective staff and that the information be withheld from public disclosure. Requests from another state regulatory body with jurisdiction conducting a confidential investigation shall be treated in a similar manner, consistent with applicable state rules and regulations.

(L)

(Continued)



**ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS**

Sheet 40

D. GENERAL, RULES, RIGHTS AND OBLIGATIONS (Cont'd.) (L)

7. CONFIDENTIALITY (Cont'd.)

d. Required Disclosure

Subject to the exception in Section D.7.c, any information that a Party claims is Confidential Information shall not be disclosed by the other Party to any person not employed or retained by the other Party, except to the extent disclosure is (i) required by law or pursuant to an order of the Commission or FERC; (ii) reasonably deemed by the disclosing Party to be required to be disclosed in connection with a dispute between or among the Parties, or the defense of litigation or dispute; (iii) otherwise permitted by consent of the other Party, such consent not to be unreasonably withheld; (iv) necessary to fulfill its obligations under this Rule; or (v) as a transmission or distribution service provider or a Control Area operator, including disclosing the Confidential Information to a Regional Transmission Organization or CAISO, or to a sub-regional, regional or national reliability organization or planning group under the applicable confidentiality provisions in the relevant tariffs. Prior to any disclosures of the other Party's Confidential Information under this subparagraph, or if any third party or Governmental Authority makes any request or demand for any of the information described in this subparagraph, the disclosing Party agrees to assert confidentiality and cooperate with the other Party in seeking to protect the Confidential Information from public disclosure by confidentiality agreement, protective order or other reasonable measures.

8. PRUDENT OPERATION AND MAINTENANCE REQUIRED

A Producer shall operate and maintain its Generating Facility and Interconnection Facilities in accordance with Prudent Electrical Practices and shall maintain compliance with this Rule.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 41

D. GENERAL, RULES, RIGHTS AND OBLIGATIONS (Cont'd.) (L)

9. CURTAILMENT AND DISCONNECTION

Distribution Provider may limit the operation or disconnect or require the disconnection of a Producer's Generating Facility from Distribution Provider's Distribution or Transmission System at any time, with or without notice, in the event of an Emergency, or to correct Unsafe Operating Conditions. Distribution Provider may also limit the operation or disconnect or require the disconnection of a Producer's Generating Facility from Distribution Provider's Distribution or Transmission System upon the provision of reasonable written notice: 1) to allow for routine maintenance, repairs or modifications to Distribution Provider's Distribution or Transmission System; 2) upon Distribution Provider's determination that a Producer's Generating Facility is not in compliance with this Rule; or 3) upon termination of the Generator Interconnection Agreement. Upon Producer's written request, Distribution Provider shall provide a written explanation of the reason for such curtailment or disconnection.

10. LOCAL FURNISHING BONDS

If a proposed Interconnection of a Generating Facility would impair the tax-exempt status of interest on the Local Furnishing Bonds or the deductibility of interest expense on the Local Furnishing Bonds to the Local Furnishing Distribution Provider under the Internal Revenue Code, Treasury Regulations and/or applicable IRS rulings, the Interconnection Customer will be required to pay the costs properly attributable to the proposed Interconnection of such Generating Facility. The Interconnection Study shall specify and estimate the cost of all remedial measures that address the financial impacts, if any, on Local Furnishing Bonds that would result from an Interconnection.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 42

D. GENERAL, RULES, RIGHTS AND OBLIGATIONS (Cont'd.)

11. COORDINATION WITH AFFECTED SYSTEMS

(L)

Distribution Provider will notify the Affected System Operators that are potentially affected by an Applicant's Interconnection Request or group of Interconnection Requests. Distribution Provider will coordinate the conduct of any studies required to determine the impact of the Interconnection Request on Affected Systems with Affected System Operators and, if possible, include those results (if available) in its applicable Interconnection Study within the time frame specified in this Rule. Distribution Provider will include such Affected System Operators in all meetings held with Applicant as required by this Rule. Applicant will cooperate with Distribution Provider in all matters related to the conduct of studies and the determination of modifications to Affected Systems. A transmission provider which may be an Affected System shall cooperate with Distribution Provider with whom interconnection has been requested in all matters related to the conduct of studies and the determination of modifications to Affected Systems. Applicant shall enter into an agreement with the owner of the Affected System, as applicable. The agreement shall specify the terms governing payments to be made by Applicant to the owner of the Affected System as well as the repayment, if applicable, by the owner of the Affected System.

12. TRANSFERABILITY OF INTERCONNECTION REQUEST

An Applicant may transfer its Interconnection Request to another entity only if such entity acquires the proposed Generating Facility identified in the Interconnection Request and the Point of Interconnection does not change.

13. SPECIAL PROVISIONS APPLICABLE TO CERTAIN NET ENERGY METERED APPLICANTS

Notwithstanding any other provision in this Rule:

- a. For NEM Generating Facilities with a capacity of 1 MW or smaller Distribution Provider may proceed from Initial to Supplemental Review to Independent Study Process to further study without waiting for Applicant concurrence, since Applicant is not responsible for payment of study costs.

(L)

For NEM-2 Generating Facilities with a capacity greater than a megawatt interconnecting on transmission see Section B.1 – *Applicability*.

(N)

(N)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 44

- D. GENERAL, RULES, RIGHTS AND OBLIGATIONS (Cont'd.) (L)
- 13. SPECIAL PROVISIONS APPLICABLE TO NET ENERGY METERED APPLICANTS (Cont'd.)
 - c. Unless Net Generator Output Metering is required, Metering Equipment necessary to obtain service under NEM-1 or NEM-2 shall be installed and operational within the timeframe required to complete Interconnection.
 - d. An Applicant with a Fast Track Interconnection Request for a NEM-1 or NEM-2 Generating Facility with a capacity of 1 MW or smaller that 1) goes for more than one year from the date of Distribution Provider's written notification that the Interconnection Request is valid without a signed Generator Interconnection Agreement, or 2) has a Generating Facility that has not been approved for Parallel Operation within one year of completion of all applicable review and/or studies, is subject to withdrawal by Distribution Provider; however, Distribution Provider may not deem the Interconnection Request to be withdrawn if i) Applicant provides reasonable evidence that the Interconnection Request is still active or ii) the delay is at no fault of Applicant. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 45

D. GENERAL, RULES, RIGHTS AND OBLIGATIONS (Cont'd.) (L)

13. SPECIAL PROVISIONS APPLICABLE TO NET ENERGY METERED APPLICANTS (Cont'd.)

e. For the purposes of establishing the interconnection requirements for Net Energy Metering Generating Facilities with a capacity greater than one megawatt (1MW)* qualifying for service under PUC Section 2827(b)(4)(B) (i.e., the California Department of Corrections and Rehabilitation or CDCR), Distribution Provider shall be afforded a prudent but necessary time, as determined by the executive director of the Commission, to study the impacts of the Interconnection Request. If the study reveals the need for upgrades to the Transmission and/or Distribution System arising solely from the Interconnection Request, Distribution Provider shall be afforded the time necessary to complete those upgrades before the Generating Facility is interconnected. The costs of the Network and/or Distribution Upgrades shall be borne by the Applicant, but the exemption from application fees and study costs applicable to Generating Facilities eligible for Net Energy Metering under PUC Section 2827 shall apply. Distribution Provider shall consider the receipt date of the completed Interconnection Request when completing the study allowed for herein and for purposes of determining the appropriate cost responsibility for the necessary Network and/or Distribution Upgrades triggered solely by the Interconnection Request. All Generating Facilities interconnected pursuant to this section shall comply with applicable state and federal requirements, including requirements of the FERC. (L)

For CDCR Rate Schedule NEM interconnections of Generating Facilities with a capacity greater than 1 MW, the CDCR shall comply with all FERC interconnection procedures and requirements for any Generating Facility that interconnects directly to the Transmission System or that requires upgrades to the Transmission System, and the CDCR shall be responsible for any application fees and study costs triggered by the NEM-2 Interconnection Request.** (T)

* If the generating facility is greater than 1 megawatt and interconnecting on transmission, see Applicability Section B.1. (N)

** If the CDCR generating facility is greater than 1 megawatt and interconnecting on transmission as NEM-2, also see Applicability Section B.1. (N)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 46

- D. GENERAL, RULES, RIGHTS AND OBLIGATIONS (Cont'd.) (L)
- 13. SPECIAL PROVISIONS APPLICABLE TO NET ENERGY METERED APPLICANTS (Cont'd.)
 - f. Applicants with an Interconnection Request for a Net Energy Metering Generating Facility, or a Non-Export Generating Facility, shall have the opportunity to select the Cost Envelope Option in accordance with Section F.7. Applicants who are determined to not have responsibility for any applicable upgrade costs will be automatically withdrawn from the Cost Envelope Option.
- 14. SPECIAL PROVISIONS APPLICABLE TO NON-EXPORT ENERGY STORAGE GENERATING FACILITIES

Applicants with Non-Export Energy Storage Generating Facilities that meet the criteria listed in Section N shall be eligible to select expedited processing in their Interconnection Request and to utilize the corresponding form of Interconnection Agreement, subject to the terms and conditions of Section N.
- 15. COMPLIANCE WITH ESTABLISHED TIMELINES

Distribution Provider shall use Reasonable Efforts in meeting all the timelines provided for under this Rule. In the event Distribution Provider is not able to meet a particular timeline set forth in this Rule, Distribution Provider shall notify Applicant as soon as practicable and provide an estimated completion date with an explanation of the reasons why additional time is needed. Any Applicant dissatisfied with the Reasonable Efforts of Distribution Provider may use the informal procedures set out in Section F.1.d and/or the Dispute Resolution process in Section K.
- 16. MODIFICATION OF TIMELINES

Distribution Provider and Applicant, for good cause, may agree to modify any of the timelines in this Rule. The modified timeline shall be mutually agreed upon, in writing, between Distribution Provider and Applicant. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 47

E. INTERCONNECTION REQUEST SUBMISSION PROCESS

1. OPTIONAL PRE-APPLICATION REPORT

a. Standard Pre-Application Report*

(T)

Upon receipt of a completed Pre-Application Report Request and a non-refundable processing fee of \$300, Distribution Provider shall provide pre-application data described in this section within ten (10) Business Days of receipt. The Pre-Application Report Request shall include a proposed Point of Interconnection, generation technology and fuel source. The proposed Point of Interconnection shall be defined by latitude and longitude, site map, street address, utility equipment number (e.g. pole number), meter number, account number or some combination of the above sufficient to clearly identify the location of the Point of Interconnection.

The Pre-Application Report will include the following information if available:

1. Total Capacity (MW) of substation/area bus or bank and circuit likely to serve proposed site.
2. Allocated Capacity (MW) of substation/area bus or bank and circuit likely to serve proposed site.
3. Queued Capacity (MW) of substation/area bus or bank and circuit likely to serve proposed site.
4. Available Capacity (MW) of substation/area bus or bank and circuit most likely to serve proposed site.
5. Substation nominal distribution voltage or transmission nominal voltage if applicable.
6. Nominal distribution circuit voltage at the proposed site.
7. Approximate circuit distance between the proposed site and the substation.
8. Relevant Line Section(s) peak load estimate, and minimum load data, when available.

* If Application is at transmission voltage (See Rule 2, Section B.1) please provide CAISO Pre-Application Request Form: <http://www.aiso.com/Documents/PreApplicationRequestForm.doc>

(N)
(N)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 48

E. INTERCONNECTION REQUEST SUBMISSION PROCESS (Cont'd.)

1. OPTIONAL PRE-APPLICATION REPORT (Cont'd.)

- 9. Number of protective devices and number of voltage regulating devices between the proposed site and the substation/area.
- 10. Whether or not three-phase power is available at the site.
- 11. Limiting conductor rating from proposed Point of Interconnection to distribution substation.
- 12. Based on proposed Point of Interconnection, existing or known constraints such as, but not limited to, electrical dependencies at that location, short circuit interrupting capacity issues, power quality or stability issues on the circuit, capacity constraints, or secondary networks.
- 13. Nominal distribution circuit voltage and wiring configuration.

b. Enhanced Pre-Application Report* (T)

The Enhanced Pre-Application Report Request shall be submitted in parallel with the Standard Pre-Application Report. Requests that exclude the Standard Pre-Application Report and select only one or both of the Enhanced Pre-Application Report packages shall be assessed an additional non-refundable fee of \$100.

The Enhanced Pre-Application Report Request shall include a proposed Point of Interconnection, generation technology and fuel source. The proposed Point of Interconnection shall be defined by latitude and longitude, site map, street address, utility equipment number (e.g. pole number), meter number, account number or some combination of the above sufficient to clearly identify the location of the Point of Interconnection.

The information included in the Enhanced Pre-Application Report is dependent upon the data package selected by Applicant.

* If Application is at transmission voltage (See Rule 2, Section B.1) please provide CAISO Pre-Application Request Form: <http://www.caiso.com/Documents/PreApplicationRequestForm.doc>

(N)
(N)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

- E. INTERCONNECTION REQUEST SUBMISSION PROCESS (Cont'd.) (L)
- 1. OPTIONAL PRE-APPLICATION REPORT (Cont'd.)
 - i. Primary Service Package

Upon receipt of a completed Enhanced Pre-Application Report Request for Primary Service Package and a non-refundable fee of \$225, and additional \$100 fee if applicable, Distribution Provider shall provide the enhanced pre-application data described in this section within ten (10) Business Days of receipt.

The Primary Service Package will include the following information if available:

 1. Relevant line section(s) absolute minimum load and minimum load during the 10 AM – 4 PM period (provided when SCADA data is available).
 2. Existing upstream protection including:
 - (a) Device type (Fuse Breaker, Recloser)
 - (b) Device controller (device make/model ex: 50E/50T)
 - (c) Phase settings [IEEE Curve, Lever, Min Trip (A), Inst Trip(A)]
 - (d) Ground settings [IEEE Curve, Lever, Min Trip (A), Inst Trip(A)]
 - (e) Rated continuous current
 - (f) Short Circuit interrupting capability
 - (g) Confirm if the device is capable of bi-directional operation
 3. Provide the Available Fault Current at the proposed Point of Interconnection including existing distributed generation fault contribution. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 50

E. INTERCONNECTION REQUEST SUBMISSION PROCESS (Cont'd.)

1. OPTIONAL PRE-APPLICATION REPORT (Cont'd.)

ii. Behind the Meter Interconnection Package

Upon receipt of a completed Enhanced Pre-Application Report Request for Behind the Meter Interconnection Package and a non-refundable fee of \$800, and additional \$100 fee if applicable, Distribution Provider shall provide the enhanced pre-application data described in this section within thirty (30) Business Days of receipt. Distribution Provider shall conduct a physical verification based on field confirmation.

If a third party is submitting an Enhanced Pre-Application Report Request for Behind the Meter Interconnection Package on behalf of the Applicant, an Authorization to Receive Customer Information or Act on a Customer's Behalf [PG&E Form 79-1095] (T) shall be required to be submitted as part of the Pre-Application Report Request. Distribution Provider shall notify the Applicant if additional processing time will be required.

The Behind the Meter Interconnection Package will include the following information if available:

1. Relevant line section(s) absolute minimum load, and minimum load during the 10 AM – 4 PM period (provided when SCADA data is available)
2. Transformer Data
 - (a) Existing service transformer kVA rating
 - (b) Primary Voltage and secondary Voltage rating
 - (c) Configuration on both Primary and Secondary Side (i.e., Delta, Wye, Grounded Wye, etc.)
 - (d) Characteristic impedance (%Z)
 - (e) Confirm if the transformer is serving only one customer or multiple customers
 - (f) Provide the Available Fault Current on both the Primary and Secondary Side

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 51

- E. INTERCONNECTION REQUEST SUBMISSION PROCESS (Cont'd.) (L)
- 1. OPTIONAL PRE-APPLICATION REPORT (Cont'd.)
 - 3. Secondary Service Characteristics
 - (a) Conductor type (AL or CU) and size (AWG)
 - (b) Conductor insulation type
 - (c) Number of parallel runs
 - (d) Confirm if the existing secondary service is 3-wire or 4-wire
 - 4. Primary Service Characteristics
 - (a) Conductor type (AL or CU) and size (AWG)
 - (b) Conductor insulation type
 - (c) Number of parallel runs
 - (d) Confirm if the existing primary service is 3-wire or 4-wire
 - iii. Combined Primary Service and Behind the Meter Interconnection Packages

Applicant may choose to request a combination of the Combined Primary Service Package and Behind the Meter Interconnection Package. Upon receipt of the applicable non-refundable fee of \$1,025, and additional \$100 fee if applicable, Distribution Provider shall provide the enhanced pre-application data described in this section within thirty (30) Business Days of receipt.

If a third party is submitting an Enhanced Pre-Application Report Request for Behind the Meter Interconnection Package on behalf of the Applicant, an Authorization to Receive Customer Information or Act on a Customer's Behalf [PG&E Form 79-1095] shall be processed in accordance with the instructions therein, and shall be required to be submitted at the same time as part of the Pre-Application Report Request. Distribution Provider shall notify the Applicant if additional processing time will be required. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

E. INTERCONNECTION REQUEST SUBMISSION PROCESS (Cont'd.) (L)

1. OPTIONAL PRE-APPLICATION REPORT (Cont'd.)

Except as provided specifically in this Section E.1, the Optional Standard and Enhanced Pre-Application Reports (Pre-Application Report(s)) need only include pre-existing data and does not obligate Distribution Provider to conduct a study or other analysis of the proposed project in the event that data is not available. For all Pre-Application Reports, if Distribution Provider cannot complete all or some of a Pre-Application Report due to lack of available data, Distribution Provider will provide Applicant with a Pre-Application Report that includes the information that is available.

In requesting a Pre-Application Report, Applicant understands that 1) the existence of "Available Capacity" in no way implies that an interconnection up to this level may be completed without impacts since there are many variables studied as part of the interconnection review process, 2) the distribution system is dynamic and subject to change and 3) data provided in the Pre-Application Report may become outdated and not useful at the time of submission of the complete Interconnection Request.

Notwithstanding any of the provisions of this Section, Distribution Provider shall, in good faith, provide Pre- Application Report data that represents the best available information at the time of reporting.

2. INTERCONNECTION REQUEST PROCESS

a. Applicant Initiates Contact with Distribution Provider

Upon request, Distribution Provider will provide information and documents (such as sample agreements, Interconnection Request, technical information, listing of Certified Equipment, Initial and Supplemental Review fee information, applicable tariff schedules and Metering requirements) to a potential Applicant. Unless otherwise agreed upon, all such information shall normally be sent to an Applicant within three (3) Business Days following the initial request from Applicant. Distribution Provider will establish an individual representative as the single point of contact for Applicant, but may allocate responsibilities among its staff to best coordinate the Interconnection of an Applicant's Generating Facility.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 53

E. INTERCONNECTION REQUEST SUBMISSION PROCESS (Cont'd.) (L)

2. INTERCONNECTION REQUEST PROCESS (Cont'd.)

b. Applicant Selects a Study Process

An Applicant may select one of two interconnection evaluation processes in accordance with the following eligibility requirements:

i) Fast Track Eligibility

The Distribution Provider shall evaluate Non-Exporting Generating Facilities and NEM-1 Generating Facilities under the Fast Track Review Process described in Section F.2 below. Applicants for all other Generating Facilities may request that the Distribution Provider evaluate their project under the Fast Track Review Process described in Section F.2 below. Applicants are encouraged to review the Integration Capacity Analysis for information relevant to their project.

ii) Detailed Study Eligibility

Interconnection Requests that are not eligible for Fast Track evaluation must apply for Detailed Study. An Applicant may also choose to apply directly for Detailed Studies. Detailed Study shall require (i) an Independent Study Process, (ii) a Distribution Group Study Process, or (iii) a WDT Transmission Cluster Study Process. The specific study process used will depend on the results of the Electrical Independence Tests for the Transmission and Distribution Systems.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 54

E. INTERCONNECTION REQUEST SUBMISSION PROCESS (Cont'd.) (L)

2. INTERCONNECTION REQUEST PROCESS (Cont'd.)

b. Applicant Selects a Study Process (Cont'd.)

iii) Request for Deliverability Assessment

Unless specified otherwise in the Interconnection Request, Generating Facilities eligible to be studied under the Fast Track Process, Independent Study Process or Distribution Group Study Process will be assumed to have selected Energy-Only Deliverability Status. Nothing herein will prohibit an Applicant from seeking a deliverability assessment in accordance with the WDT. Applicants studied under the WDT Transmission Cluster Study Process may seek a deliverability assessment in accordance with the applicable provisions of the WDT.

Applicant may submit a request to convert their Interconnection Request to the Federal Energy Regulatory Commission (FERC) jurisdiction Wholesale Distribution Tariff (WDT) process subject to PG&E's WDT Section 6.8.1.1 requirements. Additional information is available at: <https://www.pge.com/egi>.

c. Applicant Completes an Interconnection Request

All Applicants shall submit a complete and valid Interconnection Request. When applicable per Table E.1, a nonrefundable \$800 Interconnection Request fee, and for Applicants that elect Detailed Study in the Interconnection Request, a study deposit shall be required per instructions in the Interconnection Request. Applicants who proceed to Detailed Study after Fast Track will provide a Detailed Study deposit as specified in Section E.3.a.

Applicant shall submit a separate Interconnection Request for each Point of Interconnection. An Interconnection Request for the expansion of capacity of an existing operating Generating Facility shall be treated the same as an Interconnection Request for a new Generating Facility pursuant to this Rule.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 55

E. INTERCONNECTION REQUEST SUBMISSION PROCESS (Cont'd.) (L)

2. INTERCONNECTION REQUEST PROCESS (Cont'd.)

c. Applicant Completes an Interconnection Request (Cont'd.)

- i) Interconnection Requests for the Independent Study Process will be accepted throughout the year, except during the Distribution Group Study windows. All Detailed Study Interconnection Requests (except those applying directly to the WDT Transmission Cluster Study Process) submitted during the Distribution Group Study Windows will be processed as Distribution Group Study Process Applicants.
- ii) Interconnection Requests to be studied under the Distribution Group Study Process shall either be (a) an Independent Study Process Interconnection Request that passed screen Q and failed Screen R for which the Applicant elects to continue to the next available Distribution Group Study, or (b) an Interconnection Request submitted during a Distribution Group Study Application window that passes Screen Q.

There will normally be two (2) Distribution Group Study Application windows annually. The first Distribution Group Study Application window will usually open on March 1 and close on March 31. The second Distribution Group Study Application window will usually open on September 1 and close on September 30. In the event that any date set in this Section is not a Business Day, then the applicable date shall be the next Business Day thereafter.

The Distribution Provider may change the Distribution Group Study Application window interval and opening or closing dates. Any changes will be posted on the Distribution Provider's website. If there is a conflict between the Distribution Group Study Application window interval and opening or closing dates posted on the Distribution Provider's website and the dates identified in the paragraph above, the dates posted on the Distribution Provider's website shall apply.

(L)

(Continued)



**ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS**

Sheet 56

- E. INTERCONNECTION REQUEST SUBMISSION PROCESS (Cont'd.)
 - 2. INTERCONNECTION REQUEST PROCESS (Cont'd.)
 - c. Applicant Completes an Interconnection Request (Cont'd.)

(L)

TABLE E.1

Summary of Interconnection Request Fees, Deposits and Exemptions

Generating Facility Type	Interconnection Request Fee	Supplemental Review Fee	Detailed Study Deposit	Additional Commissioning Test Verification	Cost Envelope Option Deposit****	Modifications Fee (Table Ee.1) *****
Non-Net Energy Metering and > 1 MW NEM-2 *****	\$800	\$2,500*	For a Generating Facility with a Gross Nameplate Rating of 5 MW or less and applying to the Independent Study Process, \$10,000 for a System Impact Study or the DGS Phase I Interconnection Study in the case of the Distribution Group Study Process; and \$15,000 for an Interconnection Facilities Study or DGS Phase II Interconnection Study in the case of the Distribution Group Study Process. For a Generating Facility with a Gross Nameplate Rating above 5 MW, \$50,000 plus \$1,000 per MW of electrical output of the Generating Facility, or the increase in electrical output of the existing Generation Facility, as applicable, rounded up to the nearest whole MW, up to a maximum of \$250,000.	\$150/Person Hour**	\$2,500	\$0
≤ 1 MW NEM-2***	\$145	\$0	\$0	N/A	\$2,500	\$0
NEM-1	\$0	\$0	\$0	N/A	\$2,500	n/a
Non-NEM Solar ≤ 1MW*****	First \$5,000 of study fees waived			\$150/Person Hour**	\$2,500	\$0

(L)
(T)
(L)

* Optional \$1,000 additional fault current study fee pursuant to Section F.2.c.ii. Pursuant to D. 20-09-035, Applicants have the option to pre-pay the non-refundable Supplemental Review Fee (such as concurrently with the Interconnection Request fee) or separately upon completion of the Initial Review.

** Plus additional costs for travel, lodging and meals.

*** Applicants that participate in the Single-Family Affordable Solar Homes (SASH) program are exempt from the Interconnection Request fee.

**** Interconnection Requests that have selected the Cost Envelope Option and that subsequently qualify for and pass the Fast Track Process evaluation, as well as NEM Generating Facilities and Solar ≤ 1 MW Generating Facilities evaluated under the Independent Study Process, must provide the Cost Envelope Option deposit in accordance with Section F.7 to remain eligible for the Cost Envelope Option.

***** The fee will be set to \$0 for now, until PG&E submits a new Advice Letter to increase it. Note: the fee does not apply to NEM-1 nor NEMFC by statute. SASH is also exempt from this fee per D. 16-01-044.

*****Solar ≤ 1MW that does not sell power to Distribution Provider (per D.01-07-027) nor participate in NEM-1 or NEM-2.

*****see Section B.1 *Applicability* regarding NEM-2 projects greater than 1 MW interconnecting on Transmission.

(L)
(N)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 57

E. INTERCONNECTION REQUEST SUBMISSION PROCESS (Cont'd.) (L)

2. INTERCONNECTION REQUEST PROCESS (Cont'd.)

d. Site Exclusivity

Documentation of Site Exclusivity must be submitted with the Interconnection Request. This requirement does not apply to Applicants with NEM-1 Generating Facilities, NEM-2 ≤ 1 MW Generating Facilities, or Non-Export Generating Facilities.

3. INTERCONNECTION REQUEST FEE AND STUDY DEPOSIT

The Interconnection Request fee shall be waived for NEM-1 Interconnection Requests and for non-NEM solar-powered Generating Facilities that do not sell power per Commission Decision 01-07-027. NEM-1 Generating Facilities are also exempt from any costs associated with Interconnection Studies.

NEM-2 Applicants are required to pay any applicable Interconnection Request fees and costs associated with Interconnection Studies pursuant to Table E.1. As noted in the table, SASH participants are exempt from the NEM-2 Interconnection Request Fee and NEM-2 ≤ 1 MW Applicants are exempt from costs associated with Interconnection Studies.

Interconnection Study fees for non-NEM solar ≤ 1 MW Generating Facilities interconnecting to the Distribution System that do not sell power will be waived up to the amount of \$5,000.

The Applicant must pay the Interconnection Request Fee as outlined in Table E.1 with the Application. The Applicant may pre-pay the Supplemental Review Fee (such as concurrently with the Interconnection Request Fee), or separately upon completion of the Initial Review.

For Applicants that pre-pay the Supplemental Review Fee (such as concurrently with the Interconnection Request Fee), the Supplemental Review, if required, will be performed following the Initial Review. The Optional Initial Review Results Meeting will not be held, but the Optional Supplemental Review Results Meeting may be held following completion of the Supplemental Review.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 58

- E. INTERCONNECTION REQUEST SUBMISSION PROCESS (Cont'd.) (L)
- 3. INTERCONNECTION REQUEST FEE AND STUDY DEPOSIT (Cont'd.)
 - a. Detailed Study Deposit
 - i) Detailed Study Deposit

To proceed with Detailed Study, Applicant must submit a Detailed Study deposit.

For a Generating Facility with a Gross Nameplate Rating of 5 MW or less, Applicant must submit a Detailed Study deposit of \$10,000 for the Interconnection System Impact Study or the DGS Phase I Interconnection Study, and where an Interconnection Facilities Study or DGS Phase II Interconnection Study in the case of the Distribution Group Study Process is required, an additional \$15,000 deposit must be submitted as required in Section F.3.b.vi or F.3.c.viii.

(Continued)

Advice 6682-E-A
Decision D.22-07-001

Issued by
Meredith Allen
Vice President, Regulatory Affairs

Submitted September 19, 2022
Effective February 28, 2023
Resolution



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 59

E. INTERCONNECTION REQUEST SUBMISSION PROCESS (Cont'd.) (L)

3. INTERCONNECTION REQUEST FEE AND STUDY DEPOSIT (Cont'd.)

a. Detailed Study Deposit (Cont'd.)

For a Generating Facility with a Gross Nameplate Rating above 5 MW, Applicant must submit a Detailed Study deposit equal to \$50,000 plus \$1,000 per MW of electrical output of the Generating Facility, or the increase in electrical output of the existing Generating Facility, as applicable, rounded up to the nearest whole MW, up to a maximum of \$250,000.

ii) Use of Detailed Study Deposit

The Detailed Study deposit shall be applied to pay for prudent costs incurred by Distribution Provider, the CAISO, or third parties at the direction of Distribution Provider or CAISO, as applicable, to perform and administer the Interconnection Studies. Deposit amounts that exceed the prudent costs incurred by Distribution Provider shall be refunded to Applicant within sixty (60) Calendar Days following either the execution of the Generator Interconnection Agreement or project withdrawal as described in more detail below.

The interconnection study costs for a Distribution Study Group shall be allocated equally among the Interconnection Requests within the Distribution Study Group, except as provided in (3) below.

The Detailed Study deposits shall be refundable as follows:

- (1) Should an Interconnection Request be withdrawn by Applicant or be deemed withdrawn by Distribution Provider by written notice under Section F.6 on or before thirty (30) Calendar Days following the scoping meeting, Distribution Provider shall refund to Applicant any portion of Applicant's Detailed Study deposit that exceeds the costs Distribution Provider, CAISO, and third parties have incurred on Applicant's behalf, including interest from the date of receipt by Distribution Provider to the date of payment to Applicant. The applicable interest shall be one-twelfth of the Federal Reserve three-month Commercial Paper Rate – Non-Financial, from the Federal Reserve Statistical Release H.15 (expressed as an annual rate).

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 60

- E. INTERCONNECTION REQUEST SUBMISSION PROCESS (Cont'd.) (L)
- 3. INTERCONNECTION REQUEST FEE AND STUDY DEPOSIT (Cont'd.)
- a. Detailed Study Deposit (Cont'd.)
- ii) Use of Detailed Study Deposit (Cont'd.)
 - (2) Should an Interconnection Request that has been moved into the Detailed Study Process be withdrawn by Applicant or be deemed withdrawn by Distribution Provider by written notice under Section F.6 more than thirty (30) Calendar Days after the scoping meeting, but on or before thirty (30) Calendar Days following the results meeting for the Interconnection System Impact Study, or DGS Phase I Interconnection Study, Distribution Provider shall refund to Applicant the difference between (i) Applicant's Detailed Study deposit and (ii) the greater of (a) the costs Distribution Provider, CAISO, and third parties have incurred on Applicant's behalf or (b) one-half of the original Detailed Study deposit up to a maximum of \$100,000, including interest from the date of receipt by Distribution Provider to the date of payment to Applicant. The applicable interest shall be one-twelfth of the Federal Reserve three-month Commercial Paper Rate – Non-Financial, from the Federal Reserve Statistical Release H.15 (expressed as an annual rate).
 - (3) Should an Interconnection Request be withdrawn by Applicant or be deemed withdrawn by Distribution Provider by written notice under Section F.6 at any time more than thirty (30) Calendar Days after the results meeting for the Interconnection System Impact Study, or DGS Phase I Interconnection Study, or thirty (30) Calendar Days after issuance of the final Interconnection System Impact Study report or DGS Phase I Interconnection Study report if a results meeting is not held, the Detailed Study deposit shall be non-refundable.
 - (4) Upon execution of a Generator Interconnection Agreement by an Applicant and Distribution Provider, Distribution Provider shall refund to Applicant any portion of Applicant's detailed study deposit that exceeds the costs Distribution

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 61

- E. INTERCONNECTION REQUEST SUBMISSION PROCESS (Cont'd.) (L)
- 3. INTERCONNECTION REQUEST FEE AND STUDY DEPOSIT (Cont'd.)
- a. Detailed Study Deposit (Cont'd.)
- ii) Use of Detailed Study Deposit (Cont'd.)
- (4) Provider, CAISO, and third parties have incurred on Applicant's behalf, including interest from the date of receipt by Distribution Provider to the date of payment to Applicant. The applicable interest shall be one-twelfth of the Federal Reserve three-month Commercial Paper Rate – Non-Financial, from the Federal Reserve Statistical Release H.15 (expressed as an annual rate).
- iii) Impact of Withdrawal
- (1) Notwithstanding the foregoing, an Applicant that withdraws or is deemed to have withdrawn its Interconnection Request shall be obligated to pay to Distribution Provider all costs in excess of the Detailed Study deposit that have been prudently incurred or irrevocably have been committed to be incurred with respect to that Interconnection Request prior to withdrawal. Distribution Provider will reimburse the CAISO or third parties, as applicable, for all work performed on behalf of the withdrawn Interconnection Request at Distribution Provider's direction. Applicant must pay all monies due before it is allowed to obtain any Interconnection Study data or results. Any proceeds of the Detailed Study deposit not otherwise reimbursed to Applicant or applied to costs incurred or irrevocably committed to be incurred for the interconnection studies shall be applied as directed by the Commission. Where an Applicant with remaining proceeds from a Detailed Study deposit cannot be located, such remaining proceeds shall escheat to the State pursuant to the Unclaimed Property Law commencing with the California Code of Civil Procedure § 1500. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 62

- E. INTERCONNECTION REQUEST SUBMISSION PROCESS (Cont'd.) (L)
- 3. INTERCONNECTION REQUEST FEE AND STUDY DEPOSIT (Cont'd.)
 - a. Detailed Study Deposit (Cont'd.)
 - iii) Impact of Withdrawal (Cont'd.)
 - (2) Forfeited Study Deposit for Distribution Group Study Process

Non-refundable Detailed Study deposits, as pursuant to Section E.3.a.ii, for a Distribution Group Study Process Interconnection Request, shall be applied to the costs associated with any following Interconnection Study or restudy work performed by Distribution Provider, CAISO, or third party for the withdrawn Interconnection Request's

Distribution Study Group. Any remaining proceeds of the Detailed Study deposit, after the withdrawn Interconnection Request's Distribution Study Group has completed all relevant Interconnection Studies or restudies, or all Interconnection Requests associated with the specific Distribution Study Group have withdrawn, not otherwise applied to costs incurred, or irrevocably committed to be incurred for the Interconnection Studies or restudies, shall be allocated to individual Applicants on a kVA basis who have remained in the Distribution Study Group by executing a Generator Interconnection Agreement.

Such funds shall be allocated to Applicants sixty (60) Calendar Days following the conclusion of the Generator Interconnection Agreement negotiation pursuant to Section F.3.e.ii. If no Applicants remain in the Distribution Study Group, such funds shall escheat to the State pursuant to the Unclaimed Property Law commencing with the California Code of Civil Procedure § 1500.
 - iv) Special Circumstances

Applicant may propose, and Distribution Provider may agree to reduced costs for reviewing atypical Interconnection Requests, such as Interconnection Requests submitted for multiple Generating Facilities, multiple sites, or otherwise as conditions warrant.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 63

E. INTERCONNECTION REQUEST SUBMISSION PROCESS (Cont'd.) (L)

4. INTERCONNECTION COST RESPONSIBILITY

An Applicant, or a Producer where those are different entities, is responsible for all fees and/or costs, including Commissioning Testing, required to complete the interconnection process. A Producer that interconnects to Distribution Provider's Distribution or Transmission System is responsible for all costs associated with Parallel Operation to support the safe and reliable operation of the Distribution and Transmission System. NEM-1 Generating Facilities and NEM-2 ≤1 MW Generating Facilities are exempt from any costs associated with Distribution or Network Upgrades.

a. Costs of Interconnection and Parallel Operation

The Interconnection and Parallel Operation of a Producer may trigger the need for Interconnection Facilities, Special Facilities or Added Facilities, Upgrades, Delivery Network Upgrades, and/or Reliability Network Upgrades. Interconnection Facilities installed on Producer's side of the PCC may be owned, operated and maintained by Producer or Distribution Provider. Interconnection Facilities installed on Distribution Provider's side of the PCC and Distribution System modifications shall be owned, operated, and maintained only by Distribution Provider.

b. Methodology and Timing of Cost Identification

Any costs triggered by a Producer are based on Producer's unique Interconnection requirements, Producer's impact on the Distribution System and/or Transmission System following allocation of capacity to earlier-queued interconnection requests, and Producer's electrical interdependence with any earlier-queued interconnection requests. Earlier-queued interconnection requests include interconnection requests under any applicable tariff. (L)

(Continued)



**ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS**

Sheet 64

- E. INTERCONNECTION REQUEST SUBMISSION PROCESS (Cont'd.) (L)
- 4. INTERCONNECTION COST RESPONSIBILITY (Cont'd.)
- c. Timing of Cost Identification

For Applicants to Fast Track, Independent Study Process, or Distribution Group Study Process, costs may be identified during the study process, or after the study process is complete and a Generator Interconnection Agreement is executed. The purpose of later identification of costs is to facilitate Applicant's Interconnection while accommodating incomplete interconnection studies for earlier-queued interconnection requests to the same Line Section, distribution circuit, and/or substation, incomplete interconnection studies for earlier-queued interconnection requests with which Applicant is electrically interdependent with respect to short circuit duty, withdrawal of earlier-queued interconnection requests for Interconnection to the Distribution or Transmission System, and delay or cancellation of planned Distribution System Upgrades.
- d. Producer Costs During Parallel Operation

All Producers are required to provide and maintain Interconnection Facilities, for the duration of the Generator Interconnection Agreement, that meet Distribution Provider's technical design and operating standards for Parallel Operation as set out in Section H or Hh, including any updates to those standards. This includes Producer responsibility for costs associated with changes to the operating characteristics at the Point of Interconnection necessitated by Distribution Provider's upgrades to the Transmission or Distribution System from time to time.
- e. Cost Allocation

For cost allocation under the Fast Track Process or the Independent Study Process: Except where exempt by law or Commission decision, costs triggered by an Interconnection Request are the responsibility of the triggering Interconnection Request.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 65

E. INTERCONNECTION REQUEST SUBMISSION PROCESS (Cont'd.) (L)

4. INTERCONNECTION COST RESPONSIBILITY (Cont'd.)

e. Cost Allocation (Cont'd.)

For cost allocation under the Distribution Group Study Process: The costs of Interconnection Facilities will be assigned to the triggering Interconnection Request. The costs of Distribution Upgrades or Network Upgrades identified through a Distribution Group Study shall be allocated among the Interconnection Requests in a Distribution Study Group based on nameplate kilovolt amperes (kVA) and, in some instances, as determined by Distribution Provider, also based on an Applicant's specific contributions to the upgrade costs. Costs for upgrades will be allocated based upon an Applicant's specific contributions to a particular upgrade only if the Distribution Provider determines that; based on overall fairness to the Distribution Study Group, the individual applicant, rather than the Distribution Study Group, should be responsible for the costs. Cost allocation within the Distribution Study Group will not always align with cost contribution under a per kVA plus specific contribution allocation method. The DGS Phase I and Phase II study reports will indicate how cost allocation is determined. Examples of the possible types of shared costs include but may not be limited to: upgraded transformers, reconductoring, circuit switchers, and breakers.

Costs triggered by an Interconnection Request under this Rule that transitions to the WDT Transmission Cluster Study Process are allocated pursuant to the terms of Distribution Provider's WDT or other applicable tariff.

(L)

(Continued)



**ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS**

E. INTERCONNECTION REQUEST SUBMISSION PROCESS (Cont'd.)

(L)

4. INTERCONNECTION COST RESPONSIBILITY (Cont'd.)

f. Summary Tables

Table E.2 summarizes cost responsibility for costs and fees that may arise in the course of the interconnection process for NEM and non-NEM Applicants. Table E.3 summarizes cost responsibility for costs and fees that may arise in the course of the interconnection process for NEM Applicants under various sequences of interconnecting NEM and non-NEM Generators on the same PCC interconnecting to the Distribution or Transmission System.

Table E.2 Summary of Producer Cost Responsibility

Generating Facility Type	Interconnection Request Fee		Supplemental Review Fee		Detailed Study Cost (ISP, DGSP, or TCSP)		Interconnection Facilities Cost		Distribution Upgrades Cost		Transmission Network Upgrade Cost (per Applicable CAISO Tariff at signing of IA)	
	YES	NO	YES	NO	YES	NO	YES	NO	YES	NO	YES	NO
Non-NEM and NEM-2 (>1MW)***	X		X		X		X		X		X	
NEM-1		X		X		X	X			X ^a		X ^a
NEM-2 (≤1MW)*	X			X		X ^{**}	X			X		X ^{**}

* Applicants participating in the Single-Family Affordable Solar Homes program are exempt from the Interconnection Request Fee.

** Except as provided in Section F.3.d.

*** see Section B.1 *Applicability* regarding NEM-2 projects greater than 1 MW interconnecting on Transmission.

(L)
(T)
(L)

(L)

(N)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 67

E. INTERCONNECTION REQUEST SUBMISSION PROCESS (Cont'd.)

4. INTERCONNECTION COST RESPONSIBILITY (Cont'd.)

f. Summary Tables (Cont'd.)

Table E.3 Summary of Producer Cost Responsibility for Multiple Tariff Interconnections

Existing Generating Facility	New Generating Facility	Interconnection Request Fee		Supplemental Review Fee		Detailed Study Cost		Interconnection Facilities Cost		Distribution Upgrades Cost	
		YES	NO	YES	NO	YES	NO	YES	NO	YES	NO
NEM	Non-NEM, NEM-2 (>1 MW)	X		X		X		X		X ^b	
NEM-1	NEM-1		X		X		X	X			X
NEM-1	NEM-2 (≤1MW)*	X			X		X	X			X
Non-NEM	NEM-1		X ^c		X ^c		X ^c	X			X ^{b,c}
Non-NEM	NEM-2 (>1 MW)	X		X		X		X		X	
Non-NEM	NEM-2 (≤1MW)*	X			X ^c		X ^c	X			X ^{b,c}
Simultaneous NEM and Non-NEM		X		X		X		X		X ^b	
a) Except as provided in Section D.13.e											
b) Proration will be based upon the annual expected energy output (kWh) derived from the nameplate of the Generator(s) modified by technology-specific capacity/availability factors of all NEM and non-NEM Generators for the costs that cannot be clearly assigned to each type of tariff.											
c) Change of operation of a non-NEM eligible Generator at any time to export is treated as a simultaneous NEM and non-NEM Interconnection Request, resulting in associated costs being allocated to Producer.											

(D)
—
(D)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 68

E. INTERCONNECTION REQUEST SUBMISSION PROCESS (Cont'd.) (L)

5. INTERCONNECTION REQUEST VALIDATION AND ASSIGNMENT OF QUEUE POSITION

Any Applicant for Interconnection to Distribution Provider's Distribution or Transmission System must submit a complete and valid Interconnection Request. An Interconnection Request will be considered complete and valid when all items required for an Interconnection Request have been received by Distribution Provider and deemed valid by Distribution Provider.

a. Acknowledgement of Interconnection Request

For Interconnection Requests that have not elected the Cost Envelope Option, Distribution Provider shall provide a first written notification to the Interconnection Customer within ten (10) Business Days of receipt of the Interconnection Request, which notice shall state whether the Interconnection Request is deemed complete and valid.

For Interconnection Requests that have elected the Cost Envelope Option, Distribution Provider shall provide a first written notification to the Interconnection Customer within twenty (20) Business Days of receipt of the Interconnection Request, which notice shall state whether the Interconnection Request is deemed complete and valid.

b. Deficiencies in Interconnection Request

i) First Notification of Deficiency

If an Interconnection Request fails to meet the requirements, Distribution Provider shall state in its first written notification the reasons for such failure and that the Interconnection Request does not constitute a valid request.

Applicant shall provide Distribution Provider the additional requested information needed to constitute a complete and valid request within ten (10) Business Days from the date of the first written notification that the Interconnection Request is invalid. (L)

(Continued)



**ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS**

Sheet 69

- E. INTERCONNECTION REQUEST SUBMISSION PROCESS (Cont'd.) (L)
- 5. INTERCONNECTION REQUEST VALIDATION AND ASSIGNMENT OF QUEUE POSITION (Cont'd.)
 - b. Deficiencies in Interconnection Request (Cont'd.)
 - ii) Second Notification of Deficiency

Distribution Provider shall provide a second written notification to Applicant within ten (10) Business Days of receipt of the additional requested information, stating whether the Interconnection Request is valid or the reasons for any failure.

Applicant shall provide Distribution Provider the additional requested information needed to constitute a complete and valid request within five (5) Business Days from the date of the second written notification that the Interconnection Request is invalid.
 - iii) Extension Request

Upon request, Applicant can receive one extension of up to twenty (20) Business Days to resolve deficiencies in the Interconnection Request.
 - iv) Failure to Resolve Deficiencies

If Applicant does not resolve deficiencies in the Interconnection Request within the time frames set out above, Distribution Provider will deem the Interconnection Request withdrawn. Applicant may submit a new Interconnection Request.

Applicants with invalid Interconnection Requests under this Section may seek relief under the dispute resolution provisions in Section K by so notifying Distribution Provider within two (2) Business Days of receipt of the first or second written notification that the Interconnection Request is incomplete and/or invalid. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 70

E. INTERCONNECTION REQUEST SUBMISSION PROCESS (Cont'd.)

5. INTERCONNECTION REQUEST VALIDATION AND ASSIGNMENT OF QUEUE POSITION (Cont'd.)

c. Assignment of Queue Position

Distribution Provider shall assign a queue position to all NEM-2 Applicants with Generating Facilities sized above 1 MW (except as provided in Section D.13.e) and all non-Net Energy Metering Applicants. Applicants applying for Momentary Parallel Operation of any size, or Non-Export Applicants with Gross Nameplate Capacity of 30 kW or less, will not be assigned a queue position by the Distribution Provider. If there were no deficiencies in the Interconnection Request, the queue position will be based on the date Distribution Provider received the Interconnection Request. If there were deficiencies in the Interconnection Request, the queue position will be based on the date Distribution Provider determines an Interconnection Request to be complete and valid. Should Distribution Provider not meet any deadline for providing the first (Section E.5.b.i) or second written notification (Section E.5.b.ii) to Applicant regarding the Interconnection Request, Applicant's queue position shall be set on the final day of the period in which Distribution Provider was obligated to provide such written notification, provided, however, that Applicant meets deadlines as set out above to submit any additional information required for a valid Interconnection Request following such written notification under Section E.5.b.i or E.5.b.ii, and that Distribution Provider determines that the Interconnection Request is valid.

Distribution Provider shall maintain a single queue for all Interconnection Requests requiring a Queue Position and governed by this Rule with a Point of Interconnection on Distribution Provider's Distribution System. For Interconnection Requests that are studied under the Distribution Group Study Process, the effective queue position for all Interconnection Requests in a Distribution Study Group will be derived on the last day of the Distribution Group Study window for that WDT Distribution Study Group. For Interconnection Requests that are studied under the Transmission Cluster Study Process, the queue position will be the applicable cluster's queue position.

(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 71

- E. INTERCONNECTION REQUEST SUBMISSION PROCESS (Cont'd.) (L)
- 5. INTERCONNECTION REQUEST VALIDATION AND ASSIGNMENT OF QUEUE POSITION (Cont'd.)
 - d. Publication of the Interconnection Queue

Distribution Provider shall publish and update monthly on its website the interconnection queue for all Interconnection Requests governed by this Rule with a Point of Interconnection on Distribution Provider's Distribution System that have been assigned a queue position. Nothing here prohibits Distribution Provider from publishing this queue combined with other interconnection requests to Distribution Provider's Distribution System. The published interconnection queue may include the following information for each Interconnection Request governed by this Rule, subject to Energy Division approval:

 - i) Interconnection Request and Queue Position Data
 - (1) The assigned number, if any;
 - (2) the queue position;
 - (3) the date the Interconnection Request was received by Distribution Provider;
 - (4) the date the Interconnection Request was determined to be complete and valid;
 - (5) the review process to which Applicant originally applied and is currently assigned;
 - (6) the original requested In-Service Date;
 - (7) the currently requested In-Service Date;
 - (8) the agreed-upon Commercial Operation Date or actual Commercial Operation Date.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 72

- E. INTERCONNECTION REQUEST SUBMISSION PROCESS (Cont'd.) (L)
 - 5. INTERCONNECTION REQUEST VALIDATION AND ASSIGNMENT OF QUEUE POSITION (Cont'd.)
 - d. Publication of the Interconnection Queue (Cont'd.)
 - ii) Applicant Generating Facility/Storage System and Point of Interconnection Data
 - (1) the maximum summer and winter MW electrical output;
 - (2) the type of generating or storage facility to be constructed;
 - (3) the fuel source;
 - (4) the proposed Point of Interconnection location by county;
 - (5) the proposed Point of Interconnection location by substation/area and, if applicable, circuit.
- (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 73

Ee. MODIFICATION TO INTERCONNECTED GENERATING FACILITIES

(L)

1. MODIFICATIONS TO EXISTING EQUIPMENT (D.19-03-013 - Type II)

Certain non-material modifications to existing facilities are permitted as described below in Tables Ee.1, 2 and 3. Modification requests shall incur any incremental fees as noted below. From the date of the proposed modification request is received, the Distribution Provider shall process the request within:

- (a) ten (10) Business Days if no re-study is required
- (b) twenty (20) Business Days if a re-study is required

Table Ee.1 – Replacing existing equipment				
Description of Modification	Notification Required?	Interconnection request is required?	Proceed without PG&E approval?	Fee (See table E.1)
Replace equipment with exact same equipment type	No	No	Yes	n/a
Replace with “like-for-like,” ⁴ where: 1. system output does not exceed what is listed in the original interconnection agreement and 2. operating mode is not adjusted.	Yes	No	Yes	Modification Fee in Table E.1 ¹
Replacement increases nameplate capacity of the system, but which employ inverter power controls that limit the active power output to the inverter listed size in the original agreement.	Increases nameplate to <100kw ²	Yes	No	Modification Fee in Table E.1 ¹
	Increases nameplate to >100kw and ≤ 110% of original capacity	Yes	No	Modification Fee in Table E.1 ¹
	Increase nameplate to > 100kw and > 110% of original capacity	No	Yes	E.1 ³
Replacing equipment such that the system capacity increases and no inverter power controls are employed to limit the active power output to the inverter listed size in the original agreement	No	Yes	No	E.1 ³
All other scenarios	No	Yes	No	E.1

¹ See Modification Fees in Table E.1.

² For projects increasing capacity to less than or equal to 100 kilowatt (kW), pending the creation of certification schemes for inverter power controls (software/firmware) to limit export (per D. 19-03-013, OP6).

³ “E.1” refers to applicable charges/fees in Rule 21 Table E.1 for a new application.

⁴ Like-for-Like is defined in Section C.

(L)
(P)/(L)
(L)

(L)
(P)/(L)
(L)

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 74

Ee. Modification to Interconnected Generating Facilities (CONT'D.)

(L)

1. MODIFICATIONS TO EXISTING EQUIPMENT (D. 19-03-013 - Type II) (CONT'D.)

Table Ee.2 – Upgrading Inverter Firmware /Changing Inverter Characteristics				
Description of Modification:	Notification Required?	Interconnection Request Required	Proceed without PG&E approval?	Fee (See table E.1)
Only performing upgrades to inverter firmware that do not affect grid interactions	No	No	Yes	n/a
Changing inverter operating characteristics.	No	Yes	No	E.1
All Other Scenarios	No	Yes	No	E.1

Table Ee.3 -- Adding Storage or Capacity					
Description of Modification:	Notification Required?	Interconnection Request Required?	Proceed without PG&E approval?	Fee (See table E.1)	
Adding storage capacity to an existing storage facility without changing inverter	Generator's maximum output based on its rated capacity ¹	Yes	No	Yes	\$0
	Generator's maximum output based on its operational profiles ²	Yes	No	Yes	Modification Fees in E.1
Adding storage to an existing generating facility that does not have storage.	No	Yes	No	E.1	
Adding such that system capacity increases and no inverter power controls are employed to limit the active power output to the inverter listed size in the original agreement.	No	Yes	No	E.1	
All Other Scenarios	No	Yes	No	E.1	

¹ If the Commission determines that a generator's maximum output should be based on its rated capacity (per D. 19-03-013, OP6).

² If the Commission determines that operational profiles of systems should be used to determine system impacts D.19-03-013, (per OP6).

(L)
(P)/(L)
(L)

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 75

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS

(L)

1. OVERVIEW OF THE INTERCONNECTION REVIEW PROCESS

a. Valid Interconnection Request

After an Interconnection Request is deemed complete and valid, Distribution Provider will perform Fast Track evaluation unless an Applicant applies for Detailed Study or is not eligible for Fast Track evaluation. The eligibility requirements for Fast Track evaluation are set forth in Section E.2.b. See Section D.13 for special provisions related to the timeframe and costs applicable to certain NEM Applicants as provided therein. See Section D.14 and Section N for special provisions applicable to Non-Export Energy Storage Generating Facilities, as provided therein.

(L)

(Continued)

Advice 6682-E-A
Decision D.22-07-001

Issued by
Meredith Allen
Vice President, Regulatory Affairs

Submitted September 19, 2022
Effective February 28, 2023
Resolution



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 76

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)

1. OVERVIEW OF THE INTERCONNECTION REVIEW PROCESS (Cont'd.)

b. Fast Track Review

Fast Track evaluation allows for rapid review of the Interconnection of those Generating Facilities that do not require Detailed Study. Regardless of study process, all Generating Facilities shall be designed to meet the applicable requirements of Section H which identifies Generating Facility Design and Operation Requirements.

Fast Track review consists of an Initial Review and, if required, a Supplemental Review. The need for Supplemental Review will be determined based on the results of Initial Review Screens A through M in Section G.1. Applicants that successfully pass Initial Review Screens A through M will be allowed to interconnect without Supplemental Review.

Non-Export AC/DC Converter installations that have a complete and valid Interconnection Request will be eligible to bypass screens B through D and F through M.

If Supplemental Review is required, Distribution Provider will notify Applicant and Applicant must pay a nonrefundable Supplemental Review fee, per Table E-1 or withdraw its Interconnection Request. If the Applicant pre-paid the Supplemental Review fee (such as concurrently with the Interconnection Request Fee), the Supplemental Review, if required, will be conducted upon completion of the Initial Review. Supplemental Review shall consist of the application of Screens N through P in Section G.2. Applicants that pass Screens N through P will be allowed to interconnect without additional review.

If Supplemental Review reveals that a proposed Generating Facility cannot be interconnected to Distribution Provider's Distribution System by means of Fast Track evaluation, Distribution Provider will notify Applicant that Detailed Study will be required.

Failure to pass Fast Track evaluation means only that further review and/or study are required before the Generating Facility can be interconnected with Distribution Provider's Distribution System. It does not mean that the Generating Facility cannot be interconnected.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 77

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)

1. OVERVIEW OF THE INTERCONNECTION REVIEW PROCESS (Cont'd.)

c. Detailed Studies (L)

Except as provided in Section B.1 *Applicability* regarding NEM-2 greater than 1 MW on Transmission, Detailed Study will be required for Interconnection Requests that apply directly for Detailed Study, are not eligible for Fast Track evaluation, or do not pass Fast Track evaluation. Detailed Study shall consist of one of three study processes: (i) Independent Study Process; (ii) Distribution Group Study Process; or (iii) WDT Transmission Cluster Study Process. The specific study process that is applied will depend on the results of Screens Q and R in Section G.3. Interconnection Requests that are found to be electrically interdependent with earlier-queued interconnection requests with impacts on the Transmission System, and thereby fail screen Q, will proceed to the WDT Transmission Cluster Study Process. Interconnection Requests that are not electrically interdependent with earlier-queued interconnection requests with impacts on the Transmission System, and thereby pass Screen Q, will be studied under either the Independent Study Process or the Distribution Group Study Process, depending on the results of Screen R. (T)
(T)
(L)

d. Compliance with Timelines

Distribution Provider shall use Reasonable Efforts in meeting all the timelines set out in this Rule, or mutually modified by Distribution Provider and Applicant pursuant to Section D.16. Each Distribution Provider shall designate an ombudsman with authority to resolve disputes over missed timelines. The identity, role, and contact information of the ombudsman shall be available on Distribution Provider's website.

If at any time an Applicant is dissatisfied with the Reasonable Efforts of Distribution Provider to meet the timelines in this Section, Applicant may use the following procedures:

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 78

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)

1. OVERVIEW OF THE INTERCONNECTION REVIEW PROCESS (Cont'd.)

d. Compliance with Timelines (Cont'd.)

(i) Contact the ombudsman designated by Distribution Provider;

(ii) If the Distribution Provider ombudsman (Rule21.Ombudsman@pge.com) is unable to resolve the dispute within ten (10) Business Days, Applicant may either:

a) Contact the Consumer Affairs Branch (CAB) at the Commission.

b) Upon mutual agreement with Distribution Provider, make a written request for mediation to the Alternative Dispute Resolution (ADR) Coordinator in the Commission's Administrative Law Judge (ALJ) Division. The request may be made by electronic mail to adr_program@cpuc.ca.gov, and shall state "Rule 21" in the subject line. The request shall contain the relevant facts of the timeline dispute. A copy of the request shall be sent to the Distribution Provider ombudsman. Provided that resources are available, the mediator assigned shall schedule a mediation with Applicant and Distribution Provider within ten (10) Business Days of receiving the request.

c) Initiate dispute resolution processes in accordance with Section K.

At any time, Applicant may file a formal complaint before the Commission pursuant to California PUC Section 1702 and Article 4 of the Commission's Rules of Practice and Procedure.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 79

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)

2. FAST TRACK INTERCONNECTION REVIEW PROCESS

a. Initial Review

Upon receipt of a complete and valid Interconnection Request, Distribution Provider shall perform Initial Review using the process in Section G.1. The Initial Review determines if (i) the Generating Facility qualifies for Fast Track Interconnection through Initial Review, or (ii) the Generating Facility requires a Supplemental Review. Absent extraordinary circumstances, Distribution Provider shall notify Applicant in writing of the results of Initial Review within fifteen (15) Business Days following validation of an Interconnection Request. (L)

As part of the evaluation of Screen M, when Integration Capacity Analysis Values are available at the requested Point of Interconnection, Distribution Provider will determine if Integration Capacity Analysis Values at the proposed Point of Interconnection need to be updated. If Distribution Provider determines that the Integration Capacity Analysis Values at the proposed Point of Interconnection need to be updated, the Distribution Provider will update the values for the proposed Point of Interconnection using the Integration Capacity Analysis tool on the specific electrical node or by running the Integration Capacity Analysis on all the electrical nodes in the circuit. Distribution Provider shall not perform additional Integration Capacity Analysis as part of the interconnection process of projects with less than 30 kilovolt amperes nameplate capacity. Distribution Provider shall share the results of any Integration Capacity Analysis updates with the Applicant and provide an explanation of changes to grid conditions or the interconnection queue which led to the need to obtain updated Integration Capacity Analysis Values. Distribution Provider shall comply with confidentiality provisions and data redaction policies (P)/(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 81

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)

2. FAST TRACK INTERCONNECTION REVIEW PROCESS

a. Initial Review (Cont'd.)

For Interconnection Requests that fail Initial Review, Distribution Provider shall provide the technical reason, data and analysis supporting the Initial Review results in writing and provide Applicant the option to either attend an Initial Review results meeting or proceed directly to Supplemental Review. NEM-1 and ≤ 1 MW NEM-2 Applicants covered under Section D.13.a, and Applicants that pre-pay for the Supplemental Review (such as concurrently with the Interconnection Request Fee), shall proceed directly to Supplemental Review without an Initial Review results meeting. Applicant shall notify Distribution Provider within ten (10) Business Days following such notification whether to (i) proceed to an Initial Review results meeting, (ii) proceed to Supplemental Review, or (iii) withdraw the Interconnection Request. Applicant may request one extension of no more than ten (10) Business Days to respond. If Applicant fails to notify Distribution Provider within ten (10) Business Days of such notification, or at the end of the extension, if one was requested, the Interconnection Request shall be deemed withdrawn.

No changes may be made to the planned Point of Interconnection or Generating Facility size included in the Interconnection Request during the Fast Track Process, except as provided in Table F.1 below, or unless such changes are agreed to by Distribution Provider. Where agreement has not been reached, Applicants choosing to change the Point of Interconnection or Generating Facility size, except as provided for in Table F.1, must reapply and submit a new Interconnection Request.

Applicants that elect to proceed to Supplemental Review, unless the Applicant has pre-paid, shall provide a nonrefundable Supplemental Review fee set forth in Section E.2.c with their response. The Supplemental Review fee shall be waived for Interconnection Requests requesting Interconnection of NEM-1 or ≤ 1 MW NEM-2 Generating Facilities and for solar-powered non-NEM ≤ 1 MW Generating Facilities that do not sell power to Distribution Provider, per Commission D.01-07-027.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 82

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.)

(L)

2. FAST TRACK INTERCONNECTION REVIEW PROCESS

a. Initial Review (Cont'd.)

TABLE F.1 – MODIFICATION TO PENDING APPLICATIONS (D. 19-03-013 Type I Changes)

Modifications to Interconnection Applications Under the Fast Track		
1. The number of modification requests per Interconnection Request is limited to one. 2. D.19-03-013 gives Distribution Provider the discretion to allow additional modification requests. Distribution Provider is encouraged to exercise this discretion in instances when Distribution Provider has caused the need for an additional modification request. 3. From the date of the proposed modification request is received, the Distribution Provider shall process the request within: (i) ten (10) Business Days if no re-study is required (ii) twenty (20) Business Days if a re-study is required 4. Except as allowed in Section E.4 for NEM customers, if a project downsizes, the revised shall not affect the cost responsibility or timing of interconnection of other projects. 5. Additional changes outside of the modification types identified herein will not be accepted under the Fast Track process.		
Description of Modification	Application Modifications Allowed?	Fee
"Like-for-like" ¹ equipment replacements meeting the following criteria: <ul style="list-style-type: none"> Does not increase facility size²; No size decrease exceeding 20%; and No identified upgrades or mitigations. 	Yes	n/a
Size reductions meeting the following criteria: <ol style="list-style-type: none"> No size reduction exceeding 20%; and Identified upgrades or mitigations are paid for by the customer 	Yes	n/a
Size reductions to avoid upgrades meeting the following criteria: <ol style="list-style-type: none"> The re-study determines that the modification affects no other distributed energy resource 	Yes	\$300 ³
Other types of modifications outside of those listed in this table will not be accepted without a new application.	No	

¹ Like-for-like is defined in Section C

² System size pursuant to D.19-03-013, footnote 43 on p.22 is defined as the follows:

For solar systems	For energy storage systems	For all other generation types
the lesser of inverter nameplate capacity (kW) or maximum solar output (CEC-AC rating)	both the inverter nameplate capacity (kW) and the capacity of the storage device (kWh) are considered in the definition of size.	the gross nameplate rating of the generator

³ Pursuant to D.19-03-013, p.22

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 83

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)

2. FAST TRACK INTERCONNECTION REVIEW PROCESS (Cont'd.)

b. Optional Initial Review Results Meeting

Within five (5) Business Days of Applicant's request for an Initial Review results meeting, Distribution Provider shall contact Applicant and offer to convene a meeting at a mutually acceptable time to review the Initial Review screen analysis and related results to determine what modifications, if any, may permit the Generating Facility to be connected safely and reliably without Supplemental Review.

In the event the Applicant has pre-paid the Supplemental Review fee (such as concurrently with the Interconnection Request Fee), the Distribution Provider will proceed, if necessary, with Supplemental Review upon completion of Initial Review and shall not be required to offer an Initial Review results meeting.

If modifications that obviate the need for Supplemental Review are identified, and Applicant and Distribution Provider agree to such modifications, Distribution Provider shall provide Applicant with a Generator Interconnection Agreement within fifteen (15) Business Days of the Initial Review results meeting if no Interconnection Facilities or Distribution Upgrades are required. If Interconnection Facilities or Distribution Upgrades are required, Distribution Provider shall provide Applicant with a non-binding cost estimate of any Interconnection Facilities or Distribution Upgrades within fifteen (15) Business Days of the Initial Review results meeting. For those Interconnection Requests where Applicant has selected the Cost Envelope Option, within ten (10) Business Days of providing Applicant the non-binding cost estimate for the required Interconnection Facilities and/or Distribution Upgrades, Applicant shall provide the Distribution Provider the Cost Envelope Option deposit, in accordance with Section F.7.a.i.3. If Applicant fails to provide the Cost Envelope Option deposit in accordance with Section F.7.a.i.3, Applicant's request for the Cost Envelope Option shall be deemed withdrawn and the Interconnection Request shall not be eligible for the Cost Envelope Option.

For all Interconnection Requests that pass Initial Review, refer to Section F.2.e for cost responsibility and time frames for completing the Generator Interconnection Agreement.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 84

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)

2. FAST TRACK INTERCONNECTION REVIEW PROCESS (Cont'd.)

b. Optional Initial Review Results Meeting (Cont'd.)

If Applicant and Distribution Provider are unable to identify or agree to modifications that enable Applicant to pass Initial Review, Applicant shall notify Distribution Provider within ten (10) Business Days of the Initial Review results meeting whether it would like to proceed with Supplemental Review or withdraw its Interconnection Request. Applicant may request one extension of no more than ten (10) Business Days to respond. If Applicant fails to notify Distribution Provider within ten (10) Business Days of the Initial Review results meeting, or at the end of the extension, if one was requested, the Interconnection Request shall be deemed withdrawn.

c. Supplemental Review

- i) If Applicant requests Supplemental Review and submits a nonrefundable Supplemental Review fee, if required, Distribution Provider shall complete Supplemental Review within twenty (20) Business Days, absent extraordinary circumstances, following authorization and receipt of the fee. Supplemental Review determines if (i) the Generating Facility qualifies for Fast Track Interconnection, or (ii) the Generating Facility requires Detailed Study.
- ii) If the Applicant pre-paid the Supplemental Review fee (such as concurrently with the Interconnection Request Fee), Distribution Provider will complete the Supplemental Review, if required, within twenty (20) Business Days from the completion of the Initial Review.
- iii) If the Applicant chooses to move to Supplemental Review or has pre-paid the non-refundable Supplemental Review fee, they have the option to elect that the Distribution Provider provide a fault current study as part of the Supplemental Review. This fault current study would extend the Supplemental Review time by up to ten (10) Business Days, and would require an additional nonrefundable fee of \$1,000.

This fault current study will determine if the Generating Facility can detect phase and ground faults on the Distribution Provider's Distribution System or the distribution feeder breaker where the Applicant proposes to connect the Generating Facility.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 85

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.)

2. FAST TRACK INTERCONNECTION REVIEW PROCESS (Cont'd.)

c. Supplemental Review (Cont'd.)

iii) The result of the fault current study will determine if direct transfer trip (DTT) will be required from the Distribution System to the Generating Facility site. Note that for Applicants proposing to interconnect to the Distribution System where there is expected to be power backfeed to the Transmission System, DTT from the transmission may still be required and a Detailed Interconnection Study will be required to make this determination (Cont'd).

(L)

Should the Applicant request a Supplemental Review results meeting, as described in Section F.2d, the optional fault current study analysis and related results shall, at the Applicant's request, be reviewed to determine what modifications, if any, may permit the Generating Facility to be connected safely and reliably.

The Applicant must provide the following data to Distribution Provider when requesting Supplemental Review in order to select this option:

Generator:

- MVA Rating
- kV Rating
- Base MVA
- Base kV
- Xd" (direct axis subtransient reactance)
- Xd' (direct axis transient reactance)
- Xd (Synchronous reactance)
- X2 (Negative Sequence reactance)
- X0 (Zero Sequence reactance)

XFMR Data:

- Winding configuration (delta-Wye grd or Wye grd-Delta)
- MVA Rating
- KV Rating
- Base MVA
- Base KV
- Z1 HV-LV
- Z0 HV-LV

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 86

- F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)
- 2. FAST TRACK INTERCONNECTION REVIEW PROCESS (Cont'd.)
- c. Supplemental Review (Cont'd.)
 - iii) Line Data:
 - Impedance data for line from XFMR to POI (if applicable)
 - Z1
 - Z0

POI Location
 - iv) For Interconnection Requests that pass Supplemental Review and do not require Interconnection Facilities or Distribution Upgrades, Distribution Provider shall provide Applicant with a Generator Interconnection Agreement within fifteen (15) Business Days of providing notice of Supplemental Review results. For Interconnection Requests that pass Supplemental Review and do require Interconnection Facilities or Distribution Upgrades, within fifteen (15) Business Days of providing notice of Supplemental Review results, Distribution Provider shall provide Applicant with a non-binding cost estimate of any Interconnection Facilities or Distribution Upgrades. For those Interconnection Requests where Applicant has selected the Cost Envelope Option, within ten (10) Business Days of providing Applicant the non-binding cost estimate for the required Interconnection Facilities and/or Distribution Upgrades, Applicant shall provide the Distribution Provider the Cost Envelope Option deposit, in accordance with Section F.7.a.i.3. If Applicant fails to provide the Cost Envelope Option deposit in accordance with Section F.7.a.i.3, Applicant's request for the Cost Envelope Option shall be deemed withdrawn and the Interconnection Request shall not be eligible for the Cost Envelope Option.

For all Interconnection Requests that pass Supplemental Review, refer to Section F.2.e for cost responsibility and time frames for completing the Generator Interconnection Agreement. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 87

- F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)
- 2. FAST TRACK INTERCONNECTION REVIEW PROCESS (Cont'd.)
- c. Supplemental Review (Cont'd.)
 - v) For Interconnection Requests that fail Supplemental Review, Distribution Provider shall provide the technical reason, data and analysis supporting the Supplemental Review results in writing, including, if Distribution Provider can make the determination, which Detailed Study track Applicant qualifies for, and provide Applicant the option to attend a Supplemental Review results meeting or proceed directly to Detailed Study. Applicant shall notify Distribution Provider within fifteen (15) Business Days following such notification whether to (i) proceed to a Supplemental Review results meeting, (ii) proceed to Detailed Study, or (iii) withdraw the Interconnection Request. Applicant may request one extension of no more than fifteen (15) Business Days to respond. If Applicant fails to notify Distribution Provider within fifteen (15) Business Days of such notification, or at the end of the extension, if one was requested, the Interconnection Request shall be deemed withdrawn.

Applicants that elect to proceed to Detailed Study shall provide the applicable study deposit set forth in Section E.3.a with their response. Detailed Study fees for solar Generating Facilities up to 1 MW interconnecting to the Distribution System that do not sell power to Distribution Provider will be waived up to the amount of \$5,000. Except as provided for in Section F.3.d, NEM-1 and ≤1 MW NEM-2 Generating Facilities are exempt from any costs associated with Detailed Studies.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 88

- F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)
- 2. FAST TRACK INTERCONNECTION REVIEW PROCESS (Cont'd.)
- d. Optional Supplemental Review Results Meeting
 - Within five (5) Business Days of Applicant's request for a Supplemental Review results meeting, Distribution Provider shall contact Applicant and offer to convene a meeting at a mutually acceptable time to review the Supplemental Review screen analysis and related results to determine what modifications, if any, may permit the Generating Facility to be connected safely and reliably without Detailed Study.
 - If modifications that obviate the need for Detailed Study are identified and Applicant and Distribution Provider agree to such modifications, Distribution Provider shall provide Applicant with a Generator Interconnection Agreement within fifteen (15) Business Days of the Supplemental Review results meeting if no Interconnection Facilities or Distribution Upgrades are required. If Interconnection Facilities or Distribution Upgrades are required, Distribution Provider shall provide Applicant with a non-binding cost estimate of any Interconnection Facilities or Distribution Upgrades within fifteen (15) Business Days of the Supplemental Review results meeting. For those Interconnection Requests where Applicant has selected the Cost Envelope Option, within ten (10) Business Days of providing Applicant the non-binding cost estimate for the required Interconnection Facilities and/or Distribution Upgrades, Applicant shall provide the Distribution Provider the Cost Envelope Option deposit, in accordance with Section F.7.a.i.3. If Applicant fails to provide the Cost Envelope Option deposit in accordance with Section F.7.a.i.3, Applicant's request for the Cost Envelope Option shall be deemed withdrawn and the Interconnection Request shall not be eligible for the Cost Envelope Option.
 - For all Interconnection Requests that pass Supplemental Review, refer to Section F.2.e for cost responsibility and time frames for completing the Generator Interconnection Agreement. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

- F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)

 - 2. FAST TRACK INTERCONNECTION REVIEW PROCESS (Cont'd.)

 - d. Optional Supplemental Review Results Meeting (Cont'd.)
 - If Applicant and Distribution Provider are unable to identify or agree to modifications, Applicant shall notify Distribution Provider within twenty (20) Business Days of the Supplemental Review Results Meeting whether it would like to proceed with Detailed Study or withdraw its Interconnection Request. Applicant may request one extension of no more than twenty (20) Business Days to respond. If Applicant fails to notify Distribution Provider within twenty (20) Business Days of the Supplemental Review results meeting, or at the end of the extension, if one was requested, the Interconnection Request shall be deemed withdrawn. Applicants that elect to proceed to Detailed Study shall provide the applicable study deposit set forth in Section E.3.a.
 - e. Execution of the Generator Interconnection Agreement
 - For Interconnection Requests where Applicant has not selected the Cost Envelope Option, Following the receipt of a cost estimate for any Distribution Upgrades and/or Interconnection Facilities that have been identified, Applicant shall notify Distribution Provider within fifteen (15) Business Days whether Applicant: (i) requests a Generator Interconnection Agreement, or (ii) withdraws its Interconnection Request. Applicant may request one extension of no more than fifteen (15) Business Days to respond. If Applicant fails to notify Distribution Provider within fifteen (15) Business Days, or at the end of the extension, if one was requested, the Interconnection Request shall be deemed withdrawn. If Applicant elects to proceed to a Generator Interconnection Agreement, Distribution Provider shall provide Applicant with a Generator Interconnection Agreement for Applicant's signature within fifteen (15) Business Days of Applicant's request. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 90

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)

2. FAST TRACK INTERCONNECTION REVIEW PROCESS (Cont'd.)

e. Execution of the Generator Interconnection Agreement (Cont'd.)

For those Interconnection Requests where Applicant has selected the Cost Envelope Option and has provided the Cost Envelope Option deposit in accordance with Section F.7.a.i.3, Distribution Provider shall complete and issue to Applicant the Cost Envelope Estimate within twenty (20) Business Days following Distribution Provider's receipt of the Cost Envelope Option deposit in accordance with F.7.d. Once the Cost Envelope Estimate is issued, Applicant shall notify Distribution Provider within fifteen (15) Business Days of notification whether Applicant: (i) requests a Generator Interconnection Agreement, or (ii) withdraws its Interconnection Request. Applicant may request one extension of no more than fifteen (15) Business Days to respond. If Applicant fails to notify Distribution Provider within fifteen (15) Business Days, or at the end of the extension, if one was requested, the Interconnection Request shall be deemed withdrawn. If Applicant elects to proceed to a Generator Interconnection Agreement, Distribution Provider shall provide Applicant with a Generator Interconnection Agreement for Applicant's signature within fifteen (15) Business Days of Applicant's request.

Upon receipt of a draft Generator Interconnection Agreement, Applicant has ninety (90) Calendar Days to sign and return the Generator Interconnection Agreement. Applicant shall provide written comments, or notification of no comments, to the draft Generator Interconnection Agreement and appendices within thirty (30) Calendar Days. At the request of Applicant, Distribution Provider shall begin negotiations with Applicant at any time after Distribution Provider provides Applicant with the draft Generator Interconnection Agreement, which contains in its appendices the cost estimate for any Distribution Upgrades and/or Interconnection Facilities that have been identified by Distribution Provider. Distribution Provider and Applicant

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 91

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)

2. FAST TRACK INTERCONNECTION REVIEW PROCESS (Cont'd.)

e. Execution of the Generator Interconnection Agreement (Cont'd.)

shall negotiate concerning the cost estimate, or any disputed provisions of the appendices to a draft Generator Interconnection Agreement, for not more than ninety (90) Calendar Days after Distribution Provider provides Applicant with the Generator Interconnection Agreement. If Applicant determines that negotiations are at an impasse, it may request termination of the negotiations and initiate Dispute Resolution procedures pursuant to Section K. If Applicant fails to sign the Generator Interconnection Agreement or initiate Dispute Resolution within ninety (90) Calendar Days, the Interconnection Request shall be deemed withdrawn.

After Applicant, or a Producer where those are different entities, has executed the Generator Interconnection Agreement, Distribution Provider will commence design, procurement, construction and installation of Distribution Provider's Distribution Upgrades and/or Interconnection Facilities that have been identified in the Generator Interconnection Agreement. Distribution Provider and Producer will use good faith efforts to meet schedules in accordance with the requirements of the Generator Interconnection Agreement and estimated costs as appropriate. Producer is responsible for all applicable costs associated with Parallel Operation to support the safe and reliable operation of the Distribution System and Transmission System as set forth in Section E.4.

Distribution Provider and Producer shall negotiate in good faith concerning a schedule for the construction of Distribution Provider's Interconnection Facilities and Distribution Upgrades.

Unless agreed to otherwise between Applicant and Distribution Provider, Distribution Provider shall schedule a mitigation work scoping meeting no later than 10 business days after receiving the payment for the engineering advance.

Distribution Provider shall provide quarterly updates on substation upgrades to Producers whose projects are dependent on a substation upgrade.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 92

- F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)
- 3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS |
- a. Detailed Study Track Selection Process |
- For all Detailed Study Applicants, as well as Applicants that have failed Fast Track initial review and/or supplemental review, the specific Detailed Study track for which Applicant is eligible will be determined by the application of Screens Q and R. For Applicants that require application of Screens Q and R, absent extraordinary circumstances, within twenty (20) Business Days following validation of an Interconnection Request and receipt of the appropriate study deposit set forth in Section E.3.a, Distribution Provider will apply Screen Q, and if applicable, Screen R and provide Applicant with the screen results as set forth below. |
- If Applicant fails Screen Q, Distribution Provider shall provide the data and analysis supporting Screen Q results in writing. The Interconnection Request will be processed in accordance with Section F.3.d below. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 93

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)

3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)

a. Detailed Study Track Selection Process (Cont'd.)

If Applicant passes Screen Q, but fails Screen R, Distribution Provider shall provide data and analysis supporting the Screen R results in writing. Applicant shall notify Distribution Provider within twenty (20) Business Days following such notification whether it would like to (i) proceed to the Distribution Group Study Process or (ii) withdraw the Interconnection Request. Applicant may request one extension of no more than twenty (20) Business Days to respond. However, Applicant's decision must be received prior to the close of a given Distribution Group Study window, to participate in that Distribution Study Group. If the decision is received after the close of a particular Distribution Group Study window, then Applicant's Interconnection Request will be included in the next available Distribution Group Study window.

If Applicant fails to notify Distribution Provider within twenty (20) Business Days of receiving Screen R results, or at the end of the extension, if one was requested, the Interconnection Request shall be deemed withdrawn.

If Applicant elects to proceed to the Distribution Group Study Process, the Interconnection Request will be processed in accordance with Section F.3.c below.

A Distribution Study Group will be comprised of all Interconnection Requests that are determined to be electrically interdependent based on results of Screen R. A Distribution Study Group may contain only one Interconnection Request.

Applicant(s) that opt to proceed to the Distribution Group Study Process will be re-evaluated under Screen Q. If the Distribution Study Group fails Screen Q, the Applicants will be required to withdraw and move to the WDT Transmission Cluster Process.

If Applicant passes Screens Q and R, the Interconnection Request will be processed in accordance with Section F.3.b below.

If Applicant elects to proceed to the WDT Transmission Cluster Study Process, Interconnection Request will be processed in accordance with Section F.3.d. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 94

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.)

3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)

(L)

b. Independent Study Process

i) Scoping Meeting

Within five (5) Business Days after Distribution Provider notifies Applicant that the Interconnection Request has passed Screens Q and R and is thus eligible for the Independent Study Process, Distribution Provider shall contact Applicant to establish a date agreeable to Applicant and Distribution Provider for a scoping meeting. Distribution Provider shall inform Applicant of the Detailed Study start date.

The purpose of the scoping meeting shall be: (i) to discuss reasonable Commercial Operation Dates and alternative interconnection options; (ii) to exchange information, including any transmission data that would reasonably be expected to impact Applicant's interconnection options; (iii) to analyze such information; and (iv) to determine feasible Points of Interconnection and eliminate alternatives given resources and available information.

Distribution Provider will bring to the scoping meeting, as reasonably necessary to accomplish its purpose, such already available technical data, including, but not limited to; (i) general facility loadings, (ii) general instability issues, (iii) general short circuit issues, (iv) general voltage issues, and (v) general reliability issues.

Applicant will bring to the scoping meeting, in addition to the technical data in Attachment A of the Rule 21 Exporting Generating Facility Interconnection Request form, any system studies previously performed. Distribution Provider, the CAISO, if applicable, and Applicant will also bring to the meeting personnel and other resources as may be reasonably required to accomplish the purpose of the meeting in the time allocated for the meeting. On the basis of the meeting, Applicant shall designate its Point of Interconnection. The duration of the meeting shall be only what is sufficient to accomplish its purpose.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)

3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)

b. Independent Study Process (Cont'd.)

i) Scoping Meeting (Cont'd.)

Within fifteen (15) Business Days after the scoping meeting, Distribution Provider shall provide Applicant with a Detailed Study Agreement, which shall contain an outline of the scope of the Interconnection System Impact Study and Interconnection Facilities Study, contain a non-binding good faith estimate of the cost to perform such studies, and shall specify that Applicant is responsible for the actual cost of the Interconnection Studies, including reasonable administrative costs. Applicant shall execute and deliver to Distribution Provider the Detailed Study Agreement no later than thirty (30) Business Days after the scoping meeting, or the Interconnection Request shall be deemed withdrawn.

ii) Timing of the Interconnection System Impact Study Results

Absent extraordinary circumstances, Distribution Provider shall complete and issue a final Interconnection System Impact Study report within sixty (60) Business Days after the execution of a Detailed Study Agreement. If the System Impact Study indicates a need for Network Upgrades on the Transmission System, Distribution Provider will share applicable study results with the CAISO for review and comment and will incorporate comments into the final Interconnection System Impact Study report.

At any time Distribution Provider determines that it will not meet the required time frame for completing the Interconnection System Impact Study, Distribution Provider shall notify Applicant in writing as to the status of the Interconnection System Impact Study and provide an estimated completion date with an explanation of the reasons why additional time is required.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 96

- F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)
- 3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)
- b. Independent Study Process (Cont'd.)
- ii) Timing of the Interconnection System Impact Study Results (Cont'd.)

Upon request, Distribution Provider shall provide Applicant all relevant supporting documentation, workpapers and pre-Interconnection Request and post-Interconnection Request power flow, short circuit and stability databases, and currently planned Distribution Upgrades relevant to the Interconnection Request for the Interconnection System Impact Study. Applicant may be required to sign a non-disclosure agreement with terms consistent with Section D.7 regarding Confidentiality.
- iii) Interconnection System Impact Study Results Meeting

Applicant shall request a results meeting within ten (10) Business Days of the issuance of the final Interconnection System Impact Study report. This results meeting, if requested, shall be held among Distribution Provider, the CAISO, if applicable, and Applicant to discuss the results of the Interconnection System Impact Study, including assigned cost responsibility. Within five (5) Business Days of the request, Distribution Provider shall contact Applicant to establish a date agreeable to Applicant, Distribution Provider and the CAISO, if applicable, for the results meeting.

If Applicant does not request a results meeting within the specified time above, the results meeting will be deemed waived. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 97

- F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.)
 - 3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)
 - b. Independent Study Process (Cont'd.)

(D)

(D)

- iv) Modifications

(T)

At any time during the course of the Interconnection Studies, Applicant, Distribution Provider, or the CAISO, as applicable, may identify changes to the planned Interconnection that may improve the costs and benefits (including reliability) of the Interconnection, and the ability of the proposed change to accommodate the Interconnection Request. To the extent the identified changes are acceptable to Distribution Provider, the CAISO, as applicable, and Applicant, such acceptance not to be unreasonably withheld, Distribution Provider shall modify the Point of Interconnection and/or configuration in accordance with such changes without altering the Interconnection Request's eligibility for participating in Interconnection Studies.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 98

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.)

3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)

b. Independent Study Process (Cont'd.)

iv) Modifications (Cont'd.)

At the Interconnection System Impact Study results meeting, Applicant should be prepared to discuss any desired modifications to the Interconnection Request. After the issuance of the final Interconnection System Impact Study report, but no later than five (5) Business Days following the Interconnection System Impact Study results meeting, Applicant shall submit to Distribution Provider, in writing, (i) modifications to any information provided in the Interconnection Request, including that information required for the Cost Envelope Option, if applicable, or (ii) confirmations of no modifications. Distribution Provider will forward Applicant's request for modification to the CAISO, if applicable, within two (2) Business Days of receipt. If no Interconnection System Impact Study results meeting is held, Applicant shall submit to Distribution Provider any requested modifications within twenty-five (25) Business Days of the receipt of the final Interconnection System Impact Study report.

Modifications permitted under this Section F.3.b.iv shall include specifically: (a) a decrease in the electrical output (MW) of the proposed Generating Facility; (b) modifying the technical parameters associated with the Generating Facility technology or the Generating Facility step-up transformer impedance characteristics; and (c) modifying the interconnection configuration. For any modifications other than those permitted above, Distribution Provider, in coordination with CAISO, if applicable, will evaluate whether the proposed modification to the Interconnection Request constitutes a Material Modification. Distribution Provider will inform Applicant in writing whether the modifications would constitute a Material Modification (i) for Interconnection Requests that have not elected the Cost Envelope Option, within ten (10) Business Days of receipt of the proposed request for modification, and (ii) for Interconnection Requests that have elected the Cost Envelope Option, within twenty (20) Business Days of receipt of the proposed request of modification.

(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 99

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.)

3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)

b. Independent Study Process (Cont'd.)

iv) Modifications (Cont'd.) (T)

Any change to the Point of Interconnection, except for that specified by Distribution Provider in an Interconnection Study or otherwise allowed under this Section F.3.b.v, shall constitute a Material Modification. (P)

If the proposed modification is determined to be a Material Modification, Applicant may either withdraw the proposed modification or proceed with a new Interconnection Request for such modification. Applicant shall make such determination within ten (10) Business Days after being provided the Material Modification determination results.

Proposed modifications determined not to be Material Modifications may still necessitate the need to re-evaluate the System Impact Study to determine modifications to the Interconnection Facilities and Distribution Upgrades, or to update the Cost Envelope Estimate, if applicable, in accordance with Section F.7. Distribution Provider will provide Applicant an estimate of time to complete the re-evaluation and the associated incremental cost required to complete the re-evaluation. Applicant may either accept the additional time and cost to complete the reevaluation, withdraw the proposed modification request, or proceed with a new Interconnection Request for such modification. Applicant shall make such determination within ten (10) Business Days after being provided the Material Modification results.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 100

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.)

3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)

b. Independent Study Process (Cont'd.)

- v) Scope and Purpose of the Interconnection Facilities Study and Study Deposit (T)

Within ten (10) Business Days of Applicant's confirmation of no modifications or Distribution Provider's determination that the Interconnection System Impact Study does not require reevaluation, Applicant shall submit to Distribution Provider the data required by Distribution Provider, including the completed form of Attachment B to the Detailed Study Agreement, if applicable. For Generating Facilities 5 MW or less, Applicant shall also submit the Interconnection Facilities Study deposit, as set out in Section E.3.a, unless the Interconnection Facilities Study will be waived in accordance with Section F.3.b.vii.

For NEM Generating Facilities and Solar ≤1 MW Generating Facilities that have elected the Cost Envelope Option, Applicant must (i) submit to Distribution Provider the Cost Envelope Option deposit within ten (10) Business Days of Applicant's confirmation of no modifications or Distribution Provider's determination that the Interconnection System Impact Study does not require reevaluation, or (ii) provide Distribution Provider written notice that it elects to withdraw its request for the Cost Envelope Option, in accordance with Section F.7. Should Applicant fail to provide the required Cost Envelope Option deposit or provide written notice within such timeframe, Applicant's request for the Cost Envelope Option shall be deemed withdrawn, and the Interconnection Request shall continue to be processed in accordance with the Independent Study Process.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 101

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.)

3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)

b. Independent Study Process (Cont'd.)

vi) Waiver of the Interconnection Facilities Study

(T)

The Interconnection Facilities Study may be waived if Distribution Provider and Applicant mutually agree to such waiver within either (i) five (5) Business Days following the Interconnection System Impact Study results meeting, or (ii) within twenty-five (25) Business Days of the issuance of the final Interconnection System Impact Study report if no Interconnection System Impact Study results meeting is held. If Distribution Provider and Applicant agree to waive the Interconnection Facilities Study for an Interconnection Request where Applicant has selected the Cost Envelope Option, the Interconnection Request shall not be eligible for the Cost Envelope Option and Applicant's request for the Cost Envelope Option shall be deemed withdrawn. The Interconnection Facilities Study may not be waived for Interconnection Requests that have selected the Cost Envelope Option and for which the Applicant elects to proceed with Distribution Provider's preparation of the Cost Envelope Estimate.

Within thirty (30) Calendar Days after Distribution Provider and Applicant mutually agree to waive the Interconnection Facilities Study, Distribution Provider shall tender a draft Generator Interconnection Agreement, together with draft appendices, to Applicant. If Applicant chooses to forgo the Interconnection Facilities Study and move directly to a Generator Interconnection Agreement, Applicant must agree in writing to be responsible for all actual costs of all required facilities deemed necessary by Distribution Provider. Applicant is responsible for all applicable costs associated with Parallel Operation to support the safe and reliable operation of the Distribution and Transmission System as set forth in Section E.4. Refer to Section F.3.e for cost responsibility and time frames for completing the Generator Interconnection Agreement.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 102

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.)

3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)

b. Independent Study Process (Cont'd.)

vii) Timing of the Interconnection Facilities Study (T)

The Interconnection Facilities Study shall be completed and provided to Applicant within sixty (60) Business Days after Applicant submits the Interconnection Facilities Study deposit in accordance with Section E.3.a and F.3.b.vi. In cases where no Distribution Upgrades and/or Network Upgrades are identified and the required facilities are limited to Distribution Provider's Interconnection Facilities only, the Interconnection Facilities Study shall be completed within forty-five (45) Business Days after Applicant submits the Interconnection Facilities Study deposit for Generating Facilities with a Gross Nameplate Rating of 5 MW or less. (T)

If applicable, Distribution Provider will share the study results with the CAISO for review and comment, and will incorporate CAISO comments, if any, into the study report prior to issuing a final Interconnection Facilities Study report to Applicant.

Within thirty (30) Calendar Days after Distribution Provider issues the final Interconnection Facilities Study report to Applicant, or within thirty (30) Calendar Days of an Interconnection Facilities Study results meeting, if requested, Distribution Provider shall tender a draft Generator Interconnection Agreement, together with draft appendices. Refer to Section F.3.e for cost responsibility and time frames for completing the Generator Interconnection Agreement.

At any time Distribution Provider determines that it will not meet the required time frame for completing the Interconnection Facilities Study, Distribution Provider shall notify Applicant in writing as to the status of the Interconnection Facilities Study and provide an estimated completion date with an explanation of the reasons why additional time is required.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 103

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.)

3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)

b. Independent Study Process (Cont'd.)

viii) Interconnection Facilities Study Results Meeting

(T)

If requested by Applicant, a results meeting shall be held among Distribution Provider, the CAISO, if applicable, and Applicant to discuss the results of the Interconnection Facilities Study, including assigned cost responsibility. Within five (5) Business Days of the request, Distribution Provider shall contact Applicant to establish a date agreeable to Applicant, Distribution Provider and the CAISO, if applicable, for the results meeting.

Within thirty (30) Calendar Days after the Interconnection Facilities Study results meeting, Distribution Provider shall tender a draft Generator Interconnection Agreement, together with draft appendices, to Applicant.

(D)

(D)

c. Distribution Group Study Process

i) Initiation of Distribution Study Process

Applicants that apply for the Independent Study Process that pass Screen Q but fail Screen R will be eligible for inclusion in a Distribution Study Group. Applicant must submit all materials required to complete their Interconnection Request no later than ten (10) Business Days after the close of the relevant Distribution Group Study window. This includes notification from Applicant that they want to proceed with the Distribution Group Study Process, if applicable, in accordance with Section F.3.a. Distribution Provider shall inform Applicant of the Detailed Study start date.

(Continued)



**ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS**

- F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)
- 3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)
- c. Distribution Group Study Process (Cont'd.)
 - i) Initiation of Distribution Study Process (Cont'd.)

Distribution Provider shall perform a Screen Q analysis for the Distribution Study Group within thirty (30) Business Days of the close of the window, using best available information about projects that have entered the Distribution Group Study Process under Rule 21 and the WDT.

If the Distribution Study Group fails Screen Q, the Distribution Provider will deem the projects withdrawn from Rule 21 and notify Applicants. Applicants may elect to proceed with the WDT Transmission Cluster Study Process pursuant to Section F.3.d.

In order to be eligible to participate in the DGS Phase I Interconnection Study, the scoping meeting must be complete and the Applicant must execute the Detailed Study Agreement prior to the start date of the DGS Phase I Interconnection Study.
 - ii) Scoping Meeting

Within five (5) Business Days after Distribution Provider performs the Electrical Independence Test, it will contact the Applicant(s) to notify them that the Interconnection Request has passed Screen Q and failed Screen R and is thus eligible for the Distribution Group Study Process, and establish a date agreeable to Applicant and Distribution Provider for a scoping meeting.

The Distribution Provider, in coordination with the CAISO, if applicable, shall determine whether the Interconnection Request is at or near the boundary of an Affected System(s) so as to potentially impact such Affected System(s). If a determination of potential impact is made, the Distribution Provider shall invite the Affected System Operator(s) to the scoping meeting by informing them of the time and place of the scheduled scoping meeting as soon as practicable. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 106

- F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)
- 3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)
- c. Distribution Group Study Process (Cont'd.)
 - ii) Scoping Meeting (Cont'd.)

Within fifteen (15) Business Days after the scoping meeting, Distribution Provider shall provide Applicant with a Detailed Study Agreement, which shall contain an outline of the scope of the DGS Phase I Interconnection Study and DGS Phase II Interconnection Study, contain a non-binding good faith estimate of the cost to perform such studies, and shall specify that Applicant is responsible for the actual cost of the Interconnection Studies, including reasonable administrative costs. Applicant shall execute and deliver to Distribution Provider the Detailed Study Agreement no later than thirty (30) Business Days after the scoping meeting or the start date of the DGS Phase I Interconnection Study, whichever is earlier, or the Interconnection Request shall be deemed withdrawn.
 - iii) Grouping of Interconnection Requests for a Distribution Group Study

The results of Screen R will determine the Interconnection Requests to be grouped together for each Distribution Group Study. An Interconnection Request that failed Screen R will be grouped with other projects that are determined to be electrically interdependent through the application of Screen R. No later than the date a DGS Phase I Interconnection Study begins, Distribution Provider may send to each Applicant in a Distribution Study Group a list of the Interconnection Requests in its Distribution Study Group.

At the Distribution Provider's option, an Interconnection Request received during a particular Distribution Group Study Application window may be studied individually (Independent Study Process) or in a Distribution Group Study for the purpose of conducting one or more of the analyses forming the Interconnection Studies. For each Interconnection Study received within the same Distribution Group Study Application window, the Distribution Provider may develop one or more Distribution Study Groups.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 107

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)

3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)

c. Distribution Group Study Process (Cont'd.)

iv) Timing of the DGS Phase I Interconnection Study

Absent extraordinary circumstances, Distribution Provider shall complete and issue a final DGS Phase I Interconnection Study report within sixty (60) Business Days from the start of the study. If the DGS Phase I Interconnection Study indicates a need for Network Upgrades, Distribution Provider will share applicable study results with the CAISO for review and comment and will incorporate comments into the final DGS Phase I Interconnection Study report.

At any time Distribution Provider determines that it will not meet the required time frame for completing the DGS Phase I Interconnection Study, Distribution Provider shall notify all Applicants in the Distribution Study Group as to the status of the DGS Phase I Interconnection Study and provide an estimated completion date with an explanation of the reasons why additional time is required.

Upon request, Distribution Provider shall provide any Applicant in the Distribution Study Group all relevant supporting documentation, workpapers and pre-Interconnection Request and post-Interconnection Request power flow, short circuit and dynamic/stability databases, and currently planned Distribution Upgrades relevant to the Interconnection Request for the DGS Phase I Interconnection Study. Applicant may be required to sign a non-disclosure agreement with terms consistent with Section D.7 regarding Confidentiality.

If applicable, Distribution Provider will share the applicable study results with the CAISO for review and comment, and will incorporate CAISO comments, if any, into the study report prior to issuing a final DGS Phase I Interconnection Study report to Applicants in the Distribution Study Group. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)

3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)

c. Distribution Group Study Process (Cont'd.)

v) DGS Phase I Interconnection Study Results Meeting

If requested by an Applicant in a Distribution Study Group or Distribution Provider, a results meeting shall be held among Distribution Provider, the CAISO, if applicable, and the Applicant to discuss the results of the DGS Phase I Interconnection Study, including assigned cost responsibility. Within five (5) Business Days of such request, Distribution Provider shall contact Applicant to establish a date agreeable to Applicant, Distribution Provider and the CAISO, if applicable, for the results meeting. If the Applicant or Distribution Provider has requested a results meeting, it must be completed within thirty (30) Calendar Days after issuance of the final DGS Phase I Interconnection Study report, unless otherwise agreed upon by the Distribution Provider and Applicant.

At the Phase I Interconnection Study results meeting, the Applicant shall provide a schedule outlining key milestones including environmental survey start date, expected environmental permitting submittal date, expected procurement date of project equipment, back-feed date for project construction, and expected project construction date. This will assist the parties in determining if proposed Commercial Operation Dates are reasonable. If large-scale Distribution Provider's Interconnection Facilities or Distribution Upgrades for the Generating Facility have been identified in the DGS Phase I Interconnection Study, such as telecommunications equipment, distribution feeders to support back feed, a new substation, and/or expanded substation work, permitting and material procurement lead times may result in the need to alter the proposed Commercial Operation Date, the Applicant and Distribution Provider may agree to a new Commercial Operation Date. In addition, where an Applicant intends to establish Commercial Operation separately for different Electric Generating Units or project phases at its Generating Facility, it may only do so in accordance with an implementation plan agreed to in advance by the Distribution Provider and the CAISO, if applicable, which agreement shall not be unreasonably withheld.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 109

- F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.)
 - 3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)
 - c. Distribution Group Study Process (Cont'd.)
 - v) DGS Phase I Interconnection Study Results Meeting (Cont'd.)

Where the parties cannot agree to a revised Commercial Operation Date, the Commercial Operation Date determined reasonable by the Distribution Provider will be used for the DGS Phase II Interconnection Study, or the Generator Interconnection Agreement (in accordance with Section F.3.e.iii) if the DGS Phase II Interconnection Study is waived in accordance with Section F.3.c.ix, where the revised Commercial Operation Date is needed to accommodate the anticipated completion, assuming Reasonable Efforts by the Distribution Provider of necessary Distribution Upgrades and/or Distribution Provider's Interconnection Facilities, pending the outcome of any relief sought by the Applicant under Sections F.1.d or K. The Applicant must notify the Distribution Provider within five (5) Business Days following the Results Meeting if it is initiating dispute procedures under Sections F.1.d or K.

Within five (5) Business Days following the DGS Phase I Interconnection Study results meeting, the Applicant shall submit to the Distribution Provider all requested information. If no DGS Phase I Interconnection Study results meeting is held, Applicant shall submit to Distribution Provider any requested information within thirty (30) Calendar Days of the receipt of the final DGS Phase I Interconnection Study report.

(D)

(D)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 110

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.)

3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)

c. Distribution Group Study Process (Cont'd.)

vi) Modifications

(T)

At any time during the course of the Interconnection Studies, Applicant, Distribution Provider, or the CAISO, as applicable, may identify changes to the planned Interconnection that may improve the costs and benefits (including reliability) of the Interconnection, and the ability of the proposed change to accommodate the Interconnection Request. To the extent the identified changes are acceptable to Distribution Provider, the CAISO, as applicable, and Applicant, such acceptance not to be unreasonably withheld, Distribution Provider shall modify the Point of Interconnection and/or configuration in accordance with such changes without altering the Interconnection Request's eligibility for participating in Interconnection Studies.

At the DGS Phase I Interconnection Study results meeting, if elected by Applicant or Distribution Provider, Applicant should be prepared to discuss any desired modifications to the Interconnection Request. After the publication of the final DGS Phase I Interconnection Study report, but no later than five (5) Business Days following the DGS Phase I Interconnection Study results meeting, Applicant shall submit to Distribution Provider, in writing, modifications to any information provided in the Interconnection Request. Distribution Provider will forward Applicant's request for modification to the CAISO, if applicable, within two (2) Business Days of receipt.

If no DGS Phase I Interconnection Study results meeting is held, Applicant shall submit to Distribution Provider any requested modifications within thirty (30) Calendar Days of the receipt of the final Phase I Interconnection Study report.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 111

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.)

3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)

c. Distribution Group Study Process (Cont'd.)

vi) Modifications (Cont'd.)

Modifications permitted under this Section F.3.c.vii shall include specifically: (a) a decrease in the electrical output (MW) of the proposed Generating Facility; (b) modifying the technical parameters associated with the Generating Facility technology or the Generating Facility step-up transformer impedance characteristics; and (c) modifying the interconnection configuration. For any modifications other than those permitted above, Distribution Provider, in coordination with CAISO, if applicable, will evaluate whether the proposed modification to the Interconnection Request constitutes a Material Modification. Distribution Provider will inform Applicant in writing whether the modifications would constitute a Material Modification within ten (10) Business Days of receipt of the proposed request for modification. Any change to the Point of Interconnection, except for that specified by Distribution Provider in an Interconnection Study or otherwise allowed under this Section F.3.c.vi, shall constitute a Material Modification. (T)

If the proposed modification is determined to be a Material Modification, Applicant may either withdraw the proposed modification or proceed with a new Interconnection Request for such modification. Applicant shall make such determination within ten (10) Business Days after being provided the Material Modification determination results.

Proposed modifications determined not to be Material Modifications may still necessitate the need to re-evaluate the DGS Phase I Interconnection Study to determine modifications to the Interconnection Facilities and Distribution Upgrades. Such re-evaluation will occur during the DGS Phase II Interconnection Study.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 112

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.)

3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)

c. Distribution Group Study Process (Cont'd.)

vii) Scope and Purpose of the DGS Phase II Interconnection Study and Study Deposit (T)

Within either (i) five (5) Business Days following the DGS Phase I Interconnection Study results meeting, or (ii) within thirty (30) Calendar Days of the receipt of the final DGS Phase I Interconnection Study report if no DGS Phase I Interconnection Study results meeting is held, Applicant shall submit to Distribution Provider the data required by Distribution Provider. Within thirty (30) Business Days of the issuance of the final DGS Phase I Interconnection Study report, for Generating Facilities 5 MW or less, Applicant shall submit the DGS Phase II Interconnection Study deposit, as set out in Section E.3.a, unless the DGS Phase II Interconnection Study is waived in accordance with Section F.3.

viii) Waiver of the DGS Phase II Interconnection Study (T)

The DGS Phase II Interconnection Study may be waived if Distribution Provider and all Applicants included in the DGS Phase I Interconnection Study mutually agree to such waiver within thirty (30) Calendar Days of the issuance of the DGS Phase I Interconnection Study report. Within thirty (30) Calendar Days after Distribution Provider and Applicants agree to waive the DGS Phase II Interconnection Study, Distribution Provider shall tender a draft Generator Interconnection Agreement, together with draft appendices, to Applicant. Applicant is responsible for all costs associated with Parallel Operation to support the safe and reliable operation of the Distribution and Transmission System as set forth in Section E.4. Refer to Section F.3.e for cost responsibility and time frames for completing the Generator Interconnection Agreement.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 113

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.)

3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)

c. Distribution Group Study Process (Cont'd.)

ix) DGS Phase II Interconnection Study Procedures (T)

Distribution Provider shall utilize existing studies to the extent practicable in conducting the DGS Phase II Interconnection Study. The Distribution Provider shall commence the DGS Phase II Interconnection Study within sixty (60) Calendar Days of the issuance of the final DGS Phase I Interconnection Study report.

Distribution Provider shall complete and distribute to Applicants the DGS Phase II Interconnection Study reports within sixty (60) Business Days after the commencement of each DGS Phase II Interconnection Study. The Distribution Provider will issue a final DGS Phase II Interconnection Study report to Applicant.

At the request of Applicant or at any time Distribution Provider determines that it will not meet the required time frame for completing the DGS Phase II Interconnection Study, Distribution Provider shall notify Applicant as to the schedule status of the DGS Phase II Interconnection Study and provide an estimated completion date. If the Distribution Provider is unable to complete the DGS Phase II Interconnection Study in the time specified, such notice shall provide an explanation of the reasons why additional time is required.

Upon request of the Applicant, Distribution Provider shall provide Applicant all supporting documentation, work papers, and relevant pre-Interconnection Request and post-Interconnection Request power, short circuit and stability databases for the DGS Phase II Interconnection Study, subject to confidentiality arrangements consistent with Section D.7.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 114

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.)

3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)

c. Distribution Group Study Process (Cont'd.)

ix) DGS Phase II Interconnection Study Procedures (Cont'd.) (T)

The Distribution Provider will conduct a DGS Phase II Interconnection Study that will incorporate eligible Interconnection Requests from the previous DGS Phase I Interconnection Study. The DGS Phase II Interconnection Study shall (i) update, as necessary, analyses performed in the DGS Phase I Interconnection Study to account for the withdrawal of Interconnection Requests or other projects in the Interconnection Study Process, (ii) identify Distribution Upgrades needed to physically interconnect the Generating Facility, (iii) assign cost responsibility for the Distribution Upgrades, (iv) identify for each Interconnection Request a final Point of Interconnection and Distribution Provider's Interconnection Facilities, (v) provide an estimate for each Interconnection Request of the Distribution Provider's Interconnection Facilities, and (vi) optimize in-service timing requirements based on operational studies in order to maximize achievement of the Commercial Operation Dates of the Generating Facilities, as applicable.

x) DGS Phase II Interconnection Study Results Meeting (T)

If requested by an Applicant in a Distribution Study Group, a results meeting shall be held among Distribution Provider, the CAISO, if applicable, and the Applicant to discuss the results of the DGS Phase II Interconnection Study, including selection of the final Commercial Operation Date and assigned cost responsibility. Within five (5) Business Days of such request, Distribution Provider shall contact Applicant to establish a date agreeable to Applicant, Distribution Provider and the CAISO, if applicable, for the results meeting. If Applicant wants to have a meeting, it must be completed within thirty (30) Calendar Days after issuance of the final DGS Phase II Interconnection Study report, unless mutually agreed upon by the Distribution Provider and Applicant.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 115

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.)

3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)

c. Distribution Group Study Process (Cont'd.)

x) DGS Phase II Interconnection Study Results Meeting (Cont'd.) (T)

Distribution Provider shall tender a draft Generator Interconnection Agreement pursuant to F.3.e.i. Refer to Section F.3.e for cost responsibility and time frames for completing the Generator Interconnection Agreement.

xi) Timing of the DGS Phase II Interconnection Study (T)

At any time Distribution Provider determines that it will not meet the required time frame for completing the DGS Phase II Interconnection Study, Distribution Provider shall notify each Applicant in the Distribution Study Group in writing as to the status of the DGS Phase II Interconnection Study and provide an estimated completion date with an explanation of the reasons why additional time is required.

(D)

(D)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 116

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.)

3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)

c. Distribution Group Study Process (Cont'd.)

- xii) Withdrawal and Reallocation of Cost to Interconnection Requests in a Distribution Study Group (T)

If at any time, an Interconnection Request is withdrawn or a Generator Interconnection Agreement is terminated, the upgrades identified in the Interconnection Studies will be reevaluated to determine if they are still needed. If the Distribution Provider determines that a restudy is needed, it will be conducted pursuant to Section F.3.c.xv. Any costs, identified in the Distribution Group Study not already funded by the withdrawing Applicant, will be the responsibility of remaining Applicants in the Distribution Group and will be reallocated in accordance with E.4.e.

(T)
(T)

- xiii) Restudy (T)

If a restudy is required following the issuance of the final DGS Phase II Interconnection Study, or the final DGS Phase I Interconnection Study if the DGS Phase II Interconnection Study is waived, due to a project withdrawal, Distribution Provider shall notify the remaining Applicant(s) in writing.

The restudy report shall be completed and provided to each Applicant remaining in the Distribution Group within sixty (60) Business Days of the withdrawal of the Interconnection Request that caused the restudy. The Applicants remaining in the Distribution Group will be responsible for the cost of the restudy.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 117

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.)

3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)

c. Distribution Group Study Process (Cont'd.)

xiv) Automatic Timing Extension

(T)

If during any six month period, the number of Interconnection Requests exceeds by fifty (50) percent the number of active Interconnection Request in the preceding six month period, the study timelines for Distribution Group Studies begun during the next twelve (12) months will automatically increase as follows. The time to complete the DGS Phase I Interconnection Study pursuant to Section F.3.c.iv will increase from sixty (60) Business Days to one hundred twenty (120) Business Days. The time to complete the DGS Phase II Interconnection Study pursuant to Section F.3.c.x will increase from sixty (60) Business Days to one hundred twenty (120) Business Days. The time to tender a draft Generator Interconnection Agreement pursuant to F.3.e.i will increase from thirty (30) Calendar Days to forty-five (45) Calendar Days. Distribution Provider will notify Applicants in the Distribution Study Group in writing after commencement of DGS Phase I Interconnection Study of the extension.

d. WDT Transmission Cluster Study Process

If Applicant's Interconnection Request fails Screen Q or elects to be studied under the WDT Transmission Cluster Study Process, Applicant shall have the option of applying for Interconnection under the WDT Transmission Cluster Study Process of the Wholesale Distribution Tariff in accordance with its provisions. If Applicant fails Screen Q, Applicant's Interconnection Request shall be deemed withdrawn under this Rule regardless of whether Applicant applies for Interconnection under the WDT. Distribution Provider shall inform Applicant of the Detailed Study start date.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 119

- F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)
- 3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)
- e. Generator Interconnection Agreement
 - i) Tender

The Distribution Provider shall tender a draft Generator Interconnection Agreement, together with draft appendices, within thirty (30) Calendar Days of the following:

 - 1) Agreement by the Distribution Provider and Applicant to waive the Interconnection Facilities Study in accordance with Section F.3.b.vii,
 - 2) Issuance of the final Interconnection Facilities Study report (or results meeting, if held) to Applicant,
 - 3) Agreement by the Distribution Provider and all Applicants included in a DGS Phase I Interconnection Study to waive the DGS Phase II Interconnection Study in accordance with Section F.3.c.ix,
 - 4) Issuance of the final DGS Phase II Interconnection Study report to each Applicant in the Distribution Study Group (or results meeting, if held).

Applicant(s) shall provide written comments, or notification of no comments, to the draft appendices within thirty (30) Calendar Days.
 - ii) Negotiation

Notwithstanding Section F.3.e.i, at the request of Applicant, Distribution Provider shall begin negotiations with Applicant concerning the appendices to the Generator Interconnection Agreement at any time after Distribution Provider provides Applicant with the final Interconnection Facilities Study report (or

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 120

- F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)
- 3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)
- e. Generator Interconnection Agreement (Cont'd.)
- ii) Negotiation (Cont'd.)

final Interconnection System Impact Study report if the Interconnection Facilities Study is waived) or final DGS Phase II Interconnection Study report (or the final DGS Phase I Interconnection Study report if the DGS Phase II Interconnection Study is waived) in the case of the Distribution Group Study Process. Distribution Provider and Applicant shall negotiate concerning any disputed provisions of the appendices to the draft Generator Interconnection Agreement for not more than ninety (90) Calendar Days after Distribution Provider provides Applicant with the final DGS Phase II Interconnection Study report (or the final DGS Phase I Interconnection Study report if the DGS Phase II Interconnection Study is waived) in the case of the Distribution Group Study Process or the final Interconnection Facilities Study report (or final Interconnection System Impact Study report if the Interconnection Facilities Study is waived) in the case of the Independent Study Process. Producers whose Interconnection Requests were studied in a Distribution Group Study Process will be required to fund upgrades triggered by more than one Interconnection Request in accordance with a payment schedule that allows such upgrades to be completed in time for the earliest Commercial Operation Date of such Interconnection requests. Producer is responsible for all costs associated with Parallel Operation to support the safe and reliable operation of the Distribution System and Transmission System as set forth in Section E.4.

If Applicant determines that negotiations are at an impasse, it may request termination of the negotiations at any time after tender of the draft Generator Interconnection Agreement pursuant to Section F.3.e.i and initiate Dispute Resolution procedures pursuant to Section K. Unless otherwise agreed by the Parties, if Applicant or Producer, where those are different entities, has not executed the Generator Interconnection Agreement, or initiated Dispute Resolution procedures pursuant to Section K, within ninety (90) Calendar Days after issuance of the final

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 121

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)

3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)

e. Generator Interconnection Agreement (Cont'd.)

ii) Negotiation (Cont'd.)

DGS Phase II Interconnection Facilities Study report (or the final DGS Phase I Interconnection Study report if the DGS Phase II Interconnection Study is waived) in the case of the Distribution Group Study Process or Interconnection Facilities Study report (or final Interconnection System Impact Study report if the Interconnection Facilities Study is waived) in the case of the Independent Study Process, it shall be deemed to have withdrawn its Interconnection Request.

Unless agreed to otherwise between Applicant and Distribution Provider, Distribution Provider will send an invoice to Applicant within five business days of execution of the Interconnection Agreement.

Unless agreed to otherwise between Applicant and Distribution Provider, Distribution Provider shall schedule a mitigation work scoping meeting no later than 10 business days after receiving the payment for the engineering advance.

iii) Extensions of Commercial Operation Date

Extensions of the Commercial Operation Date will be agreed upon in the executed Generator Interconnection Agreement. Reasonable Commercial Operation Dates will be discussed at the DGS Phase II Interconnection Study results meeting, or the DGS Phase I Interconnection Study results meeting if the DGS Phase II Interconnection Study results meeting is waived, in the case of the Distribution Group Study Process, the Interconnection Facilities Study results meeting, or the Interconnection System Impact Study results meeting if the Interconnection Facilities Study is waived in the case of the Independent Study Process. A request for an extension of the Commercial Operation Date after the Generator Interconnection Agreement is executed will be agreed to provided that, the Producer is still responsible for funding any Distribution Upgrades and Network Upgrades as specified in the Generator Interconnection Agreement and under the same payment schedule agreed upon in the Generator Interconnection Agreement. This provision has no impact on any power purchase agreement terms. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 122

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.)

3. DETAILED STUDY INTERCONNECTION REVIEW PROCESS (Cont'd.)

f. Engineering & Procurement (E&P) Agreement

Prior to executing a Generator Interconnection Agreement, in order to advance the implementation of its interconnection, an Applicant may request, and Distribution Provider shall offer, an E&P Agreement that authorizes Distribution Provider to begin engineering and procurement of long lead-time items necessary for the establishment of the interconnection. However, Distribution Provider shall not be obligated to offer an E&P Agreement if Applicant is in Dispute Resolution as a result of an allegation that Applicant has failed to meet any milestones or comply with any prerequisites specified in other parts of this Rule. The E&P Agreement is an optional procedure. The E&P Agreement shall provide for Applicant to pay the cost of all activities authorized by Applicant and to make advance payments or provide other satisfactory security for such costs.

Applicant shall pay the cost of such authorized activities and any cancellation costs for equipment that is already ordered for its interconnection, which cannot be mitigated as hereafter described, whether or not such items or equipment later become unnecessary. If Applicant withdraws its Interconnection Request, or either Applicant or Distribution Provider terminates the E&P Agreement, to the extent the equipment ordered can be canceled under reasonable terms, Applicant shall be obligated to pay the associated cancellation costs. To the extent that the equipment cannot be reasonably canceled, Distribution Provider may elect: (i) to take title to the equipment, in which event Distribution Provider shall refund Applicant any amounts paid by Applicant for such equipment and shall pay the cost of delivery of such equipment, or (ii) to transfer title to and deliver such equipment to Applicant, in which event Applicant shall pay any unpaid balance and cost of delivery of such equipment.

(D)

(D)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 123

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.)

4. BILL ON ESTIMATE

(N)

Bill on Estimate is a process intended for projects with interconnection upgrades where the cost of the upgrade is borne by the customer. Once the Applicant is deemed to be financially responsible for the upgrades and returns a signed Interconnection Agreement then the Bill on Estimate process will begin.

The Applicant will be provided with an Estimating Advance that is nonrefundable. The estimating advance is \$20,000 or 20% of the non-binding cost estimate, whichever is less. The itemized non-binding cost estimate will be provided in the completed study. Once the non-binding cost estimate payment is received PG&E will verify field conditions and begin the design phase of the interconnection upgrade. Upon completion of the design phase of the interconnection upgrade, the Applicant will receive a Special Facilities Agreement that contains the final cost of the upgrades less the Estimating Advance. Once the payment and Special Facilities Agreement is signed and returned to PG&E, then the construction phase can begin. There will be no reconciliation in this process.

(N)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 124

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)

5. COMMISSIONING TESTING AND PARALLEL OPERATION

a. Commissioning Testing

Producer Arranges for and Completes Commissioning Testing of Generating Facility and Producer's Interconnection Facilities: Producer is responsible for testing new Generating Facilities and associated Interconnection Facilities according to Section L.5 to ensure compliance with the safety and reliability provisions of this Rule prior to being operated in parallel with Distribution Provider's Distribution or Transmission System. For non-Certified Equipment, Producer shall develop a written testing plan to be submitted to Distribution Provider for its review and acceptance. Alternatively, Producer and Distribution Provider may agree to have Distribution Provider conduct the required testing at Producer's expense. Where applicable, the test plan shall include the installation test procedures published by the manufacturer of the Generating Facility or Interconnection Facilities. Facility testing shall be conducted at a mutually agreeable time, and depending on who conducts the test, Distribution Provider or Producer shall be given the opportunity to witness the tests.

b. Parallel Operation or Momentary Parallel Operation

Producer shall not commence Parallel Operation of its Generating Facility with Distribution Provider's system unless it has received Distribution Provider's express written permission to do so. Distribution Provider shall authorize Producer's Generating Facility for Parallel Operation or Momentary Parallel Operation with Distribution Provider's Distribution or Transmission System, in writing, within five (5) Business Days of satisfactory compliance with the terms of all applicable agreements. Compliance may include, but not be limited to, provision of any required documentation and satisfactorily completing any required inspections or tests as described herein or in the agreements formed between Producer and Distribution Provider.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 125

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)

6. WITHDRAWAL

Applicant may withdraw its Interconnection Request at any time by written notice of such withdrawal to Distribution Provider. In addition, after receipt of the Interconnection Request, if Applicant fails to adhere to the requirements and timelines of this tariff, except as provided in Section K (Disputes), Distribution Provider shall deem the Interconnection Request to be withdrawn and shall provide written notice to Applicant of the deemed withdrawal within five (5) Business Days and an explanation of the reasons for such deemed withdrawal. Upon receipt of such written notice, Applicant shall have five (5) Business Days in which to either respond with information or action that either cures the deficiency or supports its position that the deemed withdrawal was erroneous and notifies Distribution Provider of its intent to pursue Dispute Resolution. If Applicant cures the deficiency or supports its position that the deemed withdrawal was erroneous, Applicant shall not lose its Queue Position established pursuant to Section E.5.

Withdrawal shall result in the removal of the Interconnection Request from the Interconnection Study process. If Applicant disputes the withdrawal and removal from the Interconnection Study process and has elected to pursue Dispute Resolution as set forth in Section K, Applicant's Interconnection Request is not required to be considered in any ongoing Interconnection Study during the Dispute Resolution process.

In the event of such withdrawal, Distribution Provider, subject to the provisions in Section D.7 and Sections E.3.a, as applicable, shall provide, at Applicant's request, all information that Distribution Provider developed for any completed study conducted up to the date of withdrawal of the Interconnection Request.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 126

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)

7. COST ENVELOPE OPTION

Interconnection Requests for Generating Facilities evaluated under the Fast Track Process or Independent Study Process may qualify for the Cost Envelope Option described in this Section F.7 provided the requirements set forth in subsection (a) below are met. As further described below, under the Cost Envelope Option, Distribution Provider will prepare a Cost Envelope Estimate. The Cost Envelope Estimate will be based on the Applicant's estimated costs to interconnect a Generating Facility and will identify which elements of the estimated costs are subject to the Cost Envelope, and which are excluded from the Cost Envelope. Should an Applicant decide to proceed to a Generator Interconnection Agreement following receipt of the Cost Envelope Estimate in accordance with Section F.2.e for the Fast Track Process, or Section F.3.e.i for the Independent Study Process, the Generator Interconnection Agreement shall include cost responsibility for required upgrades based upon the Cost Envelope Estimate.

a. Eligibility for Cost Envelope Option

i) Eligibility of Interconnection Requests Under the Fast Track Process

Interconnection Requests processed under the Fast Track Process are eligible for the Cost Envelope Option if all of the following criteria are met:

- (1) Applicant selects the Cost Envelope Option in its Interconnection Request, or during any applicable results meeting if mutually agreed upon by Distribution Provider and Applicant, and provides the additional required information specified therein for the Cost Envelope Option; and,
- (2) The Interconnection Request passes the Fast Track Process evaluation pursuant to Section F.2.; and,

(L)

(Continued)



**ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS**

Sheet 127

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)

7. COST ENVELOPE OPTION (Cont'd.)

a. Eligibility for Cost Envelope Option (Cont'd.)

i) Eligibility of Interconnection Requests Under the Fast Track Process (Cont'd.)

(3) Applicant provides Distribution Provider the Cost Envelope Option deposit of \$2,500 within ten (10) Business Days following receipt of the Distribution Provider's non-binding cost estimate provided in accordance with Sections F.2.a, F.2.b, F.2.c.iii, or F.2.d, as applicable. The Cost Envelope Option deposit of \$2,500 is subject to adjustment upon mutual agreement of the Distribution Provider and Applicant.

In the event it is determined under the Initial Review or Supplemental Review that i) there are no Distribution Provider Interconnection Facilities and/or Distribution Upgrades required for interconnection of the Generating Facility, or ii) there are no Distribution Provider's Interconnection Facilities and/or Distribution Upgrades required for interconnection of the Generating Facility for which Applicant bears cost responsibility, Applicant's election of the Cost Envelope Option shall be considered not applicable and shall be deemed withdrawn. In such event, the Interconnection Request shall continue to be processed in accordance with the Fast Track Process.

ii) Eligibility of Interconnection Requests Under The Independent Study Process

(1) Applicant selects the Cost Envelope Option in its Interconnection Request and provides the additional required information specified therein for the Cost Envelope Option; and,

(2) The Interconnection Request qualifies for evaluation under the Independent Study Process pursuant to Section F.3.a; and,

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 128

- F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)
- 7. COST ENVELOPE OPTION (Cont'd.)
 - a. Eligibility for Cost Envelope Option (Cont'd.)
 - ii) Eligibility of Interconnection Requests Under The Independent Study Process (Cont'd.)
 - (3) An Interconnection System Impact Study and Interconnection Facilities Study are completed for the Interconnection Request pursuant to Sections F.3.b.ii and F.3.b.viii, respectively; and,
 - (4) In the case of a NEM Generating Facility or Solar ≤1 MW Generating Facility, Applicant provides Distribution Provider the Cost Envelope Option deposit of \$2,500 within the timeframe set forth in Section F.3.b.vi. The Cost Envelope Option deposit of \$2,500 is subject to adjustment upon mutual agreement of the Distribution Provider and Applicant.
 - b. Cost Responsibility under the Cost Envelope Option
 - i) Cost Responsibility for Facilities Subject to Cost Envelope

Applicant shall be responsible for the actual cost of the portion of interconnection facilities and/or distribution upgrades subject to the cost envelope within the range of plus or minus twenty-five (25) percent of the estimated cost of such facilities identified in the cost envelope estimate. Applicant's cost responsibility for that portion of the interconnection facilities and/or distribution upgrades subject to the cost envelope shall be capped at twentyfive (25) percent above the estimated cost, and applicant shall not be responsible for the portion of the actual cost of such interconnection facilities and/or distribution upgrades that exceeds twenty-five (25) percent of the estimate. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 129

- F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)
- 6. COST ENVELOPE OPTION (Cont'd.)
 - b. Cost Responsibility under the Cost Envelope Option (Cont'd.)
 - i) Cost Responsibility for Facilities Subject to Cost Envelope (Cont'd.)

Correspondingly, applicant's cost responsibility for the portion of the interconnection facilities and/or distribution upgrades subject to the cost envelope shall not be less than the amount determined as twenty-five (25) percent below the estimated cost, and any portion of the actual cost of such interconnection facilities and/or distribution upgrades that is below twenty-five (25) percent of the estimate shall not be refundable to applicant.
 - ii) Cost Responsibility for Facilities Not Subject to Cost Envelope

Applicant shall be responsible for the actual cost of the portion of Interconnection Facilities and/or Distribution Upgrades that are not subject to the Cost Envelope and the actual cost of Network Upgrades in accordance with Section F.7.e.
 - c. Timing of Applicant's Selection of Cost Envelope Option and Payment of Deposit
 - i) For Interconnection Requests under the Fast Track Process, Applicant must select the Cost Envelope Option in its Interconnection Request to be eligible for the Cost Envelope Option, in accordance with Section F.7.a.i. In addition, for Interconnection Requests that pass the Fast Track Process, Applicant must provide the Distribution Provider a \$2,500 Cost Envelope Option deposit within ten (10) Business Days of receipt of the Distribution Provider's non-binding cost estimate for the (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 130

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)

7. COST ENVELOPE OPTION (Cont'd.)

c. Timing of Applicant's Selection of Cost Envelope Option and Payment of Deposit (Cont'd.)

i) Interconnection Facilities and/or Distribution Upgrades required for interconnection. If Applicant fails to provide the Cost Envelope Option deposit within ten (10) Business Days of receipt of the Distribution Provider's non-binding cost estimate for the Interconnection Facilities and/or Distribution Upgrades required for interconnection, Applicant's request for the Cost Envelope Option shall be deemed withdrawn and the Interconnection Request shall not be eligible for the Cost Envelope Option. However, if the Applicant fails to provide the Cost Envelope Option deposit within the required timeframe, a Generator Interconnection Agreement may be requested by Applicant in accordance with Section F.2.e, and such Generator Interconnection Agreement will reflect the non-binding cost estimate for the Distribution Provider's required Interconnection Facilities and/or Distribution Upgrades provided during the Initial or Supplemental Review, and Applicant shall be responsible for the actual cost of such upgrades.

ii) For Interconnection Requests under the Independent Study Process, Applicant must select the Cost Envelope Option in its Interconnection Request to be eligible for the Cost Envelope Option, in accordance with Section F.7.a.ii. In the case of a NEM Generating Facility or Solar ≤1 MW Generating Facility, Applicant must also provide Distribution Provider the Cost Envelope Option deposit of \$2,500 following completion of the Interconnection System Impact Study within the timeframe set forth in Section F.3.b.vi. The Cost Envelope Option deposit of \$2,500 is subject to adjustment upon mutual agreement of the Distribution Provider and Applicant.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 131

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)

7. COST ENVELOPE OPTION (Cont'd.)

c. Timing of Applicant's Selection of Cost Envelope Option and Payment of Deposit (Cont'd.)

- ii) An Applicant must withdraw its request for the Cost Envelope Option following the Distribution Provider's completion of the Interconnection System Impact Study in the event the Distribution Provider and Applicant agree to waive the Interconnection Facilities Study in accordance with Section F.3.b.vii, by so indicating on Attachment B of the Detailed Study Agreement, or for NEM Generating Facilities by providing Distribution Provider written notice of such withdrawal prior to commencement of the Interconnection Facilities Study in accordance with Section F.3.b.vi.

d. Distribution Provider's Preparation of the Cost Envelope Estimate

For Interconnection Requests evaluated under the Fast Track Process, Distribution Provider shall complete and issue to Applicant the Cost Envelope Estimate within twenty (20) Business Days following Distribution Provider's receipt of the Cost Envelope Option deposit required pursuant to Section F.7.a.i.3. For Interconnection Requests evaluated under the Independent Study Process, the Cost Envelope Estimate will be developed as part of the Interconnection Facilities Study and will be included in the Interconnection Facilities Study report in accordance with Section F.3.b.viii.

Applicant shall be responsible for the actual cost of development of the Cost Envelope Estimate.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 132

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)

7. COST ENVELOPE OPTION (Cont'd.)

d. Distribution Provider's Preparation of the Cost Envelope Estimate (Cont'd.)

If full payment for the required Interconnection Facilities and/or Distribution Upgrades identified in the Cost Envelope Estimate has not been paid by Applicant to the Distribution Provider within two hundred ten (210) Calendar Days from the date Distribution Provider provides the Cost Envelope Estimate to Applicant, the Cost Envelope Estimate shall be subject to re-evaluation and adjustment by the Distribution Provider at Applicant's expense.

e. Cost Elements Not Subject to Cost Envelope

Any and all costs of required environmental studies, environmental mitigation, permits, and/or easements related to the construction and installation of Distribution Provider's Interconnection Facilities and/or Distribution Upgrades shall not be subject to the Cost Envelope. Such costs shall be the responsibility of Applicant based on the actual cost incurred by the Distribution Provider.

Any and all costs of required Network Upgrades shall not be subject to the Cost Envelope. Such costs shall be the responsibility of Applicant based on the actual cost incurred by the Distribution Provider.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 133

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)

6. COST ENVELOPE OPTION (Cont'd.)

e. Cost Elements Not Subject to Cost Envelope (Cont'd.)

The cost of any Distribution Provider's Interconnection Facilities and/or Distribution Upgrades triggered by one or more earlier queued Interconnection Requests that are also required for interconnection of a later-queued Generating Facility under the Cost Envelope Option shall not be subject to the Cost Envelope. In the event one or more of the earlier-queued projects withdraws (or is delayed to the extent the upgrade will not be completed in time to meet the later-queued Generating Facility's requested In-Service Date), all, or a portion, of Distribution Provider's Interconnection Facilities and/or Distribution Upgrades may become the responsibility of the later-queued Generating Facility. Upon such an occurrence, the Generator Interconnection Agreement shall be amended to reflect the Applicant's responsibility for such Distribution Provider's Interconnection Facilities and/or Distribution Upgrades based on actual costs unless Applicant requests in writing, within ten (10) Business Days of Applicant's receipt of Distribution Provider's nonbinding estimated cost of such required facilities, that it elects to include such facilities in the Cost Envelope. Within ten (10) Business Days of Applicant's request, Distribution Provider shall provide to Applicant an estimate of the cost required to update the Cost Envelope Estimate. Applicant shall notify Distribution Provider in writing within ten (10) Business Days of Applicant's receipt of Distribution Provider's estimate whether (i) Applicant elects to proceed with the update to the Cost Envelope Estimate at Applicant's expense, or (ii) that Applicant withdraws its request to include the additional facilities in the Cost Envelope. If Applicant elects to proceed with the update to the Cost Envelope Estimate, Distribution Provider shall complete the update within the sum of the time allowed for each step utilized by the Distribution Provider in preparation of the initial Cost Envelope Estimate pursuant to Section F.2 for Interconnection Requests evaluated under the Fast Track Process, or Section F.3.b for Interconnection Requests evaluated under the Independent Study Process, from receipt of payment of the estimated cost of the update. Should Applicant fail to so notify Distribution Provider within the ten (10) Business Day period, Applicant's request to include such additional facilities in the Cost Envelope shall be deemed withdrawn and such additional facilities shall be the responsibility of Applicant based on actual cost.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)

7. COST ENVELOPE OPTION (Cont'd.)

f. Modifications

Under the Fast Track Process, modifications are not permitted to the Generating Facility, related equipment, Point of Interconnection or other interconnection parameters that would require a re-evaluation of the Initial Review or Supplemental Review. However, notwithstanding these restrictions, an Applicant may identify and suggest minor changes to the Interconnection Facilities (e.g., minor adjustments to physical location of switchgear or other equipment, adjustments to routing of conductor from the Point of Common Coupling to the Point of Interconnection, etc.) upon or near completion of Applicant's final design of its Interconnection Facilities. If an Applicant identifies such changes, Applicant shall notify Distribution Provider of the requested changes and if, in the reasonable judgement of Distribution Provider, a re-evaluation of the costs under the Cost Envelope Option is required, Distribution Provider will provide Applicant within ten (10) Business Days of receipt of Applicant's notice an estimate of the time required to re-evaluate the costs under the Cost Envelope Option and the estimated cost of such re-evaluation. Applicant may either (i) accept the additional time and cost to complete the re-evaluation, (ii) withdraw the proposed changes, or (iii) proceed with a new Interconnection Request for such changes. Applicant shall provide Distribution Provider written notice of its election within ten (10) Business Days following Applicant's receipt of Distribution Provider's estimated additional time and cost required for the re-evaluation. If Applicant elects to proceed with the re-evaluation of the costs under the Cost Envelope Option, Distribution Provider shall complete the reevaluation within twenty (20) Business Days from receipt of all required technical data related to the proposed changes and payment of the estimated cost of the reevaluation. Should Applicant fail to so notify Distribution Provider within such ten (10) Business Day period, Applicant's request to make the proposed changes shall be deemed withdrawn.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 135

F. REVIEW PROCESS FOR INTERCONNECTION REQUESTS (Cont'd.) (L)

7. COST ENVELOPE OPTION (Cont'd.)

f. Modifications

Under the Independent Study Process, any requested modifications, including required updates to costs under the Cost Envelope Option, shall be made in accordance with Section F.3.b.v. If Applicant elects to proceed with re-evaluation of the costs under the Cost Envelope Option pursuant to Section F.3.b.v, Distribution Provider shall complete the re-evaluation within the sum of the time allowed for each step utilized by the Distribution Provider for preparation of the initial Cost Envelope Estimate pursuant Section F.3.b from receipt of all required technical data related to the proposed changes and payment of the estimated cost of the re-evaluation.

g. Tender of the Generator Interconnection Agreement Under the Cost Envelope Option

Negotiation and execution of the Generator Interconnection Agreement shall be in accordance with Section F.2.e for Interconnection Requests evaluated under the Fast Track Process, and in accordance with Section F.3.e.ii for Interconnection Requests evaluated under the Independent Study Process.

8. DESIGN AND CONSTRUCTION TIMELINE

The standard timeline for design and construction of interconnection-related Distribution Upgrades is as follows:

- i) 60 business days for design and 60 business days for construction, or
- ii) Design and construct timelines as agreed to between Applicant and Distribution Provider.

Distribution Provider shall use Reasonable Efforts to comply with these timelines and shall work with Applicant to reach a reasonable timeline when an emergency occurs.

The 60-day clock commences upon payment and after Applicant has done everything necessary on its end to prepare for construction.

(L)


(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

G. ENGINEERING REVIEW DETAILS

(L)



(L)


(Continued)



**ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS**

G. ENGINEERING REVIEW DETAILS (Cont'd.)

Interconnection Technical Framework- Overview



(L)

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 138

G. ENGINEERING REVIEW DETAILS (Cont'd.)

(L)

1. INITIAL REVIEW SCREENS

The Initial Review consists of Screens A through M. If any of the Screens A through H are not passed, a quick review of the failed Screen(s) may determine the requirements to address the failure(s). Otherwise, Supplemental Review is required.

Some examples of solutions that may be available to mitigate the impact of a failed Screen A through H are:

1. Replace an overloaded distribution transformer with a larger transformer.
2. Replace overloaded secondary conductors with larger conductor.
3. Determine if phase balancing on the transformer is possible with minimal review.
4. If possible without further study check if the Generating Facility will actually overstress equipment.
 - a. Screen A: Is the PCC on a Networked Secondary System?
 - If Yes (fail), must go to Supplemental Review except if the Generating Facility is on a Spot Network and meets the following criteria. If the Generating Facility meets the following criteria, continue to Screen B pursuant to Section G.1.

The proposed Generating Facility must utilize an inverter-based equipment package and, together with the aggregated other inverter-based generation, shall not exceed the smaller of 5 % of a Spot Network's maximum load or 50 kW. Under no condition shall the interconnection of a Generating Facility result in a backfeed of a Spot Network or cause unnecessary operation of any Spot Network protectors.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 139

- G. ENGINEERING REVIEW DETAILS (Cont'd.) (L)
1. INITIAL REVIEW SCREENS (Cont'd.)
- a. Screen A: Is the PCC on a Networked Secondary System? (Cont'd.)
- If No (pass), continue to Screen B.
- Significance: Special considerations must be given to Generating Facilities proposed to be installed on Networked Secondary Systems because of the design and operational aspects of network protectors. There are no such considerations for radial distribution systems.
- b. Screen B: Is Certified Equipment used?
- Does the Interconnection Request propose to use Certified Equipment as set out in Section L or does the equipment have interim Distribution Provider approval?
- If Yes (pass), continue to Screen C.
 - If No (fail) continue to Screen C pursuant to Section G.1.
- Interim approval allows Distribution Provider to treat equipment that has not completed this Rule's Certification requirements as having met the intent of this screen. Interim approval is granted at Distribution Provider's discretion on case by case bases, and approval for one Generating Facility does not guarantee approval for any other Generating Facility.
- Significance: If the Generating and/or Interconnection Facility has been Certified or previously approved by Distribution Provider, Distribution Provider does not need to repeat its full review and/or test of the Generating and/or Interconnection Facility's Protective Functions. Site Commissioning Testing may still be required to ensure that the Protective Functions are working properly.
- Certification indicates that the criteria in Section L, as appropriate, have been tested and verified. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 140

G. ENGINEERING REVIEW DETAILS (Cont'd.)

(L)

1. INITIAL REVIEW SCREENS (Cont'd.)

c. Screen C: Is the Starting Voltage Drop within acceptable limits?

- If Yes (pass), continue to Screen D.
- If No (fail), continue to Screen D pursuant to Section G.1.

Note: This Screen only applies to Generating Facilities that start by motoring the Generator(s).

Distribution Provider has two options in determining whether Starting Voltage Drop is acceptable. The option to be used is at Distribution Provider's discretion.

Option 1: Distribution Provider may determine that the Generating Facility's starting In-rush Current is equal to or less than the continuous ampere rating of the Customer's service equipment.

Option 2: Distribution Provider may determine the impedances of the service distribution transformer (if present) and the secondary conductors to Customer's service equipment and perform a voltage drop calculation. Alternatively, Distribution Provider may use tables or nomographs to determine the voltage drop. Voltage drops caused by starting a Generator must be less than 2.5% for primary Interconnections and 5% for secondary Interconnections.

Significance:

1. This Screen addresses potential voltage fluctuation problems that may be caused by Generators that start by motoring.
2. When starting, Generating Facilities should have minimal impact on the service voltage to other Distribution Provider Customers.
3. Passing this Screen does not relieve Producer from ensuring that its Generating Facility complies with the flicker requirements of this Rule, Section H.2.d.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 141

G. ENGINEERING REVIEW DETAILS (Cont'd.)

(L)

1. INITIAL REVIEW SCREENS (Cont'd.)

- d. Screen D: Is the transformer or secondary conductor rating exceeded?

Do the maximum aggregated Gross Ratings for all the Generating Facilities connected to a secondary distribution transformer exceed the transformer or secondary conductor rating, modified per established Distribution Provider practice, absent any Generating Facilities?

- If Yes (fail), continue to Screen E pursuant to Section G.1.
- If No (pass), continue to screen E.

Significance: This screen addresses potential secondary transformer or secondary conductor overloads. When Distribution Provider's analysis determines a transformer or conductor change is required, Distribution Provider will furnish Applicant with an explanation of why the change is needed.

- e. Screen E: Does the Single-Phase Generator cause unacceptable imbalance?

If the proposed Generating Facility is single-phase and is to be interconnected on a center tap neutral of a 240 volt service, does it cause unacceptable imbalance between the two phases of the 240 volt service?

- If Yes (fail), continue to Screen F pursuant to Section G.1.
- If No (pass), continue to screen F.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 142

G. ENGINEERING REVIEW DETAILS (Cont'd.)

(L)

1. INITIAL REVIEW SCREENS (Cont'd.)

- e. Screen E: Does the Single-Phase Generator cause unacceptable imbalance? (Cont'd.)

Significance: Generating Facilities connected to a single-phase transformer with 120/240 V secondary voltage must be installed such that the aggregated gross output is as balanced as practicable between the two phases of the 240 volt service. When Distribution Provider's analysis determines a transformer change is required. Distribution Provider will furnish the customer with an explanation of why the change is needed.

- f. Screens F and F1:

Screen F: Is the Short Circuit Current Contribution Ratio within acceptable limits?

- If Yes (pass), continue to Screen F1.
- If No (fail), continue to Screen F1 pursuant to Section G.1.

Note: This Screen does not apply to Generating Facilities with a Gross Rating of 30 kVA or less.

When measured at primary side (high side) of the Dedicated Distribution Transformer serving a Generating Facility, the sum of the Short Circuit Contribution Ratios of all Generating Facilities connected to Distribution Provider's Distribution System circuit that serves the Generating Facility must be less than or equal to 0.1.

Significance: If the Generating Facility passes this screen, it can be expected that it will have no significant impact on Distribution Provider's Distribution System's short circuit duty, fault detection sensitivity, relay coordination or fuse-saving schemes.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 143

G. ENGINEERING REVIEW DETAILS (Cont'd.)

(L)

1. INITIAL REVIEW SCREENS (Cont'd.)

f. Screens F and F1:

Screen F1: Is the per unit short circuit current contribution under allowable levels?

Is the short circuit current contribution less than or equal to 1.2 per unit or is the Generating Facility Gross Nameplate Rating multiplied by its per unit contribution less than the Protection Integrated Capacity Analysis (ICA) Value multiplied by 1.2 per unit?

- If Yes to either (pass), continue to Screen G.
- If No to both (fail), continue to Screen G pursuant to Section G.1.

Significance: Generating systems with a per unit short circuit contribution of 1.2 or less can bypass this screen and directly use the ICA because ICA calculations assume that Generating Facilities have a per unit short circuit contribution of 1.2. For Generating Facilities with a per unit short circuit contribution greater than 1.2, the Distribution Provider will use the Protection ICA Value¹ at the point of interconnection in conjunction with the Generating Facility's per unit short circuit contribution to determine whether the facility passes Screen F1.

g. Screen G: Is the Short Circuit Interrupting Capability Exceeded?

Does the proposed Generating Facility, in aggregate with other Generating Facilities on the distribution circuit, cause any distribution protective devices and equipment (including, but not limited to, substation breakers, fuse cutouts, and line reclosers), or Interconnection Request equipment on the system to exceed 87.5 % of the short circuit interrupting capability; or is the Interconnection proposed for a circuit that already exceeds 87.5 % of the short circuit interrupting capability?

- If Yes (fail) continue to Screen H pursuant to Section G.1.
- If No (pass), continue to Screen H

¹ The protection limit is one of the components of the ICA Value that pertains to sensing faults on the grid.

(L)

(Continued)



**ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS**

Sheet 144

G. ENGINEERING REVIEW DETAILS (Cont'd.)

(L)

1. INITIAL REVIEW SCREENS (Cont'd.)

g. Screen G: Is the Short Circuit Interrupting Capability Exceeded? (Cont'd)

Note: This Screen does not apply to Generating Facilities with a Gross Rating of 30 kVA or less.

Significance: If the Generating Facility passes this screen, it can be expected that it will not cause any of Distribution Provider's equipment to be overstressed.

h. Screen H: Is the line configuration compatible with the Interconnection type?

- If Yes (pass), continue to Screen I.
- If No (fail), continue to Screen I pursuant to Section G.1.

Note: This Screen does not apply to Generating Facilities with a Gross Rating of 30 kVA or less

Line Configuration Screen: Identify primary distribution line configuration that will serve the Generating Facility. Based on the type of Interconnection to be used for the Generating Facility, determine from Table G.1 if the proposed Generating Facility passes the Screen.

**Table G-1
Type of Interconnection**

Primary Distribution Line Type Configuration	Type of Interconnection to be made to Primary Distribution Line	Result/Criteria
Three-phase, three-wire	Any type	Pass Screen
Three-phase, four-wire	Single-phase, line-to-neutral	Pass Screen
Three-phase, four-wire (For any line that has such a section OR mixed three-wire & four-wire)	All others	To pass, aggregate Generating Facility nameplate rating must be less than or equal to 10% of Line Section peak load

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 145

G. ENGINEERING REVIEW DETAILS (Cont'd.)

(L)

1. INITIAL REVIEW SCREENS (Cont'd.)

- h. Screen H: Is the line configuration compatible with the Interconnection type? (Cont'd.)

Significance: If the primary distribution line serving the Generating Facility is of a "three-wire" configuration, or if the Generating Facility's distribution transformer is single-phase and connected in a line-to-neutral configuration, then there is no concern about overvoltages to Distribution Provider's, or other Customer's equipment caused by loss of system neutral grounding during the operating time of the Non-Islanding Protective Function.

- i. Screen I: Will power be exported across the PCC?

- If Yes, Continue to Screen J. This includes Options 5, 6, 9, 10, and 11.
- If No, then to ensure that the Generating Facility does not export across the PCC, the Generating Facility must incorporate Options 1, 2, 3, 4, 7, or 8 below. Following that selection, Screen J, K, L, and M are skipped and Initial Review is complete. If Option 8 is used, see section Mm1 to determine screen application.

Option 1 ("Reverse Power Protection"): To ensure power is never exported across the PCC, a reverse power Protective Function may be provided. The default setting for this Protective Function shall be 0.1% (export) of the service transformer's rating, with a maximum 2.0 second time delay. For multiple tariff interconnections refer to Section J.8.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 146

- G. ENGINEERING REVIEW DETAILS (Cont'd.) (L)
- 1. INITIAL REVIEW SCREENS (Cont'd.)
- i. Screen I: Will power be exported across the PCC? (Cont'd.)
 - Option 2 (“Minimum Power Protection”): To ensure at least a minimum amount of power is imported across the PCC at all times (and, therefore, that power is not exported), an under-power Protective Function may be provided. The default setting for this Protective Function shall be 5% (import) of Generating Facility’s total Gross Rating, with a maximum 2.0 second time delay.
 - Option 3 (Certified Non-Islanding Protection): To ensure the incidental export of power is limited to acceptable levels, this option requires that all of the following conditions be met: a) the total Gross Capacity of the Generating Facility must be no more than 25% of the nominal ampere rating of Producer’s service equipment; b) the total Gross Capacity of the Generating Facility must be no more than 50% of Producer’s service transformer capacity rating (this capacity requirement does not apply to Customers taking primary service without an intervening transformer); and c) the Generating Facility must be Certified as Non-Islanding.
 - The ampere rating of the Customer’s service equipment to be used in this evaluation will be that rating for which the customer’s utility service was originally sized or for which an upgrade has been approved. It is not the intent of this provision to allow increased export simply by increasing the size of the customer’s service panel, without separate approval for the resize. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 147

G. ENGINEERING REVIEW DETAILS (Cont'd.)

(L)

1. INITIAL REVIEW SCREENS (Cont'd.)

i. Screen I: Will power be exported across the PCC? (Cont'd.)

Option 4 (Relative Generating Facility Rating): This option, when used, requires the Net Rating of the Generating Facility to be so small in comparison to its host facility's minimum load, that the use of additional Protective Functions is not required to ensure that power will not be exported to Distribution Provider's Distribution or Transmission System. This option requires the Generating Facility capacity to be no greater than 50% of Producer's verifiable minimum Host Load over the past 12 months.

Option 5: Inadvertent Export as described in Section M.

Option 6: Inadvertent Export utilizing UL-1741 or UL-1741 SA/SB listed grid support (Non-Islanding) inverters as described in Section Mm.

Option 7: Non-Export utilizing Non-Export AC/DC Converter as described in Section O.

Option 8: Non-Export utilizing Certified Power Control Systems with an open loop response time no more than two seconds as described in Section Mm1.

Option 9: Limited Export utilizing Certified Power Control Systems with an open loop response time no more than two seconds as described in Section Mm2.

Option 10: Non-Export with Inadvertent Export utilizing Certified Power Control Systems with an open loop response time greater than two seconds and no more than ten seconds as described in Section Mm3.

Option 11: Limited Export with Inadvertent Export utilizing Certified Power Control Systems with an open loop response time greater than two seconds and no more than ten seconds as described in Section Mm4.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 148

G. ENGINEERING REVIEW DETAILS (Cont'd.)

(L)

1. INITIAL REVIEW SCREENS (Cont'd.)

i. Screen I: Will power be exported across the PCC? (Cont'd.)

Significance:

1. If it can be assured that the Generating Facility will not export power, Distribution Provider's Distribution or Transmission System does not need to be studied for load-carrying capability or Generating Facility power flow effects on Distribution Provider voltage regulators.
2. This Screen permits the use of reverse-power or minimum-power relaying as a Non-Islanding Protective Function (Option 1, 2, and 3).
3. This Screen allows, under certain defined conditions, for Generating Facilities that incorporate Certified Non-Islanding protection to qualify for interconnection through the Fast Track process without implementing reverse power or minimum power Protective Functions (Option 3).

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 149

G. ENGINEERING REVIEW DETAILS (Cont'd.)

(L)

1. INITIAL REVIEW SCREENS (Cont'd.)

j. Screen J: Is the Gross Rating of the Generating Facility 30 kVA or less?

- If Yes (pass), skip Screens K, L and M; Initial Review is complete.
- If No (fail), continue to Screen K.ⁱ

Significance: The Generating Facility will have a minimal impact on fault current levels and any potential line overvoltages from loss of Distribution Provider's Distribution System neutral grounding.

k. Screen K: Is the Generating Facility a Net Energy Metering (NEM) Generating Facility with nameplate capacity less than or equal to 500 kW?

- If Yes (pass), skip screen L and continue to screen M.
- If No (fail), continue to screen L.

Significance: The purpose of this Screen is solely to facilitate interconnection of NEM facilities below this size threshold by allowing such facilities to bypass Screen M. The use of nameplate capacity expedites the Initial Review analysis. In Supplemental Review, the net export will be analyzed.

ⁱ Inadvertent Export systems that meet the requirements specified in Section Mm bypass Screens K and L, and are processed under Screen M as described in Section Mm.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 150

G. ENGINEERING REVIEW DETAILS (Cont'd.)

(L)

1. INITIAL REVIEW SCREENS (Cont'd.)

I. Screen L: Transmission Dependency, and Stability, Overvoltage, and Islanding Tests

Is the Interconnection Request for an area where: (i) there are known, or posted, transient/dynamic stability limitations, or (ii) the proposed Generating Facility has interdependencies, known to Distribution Provider, with earlier-queued Transmission System interconnection requests, , or (iii) islanding conditions are possible based on PG&E's currently adopted and published screening policies with respect to antiislanding, or (iv) transmission ground fault overvoltage is possible based on PG&E's currently adopted and published screening policies with respect to overvoltage screening. Where (i) or (ii) or (ii) or (iv) above are met, the impacts of this Interconnection Request to the Transmission System may require further Study.

- If Yes (fail), Supplemental Review is required.
- If No (pass), continue to Screen M.

Significance: Special consideration must be given to those areas identified as having current or future (due to currently-queued interconnection requests) grid stability concerns.

PG&E will apply anti-islanding screens as described in Distribution Provider's Distribution Generation Interconnection Handbook.*

(L)
(P)/(L)
(P)/(L)

* Decision 21-06-002 R. 17-07-007 Ordering Paragraph 13 adopted Issue 18 regarding anti-islanding screens.

(P)/(L)
(P)/(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 151

G. ENGINEERING REVIEW DETAILS (Cont'd.)

(L)

1. INITIAL REVIEW SCREENS (Cont'd.)

- m. Screen M: When ICA Values are available at the requested Point of Interconnection, the Distribution Provider shall compare the ICA Values to the Gross Nameplate Rating or typical PV Generation Profile.

For Interconnection Requests based on Gross Nameplate Rating:

- a. Is the Generating Facility aggregate Gross Nameplate Rating less than or equal to 90% of the lowest value in the ICA-SG 576 Profile? or
- b. Is the Generating Facility aggregate Gross Nameplate Rating less than or equal to 90% of the lowest value in the ICA-OF 576 Profile?

If the response is "yes" to both a) and b), the Interconnection Request passes Screen M.

If the response is "no" to either a) or b), the Interconnection Request fails Screen M and must be evaluated under the Supplemental Review to determine mitigation requirements.

For Interconnection Requests based on typical PV Generation Profile:

- a. Is the Generating Facility Generation Profile based on PVWatts® or equivalent less than or equal to 90% of the ICA-SG 576 value in any hour? or
- b. Is the Generating Facility Generation Profile based on PVWatts® or equivalent less than or equal to 90% of the ICA-OF 576 value in any hour?

If the response is "yes" to both a) and b), the Interconnection Request passes Screen M.

If the response is "no" to either a) or b), the Interconnection Request fails Screen M and must be evaluated under the Supplemental Review to determine mitigation requirements.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 152

G. ENGINEERING REVIEW DETAILS (Cont'd.)

(L)

1. INITIAL REVIEW SCREENS (Cont'd.)

m. Screen M (Cont'd):

When ICA Values are not available at the requested Point of Interconnection, Screen M should be evaluated as follows:

Is the aggregate Generating Facility capacity on the Line Section less than 15% of Line Section peak load for all line sections bounded by automatic sectionalizing devices?

- If Yes (pass), Initial Review is complete.
- If No (fail), Supplemental Review is required.

Significance:

1. Low penetration of Generating Facility capacity will have a minimal impact on the operation and load restoration efforts of Distribution Provider's Distribution System.
2. The operating requirements for a high penetration of Generating Facility capacity may be different since the impact on Distribution Provider's Distribution System will no longer be minimal, therefore requiring additional study or controls.

The purpose of this Screen is solely to identify if the Generating Facility needs additional study and is not intended as justification for limiting the penetration of generation on a line section.

2. SUPPLEMENTAL REVIEW SCREENS

The Supplemental Review consists of Screens N through P. If any of the Screens are not passed, a quick review of the failed Screen(s) will determine the requirements to address the failure(s) or that Detailed Studies are required. In certain instances, Distribution Provider may be able to identify the necessary solution and determine that Detailed Studies are unnecessary. Some examples of solutions that may be available to mitigate the impact of a failed Screen are:

1. Replacing a fixed capacitor bank with a switched capacitor bank.
2. Adjustment of line regulation settings.
3. Simple reconfiguration of the distribution circuit.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 153

G. ENGINEERING REVIEW DETAILS (Cont'd.)

(L)

2. SUPPLEMENTAL REVIEW SCREENS (Cont'd.)

If the failure(s) cannot be addressed in Supplemental Review for Screens N through P, and generation is 100% or less of than the applicable ICA value (lowest value of the ICA-SG profile or lowest value at each hour) the Distribution Provider must identify a reason and inform the customer why a specific technical constraint is not captured by the ICA and why the project must proceed to Electrical Independence Tests and Detailed Studies. Utilities also must address any concerns in the context of the Screen that triggers the mitigation or detailed study.

a. Screen N: Penetration Test

If Integration Capacity Analysis Values are available at the requested Point of Interconnection, evaluate Screen N as follows:

i) Penetration Level Using ICA-SG 576 Profile:

For Interconnection Requests based on Gross Nameplate Rating: Is the Generating Facility aggregate Gross Nameplate Rating less than or equal to 100% of the lowest value in the ICA-SG 576 Profile?

For Interconnection Requests based on typical PV Generation Profile: Is the Generating Facility Generation Profile, based on PVWatts® or equivalent, less than or equal to 100% of the ICA-SG 576 Profile in any hour?

ii) Screen F1: Did the Interconnection Request pass Screen F1?

If yes to both of the above (pass), continue to Screen O.

If "no" to either or both of the above(fail), the Distribution Provider must perform a quick review of the failure within Supplemental Review and determine the requirements to address the failure.

- o If the Distribution Provider requires mitigations or Electrical Independence Tests and Detailed Studies, the Distribution Provider must provide the Customer the reason why.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 154

G. ENGINEERING REVIEW DETAILS (Cont'd.) (L)

2. SUPPLEMENTAL REVIEW SCREENS (Cont'd.)

a. Screen N: Penetration Test (Cont'd)

ii) Screen F1: Did the Interconnection Request pass Screen F1 (Cont'd)?

- If voltage is a prevailing constraint, then the full range of smart inverter functions including the volt/var function will be used in power flow analysis for the evaluation of the proposed project. This will reveal if the proposed project causes any voltage impacts of concern. If concerns related to steady state voltage, thermal, or protection exist and the Distribution Provider can identify simple upgrades through power flow analysis (e.g., installation of voltage regulator devices or protection devices to mitigate reduction of reach), then the Distribution Provider will determine the mitigation requirements within Screen N. When larger upgrades or complex protection evaluation is required, Screen N will fail, and the technical evaluation will be conducted under the Electrical Independence Tests or Detailed Study process.
- If no reason for further study is identified, or if requirements to address the failure can be identified in screen N, proceed to Screen O.
- Note: If Electrical Independence tests and Detailed Studies are required, Applicants will continue to the Electrical Independence Tests and Detailed Studies after review of the remaining Supplemental Review Screens if Applicant elects to proceed.
- If Integration Capacity Analysis Values are not available, evaluate Screen N as follows:

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 155

G. ENGINEERING REVIEW DETAILS (Cont'd.)

(L)

2. SUPPLEMENTAL REVIEW SCREENS (Cont'd.)

a. Screen N: Penetration Test (Cont'd)

Where 12 months of line section minimum load data is available, can be calculated, can be estimated from existing data, or determined from a power flow model, is the aggregate Generating Facility capacity on the Line Section less than 100% of the minimum load for all line sections bounded by automatic sectionalizing devices upstream of the Generating Facility?

- If yes (pass), continue to Screen O.
- If no (fail), a quick review of the failure may determine the requirements to address the failure. If voltage is a prevailing constraint, then the full range of smart inverter functions including the volt/var function will be used in power flow analysis for the evaluation of the proposed project. This will reveal if the proposed project causes any voltage impacts of concern. If concerns related to steady state voltage, thermal, or protection exist and the Distribution Provider can identify simple upgrades through power flow analysis (e.g., installation of voltage regulator devices or protection devices to mitigate reduction of reach), then the Distribution Provider will determine the mitigation requirements within Screen N. When larger upgrades or complex protection evaluation is required, Screen N will fail, and the technical evaluation will be conducted under Electrical Independence Tests and Detailed Studies. Continue to Screen O. (Note: If Electrical Independence tests and Detailed Studies are required, Applicants will continue to the Electrical Independence Tests and Detailed Studies after review of the remaining Supplemental Review Screens, if Applicant elects to proceed.)

Note 1: The type of Generating Facility technology will be taken into account when calculating, estimating, or determining circuit or Line Section minimum load relevant for the application of this screen. For solar Generating Facilities with no battery storage, daytime minimum load will be used (i.e., 10 am to 4 pm for fixed panel solar Generating Facilities and 8 am to 6 pm for solar Generating Facilities utilizing tracking systems), while absolute minimum load will be used for all other Generating Facility technologies.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 156

G. ENGINEERING REVIEW DETAILS (Cont'd.) (L)

2. SUPPLEMENTAL REVIEW SCREENS (Cont'd.)

a. Screen N: Penetration Test (Cont'd.)

Note 2: When this screen is being applied to a NEM Generating Facility, the net export in kW, if known, that may flow across the Point of Common Coupling into Distribution Provider's Distribution System will be considered as part of the aggregate generation.

Note 3: Distribution Provider will not consider as part of the aggregate Generating Facility capacity for purposes of this screen Generating Facility capacity known to be already reflected in the minimum load data.

Note 4: NEM Generating Facilities with net export less than or equal to 500 kW that may flow across the Point of Common Coupling into Distribution Provider's Distribution or Transmission System will not be studied in the WDT Transmission Cluster Study Process, but may be studied under the Independent Study Process.

Significance: Penetration of Generating Facility capacity that does not result in power flow from the circuit back toward the substation will have a minimal impact on equipment loading, operation, and protection of the Distribution System.

b. Screen O: Power Quality and Voltage Tests

In aggregate with existing Generating Facility capacity on the Line Section, distribution circuit, and/or substation.

i) Can it be determined within the Supplemental Review that the voltage regulation on the line section can be maintained in compliance with Commission Rule 2 and/or Conservation Voltage Regulation voltage requirements under all system conditions?

ii) Can it be determined within the Supplemental Review that the voltage fluctuation is within acceptable limits as defined by IEEE 1547-2018, 7.2 or utility practice similar to IEEE 1547-2018, 7.2?

(L)
(P)/(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 157

G. ENGINEERING REVIEW DETAILS (Cont'd.)

(L)

2. SUPPLEMENTAL REVIEW SCREENS (Cont'd.)

b. Screen O: Power Quality and Voltage Tests (Cont'd.)

In aggregate with existing Generating Facility capacity on the Line Section, distribution circuit, and/or substation. (Cont'd.)

iii) Can it be determined within the Supplemental Review that the harmonic levels meet IEEE 1547-2018, 7.3 limits at the Point of Common Coupling (PCC)?

(L)
(P)/(L)
(L)

iv) Can it be determined within the Supplemental Review that the Generating Facility will not cause any voltage impacts considering the settings of the Volt-Var function and the characteristics of the circuit segment?

- If yes to all of the above (pass), continue to Screen P.
- If no to any of the above (fail), a quick review of the failure may determine the requirements to address the failure; otherwise Electrical Independence Tests and Detailed Studies are required. Continue to Screen P. (Note: If Electrical Independence tests and Detailed Studies are required, Applicants will continue to the Electrical Independence Tests and Detailed Studies after review of the remaining Supplemental Review Screens.)

Significance: Adverse voltages and undesirable interference may be experienced by other Customers on Distribution Provider's Distribution System caused by operation of the Generating Facility(ies).

c. Screen P: Safety and Reliability Tests

Does the location of the proposed Generating Facility or the aggregate generation capacity on the Line Section create impacts to safety or reliability that cannot be adequately addressed without Detailed Study?

- If yes (fail), review of the failure may determine the requirements to address the failure; otherwise Electrical Independence Tests and Detailed Studies are required. Continue to Section G.3.
- If no (pass), Supplemental Review is complete.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 158

- G. ENGINEERING REVIEW DETAILS (Cont'd.) (L)
 - 2. SUPPLEMENTAL REVIEW SCREENS (Cont'd.)
 - c. Screen P: Safety and Reliability Tests (Cont'd.)
- Significance: In the safety and reliability test, there are several factors that may affect the nature and performance of an Interconnection. These include, but are not limited to:
1. Generating Facility energy source
 2. Modes of synchronization
 3. Unique system topology
 4. Possible impacts to critical load customers
 5. Possible safety impacts
- The specific combination of these factors will determine if any system study requirements are needed. The following are some examples of the items that may be considered under this screen:
1. Does the Line Section have significant minimum loading levels dominated by a small number of customers (i.e. several large commercial customers)?
 2. Is there an even or uneven distribution of loading along the feeder?
 3. Is the proposed Generating Facility located in close proximity to the substation (i.e. <2.5 electrical line miles), and is the distribution line from the substation to the customer composed of large conductor/cable (i.e. 600A class cable)? (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

- G. ENGINEERING REVIEW DETAILS (Cont'd.) (L)
2. SUPPLEMENTAL REVIEW SCREENS (Cont'd.)
- c. Screen P: Safety and Reliability Tests (Cont'd.)
4. Does the Generating Facility incorporate a time delay function to prevent reconnection of the generator to the system until system voltage and frequency are within normal limits for a prescribed time?
 5. Is operational flexibility reduced by the proposed Generating Facility, such that transfer of the line section(s) of the Generating Facility to a neighboring distribution circuit/substation may trigger overloads or voltage issues?
 6. Does the Generating Facility utilize Certified anti-islanding functions and equipment?
3. DETAILED STUDY SCREENS
- a. Screen Q: Is the Interconnection Request electrically Independent of the Transmission System?
- Distribution Provider, in consultation with the CAISO, will determine, based on knowledge of the interdependencies with earlier-queued interconnection requests under any tariff, whether the Interconnection Request to the Distribution System is of sufficient MW size and located at a point of interconnection such that it is reasonably anticipated to require or contribute to the need for Reliability Network Upgrades. In making this determination, the Distribution Provider will make a Determination of Electrical Independence for the CAISO Controlled Grid as set forth in the applicable CAISO Tariff in effect at the time the Electrical Independence Test begins.
- If Distribution Provider determines that no interdependencies exist, or that interdependencies do exist but the proposed Generating Facility is not reasonably anticipated to require or contribute to the need for Reliability Network Upgrades, then the Interconnection Request will be deemed to have passed Distribution Provider's Determination of Electrical Independence for the CAISO Controlled Grid.
- If Distribution Provider determines that interdependencies exist and that they are reasonably anticipated to require or contribute to the need for Reliability Network Upgrades, then Interconnection Request may be studied under the WDT Transmission Cluster Study Process as set forth in Section F.3.d. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 160

G. ENGINEERING REVIEW DETAILS (Cont'd.)

(L)

3. DETAILED STUDY SCREENS (Cont'd.)

a. Screen Q: Is the Interconnection Request electrically Independent of the Transmission System? (Cont'd.)

Distribution Provider will coordinate with the CAISO if necessary to conduct the Determination of Electrical Independence for the CAISO Controlled Grid as set forth in the applicable CAISO Tariff** in effect at the time the Electrical Independence Test (EIT) begins. The results of the incremental power flow, aggregate power flow, and short-circuit current contribution tests set out in the applicable CAISO Tariff in effect at the time the EIT begins will determine whether the Interconnection Request is electrically independent from the CAISO Controlled Grid.

- If Yes (pass), continue to Screen R.
- If No (fail), proceed to Section F.3.d.

Exemptions: All NEM Generating Facilities and all inverter-based Generating Facilities with a nameplate capacity less than or equal to 1 MVA will not be studied in the WDT Transmission Cluster Study Process, but may be studied under the Independent Study Process. For an Applicant that agrees to the installation, at Applicant's cost, of Distribution Provider-approved software/firmware controlled devices or equipment Nationally Recognized Testing Laboratory certified to limit the Generating Facility's net export so that it will never exceed the 1 MVA exemption limit, the Generating Facility's net export will be considered exempt from the WDT Transmission Cluster Study Process for purposes of this section.

Significance: Generating Facilities that are electrically interdependent with the Transmission System must be studied with other interconnection requests that have Transmission System interdependencies. It is possible to pass this Screen Q (i.e., be found to have no electrical interdependencies with earlier-queued Distribution System and/or Transmission System interconnection requests as set out above), be studied under the Independent Study Process, and still trigger a Reliability Network Upgrade.

** The currently effective CAISO Tariff can be accessed at the following CAISO website <http://www.caiso.com/rules/Pages/Regulatory/Default.aspx>

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 161

G. ENGINEERING REVIEW DETAILS (Cont'd.) (L)

3. DETAILED STUDY SCREENS (Cont'd.)

- b. Screen R: Is the Interconnection Request independent of other earlier-queued and yet to be studied interconnection requests interconnecting to the Distribution System?

For Interconnection Requests that are electrically independent from the CAISO Controlled Grid, Distribution Provider will evaluate each Interconnection Request for known or reasonably anticipated relationships between the Interconnection Request and any earlier-queued interconnection requests in the Distribution Group Study Process, the Independent Study Process, or interconnection requests studied under predecessor interconnection procedures that have yet to complete their respective interconnection studies. Distribution Provider may conduct incremental power flow, aggregate power flow, and/or short-circuit duty tests using existing interconnection studies, Base Case data, overall system knowledge, and engineering judgment to determine whether an Interconnection Request can be studied independently of earlier-queued interconnection requests. If the Interconnection Request being evaluated for electrical independence on the Distribution System may be electrically related to earlier-queued interconnection requests that have yet to complete interconnection studies, then it fails the evaluation of electrical independence for the Distribution System.

- If Yes (pass), continue to Independent Study Process
- If No (fail), continue to the Distribution Group Study Process

Significance: Interconnection Requests that are electrically related to earlier-queued interconnection requests that have not yet been studied do not qualify for independent study.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 162

G. ENGINEERING REVIEW DETAILS (Cont'd.) (L)

3. DETAILED STUDY SCREENS (Cont'd.)

c. Independent Study Process and Distribution Group Study Process Interconnection Studies

The Interconnection Studies shall consist of an Interconnection System Impact Study and an Interconnection Facilities Study for the Independent Study Process or the DGS Phase I Interconnection Study and the DGS Phase II Interconnection Study for the Distribution Group Study Process. The Interconnection Studies will identify Interconnection Facilities, Distribution Upgrades and Reliability Network Upgrades necessary to mitigate thermal overloads and voltage violations, and address short circuit, dynamic/stability, and reliability issues associated with the requested Interconnection Service. If Distribution Provider anticipates that Reliability Network Upgrades will be required, or the Interconnection Studies identify the need for Reliability Network Upgrades, then Distribution Provider will coordinate with the CAISO during the study process as set forth in Sections F.3.b or F.3.c above.

The estimated costs of short circuit related upgrades and shared interconnection facilities, if any, identified through a Distribution Group Study shall be assigned as provided in E.4.e.

i) Interconnection System Impact and DGS Phase I Interconnection Study.

(1) Scope of the Interconnection System Impact and DGS Phase I Interconnection Study.

The Interconnection System Impact or DGS Phase I Interconnection Study in the case of the Distribution Group Study Process may consist of a localized short circuit analysis, a stability/dynamic analysis, a power flow analysis, and any other studies that are deemed necessary. The localized short circuit analysis will evaluate impacts to the Distribution and Transmission System only with any local short circuit-duty related Reliability Network Upgrades allocated to the Generating Facility or Generating Facilities that require(s) the upgrades. Short circuit duty impacts to the

(L)

(Continued)



**ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS**

Sheet 163

G. ENGINEERING REVIEW DETAILS (Cont'd.)

(L)

3. DETAILED STUDY SCREENS (Cont'd.)

c. Independent Study Process and Distribution Group Study Process Interconnection Studies (Cont'd.)

i) Interconnection System Impact and DGS Phase I Interconnection Study. (Cont'd.)

(1) Scope of the Interconnection System Impact and DGS Phase I Interconnection Study. (Cont'd.)

CAISO Controlled Grid are appropriately evaluated only in the WDT Transmission Cluster Study Process as set forth in Section F.3.d. The short circuit duty contribution of any Interconnection Requests studied in the Independent Study Process or Distribution Group Study Process that are subsequently identified in the Cluster Study Process will be allocated its pro rata share of the short circuit duty-related Reliability Network Upgrades on the basis of the short circuit duty contribution of each Generating Facility.

The Interconnection System Impact Study or DGS Phase I Interconnection Study in the case of the Distribution Group Study Process, shall state the assumptions upon which it is based, state the results of the analyses, and provide the requirement or potential impediments to providing the requested Interconnection Service, including a preliminary indication of the cost and length of time that would be necessary to correct any problems identified in those analyses and implement the Interconnection.

The Interconnection System Impact or DGS Phase I Interconnection Study shall provide a list of Distribution Provider's Interconnection Facilities, Distribution Upgrades, and Reliability Network Upgrades that are required as a result of the Interconnection Request along with a non-binding good faith estimate of cost responsibility and the amount of construction time required.

If at any time the Distribution Provider determines that it will not meet the required time frame for completing the DGS Phase I Interconnection Study due to the large number of

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 164

- G. ENGINEERING REVIEW DETAILS (Cont'd.) (L)
- 3. DETAILED STUDY SCREENS (Cont'd.)
 - c. Independent Study Process and Distribution Group Study Process Interconnection Studies (Cont'd.)
 - i) Interconnection System Impact and DGS Phase I Interconnection Study. (Cont'd.)
 - (1) Scope of the Interconnection System Impact and DGS Phase I Interconnection Study. (Cont'd.)

Interconnection Requests in the Distribution Group Study Application window, study complexity, or unavailability of resources on a reasonable basis to perform the study in the required time frame, the Distribution Provider shall notify the Interconnection Customer(s) within the Distribution Group Study as to the schedule status of the DGS Phase I Interconnection Study and provide an estimated completion date with an explanation of the reasons why additional time is required.

Upon request, the Distribution Provider shall provide the Applicant(s) all supporting documentation, work papers and relevant pre-Interconnection Request and post-Interconnection Request power flow, short circuit and stability databases for the DGS Phase I Interconnection Study, subject to confidentiality arrangements as outlined in Section D.7.
 - ii) Interconnection Facilities Study and DGS Phase II Interconnection Study.
 - (1) Scope and Purpose of the Interconnection Facilities and DGS Phase II Interconnection Study.

The Interconnection Facilities Study or DGS Phase II Interconnection Study in the case of the Distribution Group Study Process shall specify and estimate the cost of the equipment, engineering, procurement, and construction work (including overheads) needed to implement the conclusions of the Interconnection System Impact Study or DGS Phase I Interconnection Study technical analyses in accordance with

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 165

G. ENGINEERING REVIEW DETAILS (Cont'd.)

(L)

3. DETAILED STUDY SCREENS (Cont'd.)

c. Independent Study Process and Distribution Group Study Process Interconnection Studies (Cont'd.)

ii) Interconnection Facilities Study and DGS Phase II Interconnection Study. (Cont'd.)

(1) Scope and Purpose of the Interconnection Facilities and DGS Phase II Interconnection Study. (Cont'd.)

Good Utility Practice to physically and electrically connect the Generating Facility to the Distribution or Transmission System. The Interconnection Facilities Study or DGS Phase II Interconnection Study shall also identify (i) the electrical switching configuration of the connection equipment, including, without limitation: the transformer, switchgear, meters, and other station equipment; the nature and estimated cost of any Distribution Provider's Interconnection Facilities, Distribution Upgrades, and Network Upgrades necessary to accomplish the interconnection; and an estimate of the time required to complete the construction and installation of such facilities. The analyses in the Interconnection System Impact Study (or DGS Phase I Interconnection Study in the case of the Distribution Group Study Process) will be updated as necessary in the Interconnection Facilities Study (or DGS Phase II Interconnection Study), to account for withdrawal of interconnection requests in the interconnection queue.

H. GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS

Section H shall be used for interconnection of non-inverter based technologies.

(L)

(P)/(L)

(P)/(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 166

H. GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS (L)
(Cont'd.)

1. GENERAL INTERCONNECTION AND PROTECTIVE FUNCTION REQUIREMENTS (L)

This section is consistent with the requirements of IEEE 1547-2018. In the event of conflicts, this Rule shall take precedence. (P)/(L)
(P)/(L)

The Protective Functions and requirements of this Rule are designed to protect Distribution Provider's Distribution and Transmission System and not the Generating Facility. A Producer shall be solely responsible for providing adequate protection for its Generating Facility and Interconnection Facilities. Producer's Protective Functions shall not impact the operation of other Protective Functions on Distribution Provider's Distribution and Transmission System in a manner that would affect Distribution Provider's capability of providing reliable service to its customers. (L)

a. Protective Functions Required

Generating Facilities operating in parallel with Distribution Provider's Distribution or Transmission System shall be equipped with the following Protective Functions to sense abnormal conditions on Distribution Provider's Distribution or Transmission System and cause the Generating Facility to be automatically disconnected from Distribution Provider's Distribution or Transmission System or to prevent the Generating Facility from being connected to Distribution Provider's Distribution or Transmission System inappropriately:

- i) Over and under voltage trip functions and over and under frequency trip functions;
- ii) A voltage and frequency sensing and time-delay function to prevent the Generating Facility from energizing a de-energized Distribution or Transmission System circuit and to prevent the Generating Facility from reconnecting with Distribution Provider's

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 167

- H. GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS (L)
(Cont'd.)
 - 1. GENERAL INTERCONNECTION AND PROTECTIVE FUNCTION REQUIREMENTS (Cont'd.)
 - a. Protective Functions Required (Cont'd.)
 - ii) Distribution or Transmission System unless Distribution Provider's Distribution System service voltage and frequency is within the ANSI C84.1-1995 Table 1 Range B voltage Range of 106 volts to 127 volts (on a 120 volt basis), inclusive, and a frequency range of 59.3 Hz to 60.5 Hz, inclusive, and are stable for at least 60 seconds; and
 - iii) A function to prevent the Generating Facility from contributing to the formation of an Unintended Island, and cease to energize Distribution Provider's Distribution System within two seconds of the formation of an Unintended Island. (L)
 - iv) Open-phase condition: Generating Facility shall detect and cease to energize and trip all phases within 2 seconds of any open phase condition in accordance with IEEE 1547-2018, 6.2.2. (P)/(L)
(P)/(L)
(L)
- The Generating Facility shall cease to energize Distribution Provider's Distribution System for faults on Distribution Provider's Distribution System circuit to which it is connected (IEEE 1547-2018, 6.2.1). The Generating Facility shall cease to energize Distribution Provider's Distribution circuit prior to re-closure by Distribution Provider's Distribution System equipment (IEEE 1547-2018, 6.3). (L)
(P)/(L)
(L)
- b. Momentary Paralleling Generating Facilities
 - With Distribution Provider's approval, the transfer switch or scheme used to transfer Producer's loads from Distribution Provider's Distribution or Transmission System to Producer's Generating Facility may be used in lieu of the Protective Functions required for Parallel Operation. (L)
 - Generating facilities which operate using a momentary parallel scheme are not required to comply with the functional requirements as required in the IEEE 1547-2018 standard. (P)/(L)
(P)/(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 178

H. GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS
(Cont'd.)

1. GENERAL INTERCONNECTION AND PROTECTIVE FUNCTION REQUIREMENTS
(Cont'd.)

c. Suitable Equipment Required

(T)

Circuit breakers or other interrupting equipment located at the Point of Common Coupling (PCC) must be Certified or "Listed" (as defined in Article 100, the Definitions Section of the National Electrical Code) as suitable for their intended application. This includes being capable of interrupting the maximum available fault current expected at their location. Producer's Generating Facility and Interconnection Facilities shall be designed so that the failure of any single device or component shall not potentially compromise the safety and reliability of Distribution Provider's Distribution and Transmission System. The Generating Facility paralleling-device shall be capable of withstanding 220% of the Interconnection Facility rated voltage (IEEE 1547-2018, 4.11.3). The Interconnection Facility shall have the capability to withstand voltage and current surges in accordance with the environments defined in IEEE Std C62.41.2-2002 or IEEE Std C37.90.1-2002 as applicable and as described in L.3.e (IEEE 1547-2018, 4.11.2).

(L)

|

|

(L)

(T)

(T)

d. Visible Disconnect Required

When required by Distribution Provider's operating practices, Producer shall furnish and install a ganged, manually-operated isolating switch (or a comparable device mutually agreed upon by Distribution Provider and Producer) near the Point of Interconnection to isolate the Generating Facility from Distribution Provider's Distribution or Transmission System. The device does not have to be rated for load break nor provide over-current protection.

The device must:

- i) allow visible verification that separation has been accomplished. (This requirement may be met by opening the enclosure to observe contact separation.)
- ii) include markings or signage that clearly indicates open and closed positions.
- iii) be capable of being reached:
 - a) for Emergency purposes quickly and conveniently 24 hours a day by Distribution Provider personnel for construction,

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

H. GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS (L)
(Cont'd.)

1. GENERAL INTERCONNECTION AND PROTECTIVE FUNCTION REQUIREMENTS (Cont'd.)

d. Visible Disconnect Required (Cont'd.)

iii) be capable of being reached: (Cont'd.)

a) operation, maintenance, inspection, testing or to isolate the Generating Facility from Distribution Provider's Distribution or Transmission System without obstacles or requiring those seeking access to obtain keys, special permission, or security clearances.

b) for Non-Emergency purposes during normal business hours. Distribution Provider, where possible, will provide notice to Customer for gaining access to Customer's premises.

iv) be capable of being locked in the open position,

v) be clearly marked on the submitted single line diagram and its type and location approved by Distribution Provider prior to installation. If the device is not adjacent to the PCC, permanent signage must be installed at a Distribution Provider approved location providing a clear description of the location of the device. If the switch is not accessible outside the locked premises, signage with contact information and a Distribution Provider approved locking device for the premises shall be installed.

Generating Facilities with Non-Islanding inverters totaling one (1) kilovolt-ampere (kVA) or less are exempt from this requirement.

e. Drawings Required

Prior to Parallel Operation or Momentary Parallel Operation of the Generating Facility, Distribution Provider shall approve Producer's Protective Function and control diagrams. Generating Facilities equipped with Protective Functions and a control scheme previously approved by Distribution Provider for system-wide application or only Certified Equipment may satisfy this requirement by reference to previously approved drawings and diagrams.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 170

H. GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS (L)
(Cont'd.)

1. GENERAL INTERCONNECTION AND PROTECTIVE FUNCTION REQUIREMENTS (Cont'd.)

f. Generating Facility Conditions Not Identified

In the event this Rule does not address the Interconnection conditions for a particular Generating Facility, Distribution Provider and Producer may agree upon other arrangements

2. PREVENTION OF INTERFERENCE

Producer shall not operate Generating or Interconnection Facilities that superimpose a voltage or current upon Distribution Provider's Distribution or Transmission System that interferes with Distribution Provider operations, service to Distribution Provider Customers, or communication facilities. If such interference occurs, Producer must diligently pursue and take corrective action at its own expense after being given notice and reasonable time to do so by Distribution Provider. If Producer does not take corrective action in a timely manner, or continues to operate the facilities causing interference without restriction or limit, Distribution Provider may, without liability, disconnect Producer's facilities from Distribution Provider's Distribution or Transmission System, in accordance with Section D.9 of this Rule. To eliminate undesirable interference caused by its operation, each Generating Facility shall meet the following criteria:

Except as otherwise stated, the RPA for all performance requirements shall be met at the PCC.

When the Generating Facility is less than 500KVA or when the Generating Facility operates under one of the non-exporting options or inadvertent export of no longer than 30 seconds, the RPA may be the POC.

a. Voltage Regulation

The Generating Facility shall not actively regulate the voltage at the PCC while in parallel with Distribution Provider's Distribution System. The Generating Facility shall not cause the service voltage at other customers to go outside the requirements of ANSI C84.1-1995, Range A.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 171

H. GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS (L)
(Cont'd.)

2. PREVENTION OF INTERFERENCE (Cont'd.)

b. Voltage Trip Setting

The voltage ranges in Table H.1 define protective trip limits for the Protective Function and are not intended to define or imply a voltage regulation Function. Generating Facilities shall cease to energize Distribution Provider's Distribution System within the prescribed trip time whenever the voltage at the PCC deviates from the allowable voltage operating range. The Protection Function shall detect and respond to voltage on all phases to which the Generating Facility is connected.

i) Generating Facilities (30 kVA or less)

Generating Facilities with a Gross Rating of 30 kVA or less shall be capable of operating within the voltage range normally experienced on Distribution Provider's Distribution System from plus to minus 5% of the nominal voltage (e.g. 114 volts to 126 volts, on a 120 volt base), at the service panel or PCC. The trip settings at the generator terminals may be selected in a manner that minimizes nuisance tripping between 106 volts and 132 volts on a 120-volt base (88%-110% of nominal voltage) to compensate for voltage drop between the generator terminals and the PCC. Voltage may be detected at either the PCC or the Point of Interconnection. However, the voltage range at the PCC, with the generator on-line, shall stay within +/-5% of nominal.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 172

H. GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS (L)
(Cont'd.)

2. PREVENTION OF INTERFERENCE (Cont'd.)

b. Voltage Trip Setting (Cont'd.)

ii) Generating Facilities (greater than 30 kVA)

Distribution Provider may have specific operating voltage ranges for Generating Facilities with Gross Ratings greater than 30 kVA, and may require adjustable operating voltage settings. In the absence of such requirements, the Generating Facility shall be capable of operating at a range between 88% and 110% of the applicable interconnection voltage. Voltage shall be detected at either the PCC or the Point of Interconnection, with settings compensated to account for the voltage at the PCC. However, the voltage range at the PCC, with the generator on-line, shall stay within +/-5% of nominal.

iii) Voltage Disturbances

Whenever Distribution Provider's Distribution System voltage at the PCC varies from and remains outside normal (Nominally 120 volts) for the predetermined parameters set forth in Table H-1, the Generating Facility's Protective Functions shall cause the Generator(s) to become isolated from Distribution Provider's Distribution System:

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 173

H. GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS (Cont'd.)

2. PREVENTION OF INTERFERENCE (Cont'd.)

b. Voltage Trip Setting (Cont'd.)

iii) Voltage Disturbances (Cont'd.)

(L)

(L)

Table H.1: Voltage Trip Settings for Generating Facilities*			
Voltage at Point of Common Coupling (the ranges below are used to trip the generator during abnormal distribution system conditions)		Maximum Trip Time**	
Assuming 120 Volt Base	% of Nominal Voltage	# of Cycles (Assuming 60 Hz Nominal)	Seconds
Less than 60 volts	Less than 50%	10 Cycles	0.16 Seconds
Greater than or equal to 60 volts but less than 106 volts	Greater than or equal to 50% but less than 88%	120 Cycles	2 Seconds
Greater than 132 volts but less than or equal to 144 volts	Greater than 110% but less than or equal to 120%	60 Cycles	1 Second
Greater than 144 volts	Greater than 120%	10 Cycles	0.16 Seconds
*For Generating Facilities with a Rating greater than 30 kVA, set points shall be field adjustable and different voltage set points and trip times from those in Table H.1 may be negotiated with Distribution Provider			
** "Maximum Trip Time" refers to the time between the onset of the abnormal condition and the Generating Facility ceasing to energize Distribution Provider's Distribution System. Protective Function equipment and circuits may remain connected to Distribution Provider's Distribution System to allow sensing of electrical conditions for use by the "reconnect" feature. The purpose of the allowed time delay is to allow for a Generating Facility to minimize tripping during short term system disturbances. Set points shall not be user adjustable for generating facilities less than 30 kW.			

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 174

H. GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS (L)
(Cont'd.)

2. PREVENTION OF INTERFERENCE (Cont'd.)

c. Paralleling

The Generating Facility shall parallel with Distribution Provider's Distribution or Transmission System without causing a voltage fluctuation at the PCC greater than plus/minus 5% of the prevailing voltage level of Distribution Provider's Distribution or Transmission System at the PCC, and meet the flicker requirements of Section H.2.d. Section L, Certification and Testing Criteria, provides technology-specific tests for evaluating the paralleling Function. (IEEE 1547-2018, 4.10)

(L)
(P)/(L)

d. Flicker

The Generating Facility shall not create objectionable flicker for other customers on Distribution Provider's Distribution or Transmission System. To minimize the adverse voltage effects experienced by other customers, flicker at the PCC caused by the Generating Facility should not exceed the limits of IEEE 1547-2018, 7.2.3. This requirement is necessary to minimize the adverse voltage affects experienced by other Customers on Distribution Provider's Distribution or Transmission System. Generators may be connected and brought up to synchronous speed (as an induction motor) provided these flicker limits are not exceeded.

(L)
|
(L)
(P)/(L)
(P)/(L)
(L)
|
(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 185

H. GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS
(Cont'd.)

2. PREVENTION OF INTERFERENCE (Cont'd.)

e. Integration with Distribution Provider's Distribution System Grounding

The grounding scheme of the Generating Facility shall not cause over-voltages that exceed the rating of the equipment connected to Distribution Provider's Distribution System and shall not disrupt the coordination of the ground fault protection on Distribution Provider's Distribution System (IEEE 1547-2018, 4.12) (See Section G.1.i, line configuration).

(T)

f. Frequency

Distribution Provider controls system frequency, and the Generating Facility shall operate in synchronism with Distribution Provider's Distribution or Transmission System. Whenever Distribution Provider's Distribution or Transmission System frequency at the PCC varies from and remains outside normal (nominally 60 Hz) by the predetermined amounts set forth in Table H.2, the Generating Facility's Protective Functions shall cease to energize Distribution Provider's Distribution or Transmission System within the stated maximum trip time.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 176

H. GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS
(Cont'd.)

(L)

2. PREVENTION OF INTERFERENCE (Cont'd.)

f. Frequency (Cont'd.)

Table H.2
Frequency Trip Settings

<u>Generating Facility Rating</u>	<u>Frequency Range</u> <u>(Assuming 60Hz Nominal)</u>	<u>Maximum Trip Time [1]</u> <u>(Assuming 60 Cycles per Second)</u>
Less or equal to 30kW	Less than 59.3 Hz	10 Cycles
	Greater than 60.5 Hz	10 Cycles
Greater than 30 kW	Less than 57.0 Hz	10 Cycles
	Less than an adjustable value between 59.8 Hz and 57 Hz but greater than 57 Hz. [2]	Adjustable between 10 and 18,000 Cycles. [2, 3]
	Greater than 60.5 Hz.	10 Cycles

[1] – “Maximum Trip time” refers to the time between the onset of the abnormal condition and the Generating Facility ceasing to energize Distribution Provider’s Distribution or Transmission System. Protective Function sensing equipment and circuits may remain connected to Distribution Provider’s Distribution or Transmission System to allow sensing of electrical conditions for use by the “reconnect” feature. The purpose of the allowed time delay is to allow a Generating Facility to “ride through” short-term disturbances to avoid nuisance tripping. Set points shall not be user adjustable (though they may be field adjustable by qualified personnel). For Generating Facilities with a Gross Rating greater than 30 kVA, set points shall be field adjustable and different voltage set points and trip times from those in Table H.2 may be negotiated with Distribution Provider.

[2] – Unless otherwise required by Distribution Provider, a trip frequency of 59.3 Hz and a maximum trip time of 10 cycles shall be used.

[3] – When a 10 cycle Maximum trip time is used, a second under frequency trip setting is not required.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 177

H. GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS (L)
(Cont'd.)

2. PREVENTION OF INTERFERENCE (Cont'd.)

g. Harmonics

When the Generating Facility is serving balanced linear loads, harmonic current injection into Distribution Provider's Distribution or Transmission System at the PCC shall not exceed the limits stated in IEEE 1547-2018, 7.3. The harmonic current injections shall be exclusive of any harmonic currents due to harmonic voltage distortion present in Distribution Provider's Distribution or Transmission System without the Generating Facility connected. The harmonic distortion of a Generating Facility shall be evaluated using the same criteria as for the Host Loads.

(L)
(P)/(L)
(L)
(L)
(P)/(L)
(L)
(L)

(P)/(L)

(P)/(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 178

- H. GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS (L)
(Cont'd.)
- 2. PREVENTION OF INTERFERENCE (Cont'd.)
- h. Direct Current Injection
 - Generating Facilities should not inject direct current greater than 0.5% of rated output current into Distribution Provider's Distribution or Transmission System.
- i. Power Factor
 - Producer shall provide adequate reactive power compensation on site to maintain the Generating Facility power factor near unity at rated output or a Distribution Provider specified power factor within a power factor range from 0.9 leading to 0.9 lagging, based on local system conditions. While not required, for generators that do not have inherent reactive power control capability Distribution Provider at its option may offer reactive power support in the form of power factor correction capacitors on its Distribution or Transmission System, under a Generator Interconnection Agreement or an Added Facilities or Special Facilities agreement, as described in Rule 2.H, as applicable. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 189

H. GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS
(Cont'd.)

3. TECHNOLOGY SPECIFIC REQUIREMENTS

a. Technology Specific Requirements

Three-Phase Synchronous Generators: For three phase Generators, the Generating Facility circuit breakers shall be three-phase devices with electronic or electromechanical control. Producer shall be responsible for properly synchronizing its Generating Facility with Distribution Provider's Distribution or Transmission System by means of either manual or automatic synchronous equipment. Automatic synchronizing is required for all synchronous Generators that have a Short Circuit Contribution Ratio (SCCR) exceeding 0.05. Loss of synchronism protection is not required except as may be necessary to meet Section H.2.d (Flicker) (IEEE 1547-2018, 7.2.3). Unless otherwise agreed upon by Producer and Distribution Provider, synchronous Generators shall automatically regulate power factor, not voltage, while operating in parallel with Distribution Provider's Distribution System. A power system stabilization Function is specifically not required for Generating Facilities under 10 MW Net Rating.

(T)

b. Induction Generators

Induction Generators (except self-excited Induction Generators) do not require a synchronizing Function. Starting or rapid load fluctuations on induction Generators can adversely impact Distribution Provider's Distribution or Transmission System voltage. Corrective step-switched capacitors or other techniques may be necessary and may cause undesirable ferro-resonance. When these counter measures (e.g. additional capacitors) are installed on Producer's side of the PCC, Distribution Provider must review these measures. Additional equipment may be required as determined in a Supplemental Review or an Interconnection Study.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 180

H. GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS (L)
(Cont'd.)

3. TECHNOLOGY SPECIFIC REQUIREMENTS (Cont'd.)

c. Inverters

Grid-interactive inverters do not require separate synchronizing equipment. Non-grid-interactive or "stand-alone" inverters shall not be used for Parallel Operation with Distribution Provider's Distribution or Transmission System.

d. Limitations on Inverters Not Classified as Smart Inverters

i) Inverter based systems may continue to be installed per Section H until September 8, 2017. Section Hh may be used in all or in part, for inverter based technologies by mutual agreement of the Distribution Provider and the Applicant.

ii) The replacement of an existing inverter to an inverter that is of equal or greater ability than the original is allowed per Section H. Section Hh may be used in all or in part, for replacement inverter-based technologies by mutual agreement of the Distribution Provider and the Applicant. If a developer replaces an existing inverter with an inverter of greater ability, the replacement inverter shall have all the required functionalities and be set according to current Commission practices as of the date the new smart inverter is installed, unless the interconnection applicant can demonstrate that safety or operational needs necessitate otherwise, per D.19-03-013 OP 12.

e. Non-Export AC/DC Converters

A Non-Export AC/DC Converter must satisfy the definition in Section C.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 181

H. GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS
(Cont'd.)

4. SUPPLEMENTAL GENERATING FACILITY REQUIREMENTS

a. Fault Detection

A Generating Facility with an SCCR exceeding 0.1 or one that does not cease to energize Distribution Provider's Distribution or Transmission System within two seconds of the formation of an Unintended Island shall be equipped with Protective Functions designed to detect Distribution or Transmission System faults, both line-to-line and line-to-ground, and cease to energize Distribution Provider's Distribution or Transmission System within two seconds of the initiation of a fault.

b. Transfer Trip

For a Generating Facility that cannot detect Distribution or Transmission System faults (both line-to-line and line-to-ground) or the formation of an Unintended Island, and cease to energize Distribution Provider's Distribution or Transmission System within two seconds, Distribution Provider may require a Transfer Trip system or an equivalent Protective Function.

c. Reclose Blocking

Where the aggregate Generating Facility capacity exceeds 15% of the peak load on any automatic reclosing device, Distribution Provider may require additional Protective Functions, including, but not limited to reclose-blocking on some of the automatic reclosing devices.

(D)

(D)

¹ "The Standard for Inverters, Converters, and Controllers for Use in Independent Power Systems".

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 182

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS

(T)

When requirements for “Smart Inverter” are specified in this section, those requirements can also be met by a “DER Interconnection System” as defined in this tariff.

The inverter requirements are intended to be consistent with UL 1741 – Supplement SB using as the source requirement document ANSI/IEEE 1547-2018 and IEEE 1547.1-2020 Standard for Interconnecting Distributed Resources with Electric Power Systems where possible. In the event of conflict between this Rule and UL 1741 – Supplement SB and/or IEEE 1547-2018 or IEEE 1547.1-2020, this Rule shall take precedence.

The Smart Inverter default settings and default activation states may be modified upon mutual agreement between Applicant or Producer and Distribution Provider.

Process for changing default settings for new Interconnection Requests:

Distribution Provider, in the study process for new Generating Facilities, may determine and provide the optimum Smart Inverter Settings for the reactive power settings, including changes to the reactive power default settings (Example: Deactivate Volt/Var and activate Fixed Power Factor at given power factor).

Distribution Provider, in the study process for new Generating Facilities, may determine and provide the optimum Smart Inverter Settings for the Ramp Rate settings depending on the Generating Facility technology (such as solar, storage).

Distribution Provider, in the study process for new Generating Facilities, may determine the optimum Smart Inverter Settings for the volt/watt settings, including changes to the default settings (Example: Change the volt/watt set points). The Applicant may select to agree on the new settings or select to perform upgrades to operate using the existing default volt/watt settings.

(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 183

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd.)

(T)

Default settings for voltage ride-through, frequency ride-through requirements, and Frequency/Watt should not be modified on an individual project basis unless the Interconnection Studies have determined that the default settings may not meet grid reliability requirements.

Process for changing default settings for Generating Facilities with an executed Interconnection Agreement:

When grid changes or Generating Facility changes require that the Smart Inverter operating parameters be reevaluated, the Distribution Provider or Producer may request changes to the Smart Inverter operating parameters. The request must include the reason for and timing of the proposed changes. The requested changes must be within the Smart Inverter function adjustability limits, must be within the limits specified in this tariff, and must be mutually agreed upon.

1. General Interconnection and Protective Function Requirements

The Protective Functions and requirements of this Rule are designed to protect Distribution Provider's Distribution and Transmission System and not the Generating Facility. A Producer shall be solely responsible for providing adequate protection for its Generating Facility and Interconnection Facilities. Producer's Protective Functions shall not impact the operation of other Protective Functions on Distribution Provider's Distribution and Transmission System in a manner that would affect Distribution Provider's capability of providing reliable service to its customers.

(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 184

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd.)

(T)

1. General Interconnection and Protective Function Requirements (Cont'd)

a. Protective Functions Required

Smart Inverters operating in parallel with Distribution Provider's Distribution or Transmission System shall be equipped with the following Protective Functions to sense abnormal conditions on Distribution Provider's Distribution or Transmission System and cause the Smart Inverter to be automatically disconnected from Distribution Provider's Distribution or Transmission System or to prevent the Smart Inverter from being connected to Distribution Provider's Distribution or Transmission System inappropriately:

- (i) Over and under voltage trip functions and over and under frequency trip functions;
- (ii) A voltage and frequency sensing and time-delay function to prevent the Smart Inverter from energizing a de-energized Distribution or Transmission System circuit and to prevent the Smart Inverter from reconnecting with Distribution Provider's Distribution or Transmission System unless Distribution Provider's Distribution System service voltage and frequency is within the ANSI C84.1-1995 Table 1 Range B voltage Range of 106 volts to 127 volts (on a 120 volt basis), inclusive, and a frequency range of 59.0 Hz to 60.5 Hz, inclusive, and are stable for at least 15 seconds; and
- (iii) A function to prevent the Smart Inverter from contributing to the formation of an Unintended Island, and cease to energize Distribution Provider's Distribution System within two seconds of the formation of an Unintended Island.

The Smart Inverter shall cease to energize Distribution Provider's Distribution System for faults on Distribution Provider's Distribution System circuit to which it is connected (IEEE 1547-2018, 6.2.1). The Smart Inverter shall cease to energize Distribution Provider's Distribution circuit prior to re-closure by Distribution Provider's Distribution System equipment (IEEE 1547-2018, 6.3).

(T)

(Continued)



**ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS**

Sheet 185

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd.) (T)

1. General Interconnection and Protective Function Requirements (Cont'd)

a. Protective Functions Required (Cont'd)

- (iv) Open-phase condition: Generating Facility shall detect and cease to energize and trip all phases within 2 seconds of any open phase condition in accordance with IEEE 1547-2018, 6.2.2.

The Smart Inverter Facility shall cease to energize Distribution Provider's Distribution System for faults on Distribution Provider's Distribution System circuit to which it is connected (IEEE 1547-2018, 6.2.1). The Generating Facility shall cease to energize Distribution Provider's Distribution circuit prior to re-closure by Distribution Provider's Distribution System equipment (IEEE 1547-2018, 6.3).

b. Momentary Paralleling Smart Inverter Generating Facilities

With Distribution Provider's approval, the transfer switch or scheme used to transfer Producer's loads from Distribution Provider's Distribution or Transmission System to Producer's Generating Facility may be used in lieu of the Protective Functions required for Parallel Operation.

Smart Inverters which operate using a momentary parallel scheme are not required to comply with the functional requirements as required in the IEEE 1547-2018 standard.

(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd.)

(T)

1. General Interconnection and Protective Function Requirements (Cont'd)

c. Suitable Equipment Required

Circuit breakers or other interrupting equipment located at the Point of Common Coupling (PCC) must be Certified or "Listed" (as defined in Article 100, the Definitions Section of the National Electrical Code) as suitable for their intended application. This includes being capable of interrupting the maximum available fault current expected at their location. Producer's Smart Inverter and Interconnection Facilities shall be designed so that the failure of any single device or component shall not potentially compromise the safety and reliability of Distribution Provider's Distribution and Transmission System. The Smart Inverter paralleling-device shall be capable of withstanding 220% of the Interconnection Facility rated voltage (IEEE 1547-2018, 4.11.3). The Interconnection Facility shall have the capability to withstand voltage and current surges in accordance with the environments defined in IEEE Std C62.41.2-2002 or IEEE Std C37.90.1-2002 as applicable and as described in L.3.e (IEEE 1547-2018, 4.11.2).

d. Visible Disconnect Required

When required by Distribution Provider's operating practices, Producer shall furnish and install a ganged, manually-operated isolating switch (or a comparable device mutually agreed upon by Distribution Provider and Producer) near the Point of Interconnection to isolate the Smart Inverter from Distribution Provider's Distribution or Transmission System. The device does not have to be rated for load break nor provide over-current protection.

The device must:

- (i) allow visible verification that separation has been accomplished. (This requirement may be met by opening the enclosure to observe contact separation.)
- (ii) Include markings or signage that clearly indicates open and closed positions.
- (iii) be capable of being reached:

(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 187

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd) (T)

1. General Interconnection and Protective Function Requirements (Cont'd)

d. Visible Disconnect Required (Cont'd)

(iii) be capable of being reached (Cont'd):

a) for Emergency purposes quickly and conveniently 24 hours a day by Distribution Provider personnel for construction, operation, maintenance, inspection, testing or to isolate the Smart Inverter from Distribution Provider's Distribution or Transmission System without obstacles or requiring those seeking access to obtain keys, special permission, or security clearances.

b) for Non-Emergency purposes during normal business hours. Distribution Provider, where possible, will provide notice to Customer for gaining access to Customer's premises.

(iv) be capable of being locked in the open position.

(v) be clearly marked on the submitted single line diagram and its type and location approved by Distribution Provider prior to installation. If the device is not adjacent to the PCC, permanent signage must be installed at a Distribution Provider approved location providing a clear description of the location of the device. If the switch is not accessible outside the locked premises, signage with contact information and a Distribution Provider approved locking device for the premises shall be installed.

Generating Facilities with Non-Islanding inverters totaling one (1) kilovolt-ampere (kVA) or less are exempt from this requirement.

e. Drawings Required

Prior to Parallel Operation or Momentary Parallel Operation of the Smart Inverter, Distribution Provider shall approve Producer's Protective Function and control diagrams. Generating Facilities equipped with Protective Functions and a control scheme previously approved by Distribution Provider for system-wide application or only Certified Equipment may satisfy this requirement by reference to previously approved drawings and diagrams.

(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 188

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd)

(T)

2. PREVENTION OF INTERFERENCE (Cont'd.)

1. General Interconnection and Protective Function Requirements (Cont'd)

f. Generating Facility Conditions Not Identified

In the event this Rule does not address the Interconnection conditions for a particular Smart Inverter, Distribution Provider and Producer may agree upon other arrangements.

g. Generating Facilities that use certified Power Control Systems (PCS) must use PCS listed in a Distribution Provider pre-approved list.

2. Prevention of Interference

Producer shall not operate Smart Inverters that superimpose a voltage or current upon Distribution Provider's Distribution or Transmission System that interferes with Distribution Provider operations, service to Distribution Provider Customers, or communication facilities. If such interference occurs, Producer must diligently pursue and take corrective action at its own expense after being given notice and reasonable time to do so by Distribution Provider. If Producer does not take corrective action in a timely manner, or continues to operate the facilities causing interference without restriction or limit, Distribution Provider may, without liability, disconnect Producer's facilities from Distribution Provider's Distribution or Transmission System, in accordance with Section D.9 of this Rule. To eliminate undesirable interference caused by its operation, each Smart Inverter shall meet the following criteria:

Except as otherwise stated, the RPA for all performance requirements shall be met at the PCC.

When the Generating Facility is less than 500KVA or when the Generating Facility operates under one of the non-exporting options or inadvertent export of no longer than 30 seconds, the RPA may be the Point of Generating Resource Connection (POC).

(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 189

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd)

(T)

2. Prevention of Interference (Cont'd)

a. Voltage Regulation

If approved by the Distribution Provider, the Smart Inverter may actively regulate the voltage at the PCC while in parallel with Distribution Provider's Distribution System. Smart Inverter shall not cause the service voltage at other customers to go outside the requirements of ANSI C84.1-1995, Range A. (IEEE 1547-2018, 5.1)

b. Voltage Trip and Ride-Through Setting

The voltage ranges in Table Hh-1 define protective trip limits for the Protective Function and are not intended to define or imply a voltage regulation Function. Generating Facilities shall cease to energize Distribution Provider's Distribution System within the prescribed trip time whenever the voltage at the PCC deviates from the allowable voltage operating range. The Protection Function shall detect and respond to voltage on all phases to which the Generating Facility is connected.

i) Smart Inverters

Smart Inverters shall be capable of operating within the voltage range normally experienced on Distribution Provider's Distribution System from plus to minus 5% of the nominal voltage (e.g. 114 volts to 126 volts, on a 120 volt base), at the service panel or PCC. The trip settings at the generator terminals may be selected in a manner that minimizes nuisance tripping in accordance with Table Hh-1 to compensate for voltage drop between the generator terminals and the PCC. Voltage may be detected at either the PCC or the Point of Interconnection. However, the voltage range at the PCC, with the generator on-line, shall stay within +/-5% of nominal.

(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 190

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd.)

(T)

2. Prevention of Interference (Cont'd)

b. Voltage Trip and Ride-Through Setting (Cont'd)

ii) Voltage Disturbances

Whenever Distribution Provider's Distribution System voltage at the RPA varies from and remains outside the Continuous Operation region for the predetermined parameters set forth in Table Hh-1b, the Smart Inverter's Protective Functions shall cause the Smart Inverter(s) to trip and become isolated from Distribution Provider's Distribution System as required in table Hh-1a:

1. The Smart Inverter shall stay connected to the Distribution Provider's Transmission or Distribution System while the grid remains within the "Voltage Range (p.u.)" and must stay connected in the corresponding "Operating Mode."
2. If the distribution system voltage does not exit the ride-through region and recovers to normal system voltage, the Smart Inverter shall restore continuous operation within 2 sec.
3. If the Distribution Provider's Transmission or Distribution System voltage does not exit the ride-through region and returns from the $V < 0.5$ pu region to the $0.5 \leq V < 0.7$ or $0.7 \leq V < 0.88$ pu region, the Smart Inverter shall restore available current within 2 seconds.
4. Different voltage-time settings could be permitted by the Distribution Provider.

(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd.)

(T)

2. Prevention of Interference (Cont'd)

b. Voltage Trip and Ride-Through Setting (Cont'd)

ii) Voltage Disturbances (Cont'd)

Table Hh-1a: Smart Inverter Voltage Trip Settings

Shall Trip Function	Voltage Trip Default Settings (p.u. of nominal voltage)	Voltage Range of Shall Trip Function (p.u. of nominal voltage)	Default Clearing Time (s)
OV2	1.20	$V \geq 1.20$	0.16
OV1	1.10	$1.10 \leq V < 1.20$	13.0
Continuous Operation	NA	$0.88 < V < 1.10$	NA
UV1	0.88	$0.50 < V \leq 0.88$	21.0
UV2	0.50	$V \leq 0.50$	2.0

Table Hh-1b – Smart Inverter Voltage Ride-through Settings

Voltage Range (p.u.)	Operating mode/response	Minimum ride-through time (s)	Maximum response time (s)
$V > 1.20$	Cease to Energize	NA	0.16
$1.10 < V \leq 1.20$	Momentary Cessation	12	0.083
$0.88 \leq V \leq 1.10$	Continuous Operation	Infinite	NA
$0.70 \leq V < 0.88$	Mandatory Operation	20	NA
$0.50 \leq V < 0.70$	Mandatory Operation	10	NA
$V < 0.50$	Momentary Cessation	1	0.083

iii) Voltage Phase Angle Change Ride-Through

Voltage phase angle change ride-through as specified in IEEE 1547-2018, 6.5.2.6.

(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 192

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd.)

(T)

2. Prevention of Interference (Cont'd)

c. Paralleling

The Smart Inverter shall parallel with Distribution Provider's Distribution or Transmission System without causing a voltage fluctuation at the PCC greater than plus/minus 5% of the prevailing voltage level of Distribution Provider's Distribution or Transmission System at the PCC, and meet the flicker requirements of Section H.2.d. Section L, Certification and Testing Criteria, provides technology-specific tests for evaluating the paralleling Function. (IEEE 1547-2018, 4.10.4)

d. Flicker

The Generating Facility shall not create objectionable flicker for other Customers on Distribution Provider's Distribution or Transmission System. To minimize the adverse voltage effects experienced by other Customers, flicker at the P caused by the Generating Facility should not exceed the limits of IEEE 1547-2018, 7.2.3. This requirement is necessary to minimize the adverse voltage affects experienced by other Customers on Distribution Provider's Distribution or Transmission System. Generators may be connected and brought up to synchronous speed (as an induction motor) provided these flicker limits are not exceeded.

e. Integration with Distribution Provider's Distribution System Grounding

The grounding scheme of the Smart Inverter shall not cause over-voltages that exceed the rating of the equipment connected to Distribution Provider's Distribution System and shall not disrupt the coordination of the ground fault protection on Distribution Provider's Distribution System (IEEE 1547-2018, 4.10.12) (See Section G.1.i, line configuration).

(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd)

(T)

2. Prevention of Interference (Cont'd)

f. Frequency

Distribution Provider controls system frequency, and the Smart Inverter shall operate in synchronism with Distribution Provider's Distribution or Transmission System. Whenever Distribution Provider's Distribution or Transmission System frequency at the PCC varies from and remains outside normal (nominally 60 Hz) by the predetermined amounts set forth in Table P 2a, the Smart Inverter's Protective Functions shall cease to energize Distribution Provider's Distribution or Transmission System within the stated maximum trip time.

i) Frequency Ride-Through Requirements

Smart Inverter based systems shall remain connected to the Distribution Provider's Distribution or Transmission System while the grid is within the frequency-time range indicated in Table Hh-2b, and shall disconnect from the electric grid during a high or low frequency event that is outside that frequency-time range as indicated in Table Hh-2a.

Table Hh-2a: Frequency Trip Settings Table

Shall Trip Function	Frequency Trip Default Setting (Hz)	Resulting Range of Shall Trip Function (Hz)	Default Clearing Time (s)
OF2	62.0	$f \geq 62.0$	0.16
OF1	61.2	$61.2 \leq f < 62$	300
Continuous Operation	NA	$58.5 < f < 61.2$	NA
UF1	58.5	$56.5 < f \leq 58.5$	300
UF2	56.5	$f \leq 56.5$	0.16

(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd.)

(T)

2. Prevention of Interference (Cont'd)

f. Frequency (Cont'd)

i) Frequency Ride-Through Requirements (Cont'd)

Table Hh-2b: Frequency Ride-Through Settings Table

Frequency (Hz)	Operating Mode	Minimum time(s)
$f > 62.0$	No Ride-Through requirements apply to this range	NA
$61.2 < f \leq 61.8$	Mandatory Operation	299
$58.8 \leq f \leq 61.2$	Continuous Operation	Infinite
$57.0 \leq f < 58.8$	Mandatory Operation	299
$F < 57.0$	No Ride-Through requirements apply to this range	NA

ii) Rate of Change of Frequency (ROCOF) Ride-through

Smart Inverter shall not trip for frequency excursion having magnitude rates of change of frequency (ROCOF) that is less than or equal to 3.0Hz per second as specified in IEEE 1547-2018, section 6.5.2.5 category III. For ROCOF greater than 3Hz per second, it is preferred for Smart Inverter to ride-through as long as frequency remains in the continuous operating region, low frequency ride-through region (and corresponding duration times), or high frequency region (and corresponding duration times).

(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd.)

(T)

2. Prevention of Interference (Cont'd)

Dynamic Volt/Var Operations Default Settings


Table Hh-3 and Figure Hh-1 depict the default setting, which should be applied for all inverter size. Specific volt/var settings may be required for larger generating facilities (such as 100 kW or greater) or for specific areas with the Distribution System as determined by the Distribution Provider.

Default Open Loop Response Time for volt/var operation setting should be five (5) seconds.

Table Hh-3: Voltage and Reactive Default Settings

Voltage Setpoint	Voltage Value	Reactive Setpoint	Reactive Value	Operation
V1	92.0%	Q1	30%	Reactive Power Injection
V2	97.0%	Q2	0	Unity Power Factor
V3	103.0%	Q3	0	Unity Power Factor
V4	107.0%	Q4	30%	Reactive Power Absorption

Figure Hh-1: Voltage and Reactive Default Settings



(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 197

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd.)

(T)

2. Prevention of Interference (Cont'd)

k. Enter Service Ramp Rate Requirements

The Smart Inverter is required to have the following ramp controls.

- Enter Service ramp control requirements as outlined in IEEE 1547-2018 section 4.10.3 with following default settings:
 - Delay enter service shall be 15 seconds per Hh.1.a.ii
 - Default Enter Service Duration shall be 50 seconds

l. Frequency Droop (Frequency Power, Frequency Watt) Requirements

Smart Inverters shall change their real power production as function of system frequency in accordance with IEEE 1547-2018, 6.5.2.7 with the following default settings: Deadband 36 mHz, db_{OF} and db_{UF} . k_{OF} and k_{UF} would be 0.05, open loop response time of 5 seconds.

(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 198

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd.) (T)

2. Prevention of Interference (Cont'd)

m. Voltage-Watt Default Settings Requirements

Smart Inverters shall reduce their real power production as a function measured voltage at the inverter terminal or at the Generating Facility Point of Common Coupling (PCC) in accordance with the following:

When the measured voltage is greater than 106% of nominal voltage (Example: 127.2 volts on a 120 volts nominal), the export of active power at the PCC or the production of active power by the Smart Inverter shall be reduced at a rate of 25% of active power nameplate rating per one percent of nominal voltage. Figure Hh-3 Volt-Watt Requirements illustrate the required rate of reduction. When export of active power is controlled, a certified inverter and control system shall be used.

(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd.)


(T)

2. Prevention of Interference (Cont'd)

m. Voltage-Watt Default Settings Requirements

- When the measured voltage is greater than 110% of nominal voltage (Example: 132 volts on a 120 volts nominal), the export of active power to the grid at the PCC or the production of active power by the Smart Inverter shall be reduced to 0 watts.
- Open Loop response time shall be 5 seconds.

Figure Hh-3: Volt-Watt Requirements



n. Dynamic Reactive Power Support Function

The capability for this requirement will become mandatory for Generating Facilities utilizing inverter-based technologies for which an Interconnection Request is submitted twelve (12) months after approval of a nationally recognized standard that includes the function. The utilization of this function is permissible under mutual agreement between Distribution Provider and the generating facility before the effective date.

(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 200

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd.)

(T)

(T)

- 2. Prevention of Interference (Cont'd)
 - o. Default Activation States

Unless otherwise provided by Distribution Provider, pursuant to Distribution Provider's Distribution Generation Interconnection Handbook, the default settings will be as follows:

Table Hh-4: Default Activation States

Function	State
Anti-islanding	Activated
Low/High Voltage Ride Through	Activated
Low/High Frequency Ride Through	Activated
Dynamic Volt/Var operations	Activated
Enter Service Ramp Control	Activated
Storage Inverter Normal Operation Ramp Control	Deactivated*
Fixed power factor	Deactivated
Reconnect by "soft-start" methods	Activated
Frequency/Watt	Activated
Volt/Watt	Activated
Constant Reactive Power Mode	Deactivated
Set Active Power Function Mode(Optional)	Activated under mutual agreement
Dynamic Reactive Power Support Mode (Optional)	Activated under mutual agreement

These default activation states may be modified by mutual agreement between Distribution Provider and Producer.

* May be activated under mutual agreement. For projects where the SB storage inverter Ramp Control is activated by mutual agreement, the inverter will be tested per SA 11 normal ramp rate tests. The testing must be done by a NRTL or, if available, in accordance with PG&E's interconnection handbook(s).

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 201

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd.)

(T)

2. Prevention of Interference (Cont'd)

p. Load Shedding or Transfer

The voltage and frequency ride-through requirements of Hh.2.b.ii) and Hh.2.f.i) shall not apply if either: a) The real power across the Point of Common Coupling is continuously maintained at a value less than 10% of the aggregate rating of the Smart Inverters connected to the Generating Facility prior to any voltage disturbance, and the Generation Facility disconnects from the Distribution Provider's Distribution or Transmission System, along with Generating Facility load, such that the net change in real power flow from or to the Distribution Provider's Distribution or Transmission System is less than 10% of the aggregate Smart Inverter capacity; or b) Generating Facility load real power demand equal to 90% to 120% of the predisturbance aggregate Smart Inverter real power is shed within 0.1 seconds of Smart Inverter disconnection.

q. Measurement and Calculation Accuracy

Smart Inverter shall meet minimum steady-state and transient measurement and calculation accuracy as required in IEEE 1547-2018, Section 4.4.

r. Prioritization of Smart Inverter Responses

- a) The response to disable permit to service as specified in section Hh.8.a shall take precedence over any other tripping requirements.
- b) Prioritization of tripping requirements not related to disabling permit to service shall meet IEEE 1547-2018 section 4.7.

(T)

(Continued)



**ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS**

Sheet 202

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd.)

(T)

2. Prevention of Interference (Cont'd)

s. Storage Inverter Normal Operation Ramp Control Requirements

Smart Inverters used for energy storage applications may optionally include ramp-up rate control. The default value shall be 100% of maximum current output per second or slower if required by Applicant. Other ramp-up control settings can be used, when required, as mutually agreed by the Distribution Provider and the Applicant.

t. Ride-through of Consecutive Voltage Disturbances

Ride-through of consecutive voltage disturbances shall be in accordance with IEEE 1547-2018, 6.4.2.5.

u. Restore output without dynamic voltage support

Restore output without dynamic voltage support shall be in accordance with IEEE 1547-2018, 6.4.2.7.1.

v. Transition between performance operating regions:

Transition between performance operating regions should be in accordance with IEEE 1547-2018, 6.4.2.7.3.

w. Constant Reactive Power Mode

When in this mode, the Smart Inverter shall maintain a constant reactive power. The target reactive power level and mode (injection or absorption) shall be specified by the Distribution Provider and shall be within the same range specified in IEEE 1547-2018 section 5.3.5. The reactive power settings are allowed to be adjusted locally and/or remotely as specified by the Distribution Provider. The maximum Smart Inverter response time to maintain constant reactive power shall be 10 seconds or less.

(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 203

- Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd.) (T)
- 2. Prevention of Interference (Cont'd)
 - x. Generating Facility Rapid Voltage Changes (RVC)

Generating step or ramp changes shall meet the requirements as specified in IEEE 1547-2018 section 7.2.2.
 - y. Limitations of Overvoltage Over One Fundamental Frequency Period

Generating Facility shall not contribute to instantaneous or fundamental frequency overvoltage conditions per IEEE 1547-2018, 7.4.1.
 - z. Limitation of Cumulative Instantaneous Overvoltage

Generating Facility shall not cause the instantaneous voltage on any portion of the Distribution or Transmission System to exceed the magnitudes per IEEE 1547-2018, 7.4.2.
 - 3. Technology Specific Requirements

Grid-interactive inverters do not require separate synchronizing equipment. Non grid-interactive or "stand-alone" inverters shall not be used for Parallel Operation with Distribution Provider's Distribution or Transmission System. (T)

(Continued)

Advice 7010-E
Decision

Issued by
Meredith Allen
Vice President, Regulatory Affairs

Submitted
Effective
Resolution

August 25, 2023
August 29, 2023
E-5000 and E-5036



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 204

- Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd.) (T)
4. Supplemental Smart Inverter Requirements
- a. Fault Detection
- A Smart Inverter with an SCCR exceeding 0.1 or one that does not cease to energize Distribution Provider’s Distribution or Transmission System within two seconds of the formation of an Unintended Island shall be equipped with Protective Functions designed to detect Distribution or Transmission System faults, both line-to-line and line-to-ground, and cease to energize Distribution Provider’s Distribution or Transmission System within two seconds of the initiation of a fault.
- b. Transfer Trip
- For a Generating Facility that cannot detect Distribution or Transmission System faults (both line-to-line and line-to-ground) or the formation of an Unintended Island, and cease to energize Distribution Provider’s Distribution or Transmission System within two seconds, Distribution Provider may require a Transfer Trip system or an equivalent Protective Function.
- c. Reclose Blocking
- Where the aggregate Generating Facility capacity exceeds 15% of the peak load on any automatic reclosing device, Distribution Provider may require additional Protective Functions, including, but not limited to reclose-blocking on some of the automatic reclosing devices. (T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS


Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd.)

(T)

5. Communication Requirements

Should communications to the Distribution Provider be required, Generating Facilities utilizing inverter-based technologies must adhere to the following communication requirements for communications between the Distribution Provider and the Generating Facility. The diagram below shows the interface requirements as applicable for section Hh.5. The Distribution Provider Interface (solid red line) is described in Sections Hh.5.a and Hh.5.b. The local DER interface at the Generating Facility (dotted blue line) is described in Section Hh.5.b.iii. The top row shows a direct connection between the Distribution Provider and the DER. The middle row shows a connection between the Distribution Provider and a gateway (GW) or Energy Management System (EMS). The lower row shows a connection between the Distribution Provider and an aggregator.

Figure Hh-5: Generating Facility Communications



(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 206

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd.)

(T)

5. Communication Requirements (Cont'd)

The communications requirements herein shall be between

- (i) the Distribution Provider and the individual DER, GW, or EMS;
- (ii) the Distribution Provider and communication to the Generating Facility through an aggregator not co-located or part of the Generating Facility; or
- (iii) other communication options as mutually agreed to by Applicant and Distribution Provider.

a. The communications requirements in this Section pertain to communications between the Distribution Provider and communications option selected, or required, from section Hh.5. This Rule does not specify the communication between the selected communication option and Smart Inverter but performance will be enforced by compliance with this Rule:

- i. Shall be capable of communications;
- ii. Software shall be updateable via communications remotely;
- iii. The transport level protocol shall be TCP/IP; and,
- iv. The default application-level protocol shall be IEEE 2030.5 as defined in the latest final version of the Common Smart Inverter Profile (CSIP), the Interconnection Handbook, Cyber Security Requirements or Programs and Contracts. Other application-level protocols may be used by mutual agreement of the parties including IEEE 1815/DNP3 for SCADA real-time monitoring and control and IEC 61850.

(T)

(Continued)



**ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS**

Sheet 207

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd.) (T)

5. Communication Requirements (Cont'd)

b. Additional communication protocol requirements shall also apply to Generating Facilities utilizing inverter-based technologies as provided in the following documents:

i. Distribution Provider Generation Interconnection Handbook, which shall include:

A. Details and guidelines for the implementation of communications with Generating Facilities utilizing inverter-based technologies;

B. Cybersecurity and privacy requirements (these may additionally or alternatively be included in the application-level protocol implementation guide (e.g., CSIP); and,

C. Generic device communications registration management requirements, including how to register individual Generating Facilities, Generating Facilities with energy management systems, and aggregators (these additionally or alternatively may be included in the application-level protocol implementation guide); and

D. Conditions under which communication functions are mandatory.

ii. Application-Level Protocol Implementation Guide, which shall provide:

A. Detailed communication requirements and implementation guidelines to ensure consistent interoperability of the Generating Facilities with all California investor-owned utilities under the Commission's jurisdiction.

(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 208

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd) (T)

5. Communication Requirements (Cont'd)

b. Additional communication protocol requirements shall also apply to Generating Facilities utilizing inverter-based technologies as provided in the following documents (Cont'd):

iii. Communication Protocol and Performance Requirements

A. Communication performance requirements for the interface to the Generating Facility shall comply with IEEE 1547-2018, 10.8.

B. The protocol requirements at the Generating Facility shall be per IEEE 1547-2018, 10.7.

a. If choosing IEEE 2030.5 as the protocol, then CSIP certification is required.

(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd.) (T)

6. Scheduling Capability Requirements

a. Generating Facilities which incorporate Smart Inverters shall incorporate scheduling capabilities with minimum scheduling memory capability of at least 24 events. The utilization of this function is permissible under mutual agreement between Distribution Provider and the generating facility before the effective date. Each event is composed of modifications to each, selected group of, or all of the following Smart Inverter function:

- i) Modifications to the voltage and reactive set-points of the Dynamic volt/var function.
- ii) Modifications to the reactive power set-points for the fixed power factor function.
- iii) Modifications to the voltage and watt-reduction level set-points for the volt/watt function.

b. The Generating Facility's scheduling capability requirement herein shall be met by one or more of the following options:

- i) Scheduling capability requirements may be implemented at the GW/EMS. The GW/EMS shall communicate the necessary commands to the Smart Inverters within 10 minutes, or by mutual agreement, from when the GW/EMS receives the scheduling information.
- ii) Scheduling capability requirements may be implemented at the DER within the Generating Facility.
- iii) Scheduling capability requirements may be stored at an aggregator not co-located within the Generating Facility. The aggregator shall communicate the necessary commands to the Smart Inverter within 15 minutes of the aggregator receiving the scheduling information.
- iv) Other options may be utilized by mutual agreement between the Applicant and Distribution Provider. (T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd.) (T)

6. Scheduling Capability Requirements (Cont'd)

- c. The selected scheduling control system shall store the schedules and shall send operational commands to the Smart Inverters as required by the schedule received from the Distribution Provider. The Smart Inverter shall respond by changing its mode of operation as commanded at the schedule start time with no unreasonable delay.
- d. Each scheduled mode of operation shall include and start-time and duration The Smart Inverter should return to its default settings at the end of the duration time or shall enter a new operational mode as directed by the scheduling control system.

7. Monitoring and Telemetry Requirements

- a. The Smart Inverter shall have the capability to communicate its performance information per IEEE 1547-2018, 10.5 Table 29, unless otherwise provided by PG&E, pursuant to its Distribution Generation Interconnection Handbook:
 - i) Smart Inverter production or consumption of active power (watts).
 - ii) Smart Inverter consumption or production of reactive power (vars)
 - iii) Phase measured at the AC terminals of the Smart Inverter (volts)
 - iv) Frequency measured at the AC terminals of the Smart Inverter (Hz)
 - v) Connection Status
 - vi) Alarm Status
- b. When the Generating Facility includes energy-storage with Smart Inverters, the following monitoring and telemetry capability is required:

The Smart Inverter shall be capable of communicating the operational state of charge as a percent of energy storage capacity.

(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 211

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd.) (T)

7. Monitoring and Telemetry Requirements (Cont'd)

c. Operational State as In-Service or not In-service communication capability requirements. The Smart Inverter shall be capable of communicating when the Smart Inverter is capable of providing electric services as follows:

i) In-Service

An operational state which indicates that the Smart Inverter is connected to the electric system and operating as determined locally by the Generating Facility operator or by a scheduling control system as outlined in section Hh.6.

ii) Not In-Service

An operating state which indicates that the Smart Inverter is not capable of connecting to the electric system and not capable of providing any type of electrical support as required locally or as commanded by a scheduling control system as outlined in section Hh.6.

d. Monitoring and performance information should be communicated in aggregate at the Generating Facility as follows:

i) When the Generating Facility includes only Smart Inverters, the production or consumption of active and reactive power shall be communicated as an aggregate of all Smart Inverters within the Generating Facility.

ii) When a Generating Facility includes Smart Inverters and other technologies such as synchronous or induction generation systems, the Generating Facility shall communicate the following:

a) The production or consumption of active and reactive power shall be communicated in aggregate of all Smart Inverters within the Generating Facility.

b) The production or consumption of active and reactive power shall be communicated in aggregate of all the other technologies within the Generating Facility. (T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 212

- Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd.) (T)
7. Monitoring and Telemetry Requirements (Cont'd)
- d. Monitoring and performance information should be communicated in aggregate at the Generating Facility as follows (Cont'd):
- iii) When the Generating Facility with Smart Inverters includes one or multiple energy storage systems. The available operational energy should be communicated as an aggregate of all the energy storage systems.
 - iv) Nameplate information shall be available through a local Generating Facility Interface as required in IEEE 1547-2018, 10.3 and must include the information as required in IEEE 1547-2018, Table 28.
 - v) Configuration information shall be available through a Local Generating Facility Interface as required in IEEE 1547-2018, 10.4. This information represents the present capacity and ability of the Generating Facility. When a configuration update changes the Generating Facility nameplate information, it may require a study depending on the change.
- (T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 213

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd.)

(T)

8. Control through communication capabilities

The utilization of these functions are permissible under mutual agreement between Distribution Provider and the generating facility before the effective date. Smart Inverters shall have the capabilities of accepting operational controls through communications in accordance to the following:

a. Disable permit to service control command

When the Smart Inverter receives a disable permit service command through communication, the Smart Inverter must cease-to energize and trip within 2 seconds or initiate the opening of the switch referenced in the inverter terminal in order to galvanically isolate the Smart Inverter from the Distribution System.

b. Return to service control command

When the Smart Inverter receives a return-to-service control command, the Smart Inverter may return to service operation as required by Generating Facility operator or as required by the scheduling control system as required by section H.6. This shall be accomplished by enabling permit service as required in IEEE 1547-2018, 4.10.3.

c. Limit Active Power command

When the Smart Inverter receives a command to limit its production of real power, the Smart Inverter shall reduce its real power production to the specified percent of real power capacity of the Smart Inverter or to a specified real power value. In no more than 30 seconds or in the time it takes for the primary energy source to reduce its active power output to achieve the requirements of the active power limit set point, whichever is greater.

Where the Smart Inverter operates under a non-export provision, the active power limit set point may be implemented as a maximum active power to serve the host customer load. Under mutual agreement, the Smart Inverter may be required to reduce active power below the level needed to support host customer load.

(T)

(Continued)



**ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS**

Sheet 214

Hh. SMART INVERTER GENERATING FACILITY DESIGN AND OPERATING REQUIREMENTS FOR UL1741SB INVERTERS (Cont'd)

(T)

8. Control through communication capabilities (Cont'd)

d. Set Active Power Level Mode Function

The capability for this requirement will become mandatory for Generating Facilities utilizing inverter-based technologies for which an Interconnection Request is submitted twelve (12) months after approval of a nationally recognized standard that includes the function. The utilization of this function is permissible under mutual agreement between Distribution Provider and the generating facility before the effective date.

e. Suspension of Active Power restriction

When the Smart Inverter receives a command to suspend the command for active power reduction, the Smart Inverter may return to normal operation as required by Generating Facility operator or as required by the scheduling control system as required by Section Hh.6.

f. Transition between operating modes

Transition between modes shall commence in no more than 30 seconds after the mode setting change is received at the local Generating Facility communication interface.

Changes of control functional modes shall be executed such that the Smart Inverter output is transitioned smoothly over a time period between 5 s and 300 s.

Ramping of Smart Inverter output is not required for control parameter setting changes.

For all control and protective function parameter settings, the time following the input to the local Generating Facility communication interface and preceding the point in time when the invoked action begins shall be no greater than 30 s.

(T)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 215

I. THIRD-PARTY INSTALLATIONS, RESERVATION OF UNUSED FACILITIES, AND REFUND OF SALVAGE VALUE (L)

1. INTERCONNECTION FACILITIES AND DISTRIBUTION UPGRADES

Except as provided for in the Generator Interconnection Agreement of this Rule, Interconnection Facilities connected to Distribution Provider's side of the PCC and Distribution Upgrades shall be provided, installed, owned, and maintained by Distribution Provider at Producer's expense.

2. THIRD-PARTY INSTALLATIONS

Producer may, at its option, employ a qualified contractor that meets the Contractor Qualifications set forth under Electric Rule 15, Section G, to provide and install Interconnection Facilities or Distribution Upgrades, to be owned and operated by Distribution Provider, on Distribution Provider's side of the PCC.* Such Interconnection Facilities and Distribution Upgrades shall be installed in accordance with Distribution Provider's design and specifications. Upon final inspection and acceptance by Distribution Provider, Producer shall transfer ownership of such Producer installed Interconnection Facilities or Distribution Upgrades to Distribution Provider and such facilities shall thereafter be owned and maintained by Distribution Provider at Producer's expense. Producer shall pay Distribution Provider's reasonable cost of design, administration, and monitoring of the installation for such facilities to ensure compliance with Distribution Provider's requirements. Producer shall also be responsible for all costs, including any income tax liability, associated with the transfer of Producer installed Interconnection Facilities and Distribution Upgrades to Distribution Provider.

* Only duly authorized employees of utility are allowed to connect to, disconnect from, or perform any work upon Utility's facilities.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 216

I. THIRD-PARTY INSTALLATIONS, RESERVATION OF UNUSED FACILITIES, AND REFUND OF SALVAGE VALUE (Cont'd.) (L)

3. RESERVATION OF UNUSED FACILITIES

When a Producer wishes to reserve Distribution Provider-owned Interconnection Facilities or Distribution Upgrades installed and operated as Added Facilities for Producer at Producer's expense, but idled by a change in the operation of Producer's Generating Facility or otherwise, Producer may elect to abandon or reserve such facilities consistent with the terms of its agreement with Distribution Provider. If Producer elects to reserve idle Interconnection Facilities or Distribution Upgrades, Distribution Provider shall be entitled to continue to charge Producer for the costs related to the ongoing operation and maintenance of the Added Facilities.

4. REFUND OF SALVAGE VALUE

When a Producer elects to abandon the Special Facilities or Added Facilities for which it has either advanced the installed costs or constructed and transferred to Distribution Provider, Producer shall, at a minimum, receive from Distribution Provider a credit for the net salvage value of the Added Facilities.

J. METERING, MONITORING AND TELEMETERING

1. GENERAL REQUIREMENTS

All Generating Facilities shall be metered in accordance with this Section J and shall meet all applicable standards of Distribution Provider contained in Distribution Provider's applicable tariffs and published Distribution Provider manuals dealing with Metering specifications.

2. METERING BY NON-DISTRIBUTION PROVIDER PARTIES

The ownership, installation, operation, reading, and testing of revenue Metering Equipment for Generating Facilities shall be by Distribution Provider except to the extent that the Commission authorizes any or all these services be performed by others.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 217

J. METERING, MONITORING AND TELEMETERING (Cont'd.) (L)

3. NET GENERATION OUTPUT METERING

Generating Facility customers may be required to install Net Generation Output Metering for evaluation, monitoring, and verification purposes and to determine applicable standby and non-bypassable charges as defined in Distribution Provider's tariffs, to satisfy applicable California Independent System Operator (CAISO) reliability requirements, and for Distribution System planning and operations.

However, Generating Facility customers do not need to install Net Generation Output Metering where less intrusive and/or more cost effective options, for Producer/Customer, are available for providing generator data to Distribution Provider. These Generating Facilities may opt to have Distribution Provider estimate load data in accordance with Distribution Provider's applicable tariffs to determine or meet applicable standby and non-bypassable and other applicable charges and tariff requirements. However, if a Generating Facility customer objects to Distribution Provider's estimate of the Generator(s) output, the customer may elect to install the Net Generation Output Metering, or have Distribution Provider install Net Generation Output Metering at the customer's expense.

(a) All metering options available to the customer must conform to the requirements set forth in Distribution Provider's Rule 22. If Distribution Provider does not receive meter data in accordance with Rule 22, Distribution Provider shall have the right to install Distribution Provider-owned Net Generation Output Metering at the customer's expense. The relevant factors in determining the need for Net Generation Output Metering are as listed below:

- i) Data requirements in proportion to need for information;
- ii) Producer's election to install equipment that adequately addresses Distribution Provider's operational requirements;

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 218

J. METERING, MONITORING AND TELEMETERING (Cont'd.) (L)

3. NET GENERATION OUTPUT METERING (Cont'd.)

- iii) Accuracy and type of required Metering consistent with purposes of collecting data;
- iv) Cost of Metering relative to the need for and accuracy of the data;
- v) The Generating Facility's size relative to the cost of the Metering/monitoring;
- vi) Other means of obtaining the data (e.g. Generating Facility logs, proxy data, etc.);
- vii) Requirements under any Generator Interconnection Agreement with Producer.

The requirements in this Section may not apply to Metering of Generating Facilities operating under Distribution Provider's Net Energy Metering tariffs. Nothing in this Section J.3 supersedes Section D.4, Compliance with Laws, Rules and Tariff Schedules.

Distribution Provider will report to the Commission or designated authority, on a quarterly basis, the rationale for requiring Net Generation Output Metering equipment in each instance along with the size and location of the facility.

The standard timeline for installation of Net Generation Output Meters is as follows:

- i) 20 business for design and 20 business days for construction, or
- ii) design and construction timelines as agree with the customer.

The 20-day clock commences upon payment and after the customer had done everything necessary on their end to prepare for construction. By mutual agreement, Applicant and Distribution Provider may agree to a timeline that is different from the timeline described above.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 219

J. METERING, MONITORING AND TELEMETERING (Cont'd.) (L)

4. POINT OF COMMON COUPLING (PCC) METERING

For purposes of assessing Distribution Provider's charges for retail service, Producer's PCC Metering shall be reviewed by Distribution Provider, and if required, replaced to ensure that it will appropriately measure electric power according to the provisions of the Customer's electric service Tariff. Where required, the Customer's existing meter may be replaced with a bi-directional meter so that power deliveries to and from Producer's site can be separately recorded. Alternately, Producer may, at its sole option and cost, require Distribution Provider to install multi-metering equipment to separately record power deliveries to Distribution Provider's Distribution System and retail purchases from Distribution Provider. Where necessary, such PCC Metering shall be designed to prevent reverse registration.

Generating Facilities participating in Net Energy Metering shall have metering provided pursuant to the terms of the applicable Net Energy Metering tariff schedule.

5. TELEMETERING

If the nameplate rating of the Generating Facility is 1 MW or greater, Telemetering equipment at the Net Generation Output Metering location may be required at Producer's expense. If the Generating Facility is Interconnected to a portion of Distribution Provider's Distribution System operating at a voltage below 10 kV, then Telemetering equipment may be required on Generating Facilities 250 kW or greater. Distribution Provider shall only require Telemetering to the extent that less intrusive and/or more cost effective options for providing the necessary data in real time are not available. Distribution Provider will report to the Commission or designated authority, on a quarterly basis, the rationale for requiring Telemetering equipment in each instance along with the size and location of the facility.

Customer-owned, behind-the-meter, telemetry equipment is allowed where practicable to mitigate the costs associated with Distribution Provider's ownership of the equipment (i.e., the Income Tax Component of Contribution and Cost of Ownership charges), per D.19-03-013 Ordering Paragraph 5. Distribution Provider will allow for a cap of thirty calendar days to repair or replace malfunctioning equipment as notified by the Distribution Provider and if the malfunctioning equipment is not repaired by the thirtieth day, the Distribution Provider can make the necessary repairs and charge the customer for related costs or can disconnect the distributed energy resource.

(L)
(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 220

- J. METERING, MONITORING AND TELEMETERING (Cont'd.) (L)
- 6. LOCATION

Where Distribution Provider-owned Metering is located on Producer's premises, Producer shall provide, at no expense to Distribution Provider, a suitable location for all such Metering Equipment.
- 7. COSTS OF METERING

Producer will bear all costs of the Metering required by this Rule, including the incremental costs of operating and maintaining the Metering Equipment.
- 8. MULTIPLE TARIFF METERING

The requirements of Section J.3 may not apply where a Generating Facility includes multiple generators eligible for service under more than one Net Energy Metering (NEM) tariff schedule (e.g. NEM-1, NEM-2, NEMBIO, NEMFC), or where a Generating Facility consists of one or more NEM-eligible generators in combination with one or more non-NEM eligible generators without Non-Export relays ("Reverse Power Protection"). To ensure proper tariff administration, metering will be required at the PCC and at each of the NEM eligible generator groups eligible for service under the same NEM tariff schedule. For combinations of multiple NEM eligible generators under different tariffs, billing administration and metering requirements will be as specified in the appropriate NEM tariff schedule.

Where a Generating Facility consists of one or more NEM eligible generator groups in combination with one or more non-NEM generators, metering of the non-NEM generators is not required, except as specified in Section J.3.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 221

K. DISPUTE RESOLUTION PROCESS

(L)

In addition to the informal procedures for timeline-related disputes set out in Section F.1.d, the following procedures will apply for disputes arising from this Rule:

1. SCOPE

The Commission shall have initial jurisdiction to interpret, add, delete or modify any provision of this Rule or of any agreements entered into between Distribution Provider and Applicant or Producer to implement this tariff ("Implementing Agreements") and to resolve disputes regarding Distribution Provider's performance of its obligations under Commission-jurisdictional tariffs, the applicable agreements, and requirements related to the interconnection of Applicant's or Producer's Generating Facility or Interconnection Facilities pursuant to this Rule.

2. INFORMAL DISPUTE RESOLUTION PROCEDURES

Any dispute arising between Distribution Provider and Producer (individually referred to in Section K as "Party" and collectively "the Parties") regarding Distribution Provider's or Producer's performance of its obligations under its tariffs, the Implementing Agreements, and requirements related to the interconnection of Producer's Facilities pursuant to this Rule shall be resolved according to the following procedures:

a. Informal Dispute Resolution

To initiate Informal Dispute Resolution, the aggrieved Party may submit a written notice ("notice") to the other party pursuant to either Section K.2.a.(i) (Bilateral Negotiations) or K.2.a.(ii) (Expedited Bilateral Negotiations).

This notice shall:

- specify whether the aggrieved Party is invoking the Informal Dispute Resolution procedures pursuant to either Section K.2.a.(i) (Bilateral Negotiations) or K.2.a.(ii) (Expedited Bilateral Negotiations);
- state the specific dispute and the relief sought; and
- contain all relevant known facts pertaining to the dispute.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 222

K. DISPUTE RESOLUTION PROCESS (Cont'd)

(L)

2. INFORMAL DISPUTE RESOLUTION PROCEDURES (Cont'd)

a. Informal Dispute Resolution (Cont'd)

The notice shall be sent to the Party's email address and physical address set forth in the Generator Interconnection Agreement or Interconnection Request, if there is no Generator Interconnection Agreement. A copy of the notice shall also be sent to the Energy Division, Office of the Director, at the Commission, and Rule21.Disputes@cpuc.ca.gov.

(i) Bilateral Negotiations

- 1) The receiving Party shall acknowledge the notice within five (5) Calendar Days of its receipt.
- 2) Each Party must designate a representative with the authority to make decisions for its respective Party to review the dispute within seven (7) Calendar Days of receiving Party's receipt of the notice.
- 3) The Distribution Provider shall provide the aggrieved Party with all relevant regulatory and/or technical details and analysis regarding any Distribution Provider interconnection requirements under dispute within twenty-one (21) Calendar Days of receiving Party's receipt of the notice.
- 4) Within forty-five (45) Calendar Days of the date of the notice, the Parties' authorized representatives will be required to meet and confer to try to resolve the dispute. Parties are expected to operate in good faith and use best efforts to resolve the dispute.
- 5) Parties may by mutual agreement extend any deadline identified in this section.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 223

K. DISPUTE RESOLUTION PROCESS (Cont'd)

(L)

2. INFORMAL DISPUTE RESOLUTION PROCEDURES (Cont'd)

a. Informal Dispute Resolution (Cont'd)

(ii) Expedited Bilateral Negotiations

- 1) The receiving Party shall acknowledge the notice within five (5) Calendar Days of its receipt.
- 2) Each party must designate a representative with the authority to make decisions for its respective Party to review the dispute within seven (7) Calendar Days of receiving Party's receipt of the notice.
- 3) Distribution Provider shall provide the aggrieved Party with all relevant regulatory and/or technical details and analysis regarding any Distribution Provider interconnection requirements under dispute within ten (10) Business Days of receiving Party's receipt of the notice.
- 4) Within fifteen (15) Business Days of the date of the notice, the Parties' authorized representatives will be required to meet and confer to try to resolve the dispute. Parties are expected to operate in good faith and use best efforts to resolve the dispute.
- 5) Parties may by mutual agreement extend any deadline identified in this section.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 224

K. DISPUTE RESOLUTION PROCESS (Cont'd.)

(L)

2. INFORMAL DISPUTE RESOLUTION PROCEDURES (Cont'd.)

- b. If a resolution of a dispute raised as part of section K.2.a is not reached in forty-five (45) Calendar Days from the date of the notice, either
 - 1) a Party may request to continue negotiations for an additional forty-five (45) Calendar Days; or
 - 2) the Parties may by mutual agreement make a written request for mediation to the ADR Coordinator in the Commission's ALJ Division.

The request may be submitted by electronic mail to adr_program@cpuc.ca.gov. Alternatively, both Parties by mutual agreement may request mediation from an outside third-party mediator with costs to be shared equally between the Parties.

- c. At any time, either Party may file a formal complaint before the Commission.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 225

K. DISPUTE RESOLUTION PROCESS (Cont'd.)

(L)

3. EXPEDITED INTERCONNECTION DISPUTE RESOLUTION PROCESS

The Expedited Interconnection Dispute Resolution process (“Expedited Process”) may be used to resolve eligible disputes between the Distribution Provider and an Applicant according to the following procedures.

For a complete description of all Expedited Process rules and requirements, please refer to Resolution ALJ-347, Exhibit A “Expedited Interconnection Dispute Resolution Process FINAL”. Information can also be found on the Commission’s website at <https://www.cpuc.ca.gov/industries-and-topics/electrical-energy/infrastructure/rule-21-interconnection/expedited-interconnection-dispute-resolution>. In the event of a conflict between the terms of this section and the terms of Resolution ALJ-347, the terms of Resolution ALJ-347 shall govern.

a. Eligibility

i) An Applicant may apply for Expedited Process at any stage of the interconnection process if it can demonstrate that:

- it has, in compliance with Section K.2 requirements, invoked the Section K.2.a Informal Dispute Resolution procedures and has been unable to resolve the dispute in accordance with Section K.2.aⁱⁱ;
- it has, in compliance with Section K.2 requirements, invoked the Section K.2.b Informal Dispute Resolution procedures and has been unable to resolve the dispute in accordance with Section K.2.bⁱⁱ;
- the subject matter of the dispute at issue concerns whether one or both parties’ actions are compliant with established interconnection rules and/or are reasonable, cost efficient and necessarily required under those rules to ensure safe and reliable interconnection.

ⁱⁱ The Commission’s Energy Division has the discretion to grant waivers to this eligibility requirement when the Applicant and Distribution Provider have already engaged in a dispute resolution process equivalent to Section K.2.a or K.2.b, including equivalent duration and with equivalent opportunity for both parties to understand the facts of the dispute and prepare responses. The Applicant or Distribution Provider must make a request to the Energy Division to waive the requirement.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 226

K. DISPUTE RESOLUTION PROCESS (Cont'd.)

3. EXPEDITED INTERCONNECTION DISPUTE RESOLUTION PROCESS (Cont'd)

(L)

a. Eligibility (Cont'd)

ii) The Energy Division has the authority to determine that a dispute is not eligible for this process in response to notice submitted in Section K.2.b.

b. Initiation of Expedited Process by Applicant

To request a resolution of a dispute pursuant to the Expedited Process, the Applicant shall download a PDF application form from the CPUC Expedited Interconnection Dispute Resolution Webpage (<https://www.cpuc.ca.gov/industries-and-topics/electrical-energy/infrastructure/rule-21-interconnection/expedited-interconnection-dispute-resolution>), complete the application, and email an electronic PDF application form to Rule21.disputes@cpuc.ca.gov.

i) The Applicant shall include the following in the PDF application form:

- all relevant known facts pertaining to the dispute;
- the specific dispute and the relief sought;
- express notice by the Applicant that it is requesting resolution using the Commission's Expedited Process;
- a description of all efforts to date to resolve the dispute directly with the Distribution Provider, including at minimum a showing that the Applicant meets the eligibility requirements described above; and
- names of all Interconnection Dispute Resolution Panel members who may have a conflict of interest as defined in Public Utilities Code Section 769.5(b)(1).

ii) The Applicant shall also attach to the PDF application form all materials that may aid in review of the dispute, including a copy of the Interconnection Request, any interconnection study performed for that Interconnection Request, and all correspondence between the Applicant and the Distribution Provider relevant to the dispute. For treatment of confidential materials, please refer to Resolution ALJ-347 and the relevant notes on pages 1 and 3 of the PDF application form.

(L)

(Continued)



**ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS**

Sheet 227

K. DISPUTE RESOLUTION PROCESS (Cont'd.) (236)

3. EXPEDITED INTERCONNECTION DISPUTE RESOLUTION PROCESS (Cont'd)

(L)

b. Initiation of Expedited Process by Applicant (Cont'd)

iii) The Applicant shall serve this written notice on:

- Energy Division (Rule21.Disputes@cpuc.ca.gov);
- the Distribution Provider's email address set forth in the Generator Interconnection Agreement or Interconnection Request, if there is no Generator Interconnection Agreement;
- the ombudsman designated by Distribution Provider; and
- any other interested persons. "Interested persons" for the purposes of this section are defined as the applicant, utility, a person who has submitted comments on the recommendation of the Review Sub- Panel, or a person who has a demonstrable interest in the outcome of the dispute and has written Energy Division requesting to be added to the distribution list for the dispute.

Please refer to Resolution ALJ-347 for more information and instructions for applying to the Commission for the Expedited Process.

c. Eligibility Verification

- i) The Energy Division will evaluate the submission of an Expedited Process written notice and notify the Applicant and the Distribution Provider of the dispute's eligibility within three (3) Business Days of receiving the request.
- ii) The Energy's Division's notice shall contain specific instructions regarding how the Expedited Process will be resolved. Please refer to Resolution ALJ-347 for more information.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 228

K. DISPUTE RESOLUTION PROCESS (Cont'd.)

3. EXPEDITED INTERCONNECTION DISPUTE RESOLUTION PROCESS (Cont'd.)

(L)

d. Distribution Provider Response

i) Upon receiving notice from the Energy Division of the dispute's eligibility for the Expedited Process, the Distribution Provider shall have five (5) Business Days to serve its response to the Sub-Panel (as defined in Resolution ALJ-347) assigned to the dispute, the Applicant, Energy Division and other interested persons in accordance with the procedures outlined in Resolution ALJ-347.

ii) The Distribution Provider's response shall include:

- the relevant known facts pertaining to the dispute, including the dispute's impact on safe and reliable grid operations;
- its position on the dispute as presented by the Applicant;
- a response to the relief requested by the Applicant; and
- a description of the efforts to date to resolve the dispute directly with the Applicant.

iii) The Distribution Provider shall also include in its response a copy of documentation in its possession that was not previously submitted in the Applicant's written notice that requested the Expedited Process that Distribution Provider believes may aid in review of the dispute, including the Applicant's Interconnection Request, any interconnection study performed for that Interconnection Request, and all correspondence between the Applicant and the Distribution Provider relevant to the dispute. For treatment of confidential materials, please refer to Resolution ALJ-347 and the relevant notes on pages 1 and 3 of the PDF application form.

The Distribution Provider shall serve this written notice on:

- Energy Division (Rule21.Disputes@cpuc.ca.gov);
- the Applicant's email address set forth in Applicant's written notice requesting the Expedited Process; and
- any other interested persons in accordance with the procedures outlined in Resolution ALJ-347.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 229

K. DISPUTE RESOLUTION PROCESS (Cont'd.)

3. EXPEDITED INTERCONNECTION DISPUTE RESOLUTION PROCESS (Cont'd)

(L)

e. Comments on Review Sub-Panel Recommendations

The Review Sub-panel will issue recommendations to the Executive Director of the Commission on how to resolve an Expedited Process's dispute.

Within five (5) Business Days of the issuance of the Review Sub-Panel's recommendations, Applicant, Distribution Provider, and any other interested persons may serve comments on those recommendations via Rule21.Disputes@cpuc.ca.gov.

The Applicant and Distribution Provider may serve a reply to any comments within three (3) Business Days of the last day for service of opening comments via Rule21.Disputes@cpuc.ca.gov.

Please refer to Resolution ALJ-347 and <https://www.cpuc.ca.gov/industries-and-topics/electrical-energy/infrastructure/rule-21-interconnection/expedited-interconnection-dispute-resolution> for more information regarding the service requirements.

f. Appealing the Executive Director's Order

Upon receipt of the Review Sub-Panel's recommendations, the Executive Director of the Commission will issue an order resolving the dispute within thirty (30) Calendar Days.

Within ten (10) Calendar Days of the issuance of the Executive Director's Order, the Applicant, Distribution Provider, or any interested person may appeal the Order and request Commission review. Such a request must set forth specifically the grounds on which the requester considers the Order to be unlawful or erroneous. Requests for review should be emailed to Rule21.Disputes@cpuc.ca.gov.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 230

K. DISPUTE RESOLUTION PROCESS (Cont'd.)

(L)

3. EXPEDITED INTERCONNECTION DISPUTE RESOLUTION PROCESS (Cont'd)

g. Withdrawal

At any time following Applicant's submission of a written notice under this Section, the Applicant may withdraw its notice. If the Applicant and Distribution Provider reach a settlement independent of the Commission, it is not necessary for the Commission to approve the settlement.

Notices of withdrawal should be sent to all interested parties and Rule21.Disputes@cpuc.ca.gov. Please refer to Resolution ALJ-347 for more information regarding the service requirements.

4. FORMAL COMPLAINT

At any time, either Party may file a formal complaint before the Commission pursuant to California PUC section 1702 and Article 4 of the Commission's Rules of Practice and Procedure.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 231

K. DISPUTE RESOLUTION PROCESS (Cont'd.)

5. PERFORMANCE DURING DISPUTE

Pending resolution of any dispute under this Section, the Parties shall proceed diligently with the performance of their respective obligations under this Rule and the Implementing Agreements, unless the Implementing Agreements have been terminated. Applicant and Distribution Provider may by mutual agreement suspend performance of their respective obligations under this Rule and any Implementing Agreements while the dispute is active.

Disputes as to the Interconnection Request and implementation of this Section shall be subject to resolution pursuant to the procedures set forth in this Section.

L. CERTIFICATION AND TESTING CRITERIA

1. INTRODUCTION

This Section describes the test procedures and requirements for equipment used for the Interconnection of Generating Facilities to Distribution Provider's Distribution or Transmission System. Included are Type Testing, Production Testing, Commissioning Testing, and Periodic Testing. The procedures listed rely heavily on those described in appropriate Underwriters Laboratory (UL), Institute of Electrical and Electronic Engineers (IEEE), and International Electrotechnical Commission (IEC) documents—most notably UL 1741(including UL 1741-Supplement A or B as appropriate).

(L)

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 232

L. CERTIFICATION AND TESTING CRITERIA (Cont'd.)

(L)

1. INTRODUCTION (Cont'd.)

The tests described here, together with the technical requirements in Section H, Hh, and P of this Rule, are intended to provide assurance that the Generating Facility's equipment will not adversely affect Distribution Provider's Distribution or Transmission System and that a Generating Facility will cease providing power to Distribution Provider's Distribution or Transmission System under abnormal conditions. The tests were developed assuming a low level of Generating Facility penetration or number of connections to Distribution Provider's Distribution or Transmission System. At high levels of Generating Facility penetration, additional requirements and corresponding test procedures may need to be defined.

Section L also provides criteria for "Certifying" Generators, inverters or converters. Once a Generator, inverter or converter has been Certified per this Rule, it may be considered suitable for Interconnection with Distribution Provider's Distribution or Transmission System. Subject to the exceptions described in Section L, Distribution Provider will not repeat the design review or require retesting of such Certified Equipment. It should be noted that the Certification process is intended to facilitate Generating Facilities Interconnections. Certification is not a prerequisite to interconnect a Generating Facility for Section H, except for Non-Export AC/DC Converters seeking an expedited process, but it is a prerequisite for inverters installed after September 8, 2017, pursuant to Section Hh and P of this Rule.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 233

- L. CERTIFICATION AND TESTING CRITERIA (Cont'd.) (L)
- 2. CERTIFIED AND NON-CERTIFIED INTERCONNECTION EQUIPMENT
- a. Certified Equipment
 - Equipment tested and approved (i.e. "Listed") by an accredited NRTL as having met both the Type Testing and Production Testing requirements described in this document is considered to be Certified Equipment for purposes of Interconnection with Distribution Provider's Distribution or Transmission System. Certification may apply to either a pre-packaged system or an assembly of components that address the necessary functions. Type Testing may be done in the manufacturer's factory or test laboratory, or in the field. At the discretion of the testing laboratory, field-certification may apply only to the particular installation tested. In such cases, some or all of the tests may need to be repeated at other installations.
 - When equipment is Certified by a NRTL, the NRTL shall provide to the manufacturer, at a minimum, a Certificate with the following information for each device:
 - Administrative:
 - (1) The effective date of Certification or applicable serial number (range or first in series), and/or other proof that certification is current;
 - (2) Equipment model number(s) of the Certified equipment;
 - (3) The software version utilized in the equipment, if applicable;
 - (4) Test procedures specified (including date or revision number); and
 - (5) Laboratory accreditation (by whom and to what standard). (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 234

- L. CERTIFICATION AND TESTING CRITERIA (Cont'd.) (L)
2. CERTIFIED AND NON-CERTIFIED INTERCONNECTION EQUIPMENT (Cont'd.)
- a. Certified Equipment (Cont'd.)
- Technical (as appropriate):
- (1) Device ratings (kW, kV, Volts, amps, etc.);
 - (2) Maximum available fault current in amps per IEEE 1547-2018, 11.4;
 - (3) In-rush Current in amps;
 - (4) Trip points, if factory set (trip value and timing);
 - (5) Trip point and timing ranges for adjustable settings;
 - (6) Nominal power factor or range if adjustable;
 - (7) If the equipment is Certified as Non-Exporting and the method used (reverse power or underpower);
 - (8) If the equipment is Certified as Non-Islanding; and
 - (9) If the equipment is Certified as a Non-Export AC/DC Converter.
- It is the responsibility of the equipment manufacturer to ensure that Certification information is made publicly available by the manufacturer, the testing laboratory, or by a third party.
- b. Non-Certified Equipment
- For non-Certified equipment, some or all of the tests described in this Rule may be required by Distribution Provider for each Generating and/or Interconnection Facility. The manufacturer or a laboratory acceptable to Distribution Provider may perform these tests. Test results for non-Certified equipment must be submitted to Distribution Provider for the Supplemental Review. Approval by Distribution Provider for equipment used in a particular Generating and/or Interconnection Facility does not guarantee Distribution Provider's approval for use in other Generating and/or Interconnection Facilities. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 235

L. CERTIFICATION AND TESTING CRITERIA (Cont'd.)

(L)

3. TYPE TESTING

a. Type Tests and Criteria for Interconnection Equipment Certification

Type testing provides a basis for determining that equipment meets the specifications for being designated as Certified equipment under this Rule. The requirements described in this Section cover only issues related to Interconnection and are not intended to address device safety or other issues.

Table L.1 defines the test criteria by Generator or inverter technology. While UL 1741(1) and UL 1741 – Supplement SA** were written specifically for inverters, the requirements are readily adaptable to synchronous Generators, induction Generators, as well as single/multi-function controllers and protection relays. Until a universal test standard is developed, Distribution Provider or NRTL shall adopt the procedures referenced in Table L.1 as appropriate and necessary for a Generating Facility and/or Interconnection Facilities or associated equipment performance and its control and Protection Functions. These tests shall be performed in the sequence shown in Table L.2.

Non-Export AC/DC Converters must satisfy the requirements in its definition in Section C.

** An exemption exists for DC V2G Electric Vehicle Service Equipment (EVSE) interconnecting for the purpose of participating in the Emergency Load Reduction Program, see footnote * in the opening paragraphs of Section Hh.

(L)

(Continued)



ELECTRIC RULE NO. 21 GENERATING FACILITY INTERCONNECTIONS

L. CERTIFICATION AND TESTING CRITERIA (Cont'd.)

3. TYPE TESTING (Cont'd.)

a. Type Tests and Criteria for Interconnection Equipment Certification (Cont'd.)

Table L.1, Type Test and Requirements for Interconnection Equipment Certification

Table with 7 columns: Type Test, Reference 1, Inverter (6), Smart Inverter (7), Smart Inverter 2022 (Note, 9,10), Synchronous Generators, Induction Generators. Includes various test types like Utility Interaction, DC Isolation, Dielectric Voltage Withstand, etc.

Table Notes:

- (1) References are to section numbers in either UL 1741 and/or UL 1741-Supplement SA (Inverters, Converters and Charge Controllers for Use in Independent Power Systems) or this Rule. References in UL 1741 to "photovoltaics" or "inverter" may have to be adapted to the other technologies by the testing laboratory to appropriately apply in the tests to other technologies.
(2) Required only if Non-Islanding designation.
(3) Required only if Non-Export designation is desired.
(4) Required for Generators that use Distribution Provider power to motor to speed.
(5) Required for all self-excited induction Generators as well as Inverters that operate as voltage sources when connected to Distribution Provider's Distribution or Transmission System.
(6) Inverters compliant with Section H.
(7) Inverters compliant with Sections H or P.
(8) IEEE 1547.1 refers to 2005 revision.
(9) Smart Inverter which have tested under UL1741SB and IEEE 1547.1-2020
(10) Effective August 1, 2022.

"X" = Required "-" = Not Required

(Continued)

Advice Decision 7010-E

Issued by Meredith Allen Vice President, Regulatory Affairs

Submitted Effective Resolution August 25, 2023 August 29, 2023 E-5000 and E-5036



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 237

L. CERTIFICATION AND TESTING CRITERIA (Cont'd.)

(L)

3. TYPE TESTING (Cont'd.)

a. Type Tests and Criteria for Interconnection Equipment Certification (Cont'd.)

Table L.2 Type Tests Sequence for Interconnection Equipment Certification

<u>Test No.</u>	<u>Type Test</u>
1	Distribution Provider Voltage and Frequency Variation
2	Synchronization
3	Surge Withstand Capability
4	Distribution Provider Voltage and Frequency Variation, including ride through
5	Synchronization
6	Other Required and Optional Tests

Tests 1, 2, and 3 must be done first and in the order shown. Tests 4 and on follow in order convenient to the test agency.

b. Anti-Islanding Test

Devices that pass the Anti-Islanding test procedure described in UL 1741 Supplemental SB will be considered Non-Islanding for the purposes of these Interconnection requirements. The test is required only for devices for which a Certified Non-Islanding designation is desired.

c. Non-Export Test

Equipment that passes the Non-Export test procedure described in Section L.7.a will be considered Non-Exporting for the purposes of these Interconnection requirements. This test is required only for devices for which a Certified Non-Export designation is desired.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 238

L. CERTIFICATION AND TESTING CRITERIA (Cont'd.)

3. TYPE TESTING (Cont'd.)

d. In-rush Current Test

Generation equipment that utilizes Distribution Provider power to motor up to speed will be tested using the procedure defined in Section L.7.b to determine the maximum current drawn during this startup process. The resulting In-rush Current is used to estimate the Starting Voltage Drop.

e. Surge Withstand Capability Test

The interconnection equipment shall be tested for the surge withstand requirement in Section H.1.c in all normal operating modes in accordance with IEEE Std C62.45-2002 for equipment rates less than 1000 V to confirm that the surge withstand capability is met by using the selected test level(s) from IEEE Std C62.41.2-2002.

Interconnection equipment rated greater than 1000 V shall be tested in accordance with manufacturer or system integrator designated applicable standards. For interconnection equipment signal and control circuits, use IEEE Std C37.90.1-2002. These tests shall confirm the equipment did not fail, did not misoperate, and did not provide misinformation (IEEE 1547-2018, 4.11.2).

The location/exposure category for which the equipment has been tested shall be clearly marked on the equipment label or in the equipment documentation. External surge protection may be used to protect the equipment in harsher location/exposure categories.

(L)

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 239

L. CERTIFICATION AND TESTING CRITERIA (Cont'd.) (L)

3. TYPE TESTING (Cont'd.)

f. Synchronization Test

This test is applied to synchronous Generators, self-excited induction generators, and inverters capable of operating as voltage-source while connected to Distribution Provider's Distribution or Transmission System. The test is also applied to the resynchronization Function (transition from stand-alone to parallel operation) on equipment that provides such functionality. This test may not need to be performed on both the synchronization and re-synchronization functions if the manufacturers can verify to the satisfaction of the testing organization that monitoring and controls hardware and software are common to both functions. This test is not necessary for induction generators or current-source inverters. Instead, the In-rush Current test Section L.3.d shall be applied to those generators.

This test shall demonstrate that at the moment of the paralleling-device closure, all three synchronization parameters in Table L.3 are within the stated limits. This test shall also demonstrate that if any of the parameters are outside of the limits stated in the table, the paralleling-device shall not close (IEEE 1547-2018, 4.10.4). The test will start with only one of the three parameters: (1) voltage difference between Generating Facility and Distribution Provider's Distribution or Transmission System; (2) frequency difference; or (3) phase angle outside of the synchronization specification. Verify that the Generating Facility is brought within specification prior to synchronization. Repeat the test five times for each of the three parameters. For manual synchronization with synch check or manual control with auto synchronization, the test must verify that paralleling does not occur until the parameters are brought within specifications. (L)

(Continued)



**ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS**

Sheet 240

L. CERTIFICATION AND TESTING CRITERIA (Cont'd.)

(L)

3. TYPE TESTING (Cont'd.)

f. Synchronization Test (Cont'd.)

Table L.3
Synchronization Parameter Limits [1]

Aggregate Rating of Generator Units (kVA)	Frequency Difference (Δf , Hz)	Voltage Difference (ΔV , %)	Phase Angle Difference ($\Delta \Phi$, °)
0-500	0.3	10	20
> 500-1,500	0.2	5	15
> 1,500-10,000	0.1	3	10

[1] – IEEE 1547-2018, 4.10.4

g. Paralleling Device Withstand Test

The di-electric voltage withstand test specified in Section L.1 shall be performed on the paralleling device to ensure compliance with those requirements specified in Section H.1.c (IEEE 1547-2018, 4.11.2).

h. Backfeed Test

Non-Export AC/DC Converters must satisfy the requirements in its definition in Section C.

4. PRODUCTION TESTING

At a minimum, each interconnection system shall be subjected to Distribution Provider Voltage and Frequency Variation Test procedure described in UL1741 under Manufacturing and Production Tests, Section 68 and the Synchronization test specified in Section L.3.f. Interconnection systems with adjustable set points shall be tested at a single set of set points as specified by the manufacturer. This test may be performed in the factory or as part of a Commissioning Test (Section L.5).

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 241

- L. CERTIFICATION AND TESTING CRITERIA (Cont'd.) (L)
- 5. COMMISSIONING TESTING
 - a. Commissioning Testing

Commissioning Testing, where required, will be performed on-site to verify protective settings and functionality. Upon initial Parallel Operation of a Generating Facility, or any time interface hardware or software is changed that may affect the functions listed below, a Commissioning Test must be performed. An individual qualified in testing protective equipment (professional engineer, factory-certified technician, or licensed electrician with experience in testing protective equipment) must perform Commissioning Testing in accordance with the manufacturer's recommended test procedure to verify the settings and requirements per this Rule.

Distribution Provider may require written Commissioning test procedure be submitted to Distribution Provider at least 10 working days prior to the performance of the Commissioning Test. Distribution Provider has the right to witness Commissioning Test. Distribution Provider may also require written certification by the installer describing which tests were performed and their results. Protective Functions to be tested during commissioning, particularly with respect to non-Certified equipment, may consist of the following:

 - (1) Over and under voltage
 - (2) Over and under frequency
 - (3) Anti-Islanding function (if applicable)
 - (4) Non-Exporting function (if applicable)
 - (5) Inability to energize dead line (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 242

- L. CERTIFICATION AND TESTING CRITERIA (Cont'd.) (L)
- 5. COMMISSIONING TESTING (Cont'd.)
 - a. Commissioning Testing (Cont'd.)
 - (6) Time delay on restart after Distribution Provider source is stable
 - (7) Distribution Provider system fault detection (if used)
 - (8) Synchronizing controls (if applicable)
 - (9) Other Interconnection Protective Functions that may be required as part of the Generator Interconnection Agreement

Commissioning Test shall include visual inspections of the interconnection equipment and protective settings to confirm compliance with the interconnection requirements.
 - b. Review, Study, and Additional Commissioning Test Verification Costs

A Producer shall be responsible for the reasonably incurred costs of the reviews, studies and additional Commissioning Test verifications conducted pursuant to Section E of this Rule. If the initial Commissioning Test verification is not successful through no fault of Distribution Provider, Distribution Provider may impose upon Producer a cost based charge for subsequent Commissioning Test verifications. All Costs for additional Commissioning Test verifications shall be paid by Producer within thirty days of receipt of Distribution Provider's invoice. The invoice provided by Distribution Provider shall consist of the hourly rate multiplied by the hours incurred by Distribution Provider and will separately specify the amount of time spent on-site from that spent in roundtrip travel to the Commissioning Test site. Additional cost, if any, will be specified on the invoice. If the initial Commissioning Test verification is not successful through the fault of Distribution Provider, that visit will not be considered the initial Commissioning Test verification.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 243

- L. CERTIFICATION AND TESTING CRITERIA (Cont'd.) (L)
- 5. COMMISSIONING TESTING (Cont'd.)
- c. Other Checks and Tests
 - Other checks and tests that may need to be performed include:
 - (1) Verifying final Protective Function settings
 - (2) Trip test (L.5.g)
 - (3) In-service tests (L.5.h)
- d. Certified Equipment
 - Generating Facilities qualifying for interconnection through the Fast Track process incorporate Certified Equipment that have, at a minimum, passed the Type Tests and Production Tests described in this Rule and are judged to have little or no potential impact on Distribution Provider's Distribution or Transmission System. For such Generating Facilities, it is necessary to perform only the following tests:
 - (1) Protective Function settings that have been changed after Production Testing will require field verification. Tests shall be performed using injected secondary frequencies, voltages and currents, applied waveforms, at a test connection using a Generator to simulate abnormal Distribution Provider voltage or frequency, or varying the set points to show that the device trips at the measured (actual) Distribution Provider voltage or frequency.
 - (2) The Non-Islanding function shall be checked by operating a load break disconnect switch to verify the Interconnection equipment ceases to energize Distribution Provider's Distribution or Transmission System and does not re-energize it for the required time delay after the switch is closed. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 244

- L. CERTIFICATION AND TESTING CRITERIA (Cont'd.) (L)
- 5. COMMISSIONING TESTING (Cont'd.)
- d. Certified Equipment (Cont'd.)
 - (3) The Non-Exporting function shall be checked using secondary injection techniques. This function may also be tested by adjusting the Generating Facility output and local loads to verify that the applicable Non-Exporting criteria (i.e., reverse power or underpower) are met.
 - The Supplemental Review or an Interconnection Study may impose additional components or additional testing.
- e. Non-Certified Equipment

Non-certified Equipment shall be subjected to the appropriate tests described in Type Testing (Section L.3) as well as those described in Certified Equipment Commissioning Tests (Section L.5.d). With Distribution Provider's approval, these tests may be performed in the factory, in the field as part of commissioning, or a combination of both. Distribution Provider, at its discretion, may also approve a reduced set of tests for a particular Generating Facility or, for example, if it determines it has sufficient experience with the equipment.
- f. Verification of Settings

At the completion of Commission testing, Producer shall confirm all devices are set to Distribution Provider-approved settings. Verification shall be documented in the Commissioning Test Certification. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 245

L. CERTIFICATION AND TESTING CRITERIA (Cont'd.) (L)

5. COMMISSIONING TESTING (Cont'd.)

g. Trip Tests

Interconnection Protective Functions and devices (e.g. reverse power relays) that have not previously been tested as part of the Interconnection Facilities with their associated interrupting devices (e.g. contactor or circuit breaker) shall be trip tested during commissioning. The trip test shall be adequate to prove that the associated interrupting devices open when the protective devices operate. Interlocking circuits between Protective Function devices or between interrupting devices shall be similarly tested unless they are part of a system that has been tested and approved during manufacturing.

h. In-service Tests

Interconnection Protective Functions and devices that have not previously been tested as part of the Interconnection Facilities with their associated instrument transformers or that are wired in the field shall be given an in-service test during commissioning. This test will verify proper wiring, polarity, CT/PT ratios, and proper operation of the measuring circuits. The in-service test shall be made with the power system energized and carrying a known level of current. A measurement shall be made of the magnitude and phase angle of each Alternating Current (AC) voltage and current connected to the protective device and the results compared to expected values. For protective devices with built-in Metering Functions that report current and voltage magnitudes and phase angles, or magnitudes of current, voltage, and real and reactive power, the metered values may be used for in-service testing. Otherwise, portable ammeters, voltmeters, and phase-angle meters shall be used.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 246

L. CERTIFICATION AND TESTING CRITERIA (Cont'd.) (L)

6. PERIODIC TESTING

Periodic Testing of Interconnection-related Protective Functions shall be performed as specified by the manufacturer, or at least every four years. All Periodic Tests prescribed by the manufacturer shall be performed. Producer shall maintain Periodic Test reports or a log for inspection by Distribution Provider. Periodic Testing conforming to Distribution Provider test intervals for the particular Line Section may be specified by Distribution Provider under special circumstances, such as high fire hazard areas. Batteries used to activate any Protective Function shall be checked and logged once per month for proper voltage. Once every four years, the battery must be either replaced or a discharge test performed.

7. TYPE TESTING PROCEDURES NOT DEFINED IN OTHER STANDARDS

This Section describes the additional Type Tests necessary to qualify a device as Certified under this Rule. These Type Tests are not contained in Underwriters Laboratories UL 1741 Standard *Inverters, Converters and Controllers for Use in Independent Power Systems*, or other referenced standards.

a. Non-Exporting Test Procedures

The Non-Exporting test is intended to verify the operation of relays, controllers and inverters designed to limit the export of power and certify the equipment as meeting the requirements of Screen I, Options 1 and 2, of the review process. Tests are provided for discrete relay packages and for controllers and inverters with the intended Functions integrated.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 247

- L. CERTIFICATION AND TESTING CRITERIA (Cont'd.) (L)
- 7. TYPE TESTING PROCEDURES NOT DEFINED IN OTHER STANDARDS (Cont'd.)
- a. Non-Exporting Test Procedures (Cont'd.)
- i) Discrete Reverse Power Relay Test

This version of the Non-Exporting test procedure is intended for discrete reverse power and underpower relay packages provided to meet the requirements of Options 1 and 2 of Screen I. It should be understood that in the reverse power application, the relay will provide a trip output with power flowing in the export (toward Distribution Provider's Distribution or Transmission System) direction.

Step 1: Power Flow Test at Minimum, Midpoint and Maximum Pickup Level Settings

Determine the corresponding secondary pickup current for the desired export power flow of 0.5 secondary watts (the minimum pickup setting, assumes 5 amp and 120V CT/PT secondary). Apply nominal voltage with minimum current setting at zero (0) degrees phase angle in the trip direction. Increase the current to pickup level. Observe the relay's (LCD or computer display) indication of power values. Note the indicated power level at which the relay trips. The power indication should be within 2% of the expected power. For relays with adjustable settings, repeat this test at the midpoint, and maximum settings. Repeat at phase angles of 90, 180 and 270 degrees and verify that the relay does not operate (measured watts will be zero or negative). (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 248

- L. CERTIFICATION AND TESTING CRITERIA (Cont'd.) (L)
- 7. TYPE TESTING PROCEDURES NOT DEFINED IN OTHER STANDARDS (Cont'd.)
- a. Non-Exporting Test Procedures (Cont'd.)
 - i) Discrete Reverse Power Relay Test (Cont'd.)
 - Step 2: Leading Power Factor Test

Apply rated voltage with a minimum pickup current setting (calculated value for system application) and apply a leading power factor load current in the non-trip direction (current lagging voltage by 135 degrees). Increase the current to relay rated current and verify that the relay does not operate. For relays with adjustable settings, this test should be repeated at the minimum, midpoint, and maximum settings.
 - Step 3: Minimum Power Factor Test

At nominal voltage and with the minimum pickup (or ranges) determined in Step 1, adjust the current phase angle to 84 or 276 degrees. Increase the current level to pickup (about 10 times higher than at 0 degrees) and verify that the relay operates. Repeat for phase angles of 90, 180 and 270 degrees and verify that the relay does not operate.
 - Step 4: Negative Sequence Voltage Test

Using the pickup settings determined in Step 1, apply rated relay voltage and current at 180 degrees from tripping direction, to simulate normal load conditions (for three-phase relays, use Ia at 180, Ib at 60 and Ic at 300 degrees). Remove phase-1 voltage and observe that the relay does not operate. Repeat for phases-2 and 3.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 249

- L. CERTIFICATION AND TESTING CRITERIA (Cont'd.) (L)
- 7. TYPE TESTING PROCEDURES NOT DEFINED IN OTHER STANDARDS (Cont'd.)
- a. Non-Exporting Test Procedures (Cont'd.)
 - i) Discrete Reverse Power Relay Test (Cont'd.)
 - Step 5: Load Current Test

Using the pickup settings determined in Step 1, apply rated voltage and current at 180 degrees from the tripping direction, to simulate normal load conditions (use Ia at 180, Ib at 300 and Ic at 60 degrees). Observe that the relay does not operate.
 - Step 6: Unbalanced Fault Test

Using the pickup settings determined in Step 1, apply rated voltage and 2 times rated current, to simulate an unbalanced fault in the non-trip direction (use Va at 0 degrees, Vb and Vc at 180 degrees, Ia at 180 degrees, Ib at 0 degrees, and Ic at 180 degrees). Observe that the relay, especially single phase, does operate properly.
 - Step 7: Time Delay Settings Test

Apply Step 1 settings and set time delay to minimum setting. Adjust the current source to the appropriate level to determine operating time, and compare against calculated values. Verify that the timer stops when the relay trips. Repeat at midpoint and maximum delay settings.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 250

- L. CERTIFICATION AND TESTING CRITERIA (Cont'd.) (L)
- 7. TYPE TESTING PROCEDURES NOT DEFINED IN OTHER STANDARDS (Cont'd.)
- a. Non-Exporting Test Procedures (Cont'd.)
 - i) Discrete Reverse Power Relay Test (Cont'd.)
 - Step 8: Dielectric Test
 - Perform the test described in IEC 414 using 2 kV RMS for 1 minute.
 - Step 9: Surge Withstand Test
 - Perform the surge withstand test described in IEEE C37.90.1.1989 or the surge withstand capability test described in L.3.e.
 - ii) Discrete Underpower Relay Test
 - This version of the Non-Exporting test procedure is intended for discrete underpower relay packages and meets the requirements of Option 2 of Screen I. A trip output will be provided when import power (toward Producer's load) drops below the specified level.
 - Note: For an underpower relay, pickup is defined as the highest power level at which the relay indicates that the power is less than the set level. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 251

- L. CERTIFICATION AND TESTING CRITERIA (Cont'd.) (L)
 - 7. TYPE TESTING PROCEDURES NOT DEFINED IN OTHER STANDARDS (Cont'd.)
 - a. Non-Exporting Test Procedures (Cont'd.)
 - ii) Discrete Underpower Relay Test (Cont'd.)
- Step 1: Power Flow Test at Minimum, Midpoint and Maximum Pickup Level Settings
- Determine the corresponding secondary pickup current for the desired power flow pickup level of 5% of peak load minimum pickup setting. Apply rated voltage and current at 0 (zero) degrees phase angle in the direction of normal load current.
- Decrease the current to pickup level. Observe the relay's (LCD or computer display) indication of power values. Note the indicated power level at which the relay trips. The power indication should be within 2% of the expected power. For relays with adjustable settings, repeat the test at the midpoint, and maximum settings. Repeat at phase angles of 90, 180 and 270 degrees and verify that the relay operates (measured watts will be zero or negative).
- Step 2: Leading Power Factor Test
- Using the pickup current setting determined in Step 1, apply rated voltage and rated leading power factor load current in the normal load direction (current leading voltage by 45 degrees). Decrease the current to 145% of the pickup level determined in Step 1 and verify that the relay does not operate. For relays with adjustable settings, repeat the test at the minimum, midpoint, and maximum settings. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 252

- L. CERTIFICATION AND TESTING CRITERIA (Cont'd.) (L)
- 7. TYPE TESTING PROCEDURES NOT DEFINED IN OTHER STANDARDS (Cont'd.)
- a. Non-Exporting Test Procedures (Cont'd.)
- ii) Discrete Underpower Relay Test (Cont'd.)
- Step 3: Minimum Power Factor Test
- At nominal voltage and with the minimum pickup (or ranges) determined in Step 1, adjust the current phase angle to 84 or 276 degrees. Decrease the current level to pickup (about 10% of the value at 0 degrees) and verify that the relay operates. Repeat for phase angles 90, 180 and 270 degrees and verify that the relay operates for any current less than rated current.
- Step 4: Negative Sequence Voltage Test
- Using the pickup settings determined in Step 1, apply rated relay voltage and 25% of rated current in the normal load direction, to simulate light load conditions. Remove phase 1 voltage and observe that the relay does not operate. Repeat for Phases-2 and 3.
- Step 5: Unbalanced Fault Test
- Using the pickup settings determined in Step 1, apply rated voltage and two times rated current, to simulate an unbalanced fault in the normal load direction (use Va at 0 degrees, Vb and Vc at 180 degrees, Ia at 0 degrees, Ib at 180 degrees, and Ic at 0 degrees). Observe that the relay (especially single-phase types) operates properly. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 253

- L. CERTIFICATION AND TESTING CRITERIA (Cont'd.) (L)
- 7. TYPE TESTING PROCEDURES NOT DEFINED IN OTHER STANDARDS (Cont'd.)
- a. Non-Exporting Test Procedures (Cont'd.)
- ii) Discrete Underpower Relay Test (Cont'd.)
- Step 6: Time Delay Settings Test
- Apply Step 1 settings and set time delay to minimum setting. Adjust the current source to the appropriate level to determine operating time, and compare against calculated values. Verify that the timer stops when the relay trips. Repeat at midpoint and maximum delay settings.
- Step 7: Dielectric Test
- Perform the test described in IEC 414 using 2 kV RMS for 1 minute.
- Step 8: Surge Withstand Test
- Perform the surge withstand test described in IEEE C37.90.1.1989 or the surge withstand test described in Section L.3.e. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 254

L. CERTIFICATION AND TESTING CRITERIA (Cont'd.) (L)

7. TYPE TESTING PROCEDURES NOT DEFINED IN OTHER STANDARDS (Cont'd.)

a. Non-Exporting Test Procedures (Cont'd.)

iii) Tests for Inverters and Controllers with Integrated Functions

Inverters and controllers designed to provide reverse or underpower functions shall be tested to certify the intended operation of this function. Two methods are acceptable:

Method 1: If the inverter or controller utilizes external current/voltage measurement to determine the reverse or underpower condition, then the inverter or controller shall be functionally tested by application of appropriate secondary currents and potentials as described in the Discrete Reverse Power Relay Test, Section L.7.a.i of this Rule.

Method 2: If external secondary current or voltage signals are not used, then unit-specific tests must be conducted to verify that power cannot be exported across the PCC for a period exceeding two seconds. These may be factory tests, if the measurement and control points are integral to the unit, or they may be performed in the field.

iv) Tests for Inadvertent Export Inverters

Test requirements for certified inverters with integrated functions for Inadvertent Export shall verify the performance requirements specified in Section Mm of this Rule.

(L)

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 255

- L. CERTIFICATION AND TESTING CRITERIA (Cont'd.) (L)
- 7. TYPE TESTING PROCEDURES NOT DEFINED IN OTHER STANDARDS (Cont'd.)
- a. Non-Exporting Test Procedures (Cont'd.)
 - v) Interim Tests for Non-Export AC/DC Converters (“Converter”)
 - Step 1: Limitation of Back-feed Under Steady State Conditions

Apply the nominal DC operating voltage of the Converter across its DC terminals with a battery source or simulated equivalent of a battery source. Vary the battery source by 100%, 75%, 50%, 25%, and 10% of Converter rated output power. The measured steady-state DC current component at each of the AC terminals of the Converter is required to be less than 0.5% of the Converter’s rated RMS AC current. This test is to be repeated for 80% nominal DC operating voltage and for 125% nominal DC operating voltage. Testing requirements can be modified upon mutual agreement of the Distribution Provider and the Applicant.
 - Step 2: Back-feed Under Fault Conditions – DC Output Shorted

With a battery source or simulated equivalent of a battery source connected to the DC terminals, apply rated conditions of the Converter then short its DC terminals for 200 milliseconds. After 5 cycles of inducing the short circuit, record the measured peak current at each of the AC terminals of the Converter. These peak currents within this time interval are each required to be less than 0.5% of the Converter’s rated RMS AC current. Testing requirements can be modified upon mutual agreement of the Distribution Provider and the Applicant.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 256

- L. CERTIFICATION AND TESTING CRITERIA (Cont'd.) (L)
- 7. TYPE TESTING PROCEDURES NOT DEFINED IN OTHER STANDARDS (Cont'd.)
 - a. Non-Exporting Test Procedures (Cont'd.)
 - v) Interim Tests for Non-Export AC/DC Converters (“Converter”) (Cont'd.)

Step 3: Back-feed Under Fault Conditions – AC Input Shorted: Phase-Ground, Phase-Phase, and 3-Phase

With a battery source or simulated equivalent of a battery source connected to the DC terminals, apply rated conditions of the Converter, then apply a short between any two phases on the grid side of the Converter for 200 milliseconds. After 5 cycles of inducing the short circuit, record the measured peak current at each of the AC terminals of the Converter. These peak currents within this time interval are each required to be less than 0.5% of the Converter’s rated RMS AC current. This test is to be repeated for phase-ground and 3-phase shorts. Testing requirements can be modified upon mutual agreement of the Distribution Provider and the Applicant.

Step 4: Back-feed Under Fault Conditions – Component Faults

Distribution Provider can elect to test for back-feed under the condition of a short circuit across certain components which are internal to the Converter. Potential tests can include inducing a short circuit across different terminals for electronic switches and/or across different terminals for internal transformers. Ultimately, the components used for testing will be chosen on a case-by-case basis and will depend on the Converter’s circuit topology. Testing requirements can be modified upon mutual agreement of the Distribution Provider and the Applicant.

Step 5: Harmonics Testing

Under normal loading conditions at 10%, 25%, 50%, 75%, and 100% of the Converter’s rated power output, conduct harmonic current distortion measurements on each of the AC terminals. Measurements should be below the maximum harmonic current distortion requirements given in IEEE 1547-4.3.3.

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 257

- L. CERTIFICATION AND TESTING CRITERIA (Cont'd.) (L)
- 7. TYPE TESTING PROCEDURES NOT DEFINED IN OTHER STANDARDS (Cont'd.)
- b. In-rush Current Test Procedures
 - This test will determine the maximum In-rush Current drawn by the Generator.
 - i) Locked-Rotor Method
 - Use the test procedure defined in NEMA MG-1 (manufacturer's data is acceptable if available).
 - ii) Start-up Method
 - Install and setup the Generating Facility equipment as specified by the manufacturer. Using a calibrated oscilloscope or data acquisition equipment with appropriate speed and accuracy, measure the current draw at the Point of Interconnection as the Generating Facility starts up and parallels with Distribution Provider's Distribution or Transmission System. Startup shall follow the normal, manufacturer-specified procedure. Sufficient time and current resolution and accuracy shall be used to capture the maximum current draw within 5%. In-rush Current is defined as the maximum current draw from Distribution Provider during the startup process, using a 10-cycle moving average. During the test, Distribution Provider source, real or simulated, must be capable of maintaining voltage within +/- 5% of rated at the connection to the unit under test. Repeat this test five times. Report the highest 10-cycle current as the In-rush Current. A graphical representation of the time-current characteristic along with the certified In-rush Current must be included in the test report and made available to Distribution Provider. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 258

M. INADVERTENT EXPORT

(L)

Under certain operating conditions, an Applicant may choose to completely offset their facility load by installing generation systems which are optimally sized to meet their peak demand with load following functionality on the Generator controls to ensure conditional export of electrical power from the Generating Facility to Distribution Provider's Distribution or Transmission System. In situations where the loading changes rapidly and/or the Generator cannot ramp down quickly enough, the Generating Facility may need to export small amounts of power for limited duration. The event of exporting uncompensated power for a short time is referred to as Inadvertent Export.

The following are the minimum requirements for Inadvertent Export systems. Other factors relevant to the interconnection study process (e.g. 15% screen results, short circuit current ratio, etc.) may necessitate additional technical requirements (e.g. reclose block, transfer trip, ground bank, etc.) that are not explicitly noted here. Inadvertent Export may not be available for interconnections to Networked Secondary Systems.

1. For Inadvertent Export interconnection requests, additional Protective Functions and equipment to detect Distribution or Transmission System faults (per Distribution Provider's standard practices) may be required over and above the basic Protective Functions and equipment associated with the four options in the Export Screen. Protective Functions may include, but are not limited to, directional overcurrent/voltage-restraint overcurrent Protective Functions for line-to-line fault detection and overcurrent/overvoltage Protective Functions for line-to-ground detection. The addition of a ground bank or ground detector may also be necessary.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 259

- M. INADVERTENT EXPORT (Cont'd.) (L)
2. The effect on equipment ratings can be mitigated by limiting the amount of inadvertent export allowed. To a large degree, Voltage Regulation may be similarly handled. The amount of Inadvertent Export is dependent on specific Distribution Provider requirements and should be limited to the lesser of the following values:
 - a. 50% of the Generating Facility Capacity, or
 - b. 10% of the continuous conductor rating in watts at 0.9 power factor for the lowest rated feeder conductor upstream of the GF (i.e. 200kW @ 12kV), or
 - c. 110% of the largest load block in the facility, or
 - d. 500kW or some other maximum level indicated by Distribution Provider
 3. In addition to the limits above, the following are required:
 - a. A reverse power Protective Function will be provided to trip the connected Generator(s) within two seconds if the proposed amount of Inadvertent Export is exceeded.
 - b. The frequency of Inadvertent Export occurrences should be less than two occurrences per 24-hour period.
 - c. A separate reverse power or underpower Protective Function will be required (in addition to the reverse power Protective Function described in 3a. above) to trip the connected Generator(s) if the duration of reverse power or underpower (i.e. ANY export) exceeds 60 seconds. (L)

(Continued)

Advice 7010-E
Decision

Issued by
Meredith Allen
Vice President, Regulatory Affairs

Submitted August 25, 2023
Effective August 29, 2023
Resolution E-5000 and E-5036



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 260

Mm. INADVERTENT EXPORT FOR INTERCONNECTION REQUESTS UTILIZING UL-1741 CERTIFIED OR SA/SB LISTED GRID SUPPORT (NON-ISLANDING) INVERTERS

(L)

The following are the minimum requirements for Inadvertent Export systems that meet the criteria specified below. Other factors relevant to the interconnection study process (e.g., 15% screen results, short circuit current ratio, etc.) may necessitate additional technical requirements (e.g., reclose block, transfer trip, ground bank, etc.) that are not explicitly noted here. Inadvertent Export may not be available for interconnections to Networked Secondary Systems.

The certified control functions internal to the inverter control or external control system may be used to replace the discrete reverse/under power relay functions described in Section M provided the requirements outlined below are met.

- 1) All of the following requirements must be met by the Generating Facility to qualify for Inadvertent Export under this Section.
 - a. The Generating Facility must utilize only UL-1741 certified or UL-1741 SB-listed grid support non-islanding inverters; and,
 - b. The Generating Facility must have an aggregate maximum nameplate capacity of 500 kVA or less; and,
 - c. The Generating Facility's total energy export must not exceed its nameplate rating (kVA-gross) multiplied by 0.1 hours per day over a rolling 30-day period (e.g., for a 100 kVA-gross nameplate Generating Facility, the maximum energy allowed to be exported for a 30-day period is 300 kWh) ; and,
 - d. Export from the Generating Facility across the PCC to the Distribution System is less than 100 kVA.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 261

Mm. INADVERTENT EXPORT FOR INTERCONNECTION REQUESTS UTILIZING UL-1741 CERTIFIED OR SA LISTED GRID SUPPORT (NON-ISLANDING) INVERTERS (Cont'd.) (L)

- 2) To govern the level of Inadvertent Export allowable under this Section, the Generating Facility must utilize a NRTL-certified control system or NRTL-certified inverter system that meets all of the following requirements.
 - a. Must result in the Generating Facility disconnecting from the Distribution System, ceasing to energize the Distribution System or halting energy production within two (2) seconds after either:
 - i. The period of continuous export exceeds 30 seconds;
 - or,
 - ii. The level of export exceeds 100 kVA.
 - b. Must monitor that the total energy export is maintained within the allowable energy export outlined above 1.c and provide an indication or notification (e.g., electronic, alarm) if that energy export limit is exceeded.
 - c. Failure of the of the control or inverter system for more than thirty (30) seconds, resulting from loss of control signal, loss of control power or a single component failure or related control sensing of the control circuitry, must result in the Generating Facility entering Non-Export operation where no energy is exported across to the PCC to the Distribution System.

Interim approval of the control or inverter system may be permitted upon mutual agreement of PG&E and the Producer. (L)

(Continued)

<i>Advice Decision</i>	7010-E	<i>Issued by</i> Meredith Allen <i>Vice President, Regulatory Affairs</i>	<i>Submitted Effective Resolution</i>	<u>August 25, 2023</u> <u>August 29, 2023</u> <u>E-5000 and E-5036</u>
------------------------	--------	--	---------------------------------------	--



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 262

Mm. INADVERTENT EXPORT FOR INTERCONNECTION REQUESTS UTILIZING UL-1741 CERTIFIED OR SA LISTED GRID SUPPORT (NON-ISLANDING) INVERTERS (Cont'd.) (L)

3) Applicability of Engineering Review Screens.

Inadvertent Export systems that meet the requirements described herein are processed under Initial Review Screens A through J as described in Section H. If these systems fail Screen J, they then bypass Screens K and L and are processed under Screens M and M1 as described below.

Screen M: Is the aggregate Generating Facility capacity on the Line Section less than 15% of Line Section peak load for all line sections bound by automatic sectionalizing devices?

- If Yes (pass), Initial Review is complete.
- If No (fail), continue to Screen M1.

Screen M1: Is the aggregate of all distributed energy resources (DER) causing reverse power flow (1) at a line section with a voltage regulator device(s) or (2) at a protection device, including the circuit breaker / field recloser?*,**

- If No (pass), existing DER does not cause reverse power flow at (1) or (2) and Initial Review is complete.
- If Yes (fail), existing DER causes reverse power flow at (1) or (2); fail Initial Review and Supplemental Review is required.

* For the purposes of applying Screen M1 herein, Distribution Provider shall utilize a zero coincidence factor when considering the impact of other Inadvertent Export systems that meet the requirements of Section Mm (i.e., projects that qualify for Option 6 under Section G.1.i) such that those Inadvertent Export systems do not impact Screen M1's aggregate analysis determination for the individual Inadvertent Export project being evaluated.

** The presence of existing non-certified DER on the line section may require additional review to ensure safe and reliable grid operation.

(Continued)




ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Mm. INADVERTENT EXPORT FOR INTERCONNECTION REQUESTS UTILIZING UL-1741 CERTIFIED OR SA LISTED GRID SUPPORT (NON-ISLANDING) INVERTERS (Cont'd.)

(L)

3) Applicability of Engineering Review Screens. (Cont'd.)



* For the purposes of applying Screen M1 herein, Distribution Provider shall utilize a zero coincidence factor when considering the impact of other Inadvertent Export systems that meet with the requirements of Section Mm (i.e., projects that qualify for Option 6 under Section G.1.i) such that those Inadvertent Export systems do not impact Screen M1's aggregate analysis determination for the individual analysis determination for the individual Inadvertent Export project being evaluated.

** The presence of existing non-certified DER on the line section may require additional review to ensure safe and reliable grid operation.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 264

Mm1. OPTION 8: Non-Export Utilizing Certified Power Control Systems

(L)

The following are the minimum requirements for Non-Export systems that use certified power control systems (PCS) with an open loop response time (OLRT) no more than two seconds. It should be noted that other factors relevant to the Interconnection Study process may necessitate additional technical requirements that are not explicitly noted here.

1. Use a PCS that passes the requirements of the 2019 Underwriters Laboratories (UL) Power Control Systems Certification Requirements Decision (CRD) test protocol. Non-Export systems may use a PCS that passes later published revisions to the CRD test protocol or may use a PCS that is certified to the UL 1741 certification standard, if UL incorporates the test protocol for PCS into UL 1741 in the future. The NRTL evaluation must have determined that the PCS conforms to the non-exporting functionality in accordance with the relevant CRD or UL published standard.
2. Use a PCS that is certified with an OLRT of two seconds or less, as provided in the PCS's specification data sheets.
3. The PCS must reduce export to zero or less within two seconds of commencing export. A PCS that is certified with an open-loop response time of two seconds or less, and a time to reach steady state of 10 seconds or less, meets this requirement.
4. Set the PCS to not export (zero-export).
5. Use only UL 1741 listed grid-support non-islanding inverters as approved by this tariff.
6. Maintain voltage fluctuations at the limits specified in Electric Rule 2.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 265

Mm1. OPTION 8: Non-Export Utilizing Certified Power Control Systems (Cont'd)

(L)

The evaluation of a Non-Export system requesting interconnection under this section:

1. Shall omit evaluation for screen D;
2. Shall utilize the Generating Facility's Gross Nameplate Rating for screens F, F1, and G;
3. If the Non-export system has an aggregate PCS controlled nameplate greater than 600 kVA and the maximum reported steady state value of the PCS is greater than 1% of the PCS controlled nameplate (as provided in the NRTL testing reports), the evaluation may utilize the following calculation when determining the impacts to the grid under screens I, J, K, M, N, and O: The sum of the nameplate values of the exporting DER resource (if any) plus the maximum percentage steady state value of the PCS (as provided in the NRTL testing reports) times PCS controlled nameplate capacity.
4. Screen P may be applied using the Generating Facility's Gross Nameplate Rating for evaluations that use fault current calculations. For other evaluations under screen P, the value identified in 3 above may be used.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 266

Mm2. OPTION 9: Limited Export Utilizing Certified Power Control Systems

(L)

The following are minimum requirements for limited export systems that use certified power control systems (PCS) with an open loop response time (OLRT) no more than two seconds to maintain a level of export that is lower than the nameplate rating. It should be noted that other factors relevant to the Interconnection Study process may necessitate additional technical requirements that are not explicitly noted here.

1. Use a PCS that passes the requirements of the 2019 Underwriters Laboratories (UL) Power Control Systems Certification Requirements Decision (CRD) test protocol. Limited export systems may use a PCS that passes later published revisions to the CRD test protocol, or may use a PCS that is certified to the UL 1741 certification standard, if UL incorporates the test protocol for PCS into UL 1741 in the future. The NRTL evaluation must have determined that the PCS conforms to the export limiting functionality in accordance with the relevant CRD or UL published Standard.
2. Use a PCS that is certified with an OLRT of two seconds or less as provided in the PCS's specification data sheets.
3. The PCS must reduce export to the approved export limit, or less, within two seconds of exceeding the approved export limit. A PCS that is certified with an open-loop response time of two seconds or less, and a time to reach steady state of ten seconds or less, meets this requirement.
4. Set the PCS to not exceed the proposed level of export.
5. Use only UL 1741 listed grid-support non-islanding inverters as approved by this tariff.
6. Maintain voltage fluctuations at the limits specified in Electric Rule 2.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 267

Mm2. OPTION 9: Limited Export Utilizing Certified Power Control Systems (Cont'd)

(L)

The evaluation of a limited export system requesting interconnection under this section:

1. Shall utilize the Generating Facility's Gross Nameplate Rating for screens F, F1, and G.
2. If the maximum steady state value is greater than 1% of the PCS controlled nameplate (as provided in the NRTL testing reports) utilize the requested limited export value plus the maximum steady state value of the PCS times the PCS controlled nameplate, to evaluate the impacts to the grid under screens D, I, J, K, M, N, and O. If the maximum steady state value is less than 1% of the PCS controlled nameplate (as provided in the NRTL testing reports), utilize only the requested limited export value under screens D, I, J, K, M, N and O.
3. Screen P shall be applied using the Generating Facility's Gross Nameplate Rating for evaluations that use fault current calculations. For other evaluations under screen P, the value identified in 2 above may be used.

(L)

(Continued)

Advice 7010-E
Decision

Issued by
Meredith Allen
Vice President, Regulatory Affairs

Submitted August 25, 2023
Effective August 29, 2023
Resolution E-5000 and E-5036



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 268

Mm3. OPTION 10: Non-Export with Inadvertent Export Utilizing Certified Power Control Systems (L)

The following are the minimum requirements for Non-Export systems that use certified power control systems (PCS) with an open loop response time (OLRT) between two and ten seconds. It should be noted that other factors relevant to the Interconnection Study process may necessitate additional technical requirements that are not explicitly noted here.

1. Have a nameplate capacity equal to or less than 1,000 kVA.
2. Use a PCS that passes the requirements of the 2019 Underwriters Laboratories (UL) Power Control Systems Certification Requirements Decision (CRD) test protocol. Non-Export may use a PCS that pass later published revisions to the CRD test protocol, or may use a PCS that is certified to the UL 1741 certification standard, if UL incorporates the test protocol for PCS into UL 1741 in the future. The NRTL evaluation must have determined that the PCS conforms to the non-exporting functionality in accordance with the relevant CRD or UL published standard.
3. Use a PCS that is certified with an OLRT of no more than ten seconds, as provided in the PCS's specification data sheets.
4. Set the PCS to not export (zero-export).
5. Use only UL 1741 listed grid-support non-islanding inverters as approved by this tariff.
6. Maintain voltage fluctuations at the limits specified in Electric Rule 2. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 269

Mm3. OPTION 10: Non-Export with Inadvertent Export Utilizing Certified Power Control Systems (Cont'd) (L)

The Distribution Provider evaluating Generating Facilities requesting interconnection under this section shall:

1. Apply screens A through M using the aggregate nameplate inverter rating.
2. Notify the applicant if supplemental review is required, and if so, require the applicant to identify, within 15 business days of being notified, the frequency of inadvertent export, the real power level in watts of inadvertent export, and the time duration of inadvertent export.
3. If distribution upgrades are identified, use screen P to recognize power control parameters, taking into account local feeder conditions; the customer's operating profile; and the magnitude, duration, and frequency of anticipated export;
4. Complete supplemental review within 15 days of receiving the required information specified under 2 above.
5. If the applicant does not provide the operating profile information within the specified 15 business days, perform supplemental review based on information included in the interconnection request within 30 business days of the request for customer operating profile information.
6. Use only the largest facility in the line section for aggregate evaluation for subsequent interconnection requests.

(L)

(Continued)

Advice 7010-E
Decision

Issued by
Meredith Allen
Vice President, Regulatory Affairs

Submitted August 25, 2023
Effective August 29, 2023
Resolution E-5000 and E-5036



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 270

Mm4. OPTION 11: Limited Export with Inadvertent Export Utilizing Certified Power Control Systems (L)

The following are the minimum requirements for limited export controlled systems that use certified power control systems (PCS) with an open loop response time (OLRT) between two and ten seconds to maintain a level of export that is lower than the nameplate rating. It should be noted that other factors relevant to the Interconnection Study process may necessitate additional technical requirements that are not explicitly noted here.

1. Have a nameplate capacity equal to or less than 1,000 kVA.
2. Use a PCS that passes the requirements of the 2019 Underwriters Laboratories (UL) Power Control Systems Certification Requirements Decision (CRD) test protocol. Limited export systems may use a PCS that pass later published revisions to the CRD test protocol, or may use a PCS that is certified to the UL 1741 certification standard, if UL incorporates the test protocol for PCS into UL 1741 in the future. The NRTL evaluation must have determined that the PCS conforms to the export limiting functionality in accordance with the relevant CRD or UL published standard.
3. Use a PCS that is certified with an OLRT of no more than ten seconds, as provided in the PCS's specification data sheets.
4. Set the PCS to not to exceed the proposed level of export.
5. Use only UL 1741 listed grid-support non-islanding inverters as approved by this tariff.
6. Maintain voltage fluctuations at the limits specified in Electric Rule 2. (L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 271

Mm4. OPTION 11: Limited Export with Inadvertent Export Utilizing Certified Power Control Systems (Cont'd) (L)

The Distribution Provider evaluating Generating Facilities requesting interconnection under this section shall:

1. Apply screens A through M using the aggregate nameplate inverter rating.
2. Notify the applicant if supplemental review is required, and if so, require the applicant to identify, within 15 business days of being notified, the frequency of inadvertent export, the real power level in watts of inadvertent export, and the time duration of inadvertent export.
3. If distribution upgrades are identified, use screen P to recognize power control parameters, taking into account local feeder conditions; the customer's operating profile; and the magnitude, duration, and frequency of anticipated export.
4. Complete supplemental review within 15 days of receiving the required information specified under 2 above.
5. If the applicant does not provide the operating profile information within the specified 15 business days, perform supplemental review based on information included in the interconnection request within 30 business days of the request for customer operating profile information. (L)

(Continued)

Advice 7010-E
Decision

Issued by
Meredith Allen
Vice President, Regulatory Affairs

Submitted August 25, 2023
Effective August 29, 2023
Resolution E-5000 and E-5036



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 272

N. EXPEDITED INTERCONNECTION PROCESS FOR NON-EXPORT ENERGY STORAGE GENERATING FACILITIES (L)

Applicants with Interconnection Requests for Non-Export Energy Storage Generating Facilities who meet the requirements outlined below are eligible for expedited interconnection in accordance with the Fast Track Process technical review requirements of Section F.2. Applicants with Non-Export AC/DC Converters that meet the requirements outlined in O. below are also eligible.

1. ELIGIBILITY REQUIREMENTS

Applicants seeking to interconnect a Generating Facility under the provisions of this Section N must meet the following eligibility requirements.

- a. Applicant must electronically submit a completed Interconnection Request, including completing all application fields and submitting all supporting documentation necessary to facilitate the expedited review as required by Distribution Provider. Such documentation may include, but is not limited to, single line diagrams with specific details, manufacturer data sheets for proposed equipment, description of control systems, validation of the right to do business in the state, etc. Distribution Provider shall clearly communicate these requirements as part of the application process. Applicant shall select this process option in the Interconnection Request.
- b. Applicant's Generating Facility must meet the requirements outlined in Section N.2 below.
- c. Applicant's Interconnection Request must be eligible for and select the Fast Track Process.
- d. Applicant's Interconnection Request must pass Fast Track Initial Review and not require any Interconnection Facilities, Distribution Upgrades or Network Upgrades to remain eligible under this Section. As such, Interconnection Requests that select the Cost Envelope Option are not eligible.
- e. Applicants selecting this section shall use the corresponding interconnection agreement type provided for eligible Generating Facilities.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 273

N. EXPEDITED INTERCONNECTION PROCESS FOR NON-EXPORT ENERGY STORAGE GENERATING FACILITIES (Cont'd.) (L)

2. GENERATING FACILITY ELIGIBILITY CRITERIA

An Applicant's Generating Facility must meet and adhere to the following criteria.

- a. The Generating Facility must be comprised solely of the following specific categories of generation technology: Non-Exporting battery storage.
- b. The Generating Facility must have an aggregate maximum inverter nameplate rating of no greater than 500 kW. There is no limitation on an energy storage device's kWh capacity rating.
- c. The Generating Facility must be located behind an existing single retail meter and Point of Common Coupling with a single, clearly marked and accessible disconnect. No other Generators, other than isolated back-up Generators, may be at the same Point of Interconnection or Point of Common Coupling.
- d. The Generating Facility must utilize Option 3 or Option 4 to meet the non-export protection requirements of Screen I in Section G.1.i.
- e. The Generating Facility must have a single or coordinated control system for all charging functions if utilizing multiple inverters. The control system must also ensure that there is no increase in the Interconnection Customer's existing peak load demand.
- f. The Generating Facility must utilize only inverter-based, UL 1741 and UL 1741 SA-listed equipment. Additionally, all installed equipment must meet Distribution Provider's current electric service requirements with no violations or variances.

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 274

O. Non-Export AC/DC CONVERTER ELIGIBILITY CRITERIA

Applicants with Non-Export AC/DC Converters who meet the eligibility criteria below qualify for the expedited interconnection process outlined in Section N of this Rule.

1. The Non-Export AC/DC Converter must have an aggregate maximum inverter nameplate rating of no greater than 500 kW. There is no limitation on an energy storage device’s kWh capacity rating.
2. Applicant’s Interconnection Request must be eligible for and select the Fast Track Process.
3. Applicant’s Interconnection Request must pass Fast Track Initial Review and not require any Interconnection Facilities, Distribution Upgrades or Network Upgrades to remain eligible under this Section.
4. Applicants selecting this section shall use the corresponding interconnection agreement type provided for Non-Export AC/DC Converters eligible under this Section. As such, Interconnection Requests that select the Cost Envelope Option are not eligible.
5. Applicant’s Non-Export AC/DC converter must meet the Certification requirements in the Section C Definition of “Non-Export AC/DC Converters”.

(D)

(D)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 275

Appendix A Forms Associated with Generator Interconnection Tariffs Subject to Rule 21			
Form Number	Title	Associated Tariffs	Use Guidance
AUTHORIZATION TO RECEIVE CUSTOMER INFORMATION			
79-1095	Authorization to Receive Customer Information or Act Upon a Customer's Behalf	Rule 21	Authorization for Third Party
PRE-APPLICATION REQUEST			
79-1181	Rule 21 Pre-Application Report Request	Rule 21	For Generator Developer to request basic info about local distribution circuit
COST ENVELOPE			
79-1182	Cost Envelope Option Non-NEM Request	Rule 21	Non-NEM Customer Only
79-1183	Cost Envelope Option Non-NEM Agreement Appendix	Rule 21	Non-NEM Customer Only
79-1184	Cost Envelope Option NEM Request	Rule 21	NEM Customer Only
79-1185	Cost Envelope Option NEM Agreement Appendix	Rule 21	NEM Customer Only
GENERATOR INTERCONNECTION APPLICATION (most Rule 21 programs)			
79-1174-02	Rule 21 Generator Interconnection Application	<ul style="list-style-type: none"> • NEM/NEM2 • NEMEXP • NEMMT • NEMA • NEMFC • NEMV/NEMV2, • NEMVMASH/ NEM2VMSH • NEM2VSOM • RES-BCT • Rule 21 • Export Non-export 	Rule 21 customer interconnection application form for expanded net-energy metered (all NEM > 30 kw and all non-Solar/Wind NEM), NEMFC, NEMV, NEMVMASH, RES-BCT, and non-export and limited export Rule 21 generation. (Standard NEM for solar and/or wind ≤ 30 kw will continue to use the 79-1151B application.)
79-1174-02A	Rule 21 Generator Interconnection Application – Attachment A Customer and Project Information	NEM (NEMEXP, NEMMT and NEMA), NEMFC, NEMV, NEMVMASH, RES-BCT, Rule 21	Attachment A to Form 79-1174-02
79-1174-02B	Rule 21 Generator Interconnection Application – Attachment B Non-Export	NEM (NEMEXP, NEMMT and NEMA), NEMFC, NEMV, NEMVMASH, RES-BCT, Rule 21	Attachment B to Form 79-1174-02

(L)

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 276

Appendix A (Cont'd.) Forms Associated with Generator Interconnection Tariffs Subject to Rule 21			
Form Number	Title	Associated Tariffs	Use Guidance
GENERATOR INTERCONNECTION APPLICATION (most Rule 21 programs) (Cont'd)			
79-1174-02C	Rule 21 Generator Interconnection Application – Attachment C Export	NEM (NEMEXP, NEMMT and NEMA), NEMFC, NEMV, NEMVMASH, RES-BCT, Rule 21	Attachment C to Form 79-1174-02
79-1174-02D	Rule 21 Generator Interconnection Application – Attachment D Solar (PV) Technology	NEM (NEMEXP, NEMMT and NEMA), NEMFC, NEMV, NEMVMASH, RES-BCT, Rule 21	Attachment D to Form 79-1174-02
79-1174-02E	Rule 21 Generator Interconnection Application – Attachment E Wind Turbine Technology	NEM (NEMEXP, NEMMT and NEMA), NEMFC, NEMV, NEMVMASH, RES-BCT, Rule 21	Attachment E to Form 79-1174-02
79-1174-02F	Rule 21 Generator Interconnection Application – Attachment F Machine-Based Technology	NEM (NEMEXP, NEMMT and NEMA), NEMFC, NEMV, NEMVMASH, RES-BCT, Rule 21	Attachment F to Form 79-1174-02 Rule 21 Generator Interconnection Application – Attachment F Machine-Based Technology
79-1174-02G	Rule 21 Generator Interconnection Application – Attachment F Machine-Based Technology	NEM (NEMEXP, NEMMT and NEMA), NEMFC, NEMV, NEMVMASH, RES-BCT, Rule 21	Attachment G to Form 79-1174-02
79-1174-02H	Rule 21 Generator Interconnection Application – Attachment H Energy Storage Technology	NEM (NEMEXP, NEMMT and NEMA), NEMFC, NEMV, NEMVMASH, RES-BCT, Rule 21	Attachment H to Form 79-1174-02
79-1174-02I	Rule 21 Generator Interconnection Application – Attachment I RES-BCT	NEM (NEMEXP, NEMMT and NEMA), NEMFC, NEMV, NEMVMASH, RES-BCT, Rule 21	Attachment I to Form 79-1174-02

(L)

(L)

(Continued)

Advice 7010-E
Decision

Issued by
Meredith Allen
Vice President, Regulatory Affairs

Submitted
Effective
Resolution

August 25, 2023
August 29, 2023
E-5000 and E-5036



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 277

Appendix A (Cont'd.)			
Forms Associated with Rule 21			
Generator Interconnection Tariffs Subject to Rule 21			
Form Number	Title	Associated Tariffs	Use Guidance
GENERATOR INTERCONNECTION APPLICATION (most Rule 21 programs) (Cont'd)			
79-1174-02J	Rule 21 Generator Interconnection Application – Attachment I RES-BCT	NEM (NEMEXP, NEMMT and NEMA), NEMFC, NEMV, NEMVMASH, RES-BCT, Rule 21	Attachment J to Form 79-1174-02
79-1174-02K	Rule 21 Generator Interconnection Application – Attachment K NEMFC Load Aggregation	NEM (NEMEXP, NEMMT and NEMA), NEMFC, NEMV, NEMVMASH, RES-BCT, Rule 21	Attachment K to Form 79-1174-02
79-1174-02L	Rule 21 Generator Interconnection Application – Attachment K NEMFC Load Aggregation	NEM (NEMEXP, NEMMT and NEMA), NEMFC, NEMV, NEMVMASH, RES-BCT, Rule 21	Attachment L to Form 79-1174-02
79-1174-02M	Rule 21 Generator Interconnection Application – Attachment M NEMVMASH Single Service Delivery Point	NEM (NEMEXP, NEMMT and NEMA), NEMFC, NEMV, NEMVMASH, RES-BCT, Rule 21	Attachment M to Form 79-1174-02
79-1174-02N	Rule 21 Generator Interconnection Application – Attachment N NEMVMASH Development	NEM (NEMEXP, NEMMT and NEMA), NEMFC, NEMV, NEMVMASH, RES-BCT, Rule 21	Attachment N to Form 79-1174-02 Rule 21 Generator Interconnection Application – Attachment N NEMVMASH Development
NEM and NEM2			
STANDARD NEM			
79-1151A	Agreement be used with 79-1151B Application Agreement And Customer Authorization Net Energy Metering For Solar And/Or Wind Electric Generating Facilities Of 30 Kilowatts Or Less	Standard NEM	NEM Customer Only Interconnection
79-1151A-02	Agreement And Customer Authorization - Net Energy Metering (NEM2) Interconnection For Solar And/Or Wind Electric Generating Facilities Of 30 Kilowatts Or Less	Standard NEM2	NEM2 Application to be used with 79-1151B-02 Interconnection Agreement

(L)

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 278

Appendix A (Cont'd.) Forms Associated with Generator Interconnection Tariffs Subject to Rule 21			
Form Number	Title	Associated Tariffs	Use Guidance
STANDARD NEM (Cont'd)			
79-1151B	Application - Net Energy Metering Interconnection For Solar And/Or Wind Electric Generating Facilities Of 30 Kilowatts Or Less	Standard NEM	NEM Customer Only Application to be used with 79-1151A Interconnection Agreement
79-1151B-02	Application - Net Energy Metering (NEM2) Interconnection For Solar And/Or Wind Electric Generating Facilities Of 30 Kilowatts Or Less	Standard NEM2	NEM2 Application to be used with 79-1151A-02 Interconnection Agreement
79-1217	Agreement And Customer Authorization Net Energy Metering (NEM2) Interconnection For Solar And/Or Wind Electric Generating Facilities Of 30 Kilowatts Or Less With Energy Storage Of 10 Kilowatts Or Less	Standard NEM2 + ≤ 10kw storage	Customer Authorization for Third Party Information
79-1193	Agreement and Customer Authorization Net Energy Metering (NEM) Interconnection for Solar and/or Wind Electric Generating Facilities of 30 Kilowatts or Less: with Energy Storage of 10 Kilowatts or Less	Standard NEM + ≤ 10 storage	NEM Customer Only For NEM pair storage scenarios using Power Control Systems to ensure NEM integrity
79-1193-02	Agreement and Customer Authorization Net Energy Metering (NEM2) Interconnection for Solar and/or Wind Electric Generating Facilities of 30 Kilowatts or Less: with Energy Storage of 10 Kilowatts or Less	Standard NEM2 + ≤ 10 storage	For NEM2 pair storage scenarios using Power Control Systems to ensure NEM integrity
79-1218	Agreement And Customer Authorization Net Energy Metering (NEM2) Interconnection For Solar And/Or Wind Electric Generating Facilities Of 30 Kilowatts Or Less For New Residential Construction	Standard NEM2 for New Construction	Customer Authorization for Third Party Information for New Residential Construction

(L)

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 279

Appendix A (Cont'd.) Forms Associated with Generator Interconnection Tariffs Subject to Rule 21			
Form Number	Title	Associated Tariffs	Use Guidance
EXPANDED NEM			
79-1220	Interconnection Agreement for Net Energy Metering (NEM) of a Renewable Electric Generating Facility of 1,000 kW or Less, Except Solar or Wind Facilities of 30 kW or Less, and Virtual Net Energy Metering (NEMV) of a Renewable Electric Generating Facility of 1,000 kW or Less.	Expanded NEM	NEM Customer Only Interconnection Agreement
79-1220-02	Interconnection Agreement for Net Energy Metering (NEM) of a Renewable Electric Generating Facility of 1,000 kW or Less, Except Solar or Wind Facilities of 30 kW or Less, and Virtual Net Energy Metering (NEMV) of a Renewable Electric Generating Facility of 1,000 kW or Less.	Expanded NEM	NEM2 Interconnection Agreement
LARGE NEM ≥ 1MW			
79-1198-02	Interconnection Agreement For Net Energy Metering (NEM2) And Renewable Electrical Generating Facility Sized Greater Than 1,000 Kw	>1MW NEM2	FT and Detailed Study Interconnection Agreement for >1MW NEM2 Generating Facilities
NEMA			
79-1153	NEM Load Aggregation Appendix	NEM – NEMA	NEM Customer Only - Use as an Appendix with Form 79-1151A, 79-1220, or 79-1069
79-1153-02	NEM2A Load Aggregation Appendix	NEM2 – NEM2A	Use as an Appendix with Form 79-1151A-02, 79-1220-02 or 79-1069-02
79-1202 ****	Load Aggregation Appendix	NEM, NEM2, Rule 21	Use as an Appendix with Form 79-1151A, 79-1151A-02, 79-978, 79-978-02, 79-1137, 79-1137-02, 79-1069 or 79-1069-02
NEMMT (Multiple Tariff)			
79-1069	Generating facility Interconnection Agreement (Multiple Tariff)	NEM, Rule 21	NEM Customer Only NEMMT Interconnection Agreement used with Form 79-1174-02
79-1069-02	Generating Facility Interconnection Agreement (Multiple Tariff NEM2MT)	NEM2, Rule 21	NEM2MT Interconnection Agreement used with Form 79-1174-02
MISCELLANEOUS NEM FORMS			
79-1130	Request to Opt-out of / Opt-in to Compensation for Surplus Electricity	NEM	AB 920- Opt not to receive compensation for net annual excess energy
79-1114	NEM 2010 Early True-up Request Form	NEM	NEM Customer Only

(L)

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 280

Appendix A (Cont'd.) Forms Associated with Generator Interconnection Tariffs Subject to Rule 21			
Form Number	Title	Associated Tariffs	Use Guidance
MISCELLANEOUS NEM FORMS (Cont'd)			
79-1155	Schedules NEM, NEMV, NEMVMASH, Net Surplus Electricity (NSE) Renewable Energy Credits Compensation	NEM, Rule 21	NEM Customer Only
79-1155-02	Schedules NEM2, NEM2V, NEM2VMASH, Net Surplus Electricity (NSE) Renewable Energy Credits Compensation	NEM2 NEM2V NEM2VMASH, Rule 21	NEM2 Customer Only
NEMFC (Fuel Cell)			
79-1010	Interconnection Agreement for Net Energy Metering of Fuel Cell Generating Facilities	NEM, Rule 21	NEMFC Interconnection Agreement used with Form 79-1174-02
NEMV/NEM2V			
See 79-1220 and 79-1220-02		See the Expanded NEM Section Above	
NEMVMASH/NEM2VMASH			
79-1189	Eligible Low Income Development Virtual Net Energy Metering (NEM2VMASH) Interconnection Agreement for Multifamily Affordable Housing with Solar Generation Totaling 1 MW or Less	NEM2VMASH s	NEM2VMASH Interconnection Agreement
79-1125	NEM / NEMV / NEMVMASH Inspection Report	NEM	NEM Customer Only
79-1195	Eligible Low Income Development Virtual Net Energy Metering (NEMVMASH) Interconnection Agreement for Multifamily Affordable Housing with Solar Generation Totaling 1 MW or Less	NEMVMASH, Rule 21	NEM Customer Only NEMVMASH Interconnection Agreement
NEM2VSOM			
79-1206-02	Eligible Low-Income Development Virtual Net Energy Metering (NEM2VSOM) Interconnection Agreement For The Solar On Multifamily Affordable Housing (SOMAH) Program With Solar Generation Totaling 1 Mw Or Less	NEM2VSOM	NEM2VSOM Interconnection agreement for solar 1 MW or less.
RES-BCT			
79-1191	Interconnection Agreement for Renewable Energy Self-Generation Bill Credit Transfer (RES-BCT) Generating Facility	Rule 21	RES-BCT Interconnection Agreement
79-1197	Local Government Renewable Energy Self-Generation Bill Credit Transfer (RES-BCT) Re-Allocation Request	RES-BCT	Use to establish RES-BCT benefiting account re-allocations

(L)

(L)

(Continued)



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 281

Appendix A (Cont'd.) Forms Associated with Generator Interconnection Tariffs Subject to Rule 21			
Form Number	Title	Associated Tariffs	Use Guidance
RULE 21 NON-EXPORT			
79-973	Generating Facility Interconnection Agreement For Non-Export Generating Facilities (Rule 21 Interconnection Agreement)	Rule 21 Non-Export RES-BCT	Interconnection Agreement used for RESBCT and non-NEM generation with Application 79-1197
79-992	Customer Generation Agreement (Third party Generator on Premises, Non-Exporting)	3-Party Rule 21	Third Party Non-Exporting Interconnection Agreement
79-1070	Export Addendum to Generating Facility Interconnection Agreement for Non-Export Generating Facilities (Form 79-973) Sized 2 Megawatts or Less	Rule 21	Export addendum used with Form 79-973
79-988	Generating Facility Interconnection Agreement (Third Party Non-Exporting)	3-Party Rule 21	Third Party Non-Exporting Interconnection Agreement
79-1212	Rule 21 Non-Export Generator Interconnection Notification	Rule 21	Notification Form for New Non-Export Interconnection
79-1213	Agreement and Customer Authorization Non-Export Generating Facility Sized 30 Kilowatts or Less	Rule 21	Interconnect and Operate a Non-Export Generating Facility
79-1214	Notification-Only Pilot Program Developer Eligibility Application	Rule 21	Eligibility to Participate in the Notification-only Pilot Program
STORAGE			
79-1192	Interconnection Agreement for Non-Export Storage Generating Facilities 500KW or Less	Rule 21	Used for expedited interconnection of non-export energy storage, pursuant to Rule 21 Section N, PG&E AL 4941-E & E-A and D.16-06-052, & Attachment C, Section II.1
79-1199	Agreement And Customer Authorization Non-Export Stand-Alone Energy Storage Of 30 Kilowatts Or Less	Rule 21	Interconnection Agreement For non-export storage ≤ 30 kW
RULE 21 EXPORT FOR SALE INTERCONNECTION FORMS			
79-1145	Rule 21 Exporting Generator Interconnection Request	Rule 21	For Exporting Generator
79-1200	Rule 21 Generator Interconnection Agreement For Exporting Generating Facilities	Rule 21	FT and Detailed Study Interconnection Agreement for Exporting Generating Facilities

(L)

(L)

(Continued)

Advice 7010-E
Decision

Issued by
Meredith Allen
Vice President, Regulatory Affairs

Submitted August 25, 2023
Effective August 29, 2023
Resolution E-5000 and E-5036



ELECTRIC RULE NO. 21
GENERATING FACILITY INTERCONNECTIONS

Sheet 282

Appendix A (Cont'd.)			
Forms Associated with			
Generator Interconnection Tariffs Subject to Rule 21			
Form Number	Title	Associated Tariffs	Use Guidance
RULE 21 OTHER AGREEMENTS			
INDEPENDENT STUDY & DISTRIBUTION GROUP STUDY PROCESS STUDY AGMT			
79-1162	Rule 21 Detailed Study Agreement	Rule 21	Independent Study and Distribution Group Study Process Study Agreement
79-1136	PG&E Interconnection Agreement For an Existing Small Generating Facility Interconnecting to the Distribution System under Rule 21	Rule 21	Used for existing QFs with Form 79-1174-02
MATERIAL MODIFICATIONS			
79-1211	Generating Facility Material Modification Notification Worksheet	Rule 21	Used to make Material Modifications to the Generating Facility
SPECIAL FACILITIES AGREEMENT			
79-280	Agreement for Installation of Allocation of Special Facilities for Parallel Operation of Non-Utility-Owned Generation and/or Electrical Standby Service (Electric Rules 2 and 21)	Rule 21	Special Facilities Agreement to be used with Form 79-702- this form is required every time facilities above and beyond what is required to serve a standard customer – load and a meter.
79-255	Agreement for Installation or Allocation of Special Facilities	Rule 21	Installation or Allocation of Special Facility
79-702	Appendix A: Detail of Special Facilities Charges to be used in concert with form 79-280	Rule 21	Used with Form 79-280- this appendix specifies the detail employed in determining the total charges assessed for the special facilities in the SFA
79-1100	Electric Rule 21 - Agreement to Install Applicant Requested NGOM Special Facilities for Solar Performance Metering	Rule 21	Installation of Solar Generation Performance Metering Equipment
STANDBY			
79-285	Special Agreement for Electrical Standby Service	Rule 21	Standby Service - Use this form for all generators connected in parallel not eligible for any of the NEM tariffs. Back-up generators (BUGs) do not pay standby and consequently this form is not applicable to them

(L)

(Continued)

