

**PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans
Rulemaking 18-10-007
Data Response**

PG&E Data Request No.:	CalAdvocates_044-Q05		
PG&E File Name:	WildfireMitigationPlans_DR_CalAdvocates_044-Q05		
Request Date:	February 26, 2021	Requester DR No.:	CalAdvocates-PGE-2021WMP-10
Date Sent:	March 3, 2021	Requesting Party:	Public Advocates Office
PG&E Witness:		Requester:	Alan Wehrman

The following questions related to PG&E’s 2021 Wildfire Mitigation Plan (WMP) Update.

QUESTION 05

Regarding EVM on distribution circuits:

- a. Provide PG&E’s workplan that describes where and when PG&E will undertake EVM projects in 2021.
- b. Describe how PG&E has determined which specific circuit-segments should be treated with EVM in 2021.

ANSWER 05

- a. Please see attachment “WildfireMitigationPlans_DR_CalAdvocates_044-Q05-Atch01.xlsx”. The 2021 EVM workplan is subject to revisions and updates as additional data and information becomes available. The 2021 EVM workplan is approved by the Wildfire Risk Governance Steering Committee (WRGSC). See 2021 WMP at pp. 5-6. The 2021 EVM workplan that is attached was approved by the WRGSC on February 19, 2021. PG&E’s 2021 EVM workplan addresses the locations that EVM will be performed, but does not identify specific times the work will be done given the nature of the work and availability of resources, as well as other constraints.
- b. PG&E uses the 2021 Wildfire Distribution Risk Model as modified by the EVM tree weighted prioritization list to inform the 2021 EVM workplan. Additional information and data is also reviewed by the WRGSC to review updates or revisions to the 2021 EVM workplan.