

**PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans Discovery 2023
Data Response**

PG&E Data Request No.:	CalAdvocates_009-Q015		
PG&E File Name:	WMP-Discovery2023_DR_CalAdvocates_009-Q015		
Request Date:	April 4, 2023	Requester DR No.:	CalAdvocates-PGE-2023WMP-09
Date Sent:	April 7, 2023	Requesting Party:	Public Advocates Office
DRU Index #:		Requester:	Holly Wehrman

Grid Design and System Hardening

QUESTION 015

- a) What is PG&E's forecast RSE for covered conductor system hardening completed in the second half of 2025?
- b) Please provide workpapers to support your answers to part (a).

ANSWER 015

- a) PG&E does not forecast an RSE for covered conductor system hardening for the second half of 2025 in its WMP. However, in the 2023 GRC, PG&E provided an RSE of 5.8 in 2025 for overhead system hardening (A. 21-06-021, Exhibit PG&E-4, Chapter 3, p. 3-6, Table 3-1).
- b) Please see attachment "*WMP-Discovery2023_DR_CalAdvocates_009-Q013Atch01.xlsm*" for the requested information.