

**PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans Discovery 2023
Data Response**

PG&E Data Request No.:	CalAdvocates_010-Q009		
PG&E File Name:	WMP-Discovery2023_DR_CalAdvocates_010-Q009		
Request Date:	April 4, 2023	Requester DR No.:	CalAdvocates-PGE-2023WMP-10
Date Sent:	April 10, 2023	Requesting Party:	Public Advocates Office
DRU Index #:		Requester:	Holly Wehrman

Grid operations

QUESTION 009

P. 464 of PG&E's WMP states, "By the end of 2022, we responded to 89 percent of outages on EPSS-enabled lines within 60 minutes, responding on average within 42 minutes." For the 11 percent of outages (noted in this quote) on EPSS-enabled lines that PG&E did not respond to within 60 minutes, provide the following:

- a) Average response time.
- b) Longest response time.

ANSWER 009

2022 EPSS OUTAGE RESPONSE

AVERAGE RESPONSE TIME FOR RESPONSES > 60 MINUTES	LONGEST RESPONSE TIME
95 Minutes	408 Minutes

Note: Table values reflect available data since EPSS Outage Response time tracking began. The timeframe for tracking in 2022 was May 23, 2022 – December 31, 2022.