

**PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans Discovery 2023-2025
Data Response**

PG&E Data Request No.:	CalAdvocates 044-Q013		
PG&E File Name:	WMP-Discovery2023-2025 DR CalAdvocates 044-Q013		
Request Date:	April 15, 2024	Requester DR No.:	CalAdvocates-PGE-2025WMP-08
Date Sent:	April 18, 2024	Requesting Party:	Public Advocates Office
PG&E Witness:		Requester:	Holly Wehrman

SUBJECT: SITUATIONAL AWARENESS

QUESTION 013

Table ACI-PG&E-23-23-1 on page 113 of PG&E's 2025 WMP Update includes the following entry:

Station ID & Name	Work Center	Lat	Long	Last Calibration Date	Attempt Date	Number of Attempts	Reasons for Incomplete
PGE-1978 Skaggs Hill	Santa Rosa	38.67111	-123.19447	11/1/2022	8/21/2023	1	The station was removed on September 17, 2022 due to excessive shade preventing the station from working properly. It is currently in the process of being relocated.

- a) Explain why the last calibration date of this weather station was recorded as 11/1/2022, over one month after the station was removed on September 17, 2022.
- b) Provide any records of the calibration on 11/1/2022.
- c) When did PG&E become aware that the station had been removed?
- d) When does PG&E plan to relocate the station?

ANSWER 013

- a) This calibration date was recorded erroneously due to a data pull error. This station has never been calibrated as it was removed on July 19, 2021, due to a pole replacement and then asked to be relocated due to shading. This station was originally installed in August 2020.
- b) There is no proof of calibration since the station was installed for under 12 months.
- c) The station was scheduled by PG&E to be removed due to a pole replacement on July 19, 2021.
- d) PG&E is currently working on reinstalling this station.