

Question: The existing proxy cost table addresses up to 200 MW of off-peak generation at San Mateo. What would the cost be for up to 750 MW?

Answer: With further study, the off peak transmission proxy costs for San Mateo are shown in the table below:

Off Peak Period

Cluster (Substation)	Level	Max MW in each level	Proxy facility cost (\$million)
San Mateo 230	1	400	
	2	400	\$23.64