

March 28, 2001

**ADVICE 2093-E
(Pacific Gas and Electric Company ID U39E)**

Public Utilities Commission of the State of California (CPUC)

**Subject: Relocation of the Kearney-Biola 70 Kilovolt (kV) Power Line
#702 in Fresno**

Pacific Gas and Electric Company (PG&E) hereby submits pursuant to General Order (G.O.) 131-D, Section XI, Subsection B.4, the notice of the construction and reconstruction of a power line in Kings County. The Notice described in G.O. 131-D Section XI, Paragraph C, is submitted as Attachment I.

Purpose

This advice letter provides a copy of the Notice of Proposed Construction and Reconstruction (Attachment I) and the Notice Distribution List, which comply with the noticing requirements found in G.O. 131-D, Section XI, Subsections B and C.

Background

PG&E has been requested by the City of Fresno to relocate a portion of the Kearney-Biola Power Line. PG&E will relocate approximately 800 feet of the Kearney-Biola Power Line at the intersection of Cornelia and Ashlan Avenues, to allow for improvements to the roadway. PG&E will replace five power poles with three wood poles. A portion of this relocation will be located in the Franchise area and approximately 200 feet will require overhang easements. Construction is scheduled for May 2001 and will be completed in June 2001.

Pursuant to G.O. 131-D, Section III, Paragraph B, Subsection 1(b), the relocation of this power line is exempt from a Permit to Construct. Subsection 1(b) states that a Permit to Construct is not required for the minor relocation of existing power line facilities up to 2,000 feet in length, or the intersetting of additional support structures between existing support structures.

Additionally, G.O. 131-D requires utilities to employ "no cost" and "low cost" measures to reduce public exposure to electric and magnetic fields (EMFs). PG&E

will use no cost triangular construction to compact the conductors thereby reducing the EMF fields. Low Cost measures do not apply for this project.

This filing will not increase any rate or charge, cause the withdrawal of service, or conflict with any other rate schedule or rule.

Effective Date

PG&E requests that this advice filing become effective on **May 7, 2001**, which is 40 days after the date of filing. (In accordance with G.O. 131-D, construction will not begin until 45 days after notice is first published.)

Protests

Anyone wishing to protest this filing may do so by filing a protest with the CPUC and PG&E by **April 16, 2001**, at the following address:

Energy Division
California Public Utilities Commission
505 Van Ness Avenue, Fourth Floor
San Francisco, CA 94102
Facsimile: (415) 703-2200

In addition, protests and all other correspondence regarding this advice letter should also be sent by letter and transmitted via facsimile to the attention of:

David T. Kraska
Attorney, Law Department
Pacific Gas and Electric Company
P. O. Box 7442
San Francisco, CA 94120
Facsimile (415) 973-0516

Les Guliasi
Director, Regulatory Relations
P. O. Box 77000, Mail Code B10C
San Francisco, CA 94177
Facsimile: (415) 973-7226

Persons or groups may protest the proposed construction and reconstruction if they believe that the Company has incorrectly applied for an exemption or that the conditions exist identified in G.O. 131-D, Section III, Paragraph B, Subsection 2. The protest shall set forth the grounds upon which it is based and shall be submitted expeditiously. There is no restriction on who may file a protest.

In accordance with G.O. 96-A, Section III, PG&E is electronically and postal mailing copies of this advice letter to the utilities and interested parties shown on the attached list, including the type of parties specified in G.O. 131-D, Section XI, Paragraph B, Subsections 1 and 2. These parties are identified in the "Notice Distribution List" included in Attachment I. Address change requests should be directed to Nelia Avendano at (415) 973-3529.

Vice President -- Regulatory Relations

Attachments

bcc: David Kraska
Jo Lynn Lambert
Bob Masuoka
Galen Raymond
Mike Rose
Robert Stiving