

July 19, 2002

**Advice 2264-E
(Pacific Gas and Electric Company ID U39 E)**

Public Utilities Commission of the State of California

Subject: Submits Notice of Construction, Pursuant to General Order 131-D, for the Construction of Electric Transmission System for the Feather River Energy Center in the City of Yuba City, County of Sutter

Pacific Gas and Electric Company (the Company) hereby submits notice pursuant to General Order (G.O.) 131-D, Section XI, Subsection B.4, of the construction of facilities that are exempt from a Permit to Construct.¹

Purpose

This advice letter provides a copy of the Notice of Proposed Construction (Attachment I) and the Notice Distribution List, which comply with the noticing requirements found in G.O. 131-D, Section XI.

Background

In order to interconnect Calpine's new Feather River Energy Center Power Plant in Yuba City, California, to the Company's electrical system, the Company has been asked to perform the following work: 1) Build approximately 1,000 feet of 115 kilovolt (kV) power line between Bogue Substation and the intersection of Railroad Avenue and Bogue Road. 2) Make related substation modifications at Bogue Substation. The 115 kV line will be

¹ The Company reserves all legal rights to challenge the decisions or statutes under which it has been required to make this advice filing, and nothing in this advice filing constitutes a waiver of such rights. Also, the Company reserves any additional legal rights to challenge the requirement to make this advice filing by reason of its status as a debtor under Chapter 11 of the Bankruptcy Code, and nothing in this advice filing constitutes a waiver of such rights.

installed on 3 tubular steel poles. Construction is scheduled to begin in August of 2002, or as soon as possible thereafter, and the new facilities are planned to be in operation by December 2002, or as soon as possible after construction is completed.

- This project qualifies as exempt from Permit to Construct filing requirements, pursuant to G.O. 131-D, Section III, Subsection B.1.f, which exempts, "power line facilities or substations to be relocated or constructed which have undergone environmental review pursuant to CEQA as part of a larger project, and for which the final CEQA document (Environmental Impact Report (EIR) or Negative Declaration) finds no significant unavoidable environmental impacts caused by the proposed line or substation,"

Additionally, G.O. 131-D requires utilities to employ "no cost" and specified "low cost" measures to reduce public exposure to electric and magnetic fields (EMFs). The following measures are proposed for this project:

- Because there are no EMF mitigation measures available on this project that would meet the CPUC's benchmark of 4% or less of the total project cost, no "no cost" or "low cost" measures will be employed.

This filing will not increase any rate or charge, cause the withdrawal of service, or conflict with any other rate schedule or rule.

Protests

Anyone wishing to protest this filing may do so by filing a protest with the CPUC and the Company by **August 8, 2002**, at the following address:

Director, Energy Division
California Public Utilities Commission
505 Van Ness Avenue, Fourth Floor
San Francisco, California 94102
Facsimile: (415) 703-2200

In addition, protests and all other correspondence regarding this advice letter should also be sent by letter and transmitted via facsimile to the attention of:

David T. Kraska
Attorney, Law Department
Pacific Gas and Electric Company
P.O. Box 7442
San Francisco, California 94120
Facsimile: (415) 973-0516

Les Guliasi
Director, Regulatory Relations
Pacific Gas and Electric Company
P.O. Box 770000, Mail Code B10C
San Francisco, California 94177
Facsimile: (415) 973-7226

Persons or groups may protest the proposed construction if they believe that the Company has incorrectly applied for an exemption or that the conditions set out in G.O. 131-D, Section III.B.2, exist.

Effective Date

The Company requests that this advice filing become effective on **August 28, 2002**, which is 40 days after the date of filing. (In accordance with G.O. 131-D, construction will not begin until 45 days after notice is first published.)

Notice

In accordance with G.O. 96-A, Section III, Paragraph G, the Company is electronically and postal mailing copies of this advice letter to the utilities and interested parties shown on the attached list, including the parties listed in G.O. 131-D, Section XI, Paragraphs B.1 and B.2. These parties are identified in the "Notice Distribution List" included in Attachment I. Address change requests should be directed to Rose Abao at (415) 973-2218. Advice letter filings can also be accessed electronically at:

http://www.pge.com/customer_services/business/tariffs/

Vice President -- Regulatory Relations

Attachments

cc: Parties Listed in G.O. 131-D, Paragraphs B.1 and B.2

bcc: David Kraska
Jo Lynn Lambert
Robert Masuoka
Oscar Sample
Robert Stiving