

PUBLIC UTILITIES COMMISSION

505 VAN NESS AVENUE
SAN FRANCISCO, CA 94102-3298

Tel. No. (415) 703-1691



November 3, 2006

Advice Letter 2688-E

Rose de la Torre
Pacific Gas & Electric
77 Beale Street, Room 1088
Mail Code B10C
San Francisco, CA 94105

Subject: Notice of Proposed Construction of Facilities Pursuant to G.O. 131-D, Lee 60 kilovolt Tap Relocation Project for Paseo West Subdivision, City of Manteca, County of San Joaquin

Dear Ms de la Torre:

Advice Letter 2688-E is effective August 21, 2005. A copy of the advice letter is returned herewith for your records.

Sincerely,

Sean H. Gallagher, Director
Energy Division

MAS

REGULATORY RELATIONS	
Tariffs Section	
M Brown	D Poster
R Dela Torre	S Ramaiya
B Lam	
NOV 9 2006	
Records _____	
Return to _____	File _____
cc to _____	



**Pacific Gas and
Electric Company®**

Brian K. Cherry
Director
Regulatory Relations

77 Beale Street, Room 1087
San Francisco, CA 94105

Mailing Address
Mail Code B10C
Pacific Gas and Electric Company
P. O. Box 770000
San Francisco, CA 94177

415.973.4977
Internal: 223.4977
Fax: 415.973.7226
Internet: BKC7@pge.com

July 22, 2005

**Advice 2688-E
(Pacific Gas and Electric Company ID U39 E)**

Public Utilities Commission of the State of California

**Subject: Notice of Proposed Construction of Facilities Pursuant to
General Order 131-D, Lee 60 Kilovolt Tap Relocation Project
for Paseo West Subdivision, City of Manteca, County of San
Joaquin**

Pacific Gas and Electric Company (the Company) hereby submits notice pursuant to General Order (G.O.) 131-D, Section XI, Subsection B.4 of the construction of facilities that are exempt from a Permit to Construct.

Purpose

This advice letter provides a copy of the Notice of Proposed Construction (Attachment I) and the Notice Distribution List, which comply with the noticing requirements found in GO 131-D, Section XI, Subsections B and C.

Background

Pacific Gas and Electric Company has been requested by the developer of Paseo West Subdivision in Manteca to relocate a portion of the existing Lee 60kV Tap wood pole line approximately 10 feet north to avoid a conflict with proposed Woodward Avenue street improvements. The proposed relocation to a new franchise position begins at the intersection of Main Street and Woodward Avenue continues east approximately 2416 feet and will include 8 new wood poles replacing 8 existing wood poles. One new pole is 10 feet taller than the existing poles, one is 25 taller and 6 are 15 feet taller. Construction is scheduled to begin in August 2005, or as soon as possible thereafter, and the new facilities are planned to be in operation in September 2005, or as soon as possible after project completion.

Exemption form CPUC Authority: CPUC General Order 131-D, Section III.B exempts projects meeting specific conditions from the CPUC's requirements to file an application requesting authority to construct. Pacific Gas and Electric believes this project qualifies for the following exemptions:

- “the replacement of existing powerline facilities or supporting structures with equivalent facilities or structures,” and
- “power lines or substations to be relocated or constructed which have undergone environmental review pursuant to CEQA as part of a larger project, and for which the final CEQA document (Environmental Impact Report (EIR) or Negative Declaration) finds no significant unavoidable environmental impacts caused by the proposed line or substation.” and
- “power line facilities or substations to be located in an existing franchise, road widening setback easement or in a utility corridor designated, precisely mapped and officially adopted pursuant to law by federal, state, or local agencies for which a final Negative Declaration or EIR finds no significant unavoidable environmental impacts.”

The City of Manteca issued a Mitigated Negative Declaration for the Paseo West Subdivision dated October 11, 2004 (no SCH review), which found that no significant unavoidable environmental impacts will result from the project.

Electric and Magnetic Fields (EMF): Pacific Gas and Electric Company will employ “no cost” and specified “low cost” measures to reduce public exposure to EMF in accordance with California Public Utilities Commission (CPUC) Decision 93-11-013 and Pacific Gas and Electric Company’s “EMF Design Guidelines of New Electrical Facilities: Transmission, Substation, and Distribution.” The following measure will be implemented: pole heights will be 5 feet taller than otherwise required to reduce magnetic fields at ground level.

This filing will not increase any rate or charge, cause the withdrawal of service, or conflict with any other rate schedule or rule.

Protests

Anyone wishing to protest this filing may do so by filing a protest with the CPUC and the Company by **August 11, 2005**, which is 20 days after the filing date, at the following address:

Director, Energy Division
California Public Utilities Commission
505 Van Ness Avenue, Fourth Floor
San Francisco, California 94102
Facsimile: (415) 703-2200
E-Mail: jjr@cpuc.ca.gov and jnj@cpuc.ca.gov

In addition, protests and all other correspondence regarding this advice letter should also be sent by letter and transmitted via facsimile to the attention of:

David T. Kraska
Attorney, Law Department
Pacific Gas and Electric Company
P.O. Box 7442
San Francisco, California 94120
Facsimile (415) 973-0516

Brian K. Cherry
Director, Regulatory Relations
Pacific Gas and Electric Company
P.O. Box 770000, Mail Code B10C
San Francisco, California 94177
Facsimile (415) 973-7226
E-Mail: PGETariffs@pge.com

Persons or groups may protest the proposed construction if they believe that the Company has incorrectly applied for an exemption or that the conditions identified in G.O. 131-D, Section III.B.2, exist.

Effective Date

The Company requests that this advice filing become effective on **August 21, 2005**, which is 30 days after the date of filing. (In accordance with GO 131-D, construction will not begin until 45 days after notice is first published.)

Notice

In accordance with G.O. 96-A, Section III, Paragraph G, the Company is electronically and postal mailing copies of this advice letter to the utilities and interested parties shown on the attached list, including the parties listed in G.O. 131-D, Section XI, Paragraphs B.1 and B.2. These parties are identified in the "Notice Distribution List" included in Attachment I. Address change requests should be directed to Rose de la Torre at (415) 973-4716. Advice letter filings can also be accessed electronically at: <http://www.pge.com/tariffs>



Director - Regulatory Relations

Attachments

cc: Parties Listed in G.O. 131-D, Paragraphs B.1 and B.2

CALIFORNIA PUBLIC UTILITIES COMMISSION

ADVICE LETTER FILING SUMMARY ENERGY UTILITY

MUST BE COMPLETED BY UTILITY (Attach additional pages as needed)

Company name/CPUC Utility No. **Pacific Gas and Electric Company (ID U39)**

Utility type:

ELC

GAS

PLC

HEAT

WATER

Contact Person: Michelle Brown

Phone #: (415) 973-4662

E-mail: mtt3@pge.com

EXPLANATION OF UTILITY TYPE

ELC = Electric

GAS = Gas

PLC = Pipeline

HEAT = Heat

WATER = Water

(Date Filed/ Received Stamp by CPUC)

Advice Letter (AL) #: **2688-E**

Subject of AL: General Order 131-D, Lee 60kV Tap Relocation Project for Paseo West Subdivision, City of Manteca, County of San Joaquin

Keywords (choose from CPUC listing): **Transmission Lines**

AL filing type: Monthly Quarterly Annual One-Time Other _____

If AL filed in compliance with a Commission order, indicate relevant Decision/Resolution #:

Does AL replace a withdrawn or rejected AL? If so, identify the prior AL: N/A

Summarize differences between the AL and the prior withdrawn or rejected AL¹: _____

Resolution Required? Yes No

Requested effective date: **August 21, 2005**

No. of tariff sheets: N/A

Estimated system annual revenue effect (%): _____

Estimated system average rate effect (%): _____

When rates are affected by AL, include attachment in AL showing average rate effects on customer classes (residential, small commercial, large C/I, agricultural, lighting).

Tariff schedules affected: N/A

Service affected and changes proposed¹: _____

Pending advice letters that revise the same tariff sheets: N/A

Protests and all other correspondence regarding this AL are due no later than 20 days after the date of this filing, unless otherwise authorized by the Commission, and shall be sent to:

CPUC, Energy Division

Attention: Tariff Unit

505 Van Ness Ave.,

San Francisco, CA 94102

jjr@cpuc.ca.gov and jnj@cpuc.ca.gov

Pacific Gas and Electric Company

Attn: Brian K. Cherry

Director, Regulatory Relations

77 Beale Street, Mail Code B10C

P.O. Box 770000

San Francisco, CA 94177

E-mail: PGETariffs@pge.com

¹ Discuss in AL if more space is needed.

NOTICE OF PROPOSED CONSTRUCTION

Project Name: Lee 60kV Tap Relocation Project for Paseo West Subdivision, City of Manteca, County of San Joaquin
 ADVICE LETTER NUMBER: 2688-E

Pacific Gas and Electric Company has been requested by the developer of Paseo West Subdivision in Manteca to relocate a portion of the existing Lee 60kV Tap wood pole line approximately 10 feet north to avoid a conflict with proposed Woodward Avenue street improvements. The proposed relocation to a new franchise position begins at the intersection of Main Street and Woodward Avenue continues east approximately 2416 feet and will include 8 new wood poles replacing 8 existing wood poles. One new pole is 10 feet taller than the existing pole, one is 25 feet taller and 6 are 15 feet taller. Construction is scheduled to begin in August 2005, or as soon as possible thereafter, and the new facilities are planned to be in operation in September 2005, or as soon as possible after project completion.

Electric and Magnetic Fields (EMF): Pacific Gas and Electric Company will employ "no cost" and specified "low cost" measures to reduce public exposure to EMF in accordance with California Public Utilities Commission (CPUC) Decision 93-11-013 and Pacific Gas and Electric Company's "EMF Design Guidelines of New Electrical Facilities: Transmission, Substation, and Distribution." The following measure will be implemented: pole heights will be 5 feet taller than otherwise required to reduce magnetic fields at ground level.

Exemption from CPUC Authority: CPUC General Order 131-D, Section III.B, exempts projects meeting specific conditions from the CPUC's requirement to file an application requesting authority to construct. Pacific Gas and Electric Company believes this project qualifies for the following exemptions:

- "the replacement of existing power line facilities or supporting structures with equivalent facilities or structures," and
- "power lines or substations to be relocated or constructed which have undergone environmental review pursuant to CEQA as part of a larger project, and for which the final CEQA document (Environmental Impact Report (EIR) or Negative Declaration) finds no significant unavoidable environmental impacts caused by the proposed line or substation," and
- "power line facilities or substations to be located in an existing franchise, road widening setback easement or public utility easement or in a utility corridor designated, precisely mapped and officially adopted pursuant to law by federal, state, or local agencies for which a final Negative Declaration or EIR finds no significant unavoidable environmental impacts."

The City of Manteca issued a Mitigated Negative Declaration for the Paseo West Subdivision dated October 11, 2004 (no SCH review) which found that no significant unavoidable environmental impacts will result from the project.

Public Review Process: Persons or groups may protest the proposed construction if they believe that Pacific Gas and Electric Company has incorrectly applied for an exemption or that the conditions set out in Section III.B.2 of General Order 131-D exist;

- a. There is reasonable possibility that the activity may impact on an environmental resource of hazardous or critical concern where designated, precisely mapped and officially adopted pursuant to law by federal, state, or local agencies; or
- b. The cumulative impact of successive projects of the same type in the same place, over time, is significant; or
- c. There is a reasonable possibility that the activity will have a significant effect on the environment due to unusual circumstances.

Protests should include the following:

1. Your name, mailing address and daytime telephone number.
2. Reference to the CPUC Advice Letter Number and Project Name.
3. A clear description of the reason for the protest.
4. Whether you believe that evidentiary hearings are necessary to resolve factual disputes.

Protests for this project must be filed by August 11, 2005, at the following address:

Director, Energy Division
 California Public Utilities Commission
 505 Van Ness Avenue, Fourth Floor
 San Francisco, California 94102

With a copy mailed to:

David Kraska, Law Department
 Pacific Gas and Electric Company
 P.O. Box 7442
 San Francisco, California 94120

Pacific Gas and Electric Company must respond within five business days of receipt and serve copies of its response on each protestant and the Energy Division. Within 30 days after Pacific Gas and Electric Company has submitted its response, the Executive Director of the CPUC will send you a copy of an Executive Resolution granting or denying the request and stating the reasons for the decision.

Assistance in Filing a Protest: For assistance in filing a protest, contact the CPUC Public Advisor in San Francisco at (415) 703-2074 or -1-866-849-8390 (toll-free); TTY# (415) 703-5258 (toll free); or public.advisor@cpuc.ca.gov

Additional Project Information: To obtain further information on the proposed project, please call Pacific Gas and Electric Company's Project Information Line at (415) 973-5530.

Notice Distribution List

**Lee 60 kilovolt Tap Relocation Project for Paseo West Subdivision,
City of Manteca, County of San Joaquin**

Advice 2688-E

Energy Commission

Mr. Steve Larson, Executive Director
California Energy Commission
1516 Ninth Street, Mail Stop 39
Sacramento, California 95814

Mr. Bob Therleksen, Deputy Director
Energy Facilities Siting & Environmental Protection Division
California Energy Commission
1516 Ninth Street, Mail Stop 39
Sacramento, California 95814

City of Manteca

Mr. Kyle Kollar
Director, Community Development
1001 West Center Street
Manteca, California 95337
(209) 239-8422

Newspapers

Manteca Bulletin Daily Newspaper
531 E. Yosemite Avenue
Manteca California 95336
(209) 249-3500

**PG&E Gas and Electric Advice
Filing List
General Order 96-A, Section III(G)**

ABAG Power Pool	Department of Water & Power City	Northern California Power Agency
Accent Energy	DGS Natural Gas Services	Office of Energy Assessments
Aglet Consumer Alliance	DMM Customer Services	Palo Alto Muni Utilities
Agnews Developmental Center	Douglass & Liddell	PG&E National Energy Group
Ahmed, Ali	Downey, Brand, Seymour & Rohwer	Pinnacle CNG Company
Alcantar & Elsesser	Duke Energy	PITCO
Anderson Donovan & Poole P.C.	Duke Energy North America	Plurimi, Inc.
Applied Power Technologies	Duncan, Virgil E.	PPL EnergyPlus, LLC
APS Energy Services Co Inc	Dutcher, John	Praxair, Inc.
Arter & Hadden LLP	Dynegy Inc.	Price, Roy
Avista Corp	Ellison Schneider	Product Development Dept
Barkovich & Yap, Inc.	Energy Law Group LLP	R. M. Hairston & Company
BART	Energy Management Services, LLC	R. W. Beck & Associates
Bartle Wells Associates	Enron Energy Services	Recon Research
Blue Ridge Gas	Exelon Energy Ohio, Inc	Regional Cogeneration Service
Bohannon Development Co	Exeter Associates	RMC Lonestar
BP Energy Company	Foster Farms	Sacramento Municipal Utility District
Braun & Associates	Foster, Wheeler, Martinez	SCD Energy Solutions
C & H Sugar Co.	Franciscan Mobilehome	Seattle City Light
CA Bldg Industry Association	Future Resources Associates, Inc	Sempra
CA Cotton Ginners & Growers Assoc.	G. A. Krause & Assoc	Sempra Energy
CA League of Food Processors	Gas Transmission Northwest Corporation	Sequoia Union HS Dist
CA Water Service Group	GLJ Energy Publications	SESCO
California Energy Commission	Goodin, MacBride, Squeri, Schlotz &	Sierra Pacific Power Company
California Farm Bureau Federation	Hanna & Morton	Silicon Valley Power
California Gas Acquisition Svcs	Heeg, Peggy A.	Simpson Paper Company
California ISO	Hitachi Global Storage Technologies	Smurfit Stone Container Corp
Calpine	Hogan Manufacturing, Inc	Southern California Edison
Calpine Corp	House, Lon	SPURR
Calpine Gilroy Cogen	Imperial Irrigation District	St. Paul Assoc
Cambridge Energy Research Assoc	Integrated Utility Consulting Group	Stanford University
Cameron McKenna	International Power Technology	Sutherland, Asbill & Brennan
Cardinal Cogen	Interstate Gas Services, Inc.	Tabors Caramanis & Associates
Cellnet Data Systems	J. R. Wood, Inc	Tansev and Associates
Chevron USA Production Co.	JTM, Inc	Tecogen, Inc
Childress, David A.	Kaiser Cement Corp	TFS Energy
City of Glendale	Korea Elec Power Corp	Turlock Irrigation District
City of Healdsburg	Luce, Forward, Hamilton & Scripps	U S Borax, Inc
City of Palo Alto	Marcus, David	United Cogen Inc.
City of Redding	Masonite Corporation	URM Groups
CLECA Law Office	Matthew V. Brady & Associates	Utility Cost Management LLC
Commerce Energy	Maynor, Donald H.	Utility Resource Network
Constellation New Energy	McKenzie & Assoc	Wellhead Electric Company
Cooperative Community Energy	McKenzie & Associates	Western Hub Properties, LLC
CPUC	Meek, Daniel W.	White & Case
Creative Technology	Mirant California, LLC	WMA
Cross Border Inc	Modesto Irrigation Dist	
Crossborder Inc	Morrison & Foerster	
CSC Energy Services	Morse Richard Weisenmiller & Assoc.	
Davis, Wright Tremaine LLP	Navigant Consulting	
Davis, Wright, Tremaine, LLP	New United Motor Mfg, Inc	
Defense Fuel Support Center	Norris & Wong Associates	
Department of the Army	North Coast Solar Resources	