



August 8, 2008

Advice 3315-E

(Pacific Gas and Electric Company ID U 39 E)

Public Utilities Commission of the State of California

Subject: Proposed Revisions to the California Solar Initiative Program Handbook (2)

Pacific Gas and Electric Company (PG&E) hereby submits for filing revisions to the California Solar Initiative (CSI) Handbook. The proposed revisions to the CSI Handbook are provided as Attachment A.

Purpose

Consistent with the procedures established by California Public Utilities Commission (Commission) Decision (D.) 06-08-028, PG&E, on behalf of the California Solar Initiative (CSI) Program Administrators (PA), submits this advice filing to propose a revision to the CSI Handbook. This change is intended to clarify the application process for residential, commercial, government, and non-profit CSI participants. The CSI Program Administrators are comprised of PG&E, Southern California Edison (SCE), and California Center for Sustainable Energy (CCSE).

Background

On August 24, 2006, the Commission issued D.06-08-028, which, among other things, clarified the process for submitting subsequent revisions to the CSI Handbook. In discussion of this process, the Commission also created a CSI Program Forum by stating, "Consistent with our statements in D.06-01-024, we will create a CSI Program Forum, which will provide a public venue for interested parties to identify and discuss ongoing issues related to CSI administration and implementation. The purpose of forum meetings is to provide the opportunity for CSI stakeholders to fashion consensus-based revisions to the CSI Program Handbook. If the group achieves consensus, it may designate one of its members to file a proposed Handbook revision by Advice Letter with the Energy Division. If the group achieves consensus for more substantive program modifications that go

beyond the level of the Program Handbook, it may designate a member to file a petition to modify a Commission order relating to CSI" (D.06-08-028, p.66).

Program Administrators met at their regular working group meetings to discuss these handbook revisions. These proposed revisions were presented at the July 18, 2008 CSI Program Forum.

Proposed CSI Handbook Revisions

Standardize Application Fee Amount

Remove current application fee calculation method and simplify the process by standardizing the application fee amount for non residential customers greater than 10 kW (CEC-AC) based on the following criteria:

kW \geq		kW <		FEE
10	-	50	=	\$1,250
50	-	100	=	\$2,500
100	-	250	=	\$5,000
250	-	500	=	\$10,000
500	-	1,000	=	\$20,000

Reason: The current application fee calculation method is not transparent. The proposed method simplifies the process and no calculation is needed to know the correct application fee to be eligible for the CSI program.

Affected Table(s): 9

Affected Section(s): 4.2.4 / 4.2.5 / 4.7.1.7.2 / 8.2

Remove the Word "Letter" in the CSI Handbook

Remove the word "Letter" from the CSI Handbook and replace it with "notice." The Program Administrators would like the opportunity to explore the possibility of issuing Confirmed Reservation Notices, Incentive Claim Notices, and Payment Notices through other means (emails, postcards, etc.).

Reason: Removing the word "Letter" will allow the Program Administrators to be more flexible in meeting customer needs. It will ultimately decrease paperwork and create better efficiencies in processing applications.

Affected Section(s): 1.3 / 2.2.5 / 3.2 / 4.1.4 / 4.2.6.2 / 4.2.6.3 / 4.2.6.4 / 4.2.7 / 4.2.7.1 / 4.7.2.4 / Appendix 4

Amend Inspection Requirements Section

Remove the section in the CSI Handbook relating to Material/Immaterial /Mechanical/Compliance failures and replace with a chart with the following five categories: within tolerances, outside of tolerances/less than 5% difference in incentive, outside of tolerances/more than 5% difference in incentive, incorrect equipment listed/less than 5% difference in incentive, and incorrect equipment/greater than 5% difference in incentive.

Inspection results	PA Action	Applicant Action	Failure
Results within set tolerance: Tilt $\pm 3^\circ$, Azimuth $\pm 5^\circ$, Shading $\pm 5\%$ of summer shading *Equipment matches	Accepts submitted EPBB Calculator and initiates payment as normal	No Action Necessary	No
Results outside set tolerance, but within 5% of submitted incentive *Equipment matches	Recalculate Incentive based on inspected EPBB calculator results. If new incentive is within 5% of submitted incentive, then notify Applicant of a new incentive amount change.	Applicant accepts the incentive amount change or disputes with PA for resolution	No
Results outside set tolerance and not within 5% of submitted Incentive.	Recalculate Incentive based on inspected EPBB calculator results. If new incentive is not within 5% of submitted incentive, then notify Applicant of a new incentive amount change and issue a	Applicant accepts the incentive amount change or disputes with PA for resolution	Yes

*Equipment matches	Failure.		
Results show that the equipment differs than submitted EPBB, but within 5% of submitted incentive.	Recalculate Incentive based on inspected EPBB calculator results. If incentive is within 5% of submitted incentive, then email Applicant of a new incentive amount change.	Applicant accepts the incentive amount change or disputes with PA for resolution	No
Results show that the equipment differs than submitted EPBB and not within 5% of submitted tolerance.	Recalculate Incentive based on inspected EPBB calculator results. If new incentive is not within 5% of submitted incentive, then notify Applicant of a new incentive amount change and issue a Failure.	Applicant accepts the incentive amount change or disputes with PA for resolution	Yes

Reason: This modification will make inspection requirements and results much more transparent to the Applicant in terms of what is required, the consequences, and the actions associated with the project.

Affected Section(s): 2.9 / 2.9.1 / 4.6.1 / 4.6.3

Remove the Definition of a Strike

Remove the definition of a Strike and allow high volume installers (those with >200 installations per year statewide) to accumulate four failed inspections before being on probation, where 100% field inspection is required. Five failed inspections for a high volume installer will disqualify them from participating in the CSI Program for one year. Once on probation, if no additional failures occur within one calendar year of the fourth failed inspection, all failures will be removed and the entity will be removed from probation. The removal of all failures will also apply to low volume installers as well.

Reason: The current guidelines allow high volume Installers to accumulate an infinite number of failures without accruing a Strike as long as the Installer

responds back to a failure within 60 days. This new requirement will remove the definition of a Strike and only use failures to provide easier implementation of and fairness to the program.

Affected Section(s): 2.9.1

Modify Warranty Requirement

Remove the requirement for the warranty language to be included in the Installation contract. Add a new section in the Incentive Claim Form that has verbiage stating that the Host Customer has received a 10 year warranty for no cost repair and replacement for the generating system. Also include self-install warranty language.

Reason: Further simplify the warranty requirement and not have to require paperwork or additional language.

Affected Table(s): 8

Affected Section(s): 2.4

Affected Forms: Incentive Claim Form

Remove requirement for Installer to register with the Program Administrator and remove the requirement for the Equipment Sellers to register with the CEC

Currently, Installers must register with the Program Administrators (however, no form specified) and Sellers must register with the California Energy Commission (CEC) using the NSHP-4 form. In order to streamline the process, and avoid application suspensions during the renewal period, this requirement is being removed. The PAs will verify that the Installer has an active license with the California Contractors State Licensing Board (CSLB) during Reservation Confirmation.

Reason: Easier to manage and will reduce the number of application suspensions during the renewal period. This will streamline the process by reducing the amount of required paperwork processed from the installer/seller. Reduces the effort required by the PAs to follow up with installer/sellers to encourage registration.

Affected Section(s): 2.1.4 / 2.1.5 (deleted) / 13.2 NSHP-4 form removed

Change of PG&E Address

PG&E is changing the PO Box and Overnight address (TBD).

Reason: PG&E is working on process improvement and changing the PO Box and Overnight Address where applications will be sent and received will create better efficiencies.

Affected Section(s): 9

Eliminate redundancies/confusing paragraphs

Remove the redundant incentive and trigger tables and add references to the trigger tracker

Affected Section(s): 1.4 / 1.4.1 / 1.4.2 / 3.1 / 3.2.1 / 3.2.2 / 3.3.3

Add the option for wire transfer payments per PA discretion

Affected Section(s): 4.4.5.2

Update the EPBB calculator design factor language to incorporate the most recent changes

Affected Section(s): 3.2

Revisions to the CSI Handbook are shown as Attachment A in redline format.

Protests

Anyone wishing to protest this filing may do so by letter sent via U.S. mail, by facsimile or electronically, any of which must be received no later than **August 28, 2008** which is 20 days after the date of this filing. Protests should be mailed to:

CPUC Energy Division
Tariff Files, Room 4005
DMS Branch
505 Van Ness Avenue
San Francisco, California 94102

Facsimile: (415) 703-2200
E-mail: ijnj@cpuc.ca.gov and mas@cpuc.ca.gov

Copies of protests also should be mailed to the attention of the Director, Energy Division, Room 4004, at the address shown above.

The protest also should be sent via U.S. mail (and by facsimile and electronically, if possible) to PG&E at the address shown below on the same date it is mailed or delivered to the Commission:

Brian K. Cherry
Vice President, Regulatory Relations
Pacific Gas and Electric Company
77 Beale Street, Mail Code B10C
P.O. Box 770000
San Francisco, California 94177

Facsimile: (415) 973-7226
E-mail: PGETariffs@pge.com

Effective Date

PG&E requests that this advice filing become effective on regular notice, **September 8, 2008**, which is 31 calendar days after the date of filing.¹

Notice

In accordance with General Order 96-B, Section IV, a copy of this advice letter is being sent electronically and via U.S. mail to parties shown on the attached list and on the service list for R.08-03-008. Address changes to the General Order 96-B service list should be directed to Rose de la Torre at (415) 973-4716. Advice letter filings can also be accessed electronically at: <http://www.pge.com/tariffs>

A handwritten signature in cursive script that reads "Brian K. Cherry / drc".

Vice President, Regulatory Relations

Attachments

Attachment A – CSI Handbook Revisions (Redline Version)

cc: Service List R.08-03-008

¹ The 30th day of the filing date occurs on a weekend; therefore PG&E moves the effective date to the next business day.

CALIFORNIA PUBLIC UTILITIES COMMISSION

ADVICE LETTER FILING SUMMARY ENERGY UTILITY

MUST BE COMPLETED BY UTILITY (Attach additional pages as needed)

Company name/CPUC Utility No. **Pacific Gas and Electric Company (ID U39 M)**

Utility type:

ELC

GAS

PLC

HEAT

WATER

Contact Person: Daren Chan

Phone #: (415) 973-5361

E-mail: D1CT@pge.com

EXPLANATION OF UTILITY TYPE

ELC = Electric

GAS = Gas

PLC = Pipeline

HEAT = Heat

WATER = Water

(Date Filed/ Received Stamp by CPUC)

Advice Letter (AL) #: **3315-E**

Tier: 2

Subject of AL: Proposed Revisions to the California Solar Initiative Program Handbook (2)

Keywords (choose from CPUC listing): CSI

AL filing type: Monthly Quarterly Annual One-Time Other _____

If AL filed in compliance with a Commission order, indicate relevant Decision/Resolution #: D.06-08-028

Does AL replace a withdrawn or rejected AL? If so, identify the prior AL: No

Summarize differences between the AL and the prior withdrawn or rejected AL:

Is AL requesting confidential treatment? If so, what information is the utility seeking confidential treatment for: No

Confidential information will be made available to those who have executed a nondisclosure agreement: N/A

Name(s) and contact information of the person(s) who will provide the nondisclosure agreement and access to the confidential information:

Resolution Required? Yes No

Requested effective date: **September 8, 2008**

No. of tariff sheets: N/A

Estimated system annual revenue effect (%): N/A

Estimated system average rate effect (%): N/A

When rates are affected by AL, include attachment in AL showing average rate effects on customer classes (residential, small commercial, large C/I, agricultural, lighting).

Tariff schedules affected: N/A

Service affected and changes proposed: N/A

Protests, dispositions, and all other correspondence regarding this AL are due no later than 20 days after the date of this filing, unless otherwise authorized by the Commission, and shall be sent to:

CPUC, Energy Division

Tariff Files, Room 4005

DMS Branch

505 Van Ness Ave., San Francisco, CA 94102

jn@cpuc.ca.gov and mas@cpuc.ca.gov

Pacific Gas and Electric Company

Attn: Brian K. Cherry, Vice President, Regulatory Relations

77 Beale Street, Mail Code B10C

P.O. Box 770000


San Francisco, CA 94177

E-mail: PGETariffs@pge.com

ATTACHMENT A

CSI Handbook Revisions (Redline Version)

CALIFORNIA SOLAR INITIATIVE



PROGRAM HANDBOOK

January 2008



Pacific Gas and
Electric Company



SOUTHERN CALIFORNIA
EDISON
An EDISON INTERNATIONAL Company



Center for
Sustainable Energy



SDGE
A Sempra Energy company



Arnold Schwarzenegger, Governor

The California Public Utilities Commission (CPUC) prohibits discrimination in employment, its regulatory programs, and activities on the basis of race, national origin, color, creed, religion, sex, age, disability, veteran status, sexual orientation, gender identity, or associational preference. The CPUC also affirms its commitment to providing equal opportunities and equal access to CPUC regulated facilities and programs. For additional information or to file a complaint, contact the State Personnel Board, Office of Civil Rights, Discrimination Complaint Monitoring and Analysis, Kristen Trimarche (916) 653-1621.

January 2008 Handbook: What's New

Comment [AXY1]: CPUC to update, when approved.

The CPUC has recently made decisions on a number of key areas that will affect the operation of the CSI Program. They change the current Program Handbook in the following ways:

- Non-PV Technologies: Introduce eligibility, estimation, measurement, and metering requirements for non-PV technologies:
 - Definition of non-PV systems: This definition supplements the existing definition of non-PV technologies and details the methodology used to determine the requirements for non-PV technologies. (*Sec 1.8*)
 - Eligibility of non-PV systems: Sets eligibility requirements for non-PV technologies by differentiating between electric generating and electricity displacing technologies, setting forth four categories of eligible technologies (solar space heating, solar driven cooling and non-PV solar electric generators) and stating that all non-PV technologies must be safety and performance tested by a Nationally Recognized Testing Lab. (*Sec 2.2.3*)
 - Non-PV System Capacity Rating: Establishes a methodology for quantifying the capacity of non-PV technologies. (*Sec 2.2.5.1*)
 - Metering Requirements for non-PV technologies: States that non-PV electric displacing thermal metering shall measure the system output with a Btu meter that has a combined accuracy of +/- 5% or better. (*Sec 2.9, Appendix B, Appendix E*)
 - Expected Performance-Based Buydown (EPBB) Incentives: Defines the design factor for non-PV technologies. (*Sec 3.2*)
 - PBI for non-PV Electric Displacing Thermal Systems: Defines the methodology for converting the thermal output of a system into displaced electricity (kWh) for PBI incentive payment. (*Sec 3.3.1*)
 - Non-PV Electric Displacing Thermal System PBI Metering: Sets a minimum accuracy requirement for Btu metering of non-PV electric displacing projects. (*Sec 3.3.1.1*)
 - Surface Orientation for California Locations: Provides surface orientation factor data for ten reference locations in California. (*Appendix F*)
 - Example CEC-AC Rating for Glazed Solar Collectors: Provides an example of how non-PV thermal system capacity can be calculated. (*Appendix G*)

- CSI Contract:
 - A sub-set of terms and conditions from the CSI 2-step and 3-step contracts has been moved from the application to Section 10 of the CSI Program Handbook. (*Sec 10*)

- CSI Program Contract requirement in the Proof of Project Milestone stage of the 3-Step Application Process has been removed from the Application. (Sec 4.2.7.1, Sec 4.7.2 and [Table 9](#))
- Reservation Request Form (RRF) has been revised to include the shortened contract language, and to reference the CSI Handbook during the 2-Step and 3-Step Application Processes. ([Table 8](#), [Table 9](#), Sec 4.1.2, Sec 4.2.4)

Deleted: Table 15

Deleted: Table 14

Deleted: Table 15

→ Proof of Electric Utility Service Requirement: Requirement has been eliminated, and in its place any page of the bill that includes service account name, contact information, and service account number will be sufficient. (Sec 4.7.1.2)

→ Proof of Warranty Requirement: Eliminate requirement for proof of warranty in Incentive Claim section of the process. Proof of warranty is provided in either the solar installation contract or Power Purchase Arrangement (PPA). ([Table 8](#), [Table 9](#), Sec 4.1.5, Sec 4.4.3.1, Sec 4.7.3)

Deleted: Table 14

Deleted: Table 15

→ Project Cost Breakdown Worksheet: Remove Project Cost Breakdown Worksheet in the Proof of Project Milestone stage of the 3-Step Application Process. ([Table 9](#), Sec 4.2.7.1, Sec 4.7.2)

Deleted: Table 15

→ Building Permit Requirement: Remove Building Permit Requirement in the Incentive Claim stage of the 2-Step and 3-Step Application Processes. ([Table 8](#), [Table 9](#), Sec 4.1.5, Sec 4.4.3.1, Sec 4.7.3)

Deleted: Table 14

Deleted: Table 15

→ Application for Interconnection and Net Energy Metering Agreement: Remove requirement for a copy of the completed Interconnection Application from Proof of Project Milestone stage of the 3-Step Application Process. ([Table 9](#), Sec 4.7.3.2)

Deleted: Table 15

→ Modify Time Limit for Retroactive Incentives: A customer would still be eligible for an incentive if his/her reservation request application is received within 12 months of the dated final interconnection authorization letter. However, after 12 months, the project will no longer be eligible for an incentive. (Sec 2.6)

→ Incentive Calculation Worksheet: Remove the requirement to complete a revised Incentive Calculation Worksheet in the Proof of Project Milestone stage of the 3-Step Application Process. ([Table 9](#), Sec 4.2.7.1)

Deleted: Table 15

→ System Sizing: Remove the requirement for "Revised System Sizing Calculation" worksheet, and substitute with a "Revised EPBB Calculation Printout (if applicable)" in the Proof of Project Milestone stage of the 3-step Application Process. ([Table 9](#), Sec 4.2.7.1)

Deleted: Table 15

→ EPBB Calculation Printout: Add "Revised EPBB Calculation Printout (if applicable)" in Incentive Claim stage of the 2-Step and 3-Step Application Processes. ([Table 8](#), [Table 9](#), Sec 4.1.5, Sec 4.4.3.1)

Deleted: Table 14

Deleted: Table 15

→ Third Party Payment Form: Remove authorization for 3rd party payment information from the reservation request package forms. Add an area to the ICF, with the payee information, that applicants sign to Authorize payment to a 3rd party. (CSI Program Application)

- Meter Warranty Requirements: Meter warranty requirement will remain at one-year. If the meter is integrated into the inverter, then the applicable warranty is that of the inverter itself. (Sec 1.6, Sec 2.2.4, Sec 2.4, Sec 8.2)
- Performance Monitoring and Reporting Service (PMRS) Exemption Documentation: Clarify documentation requirements for PMRS exemption requests. (Sec 4.7.3.2)
- On-Site Electrical Load for Residential Homes Smaller than 10 kW: For homes that cannot determine electrical load history, due to extensive remodeling, the calculated on-site electrical load will be at 2 watts (CEC-AC) per square foot for systems less than or equal to 10kW. For systems larger than 10kW engineering calculations will still be required. (Sec 2.2.3)
- System Sizing Based on Future Growth: Estimate based on 2 watts (CEC-AC) per square foot or engineering calculation for residential systems of 10 kW or less. Remove Non-Crystalline Cells calculation – This calculation is not needed as the new EPBB calculation is implemented. (Sec 2.2.5.1, Sec 2.2.5)
- Interconnection to the Electric Utility Distribution System: The local electric utility service provider will convey proof of interconnection to the PA. (Sec 2.6)
- Customer Tax Status: Payee must submit his/her tax ID number except in the case where the incentive is for a Dwelling Unit, in which case, the tax ID number will not be required. The following definitions have been added to the CSI Handbook: “Payee - The person, or company, to whom the incentive payment check(s) is made payable.” “Dwelling Unit – A house, apartment, condominium, mobile home, boat, or similar property.” (Sec 4.4.5, Sec 8.2)
- Host Customer is Not on the Electric Service Provider Account: The PA will request a letter explaining the relationship of Host Customer to the person who is on the utility service bill and interconnection agreement will be sent to the PA with the application. (Sec 2.1.1)
- Systems that Fail Inspections: Installers can be removed from inspection failure probation if no additional inspection failures occur within one calendar year of [the second or fourth \(for high volume installers\)](#) failed inspection. (Sec 2.9.1)
- Incentives for Residential Installations: The 100 kW CEC-AC rating does not adjust once the PBI threshold changes. Replace ‘is less than 100kW CEC-AC’ with “is within EPBB size eligibility”. (Sec 3.2.1)
- Step # 2: Submit ICF Package: Add statement: “The online tool can be used to assist at this stage even if it had not been used for the original Reservation Request application Package.” (Sec 4.1.5)
- Step #3: Submit Incentive Claim Form Package: Add statement: “The online tool can be used to assist at this stage even if it had not been used for the original Reservation Request application Package.” (Sec 4.2.8)
- Maximum System Sizing Requirement: Revise maximum system requirement by eliminating capacity factor from the maximum system sizing formula. (Sec 2.2.3)

New California Solar Initiative Resources

- Program Administrators have launched a web-based application tool to speed requests for the incentives and present program data. The tool is available at csi.powerclerk.com.
- CSI Program Administrators hold monthly training opportunities to clarify the administrative processes, shading methodology, the online application database, and other program information. See each Program Administrator's website to find the next training opportunity.

Table of Contents

<u>1. Introduction: California Solar Initiative Program</u>	<u>1</u>
<u>1.1 Program Background.....</u>	<u>2</u>
<u>1.1.1 Transition from the Emerging Renewables Program (ERP).....</u>	<u>3</u>
<u>1.1.2 Self-Generation Incentive Program (SGIP).....</u>	<u>3</u>
<u>1.2 CSI Program Budget.....</u>	<u>4</u>
<u>1.2.1 Special Funding for Affordable Housing Projects.....</u>	<u>5</u>
<u>1.2.2 Non-photovoltaic (non-PV) technologies</u>	<u>5</u>
<u>1.3 MW Targets and Step Triggers for CSI Program</u>	<u>5</u>
<u>1.4 Incentive Structure.....</u>	<u>6</u>
<u>1.4.1 Expected Performance Based Buydown (EPBB) Incentives.....</u>	<u>7</u>
<u>1.4.2 Performance Based Incentives (PBI).....</u>	<u>7</u>
<u>1.5 CSI Program Forum.....</u>	<u>8</u>
<u>1.6 Future Incentive Program Modifications.....</u>	<u>9</u>
<u>1.7 Non-PV Systems</u>	<u>9</u>
<u>2. Program Eligibility Criteria and Requirements</u>	<u>10</u>
<u>2.1 The Participants in the CSI Program.....</u>	<u>10</u>
<u>2.1.1 Host Customer</u>	<u>10</u>
<u>2.1.2 System Owner</u>	<u>11</u>
<u>2.1.3 Applicant</u>	<u>11</u>
<u>2.1.4 Installer</u>	<u>12</u>
<u>2.2 Generator System Equipment Eligibility</u>	<u>12</u>

Table of Contents

2.2.1	New Equipment, Not Pilot or Demonstration Systems	12
2.2.2	Eligibility of Replacement PV Systems	13
2.2.3	Eligibility of Non-PV Systems	13
2.2.4	Equipment Must Serve On-Site Electrical Load	13
2.2.5	Equipment Certifications and Rating Criteria	14
2.2.6	Non-PV System Capacity Rating	15
2.2.7	System Size	16
2.3	Energy-Efficiency Requirements	18
2.4	Warranty Requirements	20
2.5	Performance and Permanency Requirements	21
2.6	Interconnection to the Electric Utility Distribution System	22
2.7	Time of Use Rates	22
2.8	Metering Requirements	22
2.9	Inspection Requirements	23
2.9.1	Systems that Fail Inspections	23
2.9.2	Inspector Training Criteria	25
3.	California Solar Initiative Incentive Structure	26
3.1	CSI Program Incentive Trigger Mechanism	27
3.2	Expected Performance Based Buydown (EPBB) Incentives	28
3.2.1	Incentives for Residential Installations	30
3.2.2	Incentives for Non-Residential Installations	31

Table of Contents

<u>3.3 Performance Based Incentives (PBI)</u>	<u>31</u>
<u>3.3.1 PBI for Non-PV Electric Displacing Thermal Systems</u>	<u>32</u>
<u>3.3.2 PBI for Residential Projects</u>	<u>33</u>
<u>3.3.3 PBI for Non-Residential Projects</u>	<u>33</u>
<u>3.4 Incentive Limitations</u>	<u>34</u>
<u>3.4.1 Total Eligible Project Costs</u>	<u>34</u>
<u>3.4.2 Other Incentives or Rebates</u>	<u>34</u>
<u>3.4.3 Right to Audit Final Project Costs</u>	<u>35</u>
<u>3.4.4 Site and Host Customer Limitations</u>	<u>35</u>
<u>3.5 CSI Program Database</u>	<u>36</u>
<u>4. Application Process for California Solar Initiative Projects</u>	<u>37</u>
<u>4.1 Residential (All) and Small Non-Residential Projects (< 10 kW)</u>	<u>37</u>
<u>4.1.1 Two-Step Process for Residential and Small Non-Residential Applicants</u>	<u>38</u>
<u>4.1.2 Step # 1: Submit Reservation Request Application Package</u>	<u>39</u>
<u>4.1.3 Incomplete Reservation Requests</u>	<u>40</u>
<u>4.1.4 Approval of Reservation Request</u>	<u>40</u>
<u>4.1.5 Step # 2: Submit Incentive Claim Form Package</u>	<u>41</u>
<u>4.2 Non-Residential Projects (≥10 kW) and PBI Projects</u>	<u>41</u>
<u>4.2.1 Application Process Flow Chart for Commercial Industrial Applicants (≥10 kW)</u> <u>42</u>	

Table of Contents

4.2.2 Application Process Flow Chart for Government, Non-Profit, and Public Entities (≥10 kW)	43
4.2.3 Three-Step Process for Non-Residential Applicants (≥ 10 kW).....	44
4.2.4 Step # 1: Request to Reserve Funding.....	46
4.2.5 Application Fee Process.....	47
4.2.6 Approval of Reservation Request.....	49
4.2.7 Step # 2: Submit Proof of Project Milestone Package	50
4.2.8 Step # 3: Submit Incentive Claim Form Package.....	52
4.3 Changes to Reservations.....	52
4.3.1 Extending the Reservation Expiration Date	52
4.4 Incentive Payment Process	53
4.4.1 Requesting an Incentive Payment.....	53
4.4.2 Assignment of Incentive Payment to Third Party.....	53
4.4.3 Incentive Payment Claim Form Package.....	53
4.4.4 Submitting an Incentive Claim Form Package	54
4.4.5 Incentive Check Payment and Terms.....	54
4.5 System Changes Affecting Incentive Amount	56
4.6 Field Inspection	56
4.6.1 Field Inspections	56
4.6.2 Trained Inspectors	57
4.6.3 Failed Field Inspection	57

Table of Contents


4.7 Application Forms and Documentation	57
4.7.1 Reservation Request Package and Required Documentation	58
4.7.2 Proof of Project Milestone Package (for Projects on a Three-Step Process)	60
4.7.3 Incentive Claim Form Package.....	61
5. Other Installation Requirements and Continuing Site Access Requirements.....	63
5.1 Connection to the Utility Distribution System.....	63
5.1.1 How to Apply For Interconnection of CSI Projects	63
6. Additional Information	65
6.1 Circumstances Requiring Additional Documentation.....	65
6.1.1 Owner or Self-Installed System.....	65
6.1.2 Contractor-Installed System with Separate Seller and Installer	65
7. Measurement and Evaluation Requirements.....	66
8. Definitions and Glossary	67
8.1 Acronyms	67
8.2 Definitions.....	69
9. Program Administrator Contact Information	81
10. Additional Program Requirements	82
11. Appendix A: Description of Total Eligible Project Costs.....	84
12. Appendix B: Metering Requirements.....	85
12.1 Minimum Meter Requirements.....	86
12.1.1 Meter Type.....	86

Table of Contents

12.1.2 Meter Accuracy	86
12.1.3 Meter Measurement	86
12.1.4 Meter Testing Standards	86
12.1.5 Meter Certification	86
12.1.6 Meter Communication / Data Transfer Protocols	87
12.1.7 Meter Data Access	87
12.1.8 Meter Display	87
12.1.9 Meter Memory and Storage	87
12.1.10 Thermal Meters	87
12.2 Minimum Communication Requirements	88
12.3 Minimum Performance Monitoring & Reporting Capability Requirements	88
12.3.1 Required Solar Performance / Output Data	88
12.3.2 Minimum Report Delivery Requirements	89
12.3.3 Time Granularity of Acquired Data	89
12.3.4 Frequency of Data Collection	89
12.3.5 Minimum Reporting Requirements	89
12.3.6 Frequency of Data Reporting	89
12.3.7 Data Retention Policy	89
12.3.8 Performance Data Provider Requirements	89
12.4 Eligibility of Performance Monitoring & Reporting Service Providers	90
12.5 Eligible Recipients of Information	90

Table of Contents

12.5.1 System Owner	90
12.5.2 Program Administrators.....	90
12.5.3 Data Privacy.....	90
12.6 Advanced Metering Infrastructure (AMI) Coordination	90
12.7 Overall Cost Constraint.....	90
12.7.1 EPBB	90
12.7.2 PBI.....	91
13. Appendix C: Supplemental Forms.....	92
13.1 Current Program Contract Terms.....	92
14. Appendix D: California IOU SPC Tables (ref 2007 SPC Procedures Manual, Appendix C, January 31, 2007).....	95
15. Appendix E – Commercial Btu Meter Accuracy Requirements	97
16. Appendix F – Surface Orientation Factors for California Locations	98
17. Appendix G – Example PTC Rating for Glazed Solar Collector.....	100
18. Appendix H -- Interim CSI PBI Data Transfer Rules.....	102



1. Introduction: California Solar Initiative Program

This California Solar Initiative (CSI) Program Handbook describes the detailed requirements for receiving funding for the installation and operation of solar photovoltaic (PV) projects under the California Public Utilities Commission (CPUC or Commission)-managed incentive program. As authorized by the CPUC and Senate Bill 1 (SB 1),¹ the CPUC CSI Program has a total budget of \$2.167² billion to be used over 10 years.³ As noted in Section 1.1, the California Energy Commission manages a separate solar incentive program for new homes and maintains a separate Program Guidebook.

Beginning on January 1, 2007, the CSI Program paid performance-based incentives (PBI) for solar projects equal to or greater than 100 kilowatts (kW⁴), with monthly payments based on recorded kW hours (kWh) of solar power produced over a 5-year period. PBI payments are a flat per-kWh payment for PV system output. The CSI Program currently pays incentives to solar projects less than 50 kW through an up-front incentive, known as an expected performance-based buydown (EPBB). An EPBB payment is based on an estimate of the system's future performance. These expected-performance incentives combine the benefits of rewarding performance of the PV system with the administrative simplicity of a one-time incentive paid at the time of project installation. Any system under the EPBB/PBI cutoff can choose PBI payments. However, systems over the cutoff cannot apply for the EPBB payment. On January 1, 2008, all projects 50 kW or larger must take the PBI.

The solar project's Site must be within the service territory of and receive retail level electric service from Pacific Gas and Electric (PG&E), Southern California Edison (SCE), or San Diego Gas & Electric (SDG&E). Municipal electric utility customers are not eligible to receive incentives from the designated Program Administrators.

Responsibility for administration of the CSI Program is shared by the following three Program Administrators:

- PG&E—PG&E customers
- SCE—SCE customers
- California Center for Sustainable Energy (CCSE)—as a contractor to SDG&E for its customers.

Other notable CSI Program features include:

- A statewide on-line application process and database
- An open process to modify the CSI Program Handbook

¹ Chapter 132, Statutes of 2006 (SB1, Murray)

² CPUC D. 06-12-033, December 14, 2006

³ CPUC D. 06-08-028, August 24, 2006.

⁴ Throughout this Handbook, the use of kW refers to the CEC-AC wattage ratings of kW alternating current inverter output.

-
- A regular CSI Program Forum to provide a process for stakeholder involvement in the ongoing implementation of the CSI Program

Other components of the CSI Program that are still under development include:

- An incentive program for low-income residents
- A research and development program for solar technologies

To apply for a CSI incentive for your solar system, contact the Program Administrator for your area (Section 9) or visit www.GoSolarCalifornia.ca.gov.

1.1 Program Background

In Decision (D.) 06-01-024, the CPUC, in collaboration with the California Energy Commission (Energy Commission), established the California Solar Initiative program, an ambitious incentive program with the goal of ensuring that 3,000 MW of new solar facilities are installed in homes and businesses in California by 2017.⁵ The CSI supplants the solar portion of two former solar incentive programs, the Emerging Renewables Program (ERP) and the Self-Generation Incentive Program (SGIP). In D.06-08-028, the CPUC established implementation details for its portion of the CSI Program, particularly the adoption of the PBI structure. On August 21, 2006, the Governor signed SB 1, which directs the CPUC and the Energy Commission to implement the CSI Program consistent with specific requirements and budget limits set forth in the legislation. On December 14, 2006, the CPUC adopted Decision (D.) 06-12-033, which reconciled its previous decisions with the requirements contained within SB1.

The Energy Commission administers a separate, but coordinated program, the New Solar Homes Partnership (NSHP) that offers financial incentives for solar PV systems installed on new homes. New construction defined as follows: the entire building structure is subject to current Title 24 building efficiency standards and the certificate of occupancy has not yet been issued. Information regarding the NSHP and CSI Programs can be found on www.GoSolarCalifornia.ca.gov.

The Energy Commission manages solar PV incentives for all new residential construction, including:

1. new production and custom single family housing
2. new production and custom multi-family housing
3. the residential portion of *new* residential/nonresidential mixed use buildings
4. new owner/builder houses
5. new affordable housing (single-family and multi-family construction, including the common and service areas associated with the residential units)
6. the residential portion of new affordable multi-family residential/nonresidential mixed use buildings (including the common and service areas associated with the residential units)

⁵ The Energy Commission collaborated with the CPUC in the creation of CSI by this Commission order.

The CPUC manages solar PV incentives for:

1. all existing housing (i.e., housing that has received a Permit of Occupancy from the Building Department before applying for CSI incentives; entire structure not subject to Title 24 Building Efficiency Standards)
2. all new commercial building types, including (but not limited to) industrial, agricultural, government (including schools and municipal entities), and non-profit buildings.
3. all existing commercial building types, including (but not limited to) industrial, agricultural, government (including schools and municipal entities), and non-profit buildings.
4. the commercial portion of any *new* residential/nonresidential mixed use building
5. the commercial portion of any *new* affordable housing residential/nonresidential mixed-use building

For mixed use buildings, where the property contains commercial and residential uses (whether affordable housing or market rate), the Energy Commission will manage incentives for the new residential portion and the CPUC will offer incentives for the nonresidential or existing residential portion. The applicant must submit separate applications to the Energy Commission and CPUC programs. According to CPUC requirements, the residential and commercial PV systems must be separate. Where the non-residential portion is 10% or less of the total building space, NSHP will provide incentives for the entire project. Where there is uncertainty over the scope, the Program Administrator will use its discretion in working with the applicant.

1.1.1 Transition from the Emerging Renewables Program (ERP)

Until January 1, 2007, the Energy Commission administered the ERP to provide consumers with financial incentives to install renewable energy systems on their property, including solar.

As of January 1, 2007, the CSI Program and the NSHP programs replaced the ERP program to offer monetary incentives for solar PV systems under 1 MW. The ERP will remain in effect to provide financial incentives for qualifying non-PV self-generation equipment.

ERP applications received by the Energy Commission prior to December 31, 2006 will remain under the oversight of the Energy Commission's ERP program, regardless of whether the project will be completed after January 1, 2007. Current ERP applicants with reservations for PV systems may opt to withdraw their ERP program application and apply for the CSI Program or NSHP program, provided that the project meets the eligibility requirements of the respective programs. Rules governing the withdrawal or cancellation of the ERP project will apply.

1.1.2 Self-Generation Incentive Program (SGIP)

As of January 1, 2007, the CSI Program and the NSHP replaced the SGIP's prior monetary incentives for solar PV systems under 1 MW that displace electricity. At that time, the SGIP complemented the CSI by providing incentive funding to larger renewable and nonrenewable self-generation units up to the first 1 MW in capacity.

The SGIP remains in effect to provide financial incentives for qualifying non-PV self-generation equipment. SGIP provides incentives for the installation of new, qualifying self-generation equipment installed to meet all or a portion of the electric energy needs of a site.

SGIP applications received prior to December 31, 2006 will remain under the oversight of the SGIP Program Administrators, regardless of whether the project will be completed after January 1, 2007, provided that all program requirements and guidelines are met. Current SGIP applicants with reservations for PV systems may opt to withdraw their program application and apply for either the CSI Program or NSHP program, provided that the project meets the eligibility requirements of the respective programs. Rules governing the withdrawal or cancellation of the SGIP project will apply.

Applicants who have up to 1 MW of solar installed or approved through the SGIP program may be eligible for an additional 1 MW CEC-AC of new generation under the CSI Program. Additionally, the CSI Program will accept applications up to 5 MW with incentives being paid only on the first MW installed under the program.

Gas-displacing solar technologies are not eligible for CSI incentives, but they may become eligible in the future under SGIP.

1.2 CSI Program Budget

This section provides an overview of the CSI Program budget as authorized by the CPUC and reviews the megawatt (MW) targets for the program.

The CSI Program budget for each Program Administrator is as shown in Table 1.

Table 1
CSI Program Budget by Program Administrator, 2007-2016

Program Administrator	% of Total Budget	Budget (in millions)
PG&E	43.7%	\$ 946
SCE	46%	\$ 996
CCSE ⁶ /SDG&E	10.3%	\$ 223
Total	100%	\$ 2,165

All customer segments are eligible for the CSI Program. Table 2 demonstrates the MW expected to be accounted for by customer segments in the CSI Program.

Table 2
CSI MW Allocations by Customer Sector

Customer Sector	MW	Percent
-----------------	----	---------

⁶ CCSE is administering the program in SDG&E utility territory.

Residential	577.50	33%
Non-Residential	1172.50	67%
Total	1,750.00	100%

1.2.1 Special Funding for Affordable Housing Projects

The CPUC has allocated 10 percent of the overall CSI Program budget, or \$216 million, to incentives for affordable housing/low-income residents. As the CPUC develops these programs, more details will become available through Phase II of the CSI proceeding at the CPUC (Rulemaking (R.) 06-03-004) and on the CPUC CSI website.

1.2.2 Non-photovoltaic (non-PV) technologies

Non-photovoltaic (non-PV) technologies include, but are not limited to, electric displacing solar thermal (generally defined as solar forced air heating and solar cooler or air conditioning) and electric generating solar thermal (generally defined as dish Stirling, solar trough and concentrating solar technologies). The CPUC has included the budget for non-PV technologies within the overall CSI budget, but capped the budget for electric displacing non-PV technologies at \$100.8 million. Any MW from non-PV technologies will be counted toward and paid at the current MW trigger level.

1.3 MW Targets and Step Triggers for CSI Program

The incentive levels for the CSI Program will be reduced automatically over the duration of the program based on the volume of MW of solar reservations issued. Projects are counted toward the MW trigger once they are deemed eligible, have paid an application fee (if applicable), and have received [notice](#) their reservation has been approved. The solar incentive levels available at any particular time may vary by Program Administrator service territory, depending on the pace of solar demand in that territory. Additionally, incentive levels may differ for Residential and Non-Residential customer sectors based on the demand for those customer segments. Table 3 displays the MW targets by Program Administrator service territory and customer class. The status of each Program Administrator's trigger, and therefore incentive level, is shown at www.csi-trigger.com. See Section 3.1 for more detail.

Deleted: notice

Table 3
CSI MW Targets by Program Administrator and Customer Class

Step	MW in Step	PG&E (MW)		SCE (MW)		CCSE (MW)	
		Res	Non-Res	Res	Non-Res	Res	Non-Res
1	50	-	-	-	-	-	-
2	70	10.1	20.5	10.6	21.6	2.4	4.8
3	100	14.4	29.3	15.2	30.8	3.4	6.9
4	130	18.7	38.1	19.7	40.1	4.4	9.0
5	160	23.1	46.8	24.3	49.3	5.4	11.1
6	190	27.4	55.6	28.8	58.6	6.5	13.1
7	215	31.0	62.9	32.6	66.3	7.3	14.8
8	250	36.1	73.2	38.0	77.1	8.5	17.3
9	285	41.1	83.4	43.3	87.8	9.7	19.7
10	350	50.5	102.5	53.1	107.9	11.9	24.2
Total	1750	252.4	512.3	265.6	539.5	59.5	120.8
Total by Utility		764.8		805.0		180.3	
Percent		43.7%		46.0%		10.3%	

1.4 Incentive Structure

The program offers two types of incentives: EPBB and PBI. The EPBB incentives are paid based on verified solar system characteristics such as location, system size, shading, and orientation. The PBI incentive is a flat cents-per-kWh payment for all output from a solar system over its initial 5 years of operation. The incentive payment levels will be reduced automatically over the duration of the CSI Program in 10 steps, based on the volume of MW of solar reservations issued by each Program Administrator. The EPBB and PBI levels are directly tied to the 10 steps as outlined in Table 4. [See Section 3.1 for more detail.](#)

**Table 4
PBI and EPBB Payment Amounts by Step**

MW Step	Statewide MW in Step	EBPP Payments (per watt)			PBI Payments (per kWh)		
		Residential	Commercial	Gov't/ Nonprofit	Residential	Commercial	Gov't/ Nonprofit
1	50 ⁷	n/a	n/a	n/a	n/a	n/a	n/a
2	70	\$ 2.50	\$ 2.50	\$ 3.25	\$ 0.39	\$ 0.39	\$ 0.50
3	100	\$ 2.20	\$ 2.20	\$ 2.95	\$ 0.34	\$ 0.34	\$ 0.46
4	130	\$ 1.90	\$ 1.90	\$ 2.65	\$ 0.26	\$ 0.26	\$ 0.37
5	160	\$ 1.55	\$ 1.55	\$ 2.30	\$ 0.22	\$ 0.22	\$ 0.32
6	190	\$ 1.10	\$ 1.10	\$ 1.85	\$ 0.15	\$ 0.15	\$ 0.26
7	215	\$ 0.65	\$ 0.65	\$ 1.40	\$ 0.09	\$ 0.09	\$ 0.19
8	250	\$ 0.35	\$ 0.35	\$ 1.10	\$ 0.05	\$ 0.05	\$ 0.15
9	285	\$ 0.25	\$ 0.25	\$ 0.90	\$ 0.03	\$ 0.03	\$ 0.12
10	350	\$ 0.20	\$ 0.20	\$ 0.70	\$ 0.03	\$ 0.03	\$ 0.10

For the purpose of the CSI Program, commercial sectors include agricultural and industrial customers.

1.4.1 Expected Performance Based Buydown (EPBB) Incentives

The EPBB pays a one-time up-front incentive (\$/W) based on a system's estimated future performance. The Program Administrators will use the Energy Commission's CEC-AC method to determine the system's capacity rating. The system rating will be multiplied by a design factor that will consider certain factors (i.e., location, orientation, and shading) that have an influence on system performance. EPBB is available in 2007 to projects under 100 kW, to projects under 50 kW beginning in 2008, and to projects under 30 kW beginning in 2010. [See Section 3.2 for more detail.](#)

For projects with Building Integrated Photovoltaic systems (BIPV), applicants can pursue either the EPBB or Performance-Based Incentive if eligible by all other program requirements.

1.4.2 Performance Based Incentives (PBI)

The CSI Program will apply a PBI structure to all systems with a rated capacity equal to or greater than 100 kW CEC-AC beginning on January 1, 2007, although any other size system may also opt into the PBI structure. On January 1, 2008, PBI will apply to systems equal to or greater than 50 kW CEC-AC. Beginning in January 2010, systems equal to or greater than 30 kW CEC-AC must take the PBI incentive structure. The PBI payments will be made over a 5-

⁷ The first 50 MW are allocated under the 2006 Self-Generation Incentive Program (SGIP) and are not pro-rated by customer class or service territory. In 2006, most residential systems participated in the Energy Commission's Emerging Renewables Program (ERP).

year period following system installation, submission, and approval of incentive claim materials. Payments will be made on a monthly basis. These payments will be based on the per-kWh incentive rate and the actual energy (kWh) produced in that time period. Once the reservation is confirmed, the incentive rate will remain fixed during the 5-year payment period. [See Section 3.3 for more detail.](#)

The Program Administrator for each utility shall estimate the total 5-year PBI payments for completed projects and deposit this amount in an interest-bearing balancing account to ensure fund security over the period of the expected PBI payments.

1.5 CSI Program Forum

CPUC D. 06-08-028 directed that a CSI Program Forum should “provide a public venue for interested parties to identify and discuss ongoing issues related to CSI administration and implementation.” The Program Forum will be used to explore needed updates to this Program Handbook, as well as substantive program modifications, incentives for non-PV solar projects, and energy efficiency requirements. Forum meetings will provide the opportunity for CSI stakeholders to develop consensus-based revisions to the CSI Program Handbook and to the CSI Program itself. Beginning in 2007, the Program Administrators and the CPUC Energy Division will convene, facilitate, and develop the agenda for regular public meetings of the Forum, hosted by each Administrator, in turn. It is anticipated that the meetings will be held at least quarterly, with more frequent meetings as needed during the initial phase of implementing the program.

The CSI Program Handbook is summary of the CSI Program policies, as established by Commission decision and California State Law. To the extent that the CSI Program Handbook reflects program policies were established by Commission decision, it cannot be modified except by Commission order. If a Commission order changes some part of the Program Handbook, the Energy Division is delegated to ensure that the text of the Program Handbook gets modified to maintain its consistency with Commission policy. In addition, some aspects of program implementation were designated by the Commission to the Energy Division and/or the Program Administrators to develop in the CSI Program Handbook process, including through the Program Forum. To the extent that Program Forum process develops consensus-based recommendations for changes to the CSI Program Handbook, the Program Administrators can submit those changes to the Commission via an Advice Letter. If the changes submitted via Advice Letter are approved, the Energy Division is delegated to ensure that the text of the Program Handbook gets modified to maintain consistency with the approved changes. The Energy Division will always distribute any new versions of the CSI Program Handbook via the CPUC Service List, and it will be posted on the GoSolarCalifornia.ca.gov website.

If the Program Forum achieves consensus for more substantive program modifications that go beyond the level of the Program Handbook, the Forum may designate a member to file a petition to modify a Commission order or decision relating to the CSI Program.⁸

⁸ The CSI Program Forum is described in detail on pages 65-67 of D. 06-08-028.

1.6 Future Incentive Program Modifications

This edition of the Program Handbook is in effect as the only CPUC-approved Program Handbook until modified again by the CPUC. Should the CPUC and its Program Administrators change administration methods after this edition's release that necessitate changes to the handbook language, the Program Administrators will post one, joint, statewide "CSI Administration Addendum" factsheet next to the CSI Program Handbook on <http://www.gosolarcalifornia.ca.gov/documents/index.html> and on their own websites.

The following modifications to the CSI Program are anticipated:

- PBI will be applied to all systems 30 kW or larger beginning in 2010.
- The default capacity factor will increase from 18 to 20 percent, beginning with Step 4 of the Incentive Adjustment Mechanism.
- Time-differentiated PBI may be investigated for later stages of the program.
- Updated energy efficiency requirements.
- A revised handbook after future requests to change CSI processes are approved by the CPUC by Advice Letter.

1.7 Non-PV Systems

- In D.06-01-024, the Commission stated its intent that all solar technologies should qualify for incentives, including solar PV, solar thermal, solar heating, and air conditioning and concentrating solar technologies⁹. In D.06-12-033, the Commission directed the CSI Program administrators to assign or hire technical experts to address estimation, measurement and metering of non-PV projects that displace electricity.

⁹ The Commission noted the need for further workshops and comments to obtain further information about the non-PV solar technologies before committing to provide incentives to them.

2. Program Eligibility Criteria and Requirements

The California Solar Initiative (CSI) program offers monetary incentives for eligible systems up to the first 1,000 kW (1 MW) CEC-AC of generating capacity or displaced grid electric load. To qualify for incentives, all CSI Program eligibility criteria must be satisfied. The effective dates for the CSI Program are January 1, 2007 through December 31, 2016, or until the CSI Program budget has been fully reserved for each Program Administrator.

2.1 The Participants in the CSI Program

Any retail electric distribution customer of Pacific Gas and Electric (PG&E), Southern California Edison (SCE), or San Diego Gas & Electric (SDG&E) is eligible to install a solar project and receive incentives from the CSI Program. Within the nomenclature of the CSI Program, the person who applies for an incentive will be referred to as a Host Customer, a System Owner, and/or Applicant. Other participants include Installers and Equipment Sellers.

2.1.1 Host Customer

Any retail electric distribution customer of PG&E, SCE or SDG&E is eligible to install a solar project and receive incentives from the CSI Program and can, therefore, be a Host Customer.

The Host Customer must be the utility customer of record at the location where the generating equipment will be located. Any class of customer (industrial, agricultural, commercial, or residential) is eligible to be a Host Customer. The project's Site must be within the service territory of, and receive retail level electric service¹⁰ from, PG&E, SCE, or SDG&E. Municipal electric utility customers are not eligible to receive incentives from the designated Program Administrators. If a Host Customer ceases to be a retail level electric distribution customer of PG&E, SCE, or SDG&E, they will not be eligible to receive any remaining unpaid PBI payments.

In circumstances where the Host Customer is not on the Electric Service Provider Account, a letter of explanation must be sent to the Program Administrator explaining the relationship of the Host Customer to the person who is on the utility service bill and interconnection agreement.

The Host Customer becomes the incentive reservation holder. The Host Customer may act as the Applicant and/or System Owner. The Host Customer alone will retain sole rights to the incentive reservation and corresponding incentive reservation number. A reservation for a specific Site is not transferable (See Section 4.3.2). The Host Customer has the right to designate the Applicant, energy services provider, and/or system installer to act on their behalf. However, the Host Customer shall be party to the CSI Program contract.

The Host Customer or Applicant is encouraged to submit the CSI application as early as possible in the process in order to confirm their reservations amount. All projects must meet all eligibility requirements in order to receive the CSI incentives.

¹⁰ "...retail level electric service..." means that the Host Customer pays for and receives distribution services, as defined by their respective utility rate schedule.

The following are *not* eligible for incentives under the CSI Program:

- Customers who have entered into utility contracts for distributed generation (DG) services (e.g., DG installed as a distribution upgrade or replacement deferral) and who are receiving payment for those services. This does not include third-party ownership arrangements, i.e., power purchase agreements, which are allowed.
- Customers who have entered into agreements that entail the export and sale of electricity from the Host Customer Site. This does not include net energy metering agreements, which are allowed.
- Any portion of customer load that is committed to electric utility interruptible, curtailable rate schedules, programs, or any other state agency-sponsored interruptible, curtailable, or demand-response programs. For electric utility customers who are on an interruptible rate, only the portion of their electric load that is designated as firm service is eligible for the CSI Program. Customers must agree to maintain the firm service level at or above capacity of the proposed solar system for the duration of the required applicable warranty period (see Section 2.5). Customers may submit a letter requesting an exemption to the firm service rule if they plan to terminate or reduce a portion of their interruptible load.
- Publicly owned or investor-owned gas, electricity distribution utilities or any electrical corporation (ref. Public Utility Code 218) that generates or purchases electricity or natural gas for wholesale or retail sales.
- Residential new construction systems are not eligible for the CSI Program and should apply to the California Energy Commission's New Solar Homes Partnership Program.

2.1.2 System Owner

The System Owner is the owner of the generating equipment at the time the incentive is paid. For example, when a vendor sells a turnkey system to a Host Customer, the Host Customer is the System Owner. In the case of a third-party-owned system (or leased system, for example), the third party (or lessor) is the System Owner.

The System Owner should be designated on the Reservation Request Form, if known at that time, and on the Incentive Claim Form. If different from the Host Customer, the System Owner shall also be a party to the CSI Program contract. The Program Administrator may require documentation substantiating equipment ownership.

2.1.3 Applicant

The Applicant is the entity that completes and submits the CSI Program application and serves as the main contact person for the CSI Program Administrator throughout the application process. Host Customers may act as the Applicant or they may designate a third party to act as the Applicant on their behalf. Applicants may be third parties (e.g., a party other than the Program Administrator or the utility customer) such as, but not limited to, engineering firms,

installation contractors, equipment distributors, energy service companies (ESCO) and equipment lessors.

2.1.4 Installer

Except for those systems that are self-installed, all systems must be installed by appropriately licensed California contractors in accordance with rules and regulations adopted by the State of California Contractors State Licensing Board (CSLB). Installation contractors must have an active A, B, C-10, or a C-46 license for photovoltaic (PV) systems. Please see Section 2.4 for Warranty Requirements of Self-Installed systems and Section 6.1 for documentation of Self-Installed systems.

Although not required, installation contractors are encouraged to become certified by the North American Board of Certified Energy Practitioners (NABCEP). For additional information on NABCEP, go to www.nabcep.org.

In all cases, systems must be installed in conformance with the manufacturers' specifications and with all applicable electrical and building codes and standards.

The Program Administrator will verify that the Installer has an active license with the California Contractors State Licensing Board (CSLB), in accordance to the above requirement, during Reservation Confirmation.

2.2 Generator System Equipment Eligibility

Although PV systems (i.e., systems that cause direct conversion of sunlight to electricity) are expected to be the common technology to receive incentives from the CSI Program, the CSI Program also accepts applications for eligible non-PV technologies. Guidelines for non-PV technologies (including estimation, measurement and metering) are included in this CSI Handbook.

Details of the eligibility requirements for generation system equipment follow.

2.2.1 New Equipment, Not Pilot or Demonstration Systems

All major system components (panels and inverters) must be new and must not have been previously placed in service in any other location or for any other application. Rebuilt, refurbished, or relocated equipment is not eligible to receive CSI Program incentives, save in rare relocation exceptions (see Sections 2.5 and 2.9).

Components that are critical to the PV systems must have at least 1 year of documented commercial availability to be eligible. Commercially available means that the major solar system components are acquired through conventional procurement channels, installed and operational at a Site (see Section 8.2 for definition). Ineligible equipment includes field demonstrations for proof-of-concept operation of experimental and non-conventional systems partially or completely paid for by research and development funds. Pilot and Demonstration systems are ineligible for CSI incentives. Components that are enhancements to existing products and new

Deleted: To participate in the CSI Program, eligible companies that install system equipment must be listed with the Program Administrator. The Program Administrator will request the following information:¶
<#>Business name, address, phone, fax, and e-mail address¶
<#>Owner or principal contact¶
<#>Business license number (if applicable)¶
<#>Contractor license number (if not self-install)¶
<#>Proof of good standing on the records of the California Secretary of State, as required for corporate and limited liability entities¶
<#>Reseller's license number (if applicable)¶
This information must be submitted to the Program Administrator before eligibility for the CSI¶
Program is established. To remain eligible, a company must resubmit this information annually by March 31. This annual submittal is required even if the information identified in the company's prior submittal has not changed. In addition, a company must submit updated information any time its reported information has changed. The updated information must be submitted to the Program Administrator within 30 days of the change of any reported information. ¶
¶
The above information must be listed before the Applicant can receive any reservation confirmation or payment. The Program Administrator will compile the information and make it available to consumers to assist them in making purchase decisions' ... [33]

Deleted: <#>Equipment Sellers¶
To participate in the CSI Program, companies that sell system equipment must be certified by the Energy Commission. The Energy Commission requests the following information on their form New Solar Homes Partnership-4 Form, NSHP-4:¶
<#>Business name, address, phone, fax, and e-mail address¶
<#>Owner or principal contact¶
<#>Business license number¶
<#>Contractor license number (if applicable)¶
<#>Proof of good standing on the records of the California Secretary of State, as required for corporate and limited liability entities¶
<#>Reseller's license number¶
This information must be submitted to the Energy Commission before ... [34]

Formatted: Bullets and Numbering

models of existing product lines do not have to meet the commercial availability requirement as long as they are UL-certified and performance data exists to allow the Program Administrators to estimate their expected performance.

An alternative method of seeking eligibility for solar systems that use new technologies is to obtain certification from a nationally recognized testing laboratory indicating that the technology meets the safety and/or performance requirements of a nationally recognized standard. System component ratings must also be certified by the Energy Commission as described in Section 2.2.4.

As an exception, the Applicant may specify equipment that has not yet received Energy Commission certification, but the equipment must be certified prior to the first incentive payment.

2.2.2 Eligibility of Replacement PV Systems

Any replacement solar systems must meet the criteria for new systems and are eligible for the CSI Program only if the removed system did not previously receive an incentive through the CSI Program, the Self-Generating Incentive Program, the Energy Commission's Emerging Renewables Program, or Rebuild a Greener San Diego Photovoltaic Incentive Program.

2.2.3 Eligibility of Non-PV Systems

Eligible non-PV technologies are categorized as either electric displacing¹¹ or electric generating, and include –

- **Electric Displacing**
 - Solar space & process heating
 - Solar driven cooling (absorption & adsorption chillers, desiccant systems, etc.)
- **Electric Generating**
 - Dish Stirling
 - Solar Trough
 - Dish and Lens
 - Concentrating Solar

Note that the measurement and metering methods discussed in this document are not applicable to solar water heating systems eligible for California Center for Sustainable Energy's solar water heating pilot program¹².

2.2.4 Equipment Must Serve On-Site Electrical Load

To be eligible, the system must be sized so that the amount of electricity produced by the system primarily offsets part or all of the customer's electrical needs at the Site of installation.

¹¹ Electric displacing non-PV technologies are subject to an incentive cap of \$100.8 million.

¹² Per D.06-01-024, CCSE has proposed, and is implementing, a solar hot water heating pilot program. In that order, the Commission directed CCSE to draft and file a plan for a solar water heating pilot program in the SDG&E territory.

Unless additional load substantiation documentation is submitted, the estimated annual kWh production of the proposed system as shown on the EPBB may not be higher than the previous 12-months energy usage.

Except for systems 5 kW or less, the Applicant must show evidence of the system sizing with the submittal of the initial application.

For systems less than or equal to 10kW where historical electrical load can not be determined due to extensive remodeling, on-site electrical load can be determined using the calculation of 2 watts per square foot.

2.2.5 Equipment Certifications and Rating Criteria

PV system components must be certified through the Energy Commission's program that certifies major components of PV systems and provides lists of eligible equipment. The list of the currently certified equipment is available through:

- The California Energy Commission: www.energy.ca.gov
- California Energy Commission Call Center: (800) 555-7794

The Program Administrators will confirm that equipment identified in a reservation application meets eligibility requirements prior to providing a confirmed reservation notice. As described in Section 2.2.1, one exception would be for new equipment that has not yet received certification but for which the process has been initiated. Equipment is periodically added and removed from the lists of eligible equipment so Applicants should confirm that the components purchased for a system are eligible prior to installing them.

Deleted: notice

Deleted: letter

The Energy Commission certifies modules, inverters, and system performance meters. The system must be interconnected to the grid. Inverters and modules must each carry a 10-year warranty, and meters a one-year warranty, in 2007 and 2008. If the meter is integrated into the inverter, then the meter must also carry a 10-year warranty. Eligibility requirements for components are summarized below:

- PV modules must be certified to UL 1703 by a nationally recognized testing laboratory (NRTL).
- Performance meters must measure kWh (or Watt hours) with a manufacturer's uncertainty of ± 2 or ± 5 percent (depending on rating size and incentive), retain data in the event of a power outage, and be easy to read for the customer's benefit. See Section 12.1.2.
- Inverters must be certified to UL 1741 by a Nationally Recognized Testing Laboratory (NRTL). They also must have completed the Energy Commission's required weighted efficiency testing.

Non-PV technologies systems must be safety and performance certified by a Nationally Recognized Testing Laboratory (NRTL).

2.2.6 Non-PV System Capacity Rating

The CEC-AC capacity rating for non-PV electric generators must be established at PVUSA Test Conditions¹³ (PTC) by an NRTL¹⁴.

Non-PV electric displacement thermal systems output must be rated by an NRTL, at PTC. However, the non-PV thermal capacity must be converted into an electric capacity representing the potential electric displacement. For non-PV thermal systems a Performance Ratio (Pr) is used to convert non-PV system thermal capacity to electric capacity. The Performance Ratio is the heating or cooling energy output of the conventional electric heating or cooling system being displaced divided by its electric energy input at rated conditions.

The Performance Ratio may be calculated one of the following two ways –

1) From the minimum efficiency standards for the type and size of the conventional electric heating or cooling system being displaced. The minimum efficiency standards for this equipment is found in the statewide Standard Performance Contract program (Appendix D) and the California Appliance Efficiency Regulations¹⁵. For electric resistive heating systems, the Performance Ratio will be assumed to be 1.0. Integrated Part-Load Value (IPLV), ratings will be used for systems that modulate capacity. Energy Efficiency Ratio (EER), Seasonal Energy Efficiency Ratio (SEER), Heating Seasonal Performance Factor (HSPF) or Coefficient of Performance (COP) ratings will be used for systems that do not modulate capacity. The conversion of IPLV, EER, SEER, HSPF and COP to the dimensionless Performance Ratio is accomplished as follows -

For IPLV: $PR = IPLV / 3.412$

For SEER: $PR = SEER / 3.412$

For HSPF: $PR = HSPF / 3.412$

For EER: $PR = EER / 3.412$

For COP: $PR = COP$

2) An engineering model of the facility's heating or cooling load resulting in the electric consumption and output of the conventional electric heating or cooling system being displaced, assuming a minimum efficiency rating for the conventional system. The Performance Ratio is then calculated by dividing the modeled annual output by the electric input and converting to dimensionless units.

For non-PV solar electric generators, the system rating (CEC-AC) is the net electric power output of the system at PTC.

$CEC-AC = E_{PTC}$

Where;

¹³ The PTC rating is based upon 1,000 Watt/m² solar irradiance, 20 Celsius ambient temperature, and 1 meter/second wind speed. PTC ratings for non-PV systems should be established by a NRTL. An example CEC-AC rating using the SRCC OG100 efficiency equation for a glazed solar collector can be found in Appendix G.

¹⁴ Examples of qualified NRTL's include, but are not limited to, Solar Rating and Certification Company or National Renewable Energy Laboratory.

¹⁵ Appliance Efficiency Regulations, California Energy Commission, CEC-400-2006-002, December 2006.

CEC-AC = System electric rating at PTC.

“EPTC” = Net electric output of the non-PV system at PTC.

For non-PV thermal systems that displace electric load the system rating (CEC-AC) is the rated thermal output at PTC, divided by the Performance Ratio of the electric equipment being displaced, less any solar thermal system ancillary loads at rated conditions.

$$\text{CEC-AC} = (\text{TPTC} / \text{PR}) - \text{EAUX}$$

Where;

CEC-AC = System displaced electric rating at PTC.

“TPTC” = Thermal output (cooling or heating) of the non-PV system in kilowatts thermal (kWT) at PTC and the operating temperature of the solar collector. If the system includes an absorption chiller or other heat driven cooling system, the system thermal rated output is either the PTC rated thermal output of the panels multiplied by the rated COP15 of the absorption chiller, or the rated capacity of the absorption chiller, which ever is less.

“PR” = Dimensionless Performance Ratio of the conventional electric heating or cooling system calculated by the heating or cooling energy output of the system divided by its electric energy input.

“EAUX” = The load of the non-PV system ancillary electric equipment (e.g. pumps, etc.), at rated conditions, used for the solar thermal system operation. Ancillary electric loads may be ignored if the load magnitude is less than 5% of the gross system capacity.

2.2.7 System Size

The minimum system size eligible for an incentive is 1 kW. The maximum incentive provided for a Host Customer Site under the CSI Program is 1,000 kW (1 MW) CEC-AC; however, a Host Customer Site may elect to install up to 5 MW of generation.¹⁶ If an Applicant has already received 1 MW of funding from another solar incentive program (such as the SGIP or ERP), they can apply for up to another 1 MW of new generation under the CSI Program on the same site as long as they can demonstrate that the electricity produced by the combined system sizes do not exceed the actual energy consumed during the previous 12 months at the Site, based on the process provided in Section 2.2.4.

Program Administrators will use the CEC-AC rating, but not a Design Factor, to determine eligibility according to these minimum and maximum sizes. Program Administrators will also use the CEC-AC rating without a Design Factor to determine eligibility for the EPBB or PBI incentive.

¹⁶ Because the CSI Program and statutes only allow for customers to receive incentives up to the first MW, PBI payments for energy output on systems larger than 1 MW will be prorated based on the ratio of 1 MW to the entire size of the site. See Section 3.3 for further detail.

Because the average annual residential electricity consumption in California is approximately 7000 kWh/yr, systems that are 5 kW or less, are assumed to be in compliance with being sized to serve on-site electric load.

For all systems, the system size must be calculated using the CEC-AC rating standards,¹⁷ including inverter DC-to-AC losses. To calculate the CEC-AC rating, the following formula should be used:

$$\text{System Size Rating (kilowatts)} = \frac{\text{Quantity} \times \text{CEC Rating of Photovoltaic Modules} \times \text{CEC Inverter Efficiency Rating}}{1000 \text{ (watts/kilowatt)}}$$

However, for the Program Administrators to allocate applications against their MW in step (Section 1.3), the Program Administrators will multiply the system size rating by a design factor that reflects the system's "effective capacity."

For systems that participate under the EPBB, this is relatively straightforward, since this ratio is equal to the design factor generated by the EPBB calculator. Thus for EPBB systems, system size is equal to the system size rating times the design factor generated by the EPBB calculator for that system.

For PBI systems, the program administrators will need to derive a design factor based on the following calculations:

1. Divide the estimated annual kWh that the system is expected to produce¹⁸ by (8760 x CEC-AC rating). This is the estimated capacity factor of the applicant system.
2. Divide the capacity factor from #1 by the prevailing capacity factor assumed for a given step¹⁹ to get a proxy Design Factor.
3. Find the system size (kW) by multiplying the Design Factor from #2 times the CEC-AC size above

This calculation would allow the Program Administrators to estimate annual production from the EPBB Calculator that adjusts for performance of non-crystalline PV technology.

2.2.7.1 System Sizing Based on Future Load Growth

In the case of Applicants with new or expanded sites with no electric bill history or where the existing electric bill does not reflect the Applicant's expected expanded consumption, the Applicant must include an estimate of the expected expanded consumption. An engineering estimate is preferred. The engineering estimate must include the appropriate substantiation of the forecast of the Host Customer Site's annual energy use (in kWh) if the generating system size is based on future load growth, including new construction, load growth due to site expansion or other load growth circumstances. Suggested methods of demonstrating load growth include Application for Service with corresponding equipment schedules and single line

¹⁷ The CEC-AC rating standards are based upon 1,000 Watt/m² solar irradiance, 20 °Celsius ambient temperature, and 1 meter/second wind speed. The CEC-AC Watt rating is lower than the Standard Test Conditions (STC), a Watt rating used by manufacturers.

¹⁸ Derived from PV Watts and found in the EPBB Calculator results.

¹⁹ This equals .18 for steps 2 and 3, and .20 for steps 4-10.

diagram; building simulation program reports such as eQUEST, EnergyPro, DOE-2, and VisualDOE; or detailed engineering calculations or lists of equipment with corresponding equipment schedules. The Program Administrator will verify the load growth predicted before moving forward with the Confirmed Reservation [notice](#). Systems that are 5 kW or less, are assumed to be in compliance with being sized to serve on-site electric load and do not require substantiation.

Deleted: Notice

For small residential, installing systems of less than or equal to 10kW, a calculation of 2 watts per square foot can be used instead of an engineering estimate. Systems over 10 kW would require an engineering estimate.

2.3 Energy-Efficiency Requirements

Beginning January 1, 2007 all existing residential and commercial customers are required to have an energy efficiency audit conducted of their existing home or building if they chose to apply for a solar incentive. The acceptable audit protocols will consist of an on-line audit or telephone audit provided by the Utilities. The Utilities may also provide additional audit tools available for customers in addition to the on-line and phone audits. Customers are responsible for submitting a copy of a completed energy efficiency audit to the CSI Program Administrator with their solar incentive application.

Non- Utility Providers:

Non-utility entities may also provide audits at the expense of the customer. At a minimum, the provider must perform an online or phone audit.

Audit Exemptions:

Existing Construction:

An existing home or building may be exempt from the audit requirement if it meets one of the following circumstances and a copy of the documentation must be submitted with the customer's solar incentive application:

1. Having an acceptable energy audit report during the past three years
 - Examples of acceptable energy audit reports: Copy of energy audit report summary completed through a customer's local utility company, home inspection report from an independent vendor or consultant, Home Energy Rating Summary (HERS) from a certified HERS rater, etc.
2. Proof of Title 24 energy efficiency compliance within the past three years

Title 24 Certificate of Compliance Forms:

- Residential: CF-1R that was used to demonstrate Title 24 Compliance of the 2001 or 2005 Energy Efficiency Standards and was generated on or after January 1, 2003.
- Commercial: One or more of the Certificates of Compliance forms listed below that were used to demonstrate Title 24 Compliance of the 2001 or 2005 Energy Efficiency Standards and was generated on or after January 1, 2003.

Envelope	Mechanical	Lighting	Outdoor Lighting
ENV-1-C	MECH- 1-C	LTG-1-C	OLTG-1-C

Only compliance documents completed by persons who are Certified Energy Plans Examiners (CEPE) by the California Association of Building Energy Consultants (CABEC) are accepted. More information about this certification process can be found at: <http://www.cabec.org>. The above compliance documents must also be generated by one of the Energy Commission's approved Title 24 software programs: Micropas or Energy Pro.

3. Having one of two national certifications of energy efficiency:
 - LEED or
 - Energy Star

Customer must submit a copy of a certificate or other documentation from LEED or Energy Star which contains the building address and date of certification.

New Construction:

Commercial New Construction:

- Commercial New Construction project participants in the solar incentive program must submit copies of their current Title 24 documentation. Participants can use one or more of the Certificates of Compliance forms listed below that demonstrate Title 24 Compliance 2005 Energy Efficiency Standards in effect as of October 1, 2005.

Envelope	Mechanical	Lighting	Outdoor Lighting
ENV-1-C	MECH- 1-C	LTG-1-C	OLTG-1-C

Only compliance documents completed by persons who are Certified Energy Plans Examiners (CEPE) by the California Association of Building Energy Consultants (CABEC) are accepted. The above compliance documents must also be generated by one of the Energy Commission's approved Title 24 software programs: Micropas or Energy Pro.

Residential New Construction:

- Residential New Construction projects (single family home, custom homes and multifamily buildings) are currently handled by the California Energy Commission (CEC) under the New Solar Homes Partnership. Please contact the CEC for applications and program requirements at www.GoSolarCalifornia.ca.gov.

In 2007, the California Energy Commission developed eligibility criteria and conditions for receiving future CSI incentives, including new energy efficiency requirements. Please see <http://www.energy.ca.gov/sb1/meetings/index.html> for more information.

2.4 Warranty Requirements

Currently, all systems must have a minimum 10-year warranty provided in combination by the manufacturer and installer to protect the purchaser against defective workmanship, system or component breakdown, or degradation in electrical output of more than fifteen percent from their originally rated electrical output during the ten-year period. The warranty must cover the solar generating system only, including PV modules (panels) and inverters, solar collectors, tracking mechanisms, heat exchangers, pumps, heat driven cooling systems associated with the solar system and provide for no-cost repair or replacement of the system or system components, including any associated labor during the warranty period.

Self-installed systems must have a minimum 10-year warranty on the equipment to be installed to protect the purchaser against breakdown or electrical output degradation of major system components. In this case, the warranty need not cover the labor costs associated with removing or replacing major components because any repairs would be done by the self-installer or at the self-installer's expense.

Meters must have a one-year warranty to protect against defective workmanship, system or component breakdown, or degradation in electrical output of more than fifteen percent from their originally rated electrical output during the warranty period. For meters that are integrated into the inverter, the meter warranty period must be 10 years.

The system owner will acknowledge on the Incentive Claim Form that they have received a 10-year warranty for no cost repair and replacement of the generating system.

2.5 Performance and Permanency Requirements

Deleted: Proof of warranty can be demonstrated in the executed solar contract or power purchase agreement.¶

Formatted: Bullets and Numbering

Equipment installed under the CSI Program is intended to be in place for the duration of its useful life. Only permanently installed systems are eligible for incentives. This means that the solar system must demonstrate to the satisfaction of the Program Administrator adequate assurances of both physical and contractual permanence prior to receiving an incentive.

Physical permanence is to be demonstrated in accordance with industry practice for permanently installed equipment. Equipment must be secured to a permanent surface. Any indication of portability, including but not limited to temporary structures, quick disconnects, unsecured equipment, wheels, carrying handles, dolly, trailer, or platform, will deem the system ineligible.

In rare occasions, there may be extenuating circumstances that warrant equipment relocation. The Program Administrators will use their discretion whether to allow the relocation to continue to receive program incentives. Contractual permanence, corresponding to a time period of 10 years, is to be demonstrated as follows:

- All agreements involving the generation system receiving an incentive are to be provided to the Program Administrator for review as soon as they become available (e.g., at the proof-of-project milestones stage or the incentive-claim stage at the latest). These agreements include, but are not limited to, system purchase and installation agreements, warranties, leases, energy or solar services agreements, energy savings guarantees, and system performance guarantees.
- The System Owner agrees to notify the Program Administrator in writing a minimum of 60 days prior to any change in either the site location of the solar system or change in ownership of the generation system if the change(s) takes place within the applicable warranty period. The warranty period for the CSI Program is 10 years.
- If the solar system is removed prior to end of the 10 year warranty period, either:
 - The solar system may be installed at another site within the Program Administrator service territory within 6 months. The system installed at the alternate site would not be eligible for an additional CSI EPBB incentive; or
 - The System Owner would be unable to participate in the CSI Program for any additional installations under the CSI Program, including any active reservations that have not yet been paid.
- If the house or business is sold, the new owners can continue to receive the Performance-Based Incentives (PBI) and be eligible to receive future CSI Program incentives if they complete a new interconnection agreement. If the sellers remove the panels, they can continue to receive the incentive payments and be eligible to receive future CSI Program incentives if the panels they removed are installed within the same service territory within 6 months, and they complete an interconnection agreement at the new address. PBI recipients will receive a full five year PBI payment period (not including the period between

removing and reinstalling the system), as long as they reinstall their systems within the specified timeframe.

2.6 Interconnection to the Electric Utility Distribution System

Eligible solar electric generating energy systems must be permanently interconnected to the electrical distribution grid of the utility serving the customer's electrical load. Portable systems are not eligible. The system interconnection must comply with applicable electrical codes and utility interconnection requirements.

The Host Customer, or designate, must also submit an application and enter into an interconnection agreement with their local electric utility for connection to the electrical distribution grid. Please note that there may be insurance requirements for the Host Customer associated with the utility interconnection process. Proof of interconnection and parallel operation is required prior to receiving an incentive payment.

The local electric service provider will convey proof of interconnection to the Program Administrator.

A customer would still be eligible for an incentive for up to 12 months after receiving a final interconnection authorization letter, however after 12 months the project would no longer be eligible for an incentive

2.7 Time of Use Rates

In order to provide additional incentives for customers to install solar systems that coincide with California's peak electricity demand, CSI Applicants were required under state law (SB1) and CPUC D. 06-12-033 to take their electric service under applicable Time-Of-Use (TOU) tariffs. However, state law (AB 1714)²⁰ and CPUC D.07-06-014 have modified this order such that these TOU requirements are currently optional for CSI Applicants not otherwise required to take service on TOU rates until the CPUC develops and makes effective TOU tariffs that meet the requirements of Public Utility Code Section 2851(a)(4). Entities that receive the CSI incentive after the new TOU rates are established must go on the new TOU rates.

2.8 Metering Requirements

The CSI Program requires accurate energy production meters for all projects that receive CSI Program incentives. Accurate measurement of solar energy output is of paramount importance to ensure optimum value for both solar owners and ratepayers. For solar electric generating systems receiving an EPBB incentive, a basic meter with accuracy of ± 5 percent is required. For systems receiving PBI payments, an interval data meter with accuracy of ± 2 percent is required. An extensive discussion on metering is contained in Appendix B.

²⁰ Chapter 11, Statutes of 2007 (AB 1714, Levine)

For non-PV electric displacing thermal systems, the output must be measured with a Btu meter with a combined accuracy of +/- 5 percent or better, taking into consideration differential temperature, flow and computational errors (see Appendix E for further details).

EPBB program participants must provide Program Administrators or their authorized agents with physical access to the meter for testing or inspection, and if applicable, data gathering. If the customer's meter is located in a place that is not readily accessible, such access will be by appointment. To avoid inconvenience to customers, Installers are encouraged to locate meters in areas that are easily accessible.

PBI customers must provide Program Administrators or their authorized agents with physical access to the meter at all times.

2.9 Inspection Requirements

It is the intent of the CSI Program to provide incentives for reliable, permanent, safe systems that are professionally installed, and comply with all applicable federal, state, and local regulations. Program Administrators will conduct a system inspection visit for every EPBB system rated greater than 30 kW in order to verify that the project is installed as represented in the application, is operational, is interconnected, and conforms to the eligibility criteria of the CSI Program. Program Administrators will perform random field inspections to verify system characteristics for EPBB systems less than 30 kW. These inspections will reflect a statistically reasonable random sample. Systems receiving PBI may still be required to have a field inspection.

Deleted: from
Deleted: up to 100 kW that have not opted to receive PBI incentive payments
Deleted: a

A mandatory site inspection is required for all relocated equipment. System Owners that have received an EPBB incentive and have relocated their system must orient their relocated equipment to produce at least the same generation as their initial incentive payment was based upon.

2.9.1 Systems that Fail Inspections

After a field inspection is completed, the Program Administrators will evaluate the results of the inspection. A failure may be issued for a project if the inspection results are not within the approved tolerances, which have been developed by the Program Administrators, as shown in the chart below:

Inspection results	PA Action	Applicant Action	Failure
<u>Results within set tolerance:</u> Tilt $\pm 3^\circ$, Azimuth $\pm 5^\circ$, Shading $\pm 5\%$ of summer shading *Equipment matches	<u>Accepts submitted EPBB Calculator and initiates payment as normal</u>	<u>No Action Necessary</u>	<u>No</u>

Deleted: If a system fails a field inspection, the Program Administrator will notify the Applicant, Host Customer, and System Owner with the reasons for the field inspection failure.
Deleted: Such reasons for failure may include but are not limited to the following:
Formatted Table

<u>Inspection results</u>	<u>PA Action</u>	<u>Applicant Action</u>	<u>Failure</u>
<u>Results outside set tolerance, but within 5% of submitted incentive</u> <u>*Equipment matches</u>	<u>Recalculate Incentive based on inspected EPBB calculator results. If new incentive is within 5% of submitted incentive, then notify Applicant of a new incentive amount change.</u>	<u>Applicant accepts the incentive amount change or disputes with PA for resolution</u>	<u>No</u>
<u>Results outside set tolerance and not within 5% of submitted Incentive.</u> <u>*Equipment matches</u>	<u>Recalculate Incentive based on inspected EPBB calculator results. If new incentive is not within 5% of submitted incentive, then notify Applicant of a new incentive amount change and issue a Failure.</u>	<u>Applicant accepts the incentive amount change or disputes with PA for resolution</u>	<u>Yes</u>
<u>Results show that the equipment differs than submitted EPBB, but within 5% of submitted incentive.</u>	<u>Recalculate Incentive based on inspected EPBB calculator results. If incentive is within 5% of submitted incentive, then email Applicant of a new incentive amount change.</u>	<u>Applicant accepts the incentive amount change or disputes with PA for resolution</u>	<u>No</u>
<u>Results show that the equipment differs than submitted EPBB and not within 5% of submitted tolerance.</u>	<u>Recalculate Incentive based on inspected EPBB calculator results. If new incentive is not within 5% of submitted incentive, then notify Applicant of a new incentive amount change and issue a Failure.</u>	<u>Applicant accepts the incentive amount change or disputes with PA for resolution</u>	<u>Yes</u>

Formatted Table

Formatted: Font: (Default) Arial, 11 pt

Formatted: Font: (Default) Arial, 11 pt

Deleted: ¶
 Material mechanical failure: A failure that results in a decline in the expected performance of the system (e.g., one or more of the system components is not operating properly).
 Immaterial mechanical failure: minor failures that have no impact on the expected performance of the system and can be corrected within 60 days.
 Material compliance failure: the system as verified does not match the application's stated system and/or the system does not meet the CSI Program eligibility requirements (e.g., the EPBB characteristics are incorrect, the system components or number of components are incorrect, etc.).
 Immaterial compliance failure: failures that have no impact on the expected performance of the system and can be corrected within 60 days (e.g. submission of erroneous system data).

Deleted: ¶

Formatted: Font: (Default) Arial, 11 pt

Deleted: the materiality of non-compliance. For either mechanical or compliance failures: If a material failure

Deleted: s

Deleted: .

Deleted: (fraud),

Deleted: t

Deleted: If there is a failed inspection for *mechanical* failures, the Applicant, Host Customer, an(... [35]

Deleted: and/or s

Deleted: If the entity on probation fails a third inspection, the entity will be disqualified from participati ... [36]

Deleted: the second failed inspection will be removed and

Deleted: and

Deleted: with one failed inspection only on record. Another failed inspection after this, regardless ... [37]

If a system fails a field inspection, the Program Administrator will notify the Applicant, Host Customer, and/or System Owner with the reasons for the field inspection failure. Once notified, the Applicant, Host Customer, or System Owner will either accept the failure and change in the incentive amount or dispute the inspection results through the appeals process defined below (see last paragraph of this section). The Program Administrator will be authorized to identify the responsible party (Applicant, Installer, Seller, or other responsible party), based on available information obtained during the inspection and from applicable forms, that will receive the failure.

The Program Administrators will also exercise their judgment in assessing fraud, which can occur due to gross negligence or intentional submission of inaccurate system information in an attempt to collect more incentive dollars. The responsible party will be immediately prohibited from participating in the program for one year.

Installers, Applicants, Sellers, or other responsible parties that fail two inspections Statewide will be on probation, wherein every project will be inspected. If the entity on probation fails a third inspection, the entity will be disqualified from participating in the CSI Program for one year, except in cases of fraud. Once on probation, if no additional failures occur within one calendar year of the second failed inspection, the entity will be removed from probation, placed back into the regular CSI inspection protocol, and all failures removed.

High volume Installers, Applicants, Sellers, or other responsible parties (those that apply or install more than 200 systems per year Statewide) that fail four inspections Statewide, will be on probation wherein every project will be inspected. If the high volume entity on probation fails a fifth inspection, the entity will be disqualified from participating in the CSI Program for one year, except in cases of fraud. Once on probation, if no additional failures occur within one calendar year of the fourth failed inspection, the entity will be removed from probation, placed back into the regular CSI inspection protocol, and all failures removed.

Deleted: For h
Deleted: i
Deleted: ,

After an entity has served its one year disqualification period, it may become eligible as determined through the appeals process defined below (see last paragraph of this section). If the entity becomes eligible, it will be considered on probation and will be able to end the probation as described above.

Deleted: if the installer accumulates two strikes, the entity will be placed on probation. If no additional strikes are accumulated within the first year that the initial strike was acquired, their first strike is removed and they continue on probation until the second strike's probation year ends as determined from the date the second strike is acquired. If they acquire no additional strikes within this time, the second strike is removed, and they will be restored to a zero-strike status. However, if they acquire an additional strike after the first strike is removed, an additional probation period begins from the date of the last strike. If they accumulate three strikes, they will be disqualified from participating in the program for one year.

Deleted: the

If an Installer or Applicant disputes the failed inspection or disqualification, he or she may appeal in writing within 30 days of notification of the failed inspection via US certified mail to the Program Administrator. A panel of all of the Program Administrators and a representative from the Energy Division of the California Public Utilities Commission will review the appeal. Written appeals should substantiate any reasons he or she believes warrant reconsideration of the failure or disqualification. The appealing party may request an audience with the panel. The panel may also request additional information to substantiate the written appeal. The final decision will be provided to the Applicant or Installer within 60 days of receipt of the written appeal and the appeal decision of the panel shall be final.

2.9.2 Inspector Training Criteria

The CPUC requires that all system inspection visits must be performed by trained personnel, whether the inspection is performed by utility interconnection inspectors, other utility personnel, or contractors. The Program Administrators have developed and submitted a consistent statewide site inspectors' training plan to the CPUC Energy Division.

3. California Solar Initiative Incentive Structure

This section provides a general overview of the California Solar Initiative (CSI) Incentive structure. The CSI Program offers two types of incentives: PBI and EPBB. Table 5 provides an overview of the two incentive structures under the CSI Program. For the purpose of the CSI Program, commercial sectors include agricultural and industrial customers. Typically, the incentive structure is determined by the size of the system installed. However, customers installing smaller systems have the option to choose the PBI structure regardless of the size of their system.

**Table 5
CSI Incentive Structures**

Type of CSI Incentive	Size Category	Payment Structure	Customers Eligible	Notes
Performance Based Incentive (PBI)	≥ 50 kW	Payments based on \$/kWh produced over 5 year term	Residential, Commercial, Government and Nonprofit	<ul style="list-style-type: none"> ❖ Smaller systems may opt into PBI ❖ In 2008, PBI required for all systems ≥ 50 kW
Expected Performance Based Buydown (EPBB)	< 50 kW	One lump sum based on \$/watt	Residential, Commercial, Government and Nonprofit	<ul style="list-style-type: none"> ❖ Residential New Construction projects are funded through the Energy Commission's New Solar Homes Partnership (not CSI)

Both PBI and EPBB incentives are available for residential and Non-Residential customers as displayed in Table 6.

**Table 6
Type of CSI Incentive by Customer Sector**

Type of CSI Incentive	Size Category	Residential ²¹	Commercial	Gov't and Nonprofit
Performance Based Incentive (PBI)	≥ 50 kW ²²	√	√	√
Expected Performance Based Buydown (EPBB)	< 50 kW	√	√	√

²¹ Residential installations on existing structures. New residential construction projects will be funded through the Energy Commission's New Solar Homes Partnership.

²² Smaller systems may opt-in to receive a PBI incentive rather than the EPBB incentive.

3.1 CSI Program Incentive Trigger Mechanism

The incentive payment levels will automatically be reduced over the duration of the CSI Program in 10 steps, based on the volume of MW of confirmed reservations issued within each utility service territory.²³ On average, the CSI incentives are projected to decline at a rate of 7 percent each year following the start of implementation in 2007. The incentives will gradually phase out over the 10 steps. Table 4 outlines the 10 steps for the incentive levels for the CSI Program.

The duration of that phase-out will be dependent on: (1) whether the incentive budgets are depleted; (2) when the Program Administrators reach their MW goal; or (3) by the end of the program or 2016, whichever comes first. Table 3 displays the MW targets by Program Administrator service territory and customer class.

Program Administrators will count an application's size towards their step goals using a design factor as described in detail in Section 2.2.7.

Projects are counted toward the MW trigger once they are deemed eligible, have paid an application fee (if applicable), and have been issued a confirmed reservation. As the number of MW allocated through the confirmed reservations reaches its maximum within any particular step, the Program Administrators will move to the next step.

If there are any MWs that remain unused and unaccounted for in any previous steps, due to events such as Applicants dropping out of the process or reducing the size of their systems, those MWs will be added to the current step under which Program Administrators are issuing reservations and incentives, thus increasing the number in that step and ensuring that no MW are left outstanding. Similarly, when MWs drop out of the current step, those MW will be returned to the current step. Any reallocation of MWs from a higher step to a lower step due to drop outs or system size reductions can take place as long as the reallocation is consistent with how the MWs were initially reserved for either residential and non-residential projects. Reallocations from Step 1 may be assigned to either residential or non-residential applicants, at the discretion of the Program Administrators. The Program Administrators will provide updates to their solar application websites as close as possible to real time and no less than weekly to indicate the total MWs available for incentives at each step and in each customer sector, including those MWs newly available due to reallocations.

The CSI Program incentive levels may vary by service area, depending on the pace of solar demand in each Program Administrator's territory. Additionally, the CSI Program incentive levels may differ based on demand in the residential and non-residential customer sectors. Refer to www.csi-trigger.com to determine the step and incentive rate that is currently applicable to each customer sector in that utility's service territory.

The status of each Program Administrator's trigger, and therefore incentive level, is shown at www.csi-trigger.com.

Deleted: 7

Deleted: above

Deleted: Table 7 . PBI and EPBB Payment Amounts by Step¶ ... [38]

Deleted: 8

Deleted: above

Deleted: -----Page Break----- ¶ Table 8 CSI MW Targets by Program Administrator and Customer Class¶ ... [39]

Deleted: the Program Administrator's website

Deleted: The Program Administrators will include on their websites an indication of the MW of Confirmed Reservations in each customer sector that is as close as possible to real time.

²³ Investor-owned utility service territories only (PG&E, SCE, SDG&E)

3.2 Expected Performance Based Buydown (EPBB) Incentives

The CSI Program will pay incentives to solar projects with system ratings of less than 50 kW CEC-AC through an up-front incentive known as an EPBB. These EPBB incentives are based on an estimate of the system's future performance. EPBB incentives combine the benefits of rewarding performance with the administrative simplicity of a one-time incentive paid at the time of project completion. Applications for new non-residential construction projects are eligible for EPBB if the system size complies with EPBB size requirements.

The Program Administrators will use the Energy Commission's CEC-AC method to determine the system rating. The following formula determines the EPBB incentive:

$$\text{EPBB Incentive Payment} = \text{Reserved Incentive Rate} \times \text{System Rating}^{24} \times \text{Design Factor}$$

The design factor is a ratio comparing a proposed system to a reference system. Very simply, it reflects:

Design Factor =	$\frac{\text{Proposed System}}{\text{Reference System}}$
-----------------	--

More specifically, the Design Factor is calculated as follows:

$$\text{DF} = \text{Dcorr} * \text{Gcorr} * \text{Icorr}$$

$$\text{Dcorr (Design Correction)} = \text{Ss,p,p} / \text{Ss,p,o}$$

Ss,p,p = The system's estimated summer kWh output at the proposed location, with proposed tilt & azimuth

Ss,p,o = The system's estimated summer kWh output at the proposed location, with summer optimized tilt & azimuth allowing for equal treatment of proposed systems oriented from South to West (i.e. the optimized system's orientation shall be the same as the proposed system for orientations due south to due west).

$$\text{Gcorr (Geographic Correction)} = \text{As,p,o} / \text{As,r,o}$$

As,p,o = The system's estimated annual kWh output at the proposed location, with summer optimized tilt & south azimuth

As,r,o = The system's estimated annual kWh output at the

²⁴ CEC-AC System Rating (kilowatts) = Quantity of Modules x CEC Rating of Photovoltaic Modules x CEC Inverter Efficiency Rating / 1000 (watts/kilowatt)

reference location, with summer optimized tilt & south azimuth

$$I_{\text{corr}} (\text{Installation Correction}) = \text{PTC}_{\text{adj}} / \text{PTC}$$

PTC_{adj} = The adjusted PTC DC rating accounting for mounting method, NOCT and power temperature coefficient for that specific module. See Appendix A of this User Guide for a detailed description of the modified PTC calculation.

PTC = The DC rating of the panels at PVUSA Test Conditions.

In sum, the design factor for EPBB will:

- Treat all systems oriented between 180° and 270° equally
- Assign optimal orientation tilt for each compass direction in range of 180° and 270°, optimized for summer production
- Include location-specific criteria to account for weather variation and shading
- Be based on an optimal reference system and location
- Determine optimal reference latitude tilt that relates to local latitude.

Please refer to the EPBB User Guide for more detailed explanation of the calculator's methodology and instructions, at www.csi-epbb.com.

For non-PV systems, the Design Factor is the Surface Orientation Factor (SOF)^{25, 26}. The SOF is determined by reading the value from the chart Surface Orientation Factor for the location, tilt and azimuth of the system. Charts of SOF for various California locations may be found in Appendix F. The chart for the closest location to the system's location should be chosen and the SOF determined by reading it off of the chart using the system's tilt and azimuth. Note that the described EPBB methodology is appropriate for solar systems displacing only electric load. For solar systems designed to displace both gas and electric loads, the solar energy displacing the electric load must be metered under a PBI arrangement described in Section 3.3.1.

The CPUC and its Program Administrators have developed an EPBB calculator that helps applicants determine the EPBB incentive level. As it gains experience with the EPBB and the performance of the California Solar Initiative, the CPUC reserves the right to modify the calculator at any time without advance [notice](#) to applicants.

If the changes to the EPBB calculator do not impact the incentive amount on a given project, the PAs are not required to notify the applicant of that given project.

²⁵ The "Surface Orientation Factor" and how it is calculated is detailed in "Effects of Tilt and Azimuth on Annual Incident Solar Radiation for United States Locations", Proceedings of Solar Forum 2001, April 21-25, Washington D.C

²⁶ SOF charts for various California locations may be found in Appendix F of this paper.

$$DF = D_{\text{corr}} * G_{\text{corr}}$$

D_{corr} (Design

S_{s,p,o} =
propo:

S_{s,p,o} =
propo:
allowir
from S
shall t
due sc

G_{corr} (Geogr

A_{s,p,o} =
propo:
azimu

A_{s,r,o} =
refere:
azimu

Deleted:

Deleted: .

Deleted: notice

However, if the calculator is revised between the time an applicant submits an application and the Program Administrator's Pending Payment stage and the revision(s) alter the project's incentive amount, the Program Administrator (PA) will notify the applicant by letter (PA notification letter) and/or email.

If the Applicant received a Reservation Confirmation notice before such a calculator revision, s/he can either:

Deleted: letter

(A) resubmit the application using the new calculator (If the applicant chooses to resubmit, s/he will not lose his/her place in the queue or application fee); or

(B) notify the PA that s/he wishes to remain at the incentive level calculated in the existing application (even if the incentive would drop under the new calculator).

In both cases, the applicant must notify the PA of his/her intent, in writing, within 30 days of the date of the PA notification. If the applicant does not notify the PA of his/her intent within 30 days of the date of the PA notification, the application will remain in the queue at the level projected under the calculator used in the initial application process.

Deleted: letter

Deleted: letter

If the applicant has *not* received a Reservation Confirmation notice before such a calculator revision, the PA shall notify the Applicant of the calculator change and how it impacts the incentive amount in the Application when the Reservation Confirmation notice is issued. The notification shall contain a response portion wherein the Applicant shall sign whether they accept the newly-calculated incentive or wish to withdraw their application. The Applicant must either:

Deleted: letter

Deleted: letter

Deleted: letter

(A) return the notification to the PA indicating s/he accepts the recalculated incentive amount using the new calculator (If the applicant chooses to resubmit, s/he will not lose his/her place in the queue or application fee); or

Deleted: letter

(B) return the notification to the PA indicating s/he wishes to withdraw the application (If the Applicant chooses to withdraw the application, the PA will reimburse the application fee).

Deleted: letter

In both cases, the applicant must notify the PA of his/her intent, in writing, within 30 days of the date of the PA notification. If the applicant does not resubmit or withdraw his/her application within 30 days of the date of the PA notification, the Program Administrator will cancel the application, and the applicant will lose both his/her application fee and place in the queue.

Deleted: letter

Deleted: letter

3.2.1 Incentives for Residential Installations

Residential installations will be provided a one-time payment under the EPBB program to help reduce the cost of installation provided the system size is within EPBB size eligibility. The amount of the EPBB incentive payment is as calculated pursuant to the formula in Section 3.2, with the incentive rate portion of the formula determined as shown by Table 4.

Deleted: 9

Deleted: above

Deleted:Page Break.....
Table 9
Residential EPBB Incentive Levels
by MW Steps and Program
Administrator Territory]
Step ... [40]

The CSI Program incentive levels may vary by utility service area, depending on the pace of solar demand in each utility's territory. Refer to www.csi-trigger.com to determine the currently-effective step and incentive rate.

Deleted: the Program Administrator's website

A Power Purchase Agreement on a residence is considered a residential application.

Incentives for residential new construction projects will be funded through the Energy Commission's New Solar Homes Partnership program.

3.2.2 Incentives for Non-Residential Installations

Non-Residential installations will be provided a one-time payment under the EPBB program to help reduce the cost of installation provided the system size is within EPBB size eligibility. There are different incentive rates for System Owners who are commercial entities or Government or Non-Profit entities. If a Government or Non-Profit entity is not the System Owner, the incentive amount will be determined by the tax status of the System Owner. The amount of the EPBB incentive payment is as calculated pursuant to the formula in Section 3.2, with the incentive rate portion of the formula determined as shown in Table 4.

Government and Non-Profit entities will be required to submit verification of their tax-exempt status to receive this incentive amount. Additionally, Government and Non-Profit entities must include a certification under penalty of perjury from their chief financial officer or equivalent that they are a Government or Non-Profit entity and that the system is not receiving and will not in the future receive federal tax benefits through financial arrangements for the entire warranty period of the system (i.e., the System Owner if a third-party, which will be receiving tax benefits from the system).

The CSI Program incentive levels may vary by utility service area, depending on the pace of solar demand in each utility's territory. Refer to www.csi-trigger.com to determine the currently-effective step and incentive rate.

Deleted: 10

Deleted: above

Deleted: ¶

Page Break

Table 10
Non-Residential EPBB Incentive levels by MW Step and Program Administrator Territory¶

Step	Commercial EPBB (\$/watt)	No
1	n/a	
2	\$ 2.50	\$
3	\$ 2.20	\$
4	\$ 1.90	\$
5	\$ 1.55	\$
6	\$ 1.10	\$
7	\$ 0.65	\$
8	\$ 0.35	\$
9	\$ 0.25	\$
10	\$ 0.20	\$
Total		

Deleted: the Program Administrator's website

3.3 Performance Based Incentives (PBI)

The CSI Program will pay PBI for solar projects with systems equal to or greater than 50 kilowatts (kW) CEC-AC in 2008 (and 30 kW and greater after January 1, 2010), with monthly payments based on recorded kilowatt hours (kWh) of solar power produced over a 5-year period, provided the Host Customer remains a retail level electric distribution customer of PG&E, SCE, or SDG&E. The Commission has determined that customers who receive incentives under a performance-based approach will be motivated to focus on proper installation, maintenance, and performance of their systems. Therefore, systems above the EPBB eligibility size limits are required to participate in the PBI program. Furthermore, systems of any size may elect to opt into the PBI program.

Once the PBI incentive rate has been determined and a confirmed reservation issued, the \$/kWh incentive rate will remain constant for the 5-year term. PBI payments shall be made on a monthly basis after commissioning of the system.

PBI payments will be calculated for solar energy systems that exceed 1 MW in size by prorating the energy output based on the ratio of 1 MW to the size of the site. Thus, if a customer has installed a 5 MW system, the customer would receive PBI payments for 1/5 of the output of the system. As an alternative, and if possible, the customer may, at its election and cost, separately meter a 1 MW element of a larger system.

3.3.1 PBI for Non-PV Electric Displacing Thermal Systems

For non-PV electric displacing thermal systems, the thermal output of the system serving the customer's thermal load must be metered, divided by the Performance Ratio for the backup, displaced or replaced electric heating or cooling system. The location of the metering is critical for correct assessment of the useful thermal output of the non-PV system. Metering should be placed in the process such that the thermal energy delivered (or removed in the case of cooling) to the customer's thermal load is accurately measured.

Note that hot air solar systems will be paid incentives based on the EPBB method described in Section 3.2²⁷.

Ancillary electric loads for solar thermal heating and cooling systems, under PBI, will be measured and subtracted from the calculated gross avoided electric consumption. However, ancillary load measurements will be required only if the ancillary rated load is $\geq 5\%$ (i.e., within the uncertainty of the thermal measurement) of the gross avoided electric load potential.

The avoided monthly electric energy (kWh/month) will be calculated by dividing the measured delivered cooling or heating (in equivalent electric thermal) by the appropriate Performance Ratio and, if required, subtracting the system's measured ancillary load (kWh/month). The incentive payment is then determined by multiplying the net avoided electric load with the incentive rate (\$/kWh).

Example #1 – Solar Space Cooling System

$$\text{EDE} = ((\text{TNPV} / 3,412) / \text{PR}) - \text{EAUX}$$

$$\text{\$PBI} = \text{EDE} \times \text{\$Erate}$$

Where;

“EDE” = Displaced electricity from the grid.

“TNPV” = Measured thermal (heating or cooling) output of the non-PV system (which may include an absorption chiller or other heat driven cooling system) in Btu/month.

“PR” = Dimensionless Performance Ratio of the conventional electric heating or cooling system calculated by the heating or cooling energy output of the system divided by its electric energy input. In this example, the conventional cooling system is a 20 Ton (240 kBtu/hr) air cooled packaged chiller with a standard IPLV of 9.2. The Performance Ratio for this system is 2.7.

²⁷ Metering the thermal output of solar hot air systems, within reasonable accuracy and cost is difficult.

“EAUX” = Ancillary electric equipment (e.g. pumps, etc.) used for the solar thermal system operation.

“\$PBI” = Monthly PBI incentive payment.

“\$Erate” = Current step PBI incentive rate (e.g. \$0.34/kWh)

3.3.1.1 PBI for Non-PV Electric Displacing Thermal Systems

For hydronic solar heating and cooling systems, the BTU meter specifications shall be as follows –

- Provides totalizing outputs in BTUs per period.
- Capable of remote communications.
- Monthly totalizing accuracy of $\leq 5\%$ ²⁸.
- Flow meter and temperature sensor accuracy is National Institute of Standards and Technology (NIST) traceable.

3.3.2 PBI for Residential Projects

Monthly payments will be made based on actual electricity generated in kWh as per the monthly reading of the meter. The residential PBI incentive rate (\$/kWh) shall be in accordance with Table 4 above.

The PBI incentive levels may vary by utility service area, depending on the pace of solar demand in each utility’s territory. Refer to www.csi-trigger.com to determine the currently effective step and incentive rate.

3.3.3 PBI for Non-Residential Projects

There are different incentive rates for commercial entities and for Government or Non-Profit entities that are the System Owners. If a Government or Non-Profit entity is not the System Owner, the incentive amount will be determined by the tax status of the System Owner. The Program Administrators will make the monthly payments based on actual electricity generated in kWh as per the monthly reading of the meter. The incentive amount (\$/kWh) will be in accordance with Table 4.

The PBI incentive levels may vary by the Program Administrators’ territory, depending on the pace of solar demand in each territory. Refer to www.csi-trigger.com to determine the currently effective step and incentive rate.

Deleted: 11

Deleted: ¶
Table 11
Residential PBI Incentive Levels by
MW Steps and Program
Administrator Territory¶
Step ... [41]

Deleted: the Program
Administrator’s website

Deleted: 12

Deleted: above

Deleted: ¶
Table 12
Non-Residential PBI Incentive
levels by MW Step and Program
Administrator Territory¶
Step ... [42]

Deleted: the Program
Administrator’s website

²⁸ At least one BTU meter supplier has provided information showing that 5% accuracy is achievable. See Appendix E for an example Btu meter accuracy calculation.

Government and Non-Profit entities will be required to submit verification of their tax-exempt status to receive this incentive amount. Additionally, Government and Non-Profit entities must include a certification under penalty of perjury from their chief financial officer or equivalent that they are a Government or Non-Profit entity and that the system is not receiving and will not in the future receive federal tax benefits through financial arrangements for the entire warranty period of the system (i.e., the System Owner is a third-party, who will be receiving tax benefits from the system). This certification must be renewed annually if receiving PBI payments.

3.4 Incentive Limitations

Incentive amounts and project eligibility for the CSI Program are limited by a number of factors, including:

- Total eligible project costs
- Other incentives or rebates received
- Project size and Host Customer Site limitations.

3.4.1 Total Eligible Project Costs

No project can receive total incentives (incentives from the CSI Program combined with other programs) that exceed total eligible project costs. The Applicant must submit project cost details to report total eligible project costs and to ensure that total incentives do not exceed out-of-pocket expenses for the System Owner. See Appendix A for eligible cost items. Total eligible project costs cover the solar system and its ancillary equipment. Equipment and other costs outside of the project envelope defined in Appendix A are considered ineligible project costs but also must be reported. For large, multifaceted projects where the solar system costs are embedded, applications must include a prorated estimate of the total eligible costs for the solar system. Applications must include the project cost breakdown worksheet available from the Program Administrators' websites.

3.4.2 Other Incentives or Rebates

Customers may not receive CSI Program incentives for the same self-generation equipment from more than one Program Administrator (e.g., PG&E, SCE, and CCSE). For projects receiving incentives under other programs, the CSI Program incentive may be reduced, depending on the source of the other incentive. For projects that receive "other incentives" for the same generating equipment that are funded by California investor-owned utility ratepayers (e.g., utility or Energy Commission public goods charge programs, etc.), the CSI Program incentive is discounted by the amount of the other incentive. For projects that receive "other incentives" funded from other sources than utility ratepayers (federal and state grants, air district grants, tax credits, etc.) no adjustment is made to the CSI incentive, except where a CSI incentive would otherwise cause total incentives to exceed total costs.

In no event may the combined incentives received from CSI Program and other funding sources exceed the total eligible project cost. Host Customers, Applicants and System Owners are required to disclose information about all other incentives, including incentives for equipment or

systems ancillary to the solar system, post-installation performance payments, or additional incentives. Program Administrators will enter applications into a statewide database that will permit universal tracking of applications for this and other programs.

3.4.3 Right to Audit Final Project Costs

The Program Administrators reserve the right to conduct spot checks to verify that payments were made as identified in the final invoices or agreements provided by equipment sellers and/or installers. As part of these spot checks, the Program Administrators will require Applicants to submit copies of cancelled checks, credit card statements, or equivalent documentation to substantiate payments made to the equipment seller and/or installer. When submitting this documentation, Applicants are encouraged to remove their personal account numbers or other sensitive information identified in the documentation. Applicants must explain the difference if the final amount paid by the Applicant is different from the amount of the purchase or installation shown in any agreement or invoice or in the previously submitted Reservation Request.

If selected for a random audit, Applicants must submit final system cost documentation clearly identifying the final amount paid or legally incurred to purchase the system and the final amount paid to install the system. The cost documentation must provide proof of the final amount paid or legally incurred by the System Owner to the equipment seller and/or installer and provide sufficient information to clearly identify the equipment purchased and the labor paid. The final amount paid or legally incurred to the equipment seller and/or the final amount paid to the installer must match the cost information identified in the Reservation Confirmation and Incentive Payment Claim Form. To meet this requirement, the System Owner must submit final invoices and/or a copy of the final agreement. The actual amount paid or legally incurred by the purchaser to the equipment seller and/or the actual amount paid to the installer must be clearly indicated. If there is no direct proof of actual payment from the System Owner to an appropriately licensed installer or seller, the incentive will be cancelled or reduced.

In addition, the final invoices or agreements should clearly indicate the extent to which the California Solar Initiative program incentive lowered the cost of the system to the System Owner. If the System Owner has entered into an agreement to pay the equipment seller over time rather than in lump sum, the final agreement must indicate the terms of payment and the amount of any deposits or payments paid by Applicant to the equipment seller to date. The System Owner must pay the cost of any system installation prior to submitting a payment request to the Program Administrator.

3.4.4 Site and Host Customer Limitations

There are restrictions on the amount of incentive funding a Host Customer can reserve and receive. Host Customers can reserve up to 1 MW of maximum incentive funding from the CSI Program for a single Site for the duration of the CSI Program.

3.5 CSI Program Database

One of the notable features of the CSI Program is the on-line database. The Program Administrators are maintaining an up-to-date database on their websites, and via the www.GoSolarCalifornia.ca.gov website or directly to csi.powerclerk.com, that lists information on the progress of the CSI Program. The database shows detailed information on the number of applications, confirmed reservations, and installed PV systems from January 2007 forward. The online system or the Program Administrators' websites will have links to the archived database of all systems installed under the Energy Commission's Emerging Renewables Program, Self-Generation Incentive Program, and Rebuild a Greener San Diego Photovoltaic Incentive Program.

The database will include the following data and information from each project:

- Installer
- Seller
- City
- ZIP code
- Utility name
- Technology
- Size (Watts)
- Installed price approval
- PV manufacturer
- PV model
- Inverter manufacturer
- Inverter model
- Date completed
- Date of approved reservation.

It is anticipated that once fully developed, the database will provide program data on, or close to, a real-time basis.

4. Application Process for California Solar Initiative Projects

Through the California Solar Initiative (CSI) program, funding may be reserved for Applicants who have committed to purchase and install an eligible solar energy system at a given Site. A funding reservation provides the purchaser assurance that the reserved funds will be available when the payment claim is made.

Table 7 describes various situations and identifies the subsections that provide details on how to apply for funding.

Deleted: 13

Table 7
Summary of Application Procedures by Track

Deleted: 13

Track	Sector	Application Fee	System Size	Reservation Period	Relevant Section
1	All Residential	No	All	12 months	Section 4.1
1	Commercial	No	Less than 10 kW	*12 months for retrofit *18 months for new construction projects	Section 4.1
1	Government, Non-profit, Public Entities (small projects)	No	Less than 10 kW	12 months	Section 4.1
2	Commercial	Yes	Greater than or equal to 10 kW	*12 months for retrofit projects *18 months for new construction projects	Section 4.2 Section 4.2.1
2	Government, Non-profit, Public Entities	Yes	Greater than or equal to 10 kW	18 months	Section 4.2 Section 4.2.2


4.1 Residential (All) and Small Non-Residential Projects (< 10 kW)

This section describes the application process for all projects installed on a residential Host Customer Site as well as projects less than 10 kW installed on Non-Residential Host Customer Sites. All residential and small projects are eligible to receive a lump sum EPBB incentive payment. However, there is an option to opt in to receive PBI based on \$/kWh produced.

The CSI Program uses an on-line application tool to simplify the application process and confirm the rebate amount reserved, contingent on receiving all documents. The Reservation Request

Form may be downloaded from the Program Administrators' websites or www.GoSolarCalifornia.ca.gov or from csi.powerclerk.com.

Figure 1 outlines the application process for residential and small projects less than 10 kW.



4.1.1 Two-Step Process for Residential and Small Non-Residential Applicants

There are two primary steps for residential and small Non-Residential Applicants as follows:

1. Complete and submit an Application (on line or available at the Program Administrator's website) and Reservation Application Package
2. Complete and submit the Incentive Claim Form (on line or available at the Program Administrator's website)

Table 8 details the application forms and documentation requirements for the two-step application process. See Section 4.7 for required documentation.

Deleted: 14

Table 8
Two-Step Application Process – Forms and Documentation Requirements

Deleted: 14

Step 1: Reservation Request
Completed Reservation Request Form and Program Contract with Original Signature on CSI Program Contract
Proof of Electric Utility Service for Site
Electrical System Sizing Documentation (new/expanded load for systems greater than 5 kW)
Certification of tax-exempt status and AB1407 compliance (Gov't and Nonprofit only)
Documentation of an Energy Efficiency Audit (or Title 24 documentation or other exemptions)
Printout of EPBB Tool Calculation (www.csi-epbb.com) (for non-PV a copy of the SOF chart marking the correct data point)
Copy of Executed Agreement of Solar System Purchase and Installation
Copy of Executed Alternative System Ownership Agreement (If System Owner is Different from Host Customer)
Step 2: Reservation Confirmation and Claim
Complete Incentive Claim Form with Original Signatures
Copy of Executed PMRS Contract or PMRS Cost Cap Exemption Documentation
Revised EPBB Calculation Printout (if applicable) (for non-PV a copy of the revised SOF chart marking the correct data point)
Final Project Cost Breakdown Worksheet
Final Project Cost Affidavit

Deleted: , including warranty language

4.1.2 Step # 1: Submit Reservation Request Application Package

Once the customer has decided to install a solar system and has an executed contract with their system installer, an Application (on-line or available at the Program Administrator's website) and Reservation Request Application Package are submitted in the first step of the application process.

The Reservation Request Form must have original signatures of Applicant and Host Customer and should be submitted with the following documentation:

1. Completed Reservation Request Form and Program Contract with Original Signature.
2. Proof of Electric Utility Service for Site
3. Electrical System Sizing Documentation (new/expanded load only) for projects > 5 kW
4. Certification of tax-exempt status and AB1407 compliance (Gov't and Nonprofit only)

-
5. Documentation of an Energy Efficiency Audit (if you have not met Title 24 or other exemptions)
 6. Printout of EPBB Tool Calculation (www.csi-epbb.com) (for non-PV, a copy of the SOF chart marking the correct data point)
 7. Copy of Executed Agreement of Solar System Purchase and Installation
 8. Copy of Executed Alternative System Ownership Agreement (If System Owner is Different from Host Customer)

Refer to Section 4.7 for more information on the above-referenced forms and documents.

Detailed instructions are included with the Reservation Request Form. The Reservation Request Form may be downloaded from the Program Administrators' websites or www.GoSolarCalifornia.ca.gov.

The Host Customer and System Owner must sign the Reservation Request Form.

4.1.3 Incomplete Reservation Requests

If an application is found to require clarification, the Program Administrator will request additional information. Applicants have 20 calendar days to respond to the clarification request with the necessary information. If after 20 calendar days the Applicant has not submitted the requested information, the application will be canceled. Resubmitted application packages will be treated as new applications (i.e., all required documents must be resubmitted) and processed in sequence along with other new applications.

Incentive funds are not reserved until the Program Administrator receives all information and documentation required for the Reservation Request and the project is approved.

4.1.4 Approval of Reservation Request

Once received, the Program Administrator will review the application package for completeness and determine eligibility. Applications will also be screened to ensure that the project has not applied for incentives through other Program Administrators or other state- or government-sponsored incentive programs.

Once the Program Administrator approves the reservation request, the Program Administrator will issue a Confirmed Reservation [notice](#) that confirms that a specific incentive amount is reserved for the project. This confirmation [notice](#) will also include an Incentive Payment Claim Form.

~~Deleted: Notice~~
~~Deleted: Letter~~
~~Deleted: notice~~

The system must be purchased, installed, and put into operation by the Reservation Expiration Date (see Section 4.1.4.1 for length of reservation) as listed in the Confirmation Reservation [notice](#). The Incentive Payment Claim Form will list the specific reservation dollar amount and the Reservation Expiration Date. For more information on the Incentive Claim Form package, refer to Section 4.7.

~~Deleted: Notice~~
~~Deleted: Letter~~

4.1.4.1 Reservation Period

Incentives can be reserved for up to 12 months for residential retrofit projects and commercial retrofit projects. Incentives can be reserved for up to 18 months for government, non-profits and public entities and also for new construction projects.

4.1.5 Step # 2: Submit Incentive Claim Form Package

After the solar system is purchased, installed, and put into operation, the Applicant should submit the Incentive Claim Form and the required supporting documentation.

The Incentive Claim Form Package must have original signatures of Applicant and Host Customer and should be submitted with the following documentation:

1. Incentive Claim Form with Original Signatures
2. Copy of Executed PMRS Contract or PMRS Cost Cap Exemption Documentation
3. Revised EPBB Calculation Printout (if applicable) (for non-PV, a copy of the SOF chart marking the correct data point)
4. Final Project Cost Breakdown Worksheet
5. Final Project Cost Affidavit

The online tool can be used to assist at the Incentive Claim Form stage even if it had not been used for the original Reservation Request Application Package.

Although the Applicant is no longer required to submit Proof of Authorization to Interconnect, the Program Administrators will verify interconnection prior to any incentive payment.

For more detailed information on submitting the Incentive Claim Form package, refer to Section 4.7.3.

4.2 Non-Residential Projects (≥ 10 kW) and PBI Projects

This section describes the application process for all Non-Residential projects ≥ 10 kW for commercial and industrial, Government, Non-Profit, and Public Entities and for any project receiving payment under a PBI structure.

Please note that Non-Residential projects (≥ 10 kW) may opt into the two-step process if they would like to, but are still subject to the eligibility requirements based on their system size and type. See section 4.1.1 for required timelines and paperwork.


The Applicant can expedite the three step process by providing the requisite information to the program administrators in two steps. Non-residential projects (≥ 10 kW) are still subject to the

eligibility requirements based on their system size and type, including the submission of any required application fees. See section 4.2.3 for required timelines and paperwork.

The CSI Program anticipates an on-line application tool to simplify the application process.

4.2.1 Application Process Flow Chart for Commercial Industrial Applicants (≥10 kW)


Figure 2 documents the application process for commercial and industrial customers.



4.2.2 Application Process Flow Chart for Government, Non-Profit, and Public Entities (≥ 10 kW)

Figure 3 documents the application process for Government, Non-Profit, and Public Entities.

**Figure 3
Government, Non-Profit, and Public Entities (≥ 10 kW) Application Process Flow Chart**



4.2.3 Three-Step Process for Non-Residential Applicants (≥ 10 kW)

There are three primary steps for Non-Residential Applicants with systems larger than or equal to 10 kW as follows:

-
1. Complete and submit the Reservation Application Package (on line or available at the Program Administrator's website) and Application fee. See Section 4.2.4 for required documentation.
 2. Complete and submit the Proof of Project Milestone Package (on line or available at the Program Administrator's website). See Section 4.7.2 for required documentation.
 3. Complete and submit an Incentive Claim Form Package (on line or available at the Program Administrator's website). See Section 4.7.3 for required documentation.

[Table 9](#) details the application forms and documentation requirements for the three-step application process.

Deleted: Table 15

Please note that Non-Residential projects ($\geq 10\text{kW}$) may opt into the two-step process if they would like to, but are still subject to the eligibility requirements based on their system size and type. See section 4.1.1 for required timelines and paperwork.

The Applicant can expedite the three-step process by providing the requisite information to the program administrators in two steps. Non-residential projects ($\geq 10\text{ kW}$) are still subject to the eligibility requirements based on their system size and type, including the submission of any required application fees. See section 4.2.3 for required timelines and paperwork.

Table 9

Three-Step Application Process – Forms and Documentation Requirements

Deleted: Table 15

Step 1: Reservation Request
Completed Reservation Request Form and Program Contract with Original Signature
Proof of Electric Utility Service for Site
System Description Worksheet
Electrical System Sizing Documentation (new/expanded load only)
Application Fee (See Section 4.2.5)
Certification of tax-exempt status and AB1407 compliance (Gov't and Nonprofit only)
Documentation of an Energy Efficiency Audit (if you have not met Title 24 or other exemptions)
Printout of EPBB Tool Calculation (www.csi-epbb.com) (for non-PV a copy of the SOF chart marking the correct data point)
Step 2: Proof of Project Milestone
Completed Proof of Project Milestone Checklist
Copy of executed contract for system purchase and installation
Copy of executed alternative System Ownership agreement (if System Owner is different than Host Customer)
Revised EPBB Calculation Printout (if applicable) (for non-PV a copy of the SOF chart marking the correct data point)
Copy of RFP or solicitation (Government, Non-profit, and Public Entities only)
Step 3: Incentive Form Package
Complete Incentive Claim Form with Original Signatures
Copy of Executed PMRS Contract or PMRS Cost Cap Exemption Documentation
Revised EPBB Calculation Printout (if applicable) (for non-PV a copy of the SOF chart marking the correct data point)
Final Project Cost Breakdown Worksheet
Final Project Cost Affidavit

Deleted: 1% of EPBB-calculated CSI Incentive

4.2.4 Step # 1: Request to Reserve Funding

This subsection applies to all Non-Residential Applicants with solar systems larger than or equal to 10 kW, regardless of whether the Applicant is a private or public entity. To reserve a specified incentive amount, Applicants must submit the Reservation Request Form, Application Fee, and all required documentation attachments. The Reservation Request Form and instructions can be downloaded from the local Program Administrator’s website.

The Reservation Request Form may be downloaded from the Program Administrators’ websites or www.GoSolarCalifornia.ca.gov. The System Owner and Host Customer must always sign the Reservation Request Application. In addition, all Applicants applying for incentives must provide the following:

1. Completed Reservation Request Form and Program Contract with Original Signature
2. Proof of Electric Utility Service for Site
3. System Description Worksheet

4. Electrical System Sizing Documentation (new/expanded load only)
5. Application Fee ([See Section 4.2.5](#))
6. Certification of tax-exempt status and AB1407 compliance (Gov't and Nonprofit only)
7. Documentation of an Energy Efficiency Audit (if you have not met Title 24 or other exemptions)
8. Printout of EPBB Tool Calculation (www.csi-epbb.com) (for non-PV a copy of the SOF chart marking the correct data point)

Deleted: 1% of EPBB-calculated CSI Incentive

For more information on the above referenced forms and documents, go to Section 4.7.

4.2.5 Application Fee Process

In addition to the Reservation Request Form and Required Attachments, Applicants will also be required to submit an application fee. Applicants with projects that are residential, or less than 10 kW, need not pay an application fee.

The application fee is [a standardized amount based on the following system size \(CEC-AC\) criteria:](#)

Formatted: Indent: Left: 0", First line: 0"

<u>kW ></u>	<u>-</u>	<u>kW <</u>	<u>≡</u>	<u>FEE</u>
<u>10</u>	<u>-</u>	<u>50</u>	<u>≡</u>	<u>\$1,250</u>
<u>50</u>	<u>-</u>	<u>100</u>	<u>≡</u>	<u>\$2,500</u>
<u>100</u>	<u>-</u>	<u>250</u>	<u>≡</u>	<u>\$5,000</u>
<u>250</u>	<u>-</u>	<u>500</u>	<u>≡</u>	<u>\$10,000</u>
<u>500</u>	<u>-</u>	<u>1,000</u>	<u>≡</u>	<u>\$20,000</u>

Deleted: 1 percent of the unadjusted requested CSI Program incentive amount. Application fees will be rounded to the nearest dollar amount. The formula for the EPBB or PBI fee is as follows:}]
 Application Fee = (System Size Rating x current applicable/equivalent EPBB incentive rate) x 1%

- Applicants may submit the application fee with the Reservation Request Application with original signatures. If the application fee is not received with the Reservation Request Application, the Program Administrators will invoice the Host Customer (utility customer of record) after review of the Reservation Request Application package.
- The Host Customer will have 30 days to submit payment for the application fee in order to activate the Reservation Request. The payment must reference the project (by invoice number, facility address, and/or application number).
- Program Administrators will accept payments from either the Applicant or a third party on behalf of the Host Customer for a particular project; however, a returned application fee shall only be paid to the Host Customer.
- Program Administrators will only accept application fees in the form of a check. Cash, credit cards, money orders, promissory notes, etc. will not be accepted.
- Application fees will be linked to reservation numbers, not to the project sites; therefore, the project must be completed under the same reservation number as the one linked to the application fee.

-
- Upon verification of the installed CSI project and initial incentive payment, the application fee will be returned in full to the Host Customer.
 - No interest shall be paid on application fees.

4.2.5.1 Failure to Submit Application Fee

- Returned checks will result in the Program Administrator rejecting the Reservation Request Application.
- Failure to submit payment within 30 days will result in the cancellation of the Reservation Request Application.

4.2.5.2 Return of Application Fee

- If upon eligibility screening the project does not qualify for the CSI Program, the application fee will be returned in full to the Host Customer.
- If a project that has received an Incentive Claim Form from the Program Administrator is withdrawn due to extenuating circumstances beyond the Applicant's control, the application fee may be returned pending discussion and agreement of the Program Administrators. This will be determined on a case-by-case basis.

4.2.5.3 Forfeit of Application Fee

- Once a confirmed reservation is granted and the project is cancelled or withdrawn by the Applicant and/or Host Customer, the application fee will be forfeited.
- Once a confirmed reservation is granted and the Program Administrator rejects the project for failing to meet adequate proof of project milestone or reservation expiration date requirements, the application fee will be forfeited.
- If a project reservation is allowed to lapse and the project is later built under a new reservation, the application fee for the previous reservation will be forfeited.
- If a confirmed reservation is granted and the incentive level has been reduced (due to Commission directive, moving to the next step, etc.), the Applicant and Host Customer will be notified and given 20 calendar days to submit in writing a request to withdraw their reservation request without losing their application fee. Upon receipt of a request to withdraw, the application fee shall be returned to the Host Customer. If the Applicant fails to withdraw the reservation request within 20 calendar days, the application will be processed at the new, lower incentive level. If the application is not withdrawn within the 20-day period, the Applicant will forfeit the application fee if it subsequently withdraws or fails to pursue its project.
- All forfeited application fees will be re-allocated to the Program Administrator's incentive budget.

4.2.5.4 Effect of Change of System Change on Application Fee

- Application fees will be retained until the completion of the proposed CSI project and will not be adjusted downward due to changes in system size or incentive amount.

4.2.6 Approval of Reservation Request

Once received, the Program Administrator will review the application package for completeness and determine eligibility. Applications will also be screened to ensure that the project has not applied for incentives through other Program Administrators or other state- or government-sponsored incentive programs.

4.2.6.1 Incomplete Reservation Requests

Incentive funds are not reserved until the Program Administrator receives all information and documentation required for the Reservation Request Form Package, the application fee and the project is approved.

If an application is found to require clarification, the Program Administrator will request the information necessary to process that application further. Applicants have 20 calendar days to respond to the requested clarification with the necessary information. If after 20 calendar days, the Applicant has not submitted the requested information the applications will be canceled. Application packages that are resubmitted after such a cancellation will be treated as a new application (i.e., all required documents must be resubmitted) and processed in sequence along with other new applications.

4.2.6.2 Approval of Reservation Request

Once a Reservation Request Form package is determined to be complete and eligible, the Program Administrator will reserve a specific dollar amount for a specified system size. The Program Administrator will send a Confirmed Reservation [notice](#) to the Applicant.

The Confirmed Reservation [notice](#) documents that a specific incentive amount has been reserved for a project. The [notice](#) will list, at a minimum, the approved incentive amount and the date that the Proof of Project Milestone package must be submitted. The Confirmed Reservation [notice](#) also will list the required information that Applicants must submit by the Proof of Project Milestone.

Once the application documentation has successfully fulfilled the Proof of Project Milestone documentation, the Program Administrator will issue an Incentive Claim Form with a Reservation Expiration Date of 12 months for commercial retrofit projects, 18 months for commercial new construction projects, and 18 months for Governmental, Non-Profit, and Public Entities from the date of the initial Confirmed Reservation [notice](#).

Refer to Section 4.2.7 for more information on the Proof of Project Milestone requirements.

Deleted: Notice
Deleted: Letter
Deleted: Notice
Deleted: Letter
Deleted: letter
Deleted: Notice
Deleted: Letter

Deleted: Notice
Deleted: Letter

4.2.6.3 Reservation Period

The initial reservation is valid only until the Proof of Project Milestone Date. The Proof of Project Milestone Date will be 60 calendar days after the date of the Confirmed Reservation [notice](#) for residential and commercial projects. Within noted calendar days of the date the Confirmed Reservation [notice](#), the Applicant must submit to their Program Administrator the Proof of Project Milestone package. All project advancement criteria, including returning a signed CSI Program contract, must be satisfied. Once the Applicant has sufficiently demonstrated that the project is advancing, the Program Administrator will issue an Incentive Claim Form. The Applicant will have 12 months to complete the project from the date that the Confirmed Reservation [notice](#) is issued for retrofit projects and 18 months for new construction projects.

Deleted: Notice

Deleted: Letter

Deleted: Letter

Deleted: Notice

Deleted: Letter

4.2.6.4 Reservation Period for Government, Non-Profit and Public Entity Projects

The initial reservation is only valid for until the Proof of Project Milestone date. Within 60 days after the Confirmed Reservation [notice](#), Government, Non-Profit and public entities must turn in the Proof of Project Milestone checklist and a copy of the RFP or other solicitation for the installation of the project. Then, Government, Non-Profit, and Public Entities will have an additional 180 days to provide the entire Proof of Project Milestone package. All project advancement criteria, including returning a signed CSI Program contract, must be satisfied. Once the Applicant has sufficiently demonstrated that the project is advancing, the Program Administrator will issue an Incentive Claim Form. The Applicant will have 18 months to complete the project from the date that the Confirmed Reservation [notice](#) is issued.

Deleted: Notice

Deleted: letter

Deleted: Notice

Deleted: Letter

4.2.7 Step # 2: Submit Proof of Project Milestone Package

Within 60 calendar days (240 days for Governmental entities) of the date on the Confirmed Reservation [notice](#), the Proof of Project Milestone package with all supporting documentation must be submitted to demonstrate to the Program Administrator that the project is progressing and that there is a sustained commitment to complete the project within the allowed timeline. The specific requirements by sector are as follows:

Deleted: Letter

- Non-Residential projects greater than or equal to 10 kW and projects that are receiving a PBI payment within 60 days of the Confirmed Reservation [notice](#) must submit a Proof of Project Milestone package, including all required documentation.
- Government, Non-profit, and Public Entities, within 60 calendar days of the date of the Confirmed Reservation [notice](#), must submit a copy of the issued request for proposal (RFP or equivalent) for purchase or installation of the solar system. Within 240 calendar days of the date of the Confirmed Reservation [notice](#), they must satisfy all proof of project milestone criteria, including all required documentation.

Deleted: Notice

Deleted: Letter

Deleted: Letter

Deleted: Letter

Once the Applicant has successfully met Proof of Project Milestone requirements, the Program Administrator will issue an Incentive Claim Form with a Reservation Expiration Date of 12

months from the date of the initial Confirmed Reservation [notice](#) for commercial retrofit projects, 18 months for commercial new construction projects, and 18 months from the date of the initial Confirmed Reservation [notice](#) for Governmental, Non-Profit, and Public Entities.

Deleted: Notice

Deleted: Letter

Deleted: Notice

Deleted: Letter

4.2.7.1 Required Attachments to Demonstrate Project Milestone

The following documentation must be submitted on or before the Proof of Project Milestone date indicated in the Confirmed Reservation [notice](#).

Deleted: Letter

1. Completed Proof of Project Milestone Checklist
2. Copy of executed contract for System Purchase and Installation
3. Copy of Executed Alternative System Ownership Agreement (if System Owner is different than Host Customer)
4. Revised EPBB Calculation Printout (if applicable) (for non-PV a copy of the SOF chart marking the correct data point).
5. Copy of RFP or Solicitation (Government, Non-Profit, and Public Entities only)

For more information on the above-referenced forms, go to Section 4.7.

4.2.7.2 Incomplete Proof of Project Milestone

If submitted Proof of Project Milestone documentation is received by the Proof of Project Milestone Date but requires clarification, the Program Administrator will request the information necessary to process that application further. Applicants have 20 calendar days to respond with the necessary information. If, after 20 calendar days, the Applicant has not submitted the requested information, the applications will be canceled.

4.2.7.3 Proof of Project Milestone Extensions

In general, no extensions to the Proof of Project Milestone date are permitted.

4.2.7.4 Submitting Proof of Project Milestone

Once the Proof of Project Milestone package is complete and all the required attachments are secured, Applicants must submit their application package to the Program Administrator for review. To ensure confirmation of receipt, it is recommended that documentation is to be delivered to the appropriate Program Administrator by certified or overnight mail. No faxes or hand deliveries will be accepted.

4.2.7.5 Approval of Proof of Project Milestone

Once Applicants have successfully met the Proof of Project Milestones requirements, the Program Administrator will issue an Incentive Claim Form. This form will list the specific reservation dollar amount and the Reservation Expiration Date. Upon project completion and prior to the Reservation Expiration Date, Applicants must submit a completed Incentive Claim Form along with all of the necessary documentation to request an incentive payment.

For more information on how to submit an Incentive Claim, refer to Section 4.4.3.

4.2.8 Step # 3: Submit Incentive Claim Form Package

The online tool can be used to assist at the Incentive Claim Form stage even if it had not been used for the original Reservation Request Application Package.

Refer to Section 4.7.3 for more information about the requirements associated with submitting the Incentive Claim Form package.

4.3 Changes to Reservations

4.3.1 Extending the Reservation Expiration Date

A request to extend the Reservation Expiration Date is limited to a maximum of 180 calendar days of additional time. Any request must include a written explanation of why the extension is required and how much additional time is needed. Approval of a request for a change in Reservation Expiration Date will not change or modify any other reservation condition. Failure to submit the Incentive Claim Form package by the original or extended Reservation Expiration Date will result in a cancellation of the application. The Applicant should submit a time extension in writing to the Program Administrators. In describing the reason for the time extension request, the Applicant should provide information on the following to aid the Program Administrators in their decision to grant an extension:

1. Circumstances were beyond the control of the reservation holder that prevented the system from being installed as described in the reservation request. Describe the need and reasons for the request.
2. If there was a problem in the permitting process and it was the cause of delay, provide documentation, such as any correspondence with the building department, to support this explanation.
3. Cost documentation must demonstrate that the system purchaser has incurred at least 50 percent of the reserved system's total purchase price. However, in cases where this amount exceeds the purchaser's contribution then the purchaser may still retain 10 percent of the total system cost and meet this cost documentation requirement. Attach copies of paid invoices, checks or other verifying documentation to the Request for Project Extension Form.
4. Documentation of any equipment installed at the site.

In order for any project to receive an extension, the Applicant must show documentation of a purchase order or commitment from a PV panel manufacturer to supply the necessary equipment.

The Program Administrator reserves the right to perform a Site inspection to verify the status of the project installation prior to granting the request for extension. If required, the Program Administrator shall notify the Applicant and schedule the Site visit within 10 days of notification.

4.4 Incentive Payment Process

Once a system is completed, Applicants may request payment of the incentive amount listed on their Incentive Payment Claim Form. A project is considered completed when it is completely installed, interconnected, permitted, paid for, and capable of producing electricity in the manner and in the amounts for which it was designed.

To receive the incentive, all CSI Program requirements must be met and a complete Incentive Claim Form package is submitted prior to the Reservation Expiration Date.

The Program Administrator reserves the right to withhold final incentive payment pending review and approval of the incentive claim documentation and field inspection results if that project is determined to require a field inspection.

4.4.1 Requesting an Incentive Payment

After an eligible solar system is completed, Applicants may request payment of the incentive amount listed on their Incentive Claim Form. Payment will be disbursed once the Program Administrator verifies that the solar system is completed and meets all the eligibility requirements of the CSI.

To request an incentive payment, the Applicant completes and submits the Incentive Claim Form. Both Host Customer and System Owner must sign the Claim Form.

Please note that no incentive payment will be made until the Program Administrator has inspected and found that the system is operational and interconnected if that project is determined to require a field inspection. For further information regarding field inspections, refer to Section 4.6.

The completed Incentive Claim Form must be submitted to the Program Administrator on or before the Reservation Expiration Date, together with all required attachments described below.

4.4.2 Assignment of Incentive Payment to Third Party

The designated payee of the incentive payment may assign his or her right to receive the payment to a third party by completing the Payment Assignment Form and submitting it with the Incentive Payment Claim Form. The Payment Assignment Form may not be submitted by fax as original signatures are required to process the assignment.

4.4.3 Incentive Payment Claim Form Package

The Applicant must submit the Incentive Claim Form package, complete with all required attachments, to the Program Administrator prior to the Reservation Expiration Date. The Host Customer and System Owner must read, sign, and date the Incentive Payment Claim Form. This form must be returned to the Program Administrator by mail, as original signatures are required to process a payment.

4.4.3.1 Required Documents for Incentive Claim Form Package

In addition to the completed Incentive Claim Form, Applicants must submit the following documents when requesting an incentive payment:

1. Incentive Claim Form with Original Signatures
2. Copy of Executed PMRS Contract or Cost Cap Exemption Documentation
3. Revised EPBB Calculation Printout (if applicable) (for non-PV a copy of the SOF chart marking the correct data point)
4. Final Project Cost Breakdown Worksheet
5. Final Project Cost Affidavit

For more information on the above-referenced forms, go to Section 4.7.

4.4.4 Submitting an Incentive Claim Form Package

Once the Incentive Claim Form package is complete and all the required attachments are secured, Applicants must submit their application package to the Program Administrator for review. To ensure confirmation of receipt, it is recommended that documentation be delivered to the appropriate Program Administrator by certified or overnight mail. No faxes or hand deliveries will be accepted.

Applicants are advised to keep a copy of the Incentive Claim Form package along with all required documentation for their records.

4.4.4.1 Incomplete Incentive Claim Form Packages

If an incentive claim form package is incomplete or is found to require clarification, the Program Administrator will request the information necessary to process that application further. Applicants have 20 calendar days to respond to the requested clarification with the necessary information.

If after 20 calendar days, the Applicant has not submitted the requested information, the request for payment may be denied.

If an Incentive Claim Form package is not received by the expiration date of the Incentive Claim Form, or the Incentive Claim Form package indicates that the project is otherwise ineligible, the Program Administrator will send a written [notice](#) stating the reasons why the project is ineligible and the project will be rejected. If this is the case, the Applicant or Host Customer may reapply for an incentive reservation but will be subject to the eligibility requirements, incentive levels, and funding available at that time of reapplication.

Deleted: notice

4.4.5 Incentive Check Payment and Terms

Upon final approval of the incentive claim form documentation and completed field verification visit, the Program Administrator will issue the incentive in approximately 30 days for EPBB incentive payments. For PBI payments, the Program Administrator will issue the first incentive

payment within 30 days of the first scheduled performance output meter read. Payment will be made to the Host Customer or a third party (as designated), as indicated on the Incentive Claim Form, and will be mailed to the address provided. As the reservation holder, the Host Customer may assign payment to a third party by submitting a completed payment assignment form to the Program Administrator with the Incentive Claim Form. A payment assignment form can be requested from the Program Administrator or downloaded from the Program Administrator website.

The payee must submit their tax ID number to the Program Administrator.

4.4.5.1 Expected Performance Based Buydown (EPBB) Incentive Payment Terms

Most residential systems will receive an EPBB incentive. The EPBB incentive will be a one-time lump sum payment to help reduce the cost of installing a residential PV system. Upon final approval of the incentive claim form package and completed field inspection visit, if applicable, the Program Administrator will issue the incentive in approximately 30 days.

The EPBB payment shall be calculated according to Section 3.2 and noted on the Incentive Claim Form, provided no adjustments to the system size or estimated output are warranted after system inspection.

Please review Section 4.5 for system size changes affecting the incentive amount.

The lump sum EPBB incentive payment issued constitutes final and complete payment.

4.4.5.2 Performance Based Incentive Payment Terms

In 2007, incentives for systems equal to or greater than 100 kW, or systems less than 100 kW who elect to opt in, will receive the performance based incentive (PBI) payments. As of January 1, 2008, PBI is required for systems 50 kW or larger. PBI will be paid based on the actual kWh production of the system.

PBI payments will be made monthly and paid out over a 5-year period. The monthly PBI payment shall be calculated as follows:

Solar Electric Generating - Monthly PBI Incentive Payment = Reserved Incentive Rate x Measured kWh Output²⁹

Solar Electric Displacing - Monthly PBI Incentive Payment = Reserved Incentive Rate x measured kWh-equivalent displacement.

Upon final approval of the incentive claim form documentation and completed field verification visit, if applicable, the Program Administrator will issue the first PBI incentive payment approximately 30 days after receipt of the first scheduled meter read of energy produced. PBI payments will continue to be paid on a monthly basis for the next 60 months (5 years).

²⁹ Because the CSI Program and statutes only allow for customers to receive incentives up to the first MW, PBI payments for energy output on systems larger than 1 MW will be prorated based on the ratio of 1 MW to the entire size of the site. See Section 3.3 for further detail.

Payments will be made to the Applicant, Host Customer, or a third party (as designated), as indicated on the Incentive Payment Claim Form. At the discretion of Program Administrators, payments may either be mailed to the address provided, [wire transferred](#), or paid via credits on the utility bill. The Host Customer may assign payment to a third party by submitting a completed payment assignment form to the Program Administrator with the Incentive Claim Form. A payment assignment form can be requested from the Program Administrator or downloaded from the Program Administrator's website.

If a monthly payment is determined to be incorrect due to a faulty meter read, the correction will be made in the next available payment period.

If a Host Customer moves during the 5-year period, they must notify the Program Administrator, who may make subsequent adjustments to the CSI Program.

The 60th monthly PBI incentive payment constitutes final and complete payment.

4.5 System Changes Affecting Incentive Amount

The Program Administrator will expect a system to be installed as described in the Reservation Request Form. However, it is recognized that changes may occur during installation and that changes may be necessary in some circumstances.

If the installed system is smaller in output than specified in the Reservation Request Form or subsequent updates, the incentive amount will be calculated using the installed system size. If the installed system is larger than that originally in the Reservation Request Form or subsequent updates, the incentive will be recalculated based upon the installed system size, with the incremental addition to the system receiving the current level of incentive. If the size of the increase moves the system from the EPBB structure to the PBI structure, the entire system will receive the PBI based upon the current incentive level.

If the increase in size occurs after the expiration date of the Confirmed Reservation, the incremental addition will be considered a new project and must submit a Reservation Request with its required documentation.

If the entire available budget for a Program Administrator is reserved for other projects and there is no available funding, the Program Administrator cannot increase the reserved incentive amount.

Please review Section 3.2 for information on the application process should the calculator change.

4.6 Field Inspection

4.6.1 Field Inspections

[Upon receipt of a complete Incentive Claim Form package, the Applicant's project, depending on system size and incentive structure, may be selected for a field inspection visit to verify that](#)

the system is installed as represented in the application, is operational, is interconnected and conforms to the eligibility criteria of the CSI Program. Program Administrators will conduct field inspection visits on a statistically reasonable random sample for EPBB systems that are less than 30 kW. All EPBB systems that are greater than 30 kW will be required to receive a field inspection. And all PBI systems, may be randomly selected for field verification visits.

If randomly selected or required, the field inspection visit will be conducted concurrent with review and approval of the incentive payment. Incentive payments will be contingent on the field inspection visit and may be adjusted depending on the results of the field inspection.

It is highly recommended, but not required, that the applicant attend the inspection.

- If neither the applicant nor the host is going to be present during the inspection, the inspector must obtain permission to perform the inspection in writing or by e-mail.
- If neither the host nor the applicant is present for the inspection, the inspector will not conduct the inspection unless permission was previously obtained in writing or via e-mail allowing the inspector to conduct the inspection without the host or the applicant present.

If the Applicant, Host Customer, System Owner or Installer does not agree with the inspection results, they may request another inspection at no cost.

4.6.2 Trained Inspectors

Field inspections shall be performed by trained personnel certified to perform CSI Program system inspections. The Program Administrators have developed and submitted a consistent statewide site inspectors training plan to the CPUC Energy Division.

4.6.3 Failed Field Inspection

If the field inspection determines that the installed system varies from the documentation, it may result in a failed field inspection. If a system fails a field inspection, the Program Administrator will notify the Applicant, Host Customer, and System Owner with the reasons for the field inspection failure.

Please refer to Section 2.9.1 for more information regarding situations that constitute a failure.

4.7 Application Forms and Documentation

The following section discusses each of the forms and documentation requirements listed in the subsections above. Refer to the subsection describing the process for your application type to determine which of the following documents are required for your situation.

Deleted: of projects

Deleted: Upon receipt of a complete Incentive Payment Claim Form package, the Applicant's project may be randomly selected for a field inspection visit to verify that the system is installed as represented in the application, is operational, is interconnected and conforms to the eligibility criteria of the CSI Program.

Deleted: projects between

Deleted: and 100 kW in system size are

Deleted: to verify the accuracy of system data submitted in the original CSI Program incentive application

Deleted: Projects equal to or over 100 kW, or who have opted into

Deleted: also

Deleted: scheduled within 15 calendar days of receipt of the completed Incentive Claim Form package. Field inspections will be

Deleted: will

4.7.1 Reservation Request Package and Required Documentation

4.7.1.1 Reservation Request Application Form with Original Signature

To reserve a specified incentive amount, a Reservation Request Form must be submitted with all required documentation attached. All forms are available from the Program Administrators' website. The seller, installer, and any other third party providing service related to a system installation should be identified on the application form, together with a description of the generation site, equipment information and project incentive calculation. Reservation Request Forms for projects that are residential or less than 10 kW will include the CSI Contract.

4.7.1.2 Proof of Electric Utility Service for the Site

Eligibility requirements restrict participation in the CSI Program to customers who are located in PG&E, SCE, or SDG&E service territories and physically connected to the electric utility transmission and distribution system. All applications must include a copy of a recent electric utility bill that shows the service address of the installation Site, the name of the Host Customer, and electric energy usage for the Site. Only the page of the utility bill that shows service account name, contact information, and service account number should be submitted to ensure that this information is provided. The entire utility bill is not required. For those with online billing, a printout of the account history from the utility's online service will be sufficient, so long as it includes the required information. The utility bill information should be no older than 6 months from the date of application. For new construction, the Applicant must provide confirmation documentation from the serving utility.

4.7.1.3 Electrical System Sizing Documentation (New or expanded load only)

Except for systems of 5kW or less which need no sizing documentation (see Section 2.2.7), to confirm that participating distributed generation systems will not exceed the capacity of the Host Customer's previous 12-month historical usage, all Applicants for projects at new construction must submit a copy of the data and calculations used to determine electrical system size. Please refer to Section 2.2.5 for more details.

4.7.1.4 Documentation of an Energy Efficiency Audit (for non-exempted applicants)

See Section 2.3 for more information about energy efficiency audits.

4.7.1.5 Printout of EPBB Tool Calculation

The EPBB Tool calculates the CSI EPBB design factor in order to determine the CSI system size. Printouts of EPBB Tool Calculation can be obtained from www.csi-epbb.com.

4.7.1.6 Additional Requirements for Residential and Small Non-Residential Projects (< 10 kW)

4.7.1.6.1 Copy of Executed Agreement of Solar System Purchase and Installation

For all residential (any size) as well as small Non-Residential (<10 kW) applications, the Applicant must submit a copy of an executed agreement to purchase and install the solar system at the time of submitting the Reservation Request Application Form.

4.7.1.6.2 Copy of Executed Alternative System Ownership Agreement (If System Owner is Different from Host Customer)

For residential and small Non-residential (<10 kW) applications, if the system owner is not the host customer, applicant must submit a copy of Executed Alternative System Ownership agreement with the Reservation Request Form.

4.7.1.7 Additional Requirements for Non-residential projects ≥ 10 kW

4.7.1.7.1 System Description Worksheet

Non-Residential projects equal to or greater than 10 kW are required to complete and submit a System Description Worksheet.

4.7.1.7.2 Application Fee

The application fee is [a standardized amount based on the following system size \(CEC-AC\) criteria:](#)

<u>kW ></u>		<u>kW <</u>		<u>FEE</u>
<u>10</u>	-	<u>50</u>	≡	<u>\$1,250</u>
<u>50</u>	-	<u>100</u>	≡	<u>\$2,500</u>
<u>100</u>	-	<u>250</u>	≡	<u>\$5,000</u>
<u>250</u>	-	<u>500</u>	≡	<u>\$10,000</u>
<u>500</u>	-	<u>1,000</u>		<u>\$20,000</u>

Formatted: Indent: Left: 0", First line: 0"

4.7.1.8 Additional Requirements for Government and Non-profit projects

4.7.1.8.1 Certification of tax-exempt status and AB1407 compliance

Any Government and Non-Profit entities must include a certification under penalty of perjury from their chief financial officer or equivalent that they are a Government or Non-Profit entity and that the system is not receiving, and will not in the future receive, federal tax benefits through financial arrangements (i.e., the System Owner if a third-party, which will be receiving

Deleted: 1 percent of the unadjusted requested CSI Program incentive amount. Application fees will be rounded to the nearest dollar amount. The formula for the EPBB or PBI fee is as follows:¶
Application Fee = (System Size Rating x current applicable/equivalent EPBB incentive rate) x 1%¶

tax benefits from the system). This certification must be renewed annually if receiving PBI payments.

Additionally, any public entity applying for CSI Program incentives must certify that it has voided any existing law, under its authority, that prohibits or restricts the installation or use of a solar energy system in accordance with the requirements set forth in AB 1407.

4.7.2 Proof of Project Milestone Package (for Projects on a Three-Step Process)

4.7.2.1 Completed Proof of Project Milestone Checklist

All Proof of Project Milestone submittals must be accompanied by a completed and signed checklist.

4.7.2.2 Copy of Executed Contract for System Purchase and Installation

Applicants must submit a copy of executed contract for purchase and installation of the system, and/or alternative System Ownership agreement. Agreements must be legally binding and clearly spell out the scope of work, terms, price, solar system components to be installed. Agreements must be signed by appropriate parties (supplier/installer, Host Customer, Applicant and/or System Owner).

In the case of alternate System Ownership arrangements, the System Owner must provide a copy of their agreement(s) to purchase and install a system.

The Applicant must provide copies of executed purchase and/or installation agreements with the Reservation Request, and the information must be internally consistent and must be consistent with the Reservation Form. Agreements for the purchase of a system or system equipment must be in writing and must include, at a minimum, the following information:

- The quantity, make and model number (as shown on the Energy Commission lists of eligible equipment) for the PV modules, inverters, and system performance meters
- The total purchase price of the system before applying the incentive
- Language indicating the purchaser's commitment to buy the system
- Printed names and signatures of the purchaser and equipment seller's authorized representative.

Installation contracts must comply with the Contractors State License Board (CSLB) requirements. Please refer to the CSLB website for more information on CSLB guidelines at www.cslb.ca.gov.

Entities without a valid A, B, C-10 or C-46 contractor's license may not offer installation services or charge for installation in any agreement under the CSI Program.

In addition, these contracts must contain the following information:

- Name, address and contractor's license number of the company performing the system installation
- Site address for the system installation
- Description of the work to be performed
- Total agreed price to install the system
- Payment terms (payment dates and dollar amounts)
- Printed names and signatures of the purchaser and the company's authorized representative.

The above requirements are sufficient evidence of an agreement to purchase and install a system for cases where a contractor sells and installs the system.

4.7.2.3 Revised Incentive Calculation Worksheet (EPBB Printout) (If applicable)

When applicable, all Applicants are required to complete and submit a revised Incentive Calculation Worksheet (EPBB printout) if system or project changes have resulted in a change to the incentive amount. The Incentive Calculation Worksheet calculates the incentive and adjusts for other incentives and project cost.

4.7.2.4 Copy of RFP or solicitation (Government, Non-profit, and Public Entities only)

Within 60 days after the Confirmed Reservation [notice](#), Government, Non-Profit, and Public Entities must submit a copy of the RFP, [notice](#) to Invite Bids, or similar solicitation issued for the installation, lease, and/or purchase of the system proposed for the project. The RFP must include sufficient documentation details including the scope of work, schedule, terms, budget, and system components to be installed.

Deleted: Notice
Deleted: letter
Deleted: Notice

For Government, Non-Profit, and Public Entities not issuing an RFP for the project, all Proof of Project Milestone documentation listed in Section 4.7.2 must be submitted within Proof of Project Milestone Date.

4.7.3 Incentive Claim Form Package

4.7.3.1 Complete Incentive Claim Form with Original Signatures

A completed Incentive Claim Form must be submitted. It must be read, completed, and signed by both the Host Customer and System Owner (if different). The installer's name, telephone number and contractor license number must be included with the completed Incentive Claim Form. It must be confirmed on-site and requires original signatures from the CSI approved listed Seller/Installer confirming the as-built quantity and model numbers of inverters, meters, and modules, as well as tilt, orientation, shading, etc. as required for final calculation of the EPBB rebate. Only applications with original signatures on a single form will be accepted. Any changes in the system upon completion of the project must include supporting documentation and a recalculated incentive.

Note that solar electric displacing systems do not require interconnection.

For questions on the interconnection process, see Section 5.1.

4.7.3.2 Copy of Executed PMRS Contract or Cost Cap Exemption Documentation

All systems required to have a PMRS must provide a copy of the executed contract for a PMRS provider, a letter from the PMRS provider stating the customer has purchased their service, or an invoice from the installer clearly showing the PMRS provider information. Whichever document is submitted must clearly identify the PMRS provider information, including the name of the PMRS provider, the product or service purchased and the term of agreement, along with the address of the associated solar system site.

EPBB systems must either submit a copy of the executed PMRS contract as described above or the Cost Cap Exemption Documentation.

The Cost Cap Exemption Documentation consists of any of the following items that demonstrate PMRS costs exceed the cost cap:

- 1) A quote from an eligible PMRS provider indicating the PMRS provider's cost for providing the basic PMRS described in Appendix B, or
- 2) a quote detailing the equipment, installation, maintenance, and five-year service costs of any communications equipment and service required for the provision of the PMRS (if such equipment and service does not already exist at the customer premise), or
- 3) an invoice or quote detailing the associated metering system costs (if separate from inverter and only if necessary for the provision of the PMRS), or
- 4) a letter on the contractor letterhead showing any additional costs, including labor, materials, overhead and installer mark-up, to install and maintain the PMRS.

See Section 12. Appendix B: Metering Requirements for additional information on PMRS.

4.7.3.3 Final Project Cost Breakdown Worksheet

A final project cost breakdown worksheet must be submitted substantiating the claimed eligible project cost. The Program Administrator reserves the right to withhold final incentive payment pending review and approval of project cost and receipt of supporting documentation. For a list of total eligible project costs, see Appendix A. The Program Administrator reserves the right to periodically audit Applicant's and Host Customer's records, see Appendix C (Section 13).

4.7.3.4 Final Project Cost Affidavit

An affidavit signed by the System Owner or purchaser of the system (if other than the System Owner) must be submitted substantiating that the claimed eligible project cost is correct and has been paid in full.

5. Other Installation Requirements and Continuing Site Access Requirements

5.1 Connection to the Utility Distribution System

All solar electric generating systems receiving incentives under the California Solar Initiative (CSI) program must be connected to the local electric utility's distribution system. The interconnection, operation, and metering requirements for solar systems shall be in accordance with the local electric utility rules for customer generating facility interconnections. To connect a solar system to the utility distribution system, Host Customers, and/or System Owners will be required to execute certain documents such as, but not limited to, an Application to Interconnect a Generating Facility and a Generating Facility Interconnection Agreement or Net Energy Metering Agreement with the local electric utility.

Applicants, Host Customers, and System Owners are solely responsible to submit interconnection applications to the appropriate electric utility interconnection department as soon as the information to do so is available to prevent any delays in system parallel operation.

Incentive payments will not be made until the Program Administrator confirms valid interconnection.

5.1.1 How to Apply For Interconnection of CSI Projects

For more information on electric grid interconnections, please contact your local utility (investor-owned utilities are listed below). It is the sole responsibility of the CSI Program System Owner and Host Customer to seek and obtain approval to interconnect the solar electric system to a utility's electric distribution system. System Owners and Host Customers participating in the CSI Program should immediately contact the utility to seek guidance on how to apply for interconnection. Contact information is listed below.

Pacific Gas & Electric (PG&E)

Website: www.pge.com/gen
Email: gen@pge.com
Phone: (415) 972-5676 (PG&E Generation Interconnection Hotline)

San Diego Gas & Electric (SDG&E)

Website: www.sdge.com/business/self_generation.shtml

Contact information for photovoltaics and wind systems:

Net Metering Team

San Diego Gas & Electric
PO Box 129831, CP52F
San Diego, CA 92123-9749
Phone: (858) 636-5585
Email: netmetering@semprautilities.com

Ken Parks

San Diego Gas & Electric
PO Box 129831, CP52F
San Diego, CA 92123-9749
Phone: (858) 636-5581
Email: kparks@semprautilities.com

Southern California Edison (SCE)

NEM Program Administrator
Southern California Edison
2244 Walnut Grove Avenue
GO1 Quad 4D
Rosemead, California 91770
Phone: (626) 302-9680
E-mail: solarnem@sce.com

6. Additional Information

6.1 Circumstances Requiring Additional Documentation

6.1.1 Owner or Self-Installed System

In situations where the System Owner installs the system, the Applicant must provide the following information during the first or second stage of the application process:

- An equipment purchase agreement as described above, or
- In cases where there is not a signed agreement to purchase equipment the purchaser may provide invoices or receipts showing that at least 10 percent of the system equipment purchase price (generating equipment and inverters) has been paid to the seller(s).³⁰

6.1.2 Contractor-Installed System with Separate Seller and Installer

In situations where the owner is purchasing the system from one company and hiring a separate company (licensed contractor) for installation, the owner must obtain proof of his or her commitment to purchase and install the system in separate documents as follows:

- An equipment purchase agreement as described above, or
- In cases where there is not a signed purchase agreement the owner may provide invoices or receipts showing that at least 10 percent of the system equipment purchase price (generating equipment and inverters) has been paid to the seller(s), and
- An installation contract from the second company as described above.

³⁰ An example of this situation is where the purchaser buys new equipment via the Internet or mail order.

7. Measurement and Evaluation Requirements

To be eligible for CSI incentives, all Applicants, Host Customers, and System Owners must agree to comply with the terms and requirements of the measurement and evaluation program. This includes providing access to the Program Administrators and/or third-parties contracted by the California Public Utilities Commission and/or Program Administrator access to the site and any available data and information collected on the system.

8. Definitions and Glossary

This section provides a list of acronyms used and definitions of key concepts in this Program handbook.

8.1 Acronyms

AB (as in AB 1407): Assembly Bill

AC: Alternating Current

AMI: Advanced Metering Infrastructure

BIPV: Building Integrated Photovoltaic

BTU: British Thermal Units

CCSE: California Center for Sustainable Energy

CEC: California Energy Commission

CEC-AC: California Energy Commission Alternating Current, refers to inverter efficiency rating

CPUC: California Public Utilities Commission

CSI: California Solar Initiative

CSLB: Contractors State License Board

DC: Direct Current

ERP: Emerging Renewables Program

EPBB: Expected Performance-Based Buydown

ESCO: Energy Service Company

IDR: Interval Data Recorder

IOU: Investor-Owned Utility

KW: Kilowatt

KWH: Kilowatt-hour

M&E: Measurement and Evaluation

M&V: Measurement and Verification

MW: Megawatt

NABCEP: North American Board of Certified Energy Practitioners

NRTL: Nationally Recognized Testing Laboratory

NSHP: New Solar Homes Partnership

PBI: Performance-Based Incentives

PG&E: Pacific Gas and Electric Company

PIER: Public Interest Energy Research

PMRS: Performance Monitoring and Reporting Service

PTC: PVUSA Test Conditions

PV: Photovoltaic

PY: Program Year

SB (as in SB 1): Senate Bill

SCE: Southern California Edison Company

SDG&E: San Diego Gas & Electric Company

SGIP: Self Generation Incentive Program

SOF: Surface Orientation Factor

STC: Standard Test Conditions

UL (as in UL 1703): Underwriters Laboratories, Inc.

8.2 Definitions

AB 1407:

Assembly Bill 1407, codified as California Civil Code section 714, was signed by Governor Davis on September 3, 2003. Among other things, this legislation voids and makes unenforceable any existing covenant, restriction, or condition contained in any deed, contract, security instrument, or other instrument affecting real property, as specified, that prohibits or restricts the installation or use of a solar energy system, excepting provisions that impose reasonable restrictions on solar energy systems. This statute also mandates that whenever approval is required for the installation or use of a solar energy system, that such approval be processed in the same manner as approval of an architectural modification, and not be willfully avoided or delayed. Any Public Entity (see definition) may not receive funds from a state-sponsored grant or loan program, including the CSI, for solar energy if it fails to comply with these requirements. A Public Entity must certify that it is meeting these requirements when applying for these grants or loans. Please see California Civil Code section 714 for full statutory requirements and further detail.

Affidavit:

An affidavit is a written statement in writing, sworn to before a notary public or other approved officer. In the CSI Program, the Final Project Cost Breakdown and Affidavit includes the final Project cost breakdown worksheet, along with a signed affidavit substantiating the claimed eligible Project cost.

Alternating Current (AC):

Electric current that reverses direction, usually many times per second. Opposite of direct current (DC). Most electrical generators produce alternating current. Under the CSI Program, PV electric output calculations must always be made using the CEC-AC rating standards which include inverter DC to AC conversion losses.

Applicant:

The entity, either the Host Customer, System Owner, or third party designated by the Host Customer, that is responsible for the development and submission of the CSI application materials and the main point of communication between the CSI Program Administrator for a specific CSI Application.

Application Fee:

An Application Fee is required once the Reservation Request has been submitted for all Non-Residential projects greater than or equal to 10 kW. Where applicable, the Application Fee is [a standardized amount based on system size criteria](#), and is refundable, in general, when the Project is completed and the incentive is paid, anytime before the application receives a Confirmed Reservation, or after that time, so long as the project is withdrawn due to extenuating circumstances beyond the Host Customer's control. Application fees are also refunded anytime before the application receives a Conditional Reservation, or after that time, so long as the project is withdrawn due to extenuating circumstances beyond the Host Customer's control.

Deleted: 1% of unadjusted requested CSI incentive

Azimuth:

Azimuth is the horizontal angular distance between the vertical plane containing a point in the sky and true south. All references to azimuth within the CSI Program, unless expressly stated otherwise, refer to true, not magnetic, azimuth. For calculating an EPBB incentive, all proposed PV systems with a true azimuth orientation between 180 degrees and 270 degrees, facing south, southwest and west, will be compared to a reference system with the same orientation as the proposed system.

Backup Generators:

Backup generators operate as short-term temporary replacement for electrical power during periods of utility power outages. In addition to emergency operation they ordinarily operate for testing and maintenance. Backup generators do not produce enough power to be sold or otherwise supplied to the grid or provide power to loads that are simultaneously serviced by a utility electric grid. Backup generators only service customer loads that are isolated from the grid either by design or by manual or automatic transfer switch.

British Thermal Units (BTU)

The amount of heat required to raise the temperature of 1 pound of water 1 degree Fahrenheit.

Building Integrated Photovoltaic (BIPV):

Building integrated PV systems are solar electric systems in which the PV panels constitute part of the building's roof or facade, replacing conventional building materials. For example, solar shingles may replace conventional asphalt shingles, providing roof protection while producing electricity.

Calendar Days:

All dates and schedules in the CSI are measured in calendar days, which include all days of the week.

California Center for Sustainable Energy (CCSE):

A Non-Profit 501(c)3 corporation that implements the CSI Program on behalf of SDG&E; formerly known as the San Diego Regional Energy Office.

California Energy Commission (CEC):

California's primary energy policy and planning agency. Created in 1974 and headquartered in Sacramento, the Commission has responsibility for activities that include forecasting future energy needs, promoting energy efficiency through appliance and building standards, and supporting renewable energy technologies. On August 21, 2006, the Governor signed Senate Bill (SB 1) which directs the CPUC and the CEC to implement the CSI Program consistent with specific requirements and budget limits set forth in the legislation.

California Public Utilities Commission (CPUC):

The CPUC regulates a number of industries including the electric utility industry that impact public well-being. Among other activities, the CPUC establishes service standards and safety rules and authorizes rate changes. The CPUC, in conjunction Senate Bill 1 (SB 1), has authorized the California Solar Initiative (CSI). In CPUC Decision (D.) 06-01-024, the California Public Utilities Commission (CPUC) established the CSI Program. In D.06-08-028, the CPUC established implementation details for the CSI Program.

California Solar Initiative (CSI):

The California Solar Initiative program pays incentives to solar photovoltaic (PV) projects in the three California IOU service territories. This Program Handbook is designed to describe the requirements for receiving funding under the CSI. The program was authorized by the California Public Utilities Commission (CPUC) and Senate Bill 1 (SB 1). Responsibility for administration of the CSI Program is shared by Pacific Gas and Electric Company, Southern California Edison Company, and the California Center for Sustainable Energy (CCSE, formerly known as San Diego Regional Energy Office) for SDG&E customers.

Capacity Factor:

The ratio of the electrical energy produced by the generating system during a specific period, to the electrical energy the generating system could have produced if it had operated at full capacity rating during the same period.

Capacity Rating:

The capacity rating is a load that a power generation unit, such as a photovoltaic system, is rated by the manufacturer to be able to meet or supply. The Program Administrator will verify system capacity rating to confirm the final incentive amount.

CEC-AC Rating:

The CSI Program Administrators will use the California Energy Commission's CEC-AC method to measure nominal output power of photovoltaic cells or modules to determine the system's rating in order to calculate the appropriate incentive level. The CEC-AC rating standards are based upon 1,000 Watt/m² solar irradiance, 20 degree Celsius ambient temperature, and 1 meter/second wind speed. The CEC-AC Watt rating is lower than the Standard Test Conditions (STC).

Commercial:

Commercial entities are defined as non-manufacturing business establishments, including hotels, motels, restaurants, wholesale businesses, retail stores, and for-profit health, social, and educational institutions. For the purpose of CSI, commercial sectors include agricultural and industrial customers.

Contractor:

A person or business entity who contracts to erect buildings, or portions of buildings, or systems within buildings. Under the CSI Program, all contractors must be appropriately licensed California contractors in accordance with rules and regulations adopted by the State of California Contractors State Licensing Board.

Contractors State License Board (CSLB):

Installation contracts for photovoltaic systems installed under the CSI Program must comply with the Contractors State License Board (CSLB) requirements. Please refer to the CSLB website for more information on CSLB guidelines at: www.cslb.ca.gov.

CSI Program Forum:

The CSI Program Forum was established in CPUC D.06-08-028 to provide a public venue for interested parties to identify and discuss ongoing issues related to CSI administration and implementation. The forum will be used to provide input on any needed updates to this Program Handbook and future more substantive program modifications that may be considered. For more information on the CSI Program Forum, refer to Section 1.5.

Curtable Rate Schedule:

Also referred to as an interruptible rate schedule, a curtable rate schedule allows the transmission provider to interrupt all or part of a transmission service under specified terms due to constraints that reduce the capability of the transmission network to provide that service. Under the CSI Program, generation which serves any portion of a customer's load that is committed to curtable rate schedules, programs or any other such state agency-sponsored demand-response programs is not eligible for incentives.

Demand-Response:

Demand response refers to the reduction of customer energy usage at times of peak usage. Demand response programs may include dynamic pricing/tariffs, price-responsive demand bidding, contractually obligated and voluntary curtailment, and direct load control/cycling. Under the CSI Program any generation serving a portion of customer load that is committed to demand-response programs or on curtable rate schedules is not eligible for incentives.

Design Factor:

The Design Factor is a ratio comparing a proposed system's expected generation output with that of a baseline system. The Design Factor is used in calculating the EPBB incentive (it is multiplied by the system rating and the incentive rate to determine EPBB incentives). A Design Factor is also used by Program Administrators to allocate applications against their MW in step (Section 2.2.7).

Direct Current (DC):

Direct current (DC or "continuous current") is the continuous flow of electricity through a conductor such as a wire from high to low potential. In direct current, the electric charges flow always in the same direction, which distinguishes it from alternating current (AC). Under the CSI Program, photovoltaic electric output calculations must always be made using the CEC-AC rating standards which include inverter DC to AC conversion losses.

Electric Utility:

The Host Customer's local electric transmission and distribution service provider for their Site.

Electrical Distribution Grid:

A network of power stations transmission circuits, and substations conducting electricity. Under the CSI Program, eligible renewable energy systems must be permanently interconnected and

operating parallel to the electrical distribution grid of the utility serving the customer's electrical load.

Emerging Renewables Program (ERP):

The ERP is an Energy Commission program offering cash rebates on eligible grid-connected renewable energy electric-generating systems.

Energy Service Company (ESCO):

A business entity that designs, builds, develops, owns, operates or any combination thereof self-generation Projects for the sake of providing energy or energy services to a Host Customer.

Energy Service Provider (ESP):

An entity that provides electric power and ancillary services (including but not limited to aggregators, brokers, and marketers, but excluding utilities) to an end use customer. Also referred to as an Electric Service Provider.

Expected Performance Based Buydown (EPBB):

The EPBB incentive methodology pays an up-front incentive to participants installing systems less than 100 kW in size that is based on a system's expected future performance. EPBB incentives combine the performance benefits of PBI with the administrative simplicity of a one-time incentive paid at the time of project installation. The EPBB Incentive will be calculated by multiplying the incentive rate by the system rating by the design factor.

Firm Service Level:

Power supplies that are guaranteed to be delivered under terms defined by contract. For electric utility customers who are on an interruptible or curtailable rate, only generation that serves the portion of their electric load that is designated as firm service is eligible for CSI incentives. Under the CSI Program, Customers must agree to maintain the firm service level at or above capacity of the proposed generating system for the duration of the required applicable warranty period. Customers may submit a letter requesting an exemption to the firm service rule if they plan to terminate or reduce a portion of their available load.

Fraud:

A knowing misrepresentation of the truth or concealment of a material fact to induce another to act to his or her injury.

Government:

A Government entity is any federal, state, or local government agency. Federal government entities include the Air Force, Army, Navy, Marines, Postal Service, General Services Administration, and all other Federal agencies or departments. State government entities include the University of California, California State University, Department of Corrections, Department of General Services, the combination of the Department of Developmental Services and CalTrans, the combination of the California Youth Authority and the Department of Mental Health, and all other state agencies and departments. Local government entities include cities, counties, school districts, and water districts.

Host Customer:

An individual or entity that meets all of the following criteria: 1) has legal rights to occupy the

Site, 2) receives retail level electric service from PG&E, SCE, or SDG&E, 3) is the utility customer of record at the Site 4) is connected to the electric grid, and 5) is the recipient of the net electricity generated from the solar equipment.

Hybrid System:

A self-generation system that combines more than one type of distributed generation technology and is located behind a single Electric Utility service meter.

Incentive Adjustment Mechanism:

A mechanism for solar incentives to automatically decline each year based upon MW reserved over the 10 years of the CSI. The adjustment mechanism reduces the statewide incentive level when specified MW levels, or "triggers," of solar installations are achieved. See Section 3.1.

Interconnection Agreement:

A legal document authorizing the flow of electricity between the facilities of two electric systems. Under the CSI Program, eligible renewable energy systems must be permanently interconnected and operating in parallel to the electrical distribution grid of the utility serving the customer's electrical load. Portable systems are not eligible. Proof of interconnection and parallel operation is required prior to receiving an incentive payment.

Interruptible Rate Schedule:

The right of a utility to interrupt all or part of electric service due to system or generation constraints. May also be called a Curtailable Rate Schedule. Under the CSI Program, generation which serves any portion of customer load that is committed to such rate schedules or any other state agency-sponsored curtailable or demand-response program is not eligible for incentives.

Interval Data Recorder (IDR):

IDR is a metering device capable of recording minimum data required. Minimum data requirements include (a) hourly data required for the Direct Access settlement process; and (b) data required to bill the utility's distribution tariffs including 15-minute demand data--also referred to as Hourly Metering.

Inverter:

An electric conversion device that converts direct current (DC) electricity into alternating current (AC) electricity.

Inverter Efficiency:

The AC power output of the inverter divided by the DC power input.

Investor Owned Utility (IOU):

For purposes of the CSI, this refers to Pacific Gas & Electric Company, San Diego Gas & Electric Company, and Southern California Edison Company.

Kilowatt (kW):

A unit of electrical power equal to 1,000 watts, which constitutes the basic unit of electrical demand. The watt is a metric measurement of power (not energy) and is the rate (not the duration over which) electricity is used. 1,000 kW is equal to 1 megawatt (MW). Throughout this

Program Handbook, the use of kW refers to the CEC-AC wattage ratings of kW alternating current inverter output.

Kilowatt Hour (kWh):

The use of 1,000 watts of electricity for one full hour. Unlike kW, kWh is a measure of energy, not power, and is the unit on which the price of electrical energy is based. Electricity rates are most commonly expressed in cents per kilowatt hour.

Lessor:

A person or entity who rents property to another under a lease. Under the CSI Program, in the case of a third-party owned system (or leased system, for example), the lessor is classified as the System Owner.

Load:

Either the device or appliance which consumes electric power, or the amount of electric power drawn at a specific time from an electrical system, or the total power drawn from the system. Peak load is the amount of power drawn at the time of highest demand.

Maximum Site Electric Load:

The peak (maximum) kW demand at the Site, regardless if served by the existing generator, the local utility or a combination of the two.

Measurement and Evaluation (M&E):

A process or protocol to evaluate the performance of an energy system. As a condition of receiving incentive payments under the CSI Program, System Owners and Host Customers agree to participate in Measurement and Evaluation (M&E) activities as required by the CPUC. M&E activities will be performed by the Program Administrator or the Program Administrator's independent third-party consultant and include but are not limited to, periodic telephone interviews, on-site visits, development of a M&E Monitoring Plan, access for installation of metering equipment, collection and transfer of data from installed system monitoring equipment, whether installed by Host Customer, System Owner, a third party, or the Program Administrator.

Measurement and Verification (M&V):

A process or protocol to confirm the actual energy savings realized from a project once the project is implemented and operating.

Megawatt (MW):

Unit of electrical power equal to one million watts; also equals 1,000 kW.

Meter:

A device used to measure and record the amount of electricity used or generated by a consumer. The CSI Program requires accurate solar production meters for all solar projects that receive incentives. Systems receiving an EPBB incentive require a meter accurate to within $\pm 5\%$, while systems receiving PBI payments require a more precise meter accurate to within $\pm 2\%$.

Modules:

Under the CSI Program, a module is the smallest complete environmentally protected assembly of interconnected photovoltaic cells. Modules are typically rated between 50 and 200 W.

Nationally Recognized Testing Laboratory (NRTL):

The Occupational Safety and Health Administration's (OSHA) Directorate of Science, Technology, and Medicine operates a program that certifies private sector organizations as NRTLs, which subsequently judges that specific equipment and materials ("products") meet consensus-based standards of safety for use in the U.S. workplace. Under the CSI Program, PV Modules must be certified to UL 1703 by a Nationally Recognized Testing Laboratory (NRTL). Inverters must be certified to UL 1741 by a NRTL.

Net Energy Metering Agreement:

An agreement with the local utility which allows customers to reduce their electric bill by exchanging surplus electricity generated by certain renewable energy systems such as the PV systems the CSI subsidizes. Under net metering, the electric meter runs backwards as the customer-generator feeds extra electricity back to the utility. The CSI Program permits net energy metering agreements.

New Construction:

New construction is defined as the construction of new buildings. Residential new construction systems are not eligible for the CSI Program, and should apply to the California Energy Commission's New Solar Homes Partnership Program. A residential building is considered "new" if the entire building structure is subject to current Title 24 building efficiency standards and does not yet have a Permit of Occupancy from the relevant Building Department.

New Solar Homes Partnership (NSHP):

A California Energy Commission program offered as of January 1, 2007 that works with home builders and the building industry to accelerate the growth of PV in residential new construction.

Non Profit:

A Non-Profit institution is an entity not conducted or maintained for the purpose of making a profit, and is registered as a 501(c)3 corporation. No part of the net earnings of such entity accrues or may lawfully accrue to the benefit of any private shareholder or individual.

North American Board of Certified Energy Practitioners (NABCEP):

A professional association developing a voluntary national certification program for solar practitioners. Although not required by the CSI Program, installation contractors are encouraged to become certified by the NABCEP.

Pacific Gas & Electric Company (PG&E):

An investor owned utility (IOU). The utility that provides natural gas and electricity to most of Northern California.

Parallel Operation:

The simultaneous operation of a self-generator with power delivered or received by the electrical utility while interconnected to the grid. Parallel Operation includes only those PV

systems that are interconnected with the Electric Utility distribution system for more than 60 cycles.

Payee:

The person, or company, to whom the incentive check is made payable.

Performance Based Incentives (PBI):

The CSI Program will pay Performance Based Incentives (PBI) in monthly payments based on recorded kilowatt hours (kWh) of solar power produced over a five-year period. Solar projects receiving PBI incentives will be paid a flat per kWh payment monthly for PV system output that is serving on Site load. The monthly PBI incentive payment is calculated by multiplying the incentive rate by the measure kWh output.

Photovoltaic (PV):

A technology that uses a semiconductor to convert light directly into electricity.

Power Purchase Agreements:

An agreement for the sale of electricity from one party to another, where the electricity is generated and consumed on the Host Customer Site. Agreements that entail the export and sale of electricity from the Host Customer Site do not constitute on-site use of the generated electricity and therefore are ineligible for the CSI.

Program Administrator (PA):

For purposes of the CSI Program, PG&E, SCE & CCSE (which administers the program on behalf of SDG&E).

Program Year (PY):

January 1 through December 31.

Proof of Project Milestone Date:

The Proof of Project Milestone Date is the date when required information to demonstrate that a Project seeking CSI incentives is moving forward is due.

Project:

For purposes of the CSI, the "Project" is the installation and operation of the proposed eligible PV system, as described by the submitted Reservation Request documentation.

Public Entity:

Includes the United States, the state and any county, city, public corporation, or public district of the state, and any department, entity, agency, or authority of any thereof.³¹

Rebuild A Greener San Diego Photovoltaic Incentive Program:

San Diego area program authorized by the CPUC Resolution E-3860, created to provide incentives to homeowners rebuilding homes affected by the October 2003 wildfires. The Rebuild a Greener San Diego Photovoltaic Incentive Program accepted applications from April 1, 2004 through May 31, 2006.

³¹ Source: CALIFORNIA CODES - PUBLIC CONTRACT CODE, SECTION 21611

Renewable:

Electricity supplied by energy sources that are naturally and continually replenished, such as wind, solar power, geothermal, small hydropower, and various forms of biomass.

Reservation Expiration Date:

The Reservation Expiration Date is the date up to when the project is active in the CSI Program.

Residential:

Residential entities are private household establishments that consume energy primarily for space heating, water heating, air conditioning, lighting, refrigeration, cooking, and clothes drying. The classification of an individual consumer's account, where the use is both residential and commercial, is based on principal use. A power purchase agreement on a residence is considered a residential application.

Retrofit:

A retrofit is a modification of an existing building or facility to include new systems or components.

San Diego Gas & Electric Company (SDG&E):

One of California's four investor-owned utilities (IOU's). SDG&E provides natural gas and electricity to San Diego County and southern Orange County in southern California. It is owned by Sempra Energy. The CSI Program is available to customers of PG&E, SCE and SDG&E.

Self Generation Incentive Program (SGIP):

The SGIP, created pursuant to California Assembly Bill 970, provided financial incentives for business and residential customers who install up to 5.0 MW of "clean" distributed generation equipment onsite. The current program runs through December 31, 2007. The SGIP was extended in modified form for certain technologies through AB 1685.

Seller:

Any person or business entity that transfers property or property rights by sale in commerce. To participate in the CSI Program, companies who sell system equipment must be certified by the CEC or some approved third party.

Senate Bill 1 (SB 1):

Chapter 132, Statutes of 2006 (SB1, Murray) establishes the goals of installing 3,000 MW of solar generation capacity in the state of California, establishing a self-sufficient solar industry, and placing photovoltaic systems on 50 percent of new California homes within 13 years. The bill was signed into law on August 21, 2006, and it became effective on January 1, 2007. SB 1 requires the CPUC, in implementing the California Solar Initiative (CSI) to adopt performance-based subsidies (e.g. subsidies that pay based on the amount of electricity produced) by January 1, 2008 where 100% of incentives are based on performance for all PV systems 100 kW and larger, and 50% of incentives are based on performance for systems 30 kW and larger. Performance-based subsidies are encouraged, but not required, for smaller systems. Moreover, SB 1 authorizes the CPUC to award \$101 million in subsidies for electric-displacing solar thermal systems and authorizes the CPUC to award \$50 million for solar research and

development. The bill requires municipal utilities to establish solar energy programs in support of the 3,000 MW goal and raises the net metering cap from 0.5 percent to 2.5 percent.

Site:

The Host Customer's premises, consisting of all the real property and apparatus employed in a single enterprise on an integral parcel of land undivided, excepting in the case of industrial, agricultural, oil field, resort enterprises, and public or quasi-public institutions divided by a dedicated street, highway or other public thoroughfare or railway. Automobile parking lots constituting a part of and adjacent to a single enterprise may be separated by an alley from the remainder of the premises served. Separate business enterprises or homes on single parcel of land undivided by a highway, public road, and thoroughfare or railroad would be considered for purposes of CSI as separate Sites. Each individual Site must be able to substantiate sufficient electrical load to support the proposed system size.

Solar Irradiance:

Radiant energy emitted by the sun, particularly electromagnetic energy. In the CSI Program the CEC-AC rating standards are based upon 1,000 Watt/m² solar irradiance, 20 degree Celsius ambient temperature, and 1 meter/second wind speed. The CEC-AC watt rating is lower than the Standard Test Conditions (STC), a watt rating used by manufacturers.

Southern California Edison Company (SCE):

An investor owned utility (IOU) that provides electricity in a 50,000-square mile service territory in Southern California.

Standard Test Conditions (STC):

A watt rating used by manufacturers of photovoltaic cells or modules. The CEC-AC watt rating used in the CSI is lower than the Standard Test Conditions.

Surface Orientation Factor (SOF):

The ratio of the annual incident solar radiation on a surface for a specific tilt and orientation (MJ/m²/year) divided by the annual incident solar radiation on a surface for a south-facing surface with optimal tilt (MJ/m²/year).

System Installer:

The System Installer is responsible for installing for the Host Customer the photovoltaic system that will be eligible to receive CSI Program incentives. A qualified solar system installer should be able to evaluate factors that will affect photovoltaic system performance, such as the orientation (tilt and direction) of the system, wire length and size, shading, module output mismatch, inverter efficiency, module cleanliness, and other factors.

System Owner:

The owner of the PV system at the time the incentive is paid. For example, in the case when a vendor sells a turnkey system to a Host Customer, the Host Customer is the System Owner. In the case of a leased system, the lessor is the System Owner.

System Size:

Generally, under the CSI, system size is defined as the capacity of a given photovoltaic system based upon CEC-AC rating standards. Under the CSI Program, the incentive is determined

based on the expected production of electricity by the system, which may not exceed the actual energy consumed during the previous 12 months at the Site (see Section 2.2.5). However, for purposes of determining the capacity a given project contributes to a given step in the incentive schedule, system size is defined as the system size rating times a design factor (see Section 2.2.7).

Time of Use Rates:

Electricity prices that vary depending on the time periods in which the energy is consumed. In a time-of-use rate structure, higher prices are charged during utility peak-load times. Such rates can provide an incentive for consumers to curb power use during peak time.

UL Listed:

Tested and listed by the Underwriters Laboratories, Inc. In the CSI Program, PV modules must be certified to UL 1703 by a Nationally Recognized Testing Laboratory (NRTL). Inverters must be certified to UL 1741 by a NRTL.

Vendor:

A seller of property, goods, or services. According to the CSI Program, in cases when a vendor sells a PV system to a Host Customer, the Host Customer is the System Owner.

Warranty:

A promise, either written or implied, that the material and workmanship of a product are without defect or will meet a specified level of performance over a specified period of time. In the CSI Program, inverters and modules must each carry a 10 year warranty, and meters a one-year warranty. Meters that are integrated in the inverter must carry a 10-year warranty. The warranty may be provided in combination by the manufacturer and installer.

9. Program Administrator Contact Information

Potential Host Customers and their Applicants can receive more information and apply for incentive funding through the following Program Administrators:

Pacific Gas & Electric (PG&E)

Website: www.pge.com/csi
Email Address: solar@pge.com
Contact Person: Program Manager, California Solar Initiative Program
Telephone:

[Solar Customer Service Center: \(877\) 743-4112](tel:(877)743-4112)

Solar Hotline: (415) 973-3480

Fax: (415) 973-2510

Mailing Address: PG&E [Solar and Customer Generation \(CSI\)](#),
P.O. Box [7433](#),
San Francisco, CA 94120,

Deleted: Residential Customers:
(800) 933-9555

Deleted: Business customers: (800)
468-4743

Deleted: Integrated Processing
Center

Deleted: 265

Deleted: -7265

California Center for Sustainable Energy (CCSE)

Website: www.energycenter.org
Email Address: csi@energycenter.org
Contact Person: Program Manager, California Solar Initiative Program
Telephone: (858) 244-1177
Fax: (858) 244-1178

Mailing Address: 8690 Balboa Ave. Suite 100
San Diego, CA 92123-1502

Southern California Edison (SCE)

Website: www.sce.com/rebatesandsavings/CaliforniaSolarInitiative/
E-mail Address: csigroup@sce.com
Contact Person: Program Manager, California Solar Initiative Program
Telephone: (800) 799-4177
Fax: (626) 633-3402
Mailing Address: Southern California Edison
CSI Program Administrator
6020 A North Irwindale Avenue
Irwindale, CA 91702

10. Additional Program Requirements

As a condition of participation in the CSI Program, the Host Customer and System Owner must acknowledge and agree to the following terms and conditions, which supplement and are in addition to the program requirements described throughout this Handbook and the Contract attached to the Reservation Request Form.

Eligibility: The CSI Program is funded by California investor-owned utility customers and administered by the Program Administrator for customers within its service territory, under the auspices of the California Public Utilities Commission (CPUC). Eligible participants in the CSI Program must be current electric distribution customers of Program Administrator at the facility (“Project Site”) where the solar system (the “Project”) will be installed.

Incentives: If the Project is installed as described on the Reservation Request Form and all Program and Contract terms and conditions are complied with, including timely submission of all documents described in the CSI Program Handbook, the Program Administrator will pay an incentive to the entity designated as the incentive recipient. The Program Administrator reserves the right to modify or cancel the incentive if the actual installation of the solar system differs from the proposed installation, if the solar energy system fails inspection, if the solar system is not installed by the date shown on the Reservation Confirmation and Incentive Claim Form, and/or if the documents submitted fail to meet the requirements of the CSI Program Handbook.

Authority to Install System: The Host Customer and System Owner represent that they have the authority to install the generating system at the Project Site, or have obtained the permission of the legal owner of the Project Site, to install the generating system. System Owner and Host Customer shall, at their own expense, obtain and maintain all licenses and permits needed to perform work on the Project.

CSI Program Database: The Host Customer and System Owner shall agree to allow all information provided as part of the reservation claim process to be entered into a statewide database that will permit tracking of application for this and other incentive programs. Access to this database will be limited to Program Administrators and the California Energy Commission.

Disclosure of Other Incentives: The Host Customer and System Owner understand that other program rebates, grants, forgiven loans, financial incentives, post-installation agreements, Renewable Energy Credits (aka RECs, Green Credits, etc.), and performance payments are “other incentives” and must be disclosed as soon as those agreements or payments are made.

Withdrawal: The Host Customer and System Owner agree that either of them may withdraw from the Project for any reason by providing written [notice](#) of such withdrawal to Program Administrator. In the event the Host Customer or System Owner so withdraws, this Agreement will be cancelled and the Host Customer alone will retain sole rights to the incentive reservation and corresponding incentive reservation number assigned to this Reservation Request Form. To preserve such incentive reservation and corresponding reservation number, Host Customer must submit a new Reservation Request Form at the same time written notification of withdrawal from the Project is provided to Program Administrator. Host Customer understands that if all available funds are reserved for other Projects, the Host Customer cannot increase the originally reserved incentive amount. Host Customer also understands that submitting a new

Deleted: notice

Reservation Request Form will not move or alter the Proof of Project Advancement Milestone Date provided by Program Administrator, if any. Host Customer further understands that if Host Customer fails to re-submit a Reservation Request Form at the time of Project withdrawal, this Application will be terminated in its entirety by Program Administrator and any previously reserved incentive funding will be released. In that instance, Host Customer must apply for a new incentive reservation should Host Customer still wish to participate in the Program.

No Endorsement by Program Administrator: Host Customer and System Owner understand that the Program Administrator's review of the project described herein (Project) and authorization for CSI funding shall not be construed as confirming or endorsing the qualifications of the Applicant or any person(s) involved with the Project, including but not limited to the Project installer(s), designer(s), or manufacturer(s); endorsing the Project design; or as warranting the economic value, safety, durability or reliability of the Project. The Host Customer is solely responsible for the Project, including selection of any designer(s), manufacturer(s), contractor(s), or installer(s). Host Customer and System Owner understand that they, and any third parties involved with the Project, are independent contractors and are not authorized to make any representations on behalf of the Program Administrator. Host Customer and System Owner shall not use Program Administrator's corporate name, trademark, trade name, logo, identity, or affiliation for any reason, without prior written consent of the Program Administrator.

Audit Rights: The Program Administrator reserves the right to verify project costs were incurred as indicated in the documents submitted, as set forth in detail in the CSI Program Handbook.

Dispute Resolution: The parties to this Contract shall attempt in good faith to resolve any dispute arising out of or relating to this Contract promptly by negotiations between a vice president of Program Administrator or his or her designated representative and an executive of similar authority from System Owner and/or Host Customer. Either party must give the other party or parties written notice of any dispute. Within thirty (30) calendar days after delivery of the notice, the executives shall meet at a mutually acceptable time and place, and shall attempt to resolve the dispute. If the matter has not been resolved within thirty (30) calendar days of the first meeting, any party may pursue other remedies, including mediation. All negotiations and any mediation conducted pursuant to this clause are confidential and shall be treated as compromise and settlement negotiations, to which Section 1152.5 of the California Evidence Code shall apply, and Section 1152.5 is incorporated herein by reference. Notwithstanding the foregoing provisions, a party may seek a preliminary injunction or other provisional judicial remedy if in its judgment such action is necessary to avoid irreparable damage or to preserve the status quo. Each party is required to continue to perform its obligations under this Contract pending final resolution of any dispute arising out of or relating to this Contract.

Deleted: notice

Deleted: notice

Assignment: System Owner and Host Customer consent to Program Administrator's right to assign of all of Program Administrator's rights, duties and obligations under this Contract to the CPUC and/or its designee. Any such assignment shall relieve Program Administrator of all rights, duties and obligations arising under this Contract. Neither System Owner nor Host Customer shall assign its rights or delegate its duties without the prior written consent of Program Administrator or its assignee, if any, except in connection with the sale or merger of a substantial portion of its assets. Any such assignment or delegation without the prior written consent of Program Administrator or its assignee, if any, shall be null and void. Consent to

assignment shall not be unreasonably withheld or delayed. System Owner and Host Customer must provide assurance of the success of a Project if assigned by providing any additional information requested by Program Administrator.

No Third Party Beneficiaries: This Contract is not intended to confer any rights or remedies upon any other persons other than the undersigned Parties hereto.

11. Appendix A: Description of Total Eligible Project Costs

The California Solar Initiative program collects information on solar system project costs solely for reporting purposes. The following costs may be included in total eligible project cost:

1. Solar equipment capital costs, including tracking systems and other ancillary equipment associated with the solar system.
2. Engineering and design costs for solar systems.
3. Construction and installation costs. For projects in which the generation equipment is part of a larger project, only the construction and installation costs directly associated with the installation of the energy generating equipment are eligible.
4. Engineering feasibility study costs
5. Interconnection costs, if applicable, including:
 - a. Electric grid interconnection application fees
 - b. Metering costs associated with interconnection
6. Building permitting costs
7. Warranty and/or maintenance contract costs associated with eligible project cost equipment
8. Sales tax and use tax
9. On-site system measurement, monitoring and data acquisition equipment.
10. Customers may claim certain mounting surface costs as eligible project costs. Costs may include mounting surfaces for the photovoltaic module/solar collector and/or the materials that provide the primary support for the modules. Only the percentage of mounting surface directly under the photovoltaic module/solar collector is eligible.

11. Cost of capital included in the system price by the vendor, contractor or subcontractor (the entity that sells the system) is eligible if paid by the System Owner.

12. Appendix B: Metering Requirements

The following Appendix contains detailed information with respect to the minimum metering and monitoring requirements for participation in the CSI Program. These minimum requirements were developed to increase owner knowledge of system performance, foster adequate system maintenance, and thereby ensure ratepayer incentives result in expected levels of solar generation.

CSI Program participants are required to install the following metering related components based on the size of their system and type of program participation (i.e. EPBB or PBI), according to [Table 10](#):

Deleted: Table 16

Table 10
Metering Summary¹

Deleted: Table 16

Incentive Structure	System Size	Minimum Meter Accuracy	PMRS ² Required	Cost Cap ³
EPBB	< 30 kW	± 5%	Yes	1%
EPBB	30 kW and greater	± 5%	Yes	0.5%
PBI	All	± 2%	Yes	No Cost Cap

Notes:

- 1) All metering systems are paid for at the System Owner's expense including some form of communications, performance monitoring and reporting capability.
- 2) PMRS stands for Performance Monitoring and Reporting Service
- 3) For systems receiving an EPBB incentive, the total cost of the metering, communication and PMRS for the first five years following final project approval shall be less than 1% of total PV system eligible project costs (exclusive of metering, communication and PMRS costs) for systems up to 30kW and less than 0.5% for larger systems. If the owner of a system receiving an EPBB incentive can demonstrate to the Program Administrator that the costs for these services exceed the caps, they may request an exemption from the communication and PMRS requirements. The System Owner requesting such an exemption must, at a minimum, install a meter with an accuracy of ± 5% of actual system output that meets all applicable parts of Section 12.1 and which includes functionality that allows the System Owner or Host Customer to observe the system performance locally. However, there are no exemptions allowed for systems paid under a PBI structure.

As with other required solar system components, all installed meters and Performance Monitoring and Reporting Services (PMRS) providers must be listed with the Energy Commission. Lists of qualifying meters and PMRS providers can be found on the California Energy Commission's website at www.consumerenergycenter.org/erprebate/equipment.html.

Detailed information on these summarized requirements follows.

12.1 Minimum Meter Requirements

All systems must be installed with a meter or meters so that the System Owner and Program Administrator can determine the amount of energy produced by the system and the System Owner may support proper system operation and maintenance. The meter must be listed with the Energy Commission and must meet the minimum meter requirements of this section.

The California Energy Commission's list of qualifying meters can be found at: www.consumerenergycenter.org/erprebate/equipment.html.

12.1.1 Meter Type

For all systems receiving PBI payments, the installed meter(s) must be a separate Interval Data Recording (IDR) meter(s), or a complete system that is functionally equivalent to an IDR meter recording data no less frequently than every 15 minutes. Installed meter(s) for systems receiving an EPBB incentive do not need to be separate IDR meters and may be internal to the inverter(s). Program Administrators may have additional meter functionality requirements for systems receiving PBI payments, as the Program Administrators will use these meters to process PBI payments and system compatibility may be required. For example, meters and service panels must meet all local building codes and utility codes. Each Program Administrator will maintain a publicly-available list of any additional functionality requirements. Please consult your Program Administrator to determine whether any additional requirements apply.

12.1.2 Meter Accuracy

All systems receiving an EPBB incentive must install a solar energy production meter accurate to within $\pm 5\%$ of actual system output and systems receiving PBI payments must install a solar production meter accurate to within $\pm 2\%$ of actual system output.

Non-PV electric displacing thermal system Btu meter(s) must be accurate to $\pm 5\%$.

12.1.3 Meter Measurement

Meters must measure net generated energy output (kWh) as well as instantaneous power (kW).

12.1.4 Meter Testing Standards

$\pm 2\%$ meters must be tested according to all applicable ANSI C-12 testing protocols. Testing protocols for $\pm 5\%$ meters are being developed for the CSI Program and will be incorporated into future revisions of this Program Handbook.

12.1.5 Meter Certification

The accuracy rating of $\pm 2\%$ meters must be certified by an independent testing body (i.e., a NRTL such as UL or TUV).

Certification standards for $\pm 5\%$ meters are being developed for the CSI Program and will be incorporated into future revisions of this Program Handbook. Until these standards have been

developed, the accuracy rating of all $\pm 5\%$ meters must be certified by the manufacturer of the $\pm 5\%$ meter or an independent testing body (i.e., a NRTL such as UL or TUV).

All test results or NRTL documentation supporting the certification must be maintained on file for inspection by the Commission or Energy Commission.

12.1.6 Meter Communication / Data Transfer Protocols

As described in [Table 10](#), for systems receiving an EPBB incentive whose costs fall below the cost caps and for all systems receiving PBI payments, protocols for the minimum required Solar Performance / Output Data must enable any PMRS provider to communicate with the meter to obtain the minimum required Solar Performance / Output Data from the meter. The data transfer protocol provided to the Program Administrator must satisfy servicing the Program Administrator requirements.

Deleted: Table 16

12.1.7 Meter Data Access

All meters must provide the PMRS provider with the ability to access and retrieve the minimum required Solar Performance / Output Data from the meter using the Meter Communication / Data Transfer Protocols. In the event that the system is not required to have a PMRS Provider as shown in the [Table 10](#), the System Owner must have a means to retrieve the minimum required Solar Performance/Output Data from the meter.

Deleted: Table 16

12.1.8 Meter Display

All meters must provide a display showing the meter's measured net generated energy output and measured instantaneous power. This display must be easy to view and understand. This display must be physically located either on the meter, inverter, or on a remote device.

12.1.9 Meter Memory and Storage

All meters must have the ability to retain collected data in the event of a power outage. Meters that are reporting data remotely must have sufficient memory to retain 60 days of data if their standard reporting schedule is monthly and 7 days of data if their standard reporting schedule is daily. Meters that do not remotely report their data must retain 60 days of data. In all cases meters must be able to retain lifetime production.

12.1.10 Thermal Meters

For liquid solar heating and cooling systems, it is practical to use a commercial BTU meter³². The BTU meter specifications shall be as follows –

- Provides totalizing outputs in BTUs per period.
- Capable of remote communications.
- Monthly totalizing accuracy of $\leq 5\%$ ³³.

³² Hot air solar systems will need to be paid incentives based on the EPBB method described below. Metering the thermal output of solar hot air systems, within reasonable accuracy and cost, is difficult.

-
- Flow meter and temperature sensor accuracy is NIST traceable.

12.2 Minimum Communication Requirements

All systems must be installed with some form of communication capability that will provide meaningful feedback to System Owners and Program Administrators. In accordance with [Table 10](#), the systems should have remote communicating capability whereby performance data can be collected, accessed remotely, and uploaded for processing by a PMRS. For systems receiving an EPBB incentive that are unable to meet the cost cap, the meter display must be accessible to the System Owner, and the Program Administrator must be provided means to retrieve data to collect performance data.

Deleted: Table 16

12.3 Minimum Performance Monitoring & Reporting Capability Requirements

In order to enable System Owners to properly maintain and evaluate the performance of their systems and to allow Program Administrators to monitor the performance of systems receiving CSI incentives, a PMRS must be obtained to monitor and report on the following minimum data points and all monitoring, data collection, data retention, and reporting must be performed as specified in the corresponding sub-sections below. For EPBB incentive recipients, a PMRS is defined as, at a minimum, a service that monitors and reports the energy production data from the solar system to the system owner. For PBI incentive recipients, a PMRS is defined as, at a minimum, services that monitor and report the energy production data from the solar system to the system owner, as well as reporting the energy production data from the solar system to the Program Administrator that serves as the basis for PBI payments. The data flow between the solar energy system and the Program Administrator that serves as the basis for PBI payments must, at a minimum, meet the interim Performance Data Provider (PDP) requirements. (Appendix H – Interim CSI PBI Data Transfer Rules). PBI incentive payments are calculated and paid based on actual performance data transferred to the Program Administrator from the respective PMRS associated with each PBI incentive reservation. See [Table 10](#) for more information and exemptions.

Deleted: Table 16

The PMRS provider must be listed with the Energy Commission and must meet the minimum requirements of this section.

The California Energy Commission's list of qualifying PMRS providers can be found at www.consumerenergycenter.org/erprebate/equipment.html. www.energy.ca.gov.

12.3.1 Required Solar Performance / Output Data

The PMRS must monitor, record, and report on instantaneous AC kW and net kWh Generated by the PV system.

³³ At least one Btu meter supplier has provided information showing that 5% accuracy is achievable. See Appendix E for an example Btu meter accuracy calculation.

12.3.2 Minimum Report Delivery Requirements

The PMRS must provide for the electronic delivery of reports.

12.3.3 Time Granularity of Acquired Data

The PMRS must log all Required Solar Performance / Output Data points no less frequently than once every 15 minutes.

12.3.4 Frequency of Data Collection

The PMRS must remotely acquire and process all data points no less frequently than once per day.

12.3.5 Minimum Reporting Requirements

The PMRS must provide the following reports based on acquired, processed, and analyzed data:

- Data as collected and summarized by hour, day, month, and year.
- System alerts that indicate a non-functioning or poorly functioning system.

12.3.6 Frequency of Data Reporting

The PMRS must at all times provide System Owners with on-demand access to all reports required by Section 12.3.5. Time sensitive reports (i.e. System Alerts) shall be made available within 24 hours of the PMRS receiving the recorded data points which, when analyzed, indicated a problem with the system.

12.3.7 Data Retention Policy

The PMRS must retain and provide the System Owner and Program Administrator with remote access to 15 minute average data for a minimum of five years from the date of production for systems receiving PBI payments and two years from the date of production for systems receiving an EPBB program incentive.

12.3.8 Performance Data Provider Requirements

As per D.08-01-030, the element of PMRS that entails the data flow between the solar energy system and the Program Administrator that serves as the basis for PBI must, as a minimum, meet the interim CSI PBI data transfer rules (Appendix H).

12.4 Eligibility of Performance Monitoring & Reporting Service Providers

In order to be eligible to provide Performance Monitoring and Reporting Services, providers must be registered and listed with the CEC. The list of eligible PMRS providers is located at <http://www.consumerenergycenter.org/erprebate/monitors+rsp.html>.

12.5 Eligible Recipients of Information

Subject to the stated Data Privacy restrictions appearing in Section 12.5.3, the PMRS provider must at a minimum provide each group listed below with access to data as defined.

12.5.1 System Owner

The PMRS shall at a minimum provide System Owners and/or Host Customers (if different) with access to all Required Solar Performance / Output Data.

12.5.2 Program Administrators

The PMRS shall at a minimum provide Program Administrators with all data listed in Section 12.3 for all systems.

12.5.3 Data Privacy

Protecting the privacy of System Owners and Host Customer is of the highest order. As such, data shall be collected, processed, and reported to the System Owner and the Program Administrator in accordance with this Appendix. The PMRS may provide data to third parties, including Installers and Host Customers (if different than the System Owners), provided the System Owner has consented in writing to the release of such performance data.

12.6 Advanced Metering Infrastructure (AMI) Coordination

To the extent AMI coordination is an important component of PBI or EBPP program administration, the Commission will re-evaluate the requirements of this section at that time.

12.7 Overall Cost Constraint

Recipients of CSI funding are not precluded or penalized from purchasing or installing a metering system and subsequent PMRS that exceeds the minimum requirements or any cost caps described in this Appendix. The selection of a PMRS provider is made at the recipient's choice and expense.

12.7.1 EPBB

For systems receiving an EPBB incentive, the total cost of the metering, communication and PMRS for the first five years following final project approval shall be less than 1% of total PV system eligible project costs (exclusive of metering, communication and PRMS costs) for

systems up to 30kW and less than 0.5% for larger systems. If the owner of a system receiving an EPBB incentive can demonstrate to the Program Administrator that the costs for these services exceed the caps, they may request an exemption from the communication and PMRS requirements. The System Owners requesting such an exemption must, at a minimum, install a meter with an accuracy of $\pm 5\%$ of actual system output that meets all applicable parts of Section 12.1 and which includes functionality that allows the System Owner or Host Customer to observe the system performance locally.

12.7.2 PBI

All recipients of CSI funding under the PBI structure, regardless of system size, are required to contract with a PMRS provider for 5 years of service that meets all of the applicable minimum standards defined in this Appendix.

13. Appendix C: Supplemental Forms

13.1 Current Program Contract Terms

CONTRACT TERMS AS INCLUDED IN THE RESERVATION REQUEST FORM:

Agreement by Host Customer and System Owner:

The Host Customer and System Owner wish to install the solar energy system described on the Reservation Request Form and receive the benefits of the California Solar Initiative (CSI) Program. In consideration of Host Customer's and System Owner's participation in the CSI Program and the promises set forth below, Host Customer and System Owner agree to the following:

CSI Program Handbook Requirements: By execution of this document, System Owner and Host Customer each certifies that 1) they have received and read a copy of the CSI Handbook; 2) the Project meets all Program eligibility requirements; and 3) that the System Owner and Host Customer agree to abide by the rules and requirements set forth in the CSI Program Handbook. Such CSI Program Handbook requirements are incorporated herein by reference as though set forth in full in this contract.

Indemnification: To the greatest extent permitted by applicable law, Host Customer and System Owner agree to indemnify, defend, and hold harmless the Program Administrator, its affiliates, subsidiaries, current and future parent companies, officers, managers, directors, agents, and employees from all claims, demands, losses, damages, costs, expenses, and liability (legal, contractual, or otherwise), which arise from or are in any way connected with any:

- (1) injury to or death of persons, including but not limited to employees of the Program Administrator, Host Customer, System Owner, or any third party;
- (2) injury to property or other interests of the Program Administrator, Host Customer, System Owner, or any third party;
- (3) violation of local, state, or federal common law, statute, or regulation, including but not limited to environmental laws or regulations;
- (4) strict liability imposed by any law or regulation; or (5) generation system performance shortfall; so long as such injury, violation, strict liability, or shortfall (as set forth in (1) - (5) above) arises from or is in any way connected with the Project, including Host Customer's, System Owner's, or any third party's performance or failure to perform with respect to the Project, however caused, regardless of any strict liability or negligence of the Program Administrator, their officers, managers, or employees, excepting only such loss, damage, or liability that is caused by the willful misconduct of Program Administrator, its officers, managers, or employees.

Limitation of Liability: Program Administrator shall not be liable to System Owner, Host Customer or to any of their respective contractors or subcontractors for any special, incidental, indirect or consequential damages whatsoever, including, without limitation, loss of profits or commitments, whether in contract, warranty, indemnity, tort (including negligence), strict liability or otherwise arising from Program Administrator's performance or nonperformance of its obligations under this Contract.

Term & Termination: The Term of this Contract shall begin on the date that the last Party signs it, and shall continue for ten years, unless terminated earlier pursuant to the operation of this Contract, or unless modified by order of the California Public Utilities Commission or by written agreement of the Parties.

The Contract may be terminated by Program Administrator in the event (a) System Owner or Host Customer fails to perform a material obligation under this Contract and System Owner or Host Customer fails to cure such default within 20 days of receipt of written notice from Program Administrator, or (b) any statement, representation or warranty made by System Owner or Host Customer in connection with the Program or this Contract is false, misleading or inaccurate on the date as of which it is made.

The termination of this Contract shall not operate to discharge any liability which has been incurred by either Party prior to the effective date of such termination.

Venue: This Contract shall be interpreted and enforced according to the laws of the State of California. Sole jurisdiction and venue shall be with the courts in _____ County, California.

Integration and Modification: This Contract and the CSI Program Handbook constitute the entire Contract and understanding between the Parties as to its subject matter. It supersedes all prior or contemporaneous contracts, commitments, representations, writings, and discussions between System Owner, Host Customer, and Program Administrator concerning the Project, whether oral or written, and has been induced by no representations, statements or contracts other than those expressed herein.

NO AMENDMENT, MODIFICATION OR CHANGE TO THIS CONTRACT SHALL BE BINDING OR EFFECTIVE UNLESS EXPRESSLY SET FORTH IN WRITING AND SIGNED BY PROGRAM ADMINISTRATOR'S REPRESENTATIVE AUTHORIZED TO SIGN THE CONTRACT.

The Host Customer and System Owner are committed to completing this Project, and by signing below, are stating their intent to contract with any individual(s) necessary for completion of the Project. The Host Customer is the reservation holder and reserves the right to submit new project specifications, including a new Applicant designation, upon withdrawal from the Project and cancellation of this Agreement. The undersigned declare under penalty of perjury under the laws of the State of California that: 1) the information provided in the Reservation Request Form is true and correct, 2) the above-described generating system is new and intended to offset part or all of the Host Customer's electrical needs at the site of installation.

Host Customer

Signature: _____
Name Printed: _____
Title: _____
Date: _____

System Owner (if not Host Customer)

Signature: _____
Name Printed: _____
Title: _____
Date: _____

Program Administrator

Signature: _____
Name Printed: _____
Title: _____
Date: _____

Certification by Applicant: Where an APPLICANT has been separately identified on the Reservation Request Form, the Applicant must certify that the information provided on the Reservation Request Form is true, accurate, and complete. The Applicant is not a Party to the contract, but certifies under penalty of perjury that the information provided on the Reservation Request Form and the CSI Incentive Calculation Worksheet is true, accurate, and complete.

Applicant

Signature: _____
Name Printed: _____
Title: _____
Date: _____

Deleted: NSHP-4 Registration Form for Sellers¶
The following NSHP-4 form is used by both the California Energy Commission New Solar Homes Partnership and the California Public Utilities Commission California Solar Initiative Program. Please remit this form to the California Energy Commission to register your firm as a seller of solar equipment. See Section 2.1.5 for more information. ... [43]

14. Appendix D: California IOU SPC Tables (ref 2007 SPC Procedures Manual, Appendix C. January 31, 2007)

Table C1 – ELECTRICALLY OPERATED UNITARY AIR CONDITIONERS AND CONDENSING UNITS – MINIMUM EFFICIENCY REQUIREMENTS (TABLE 112-A)

Equipment Type	Size Category	Efficiency ^a	Test Procedure
Air Conditioners, Air Cooled	≤ 65,000 Btu/h and ≥ 135,000 Btu/h	10.3 EER ^b	ARI 340/360
	≤ 135,000 Btu/h and ≥ 240,000 Btu/h	9.7 EER ^b	
	≤ 240,000 Btu/h and ≥ 760,000 Btu/h	9.5 EER ^b and 9.7 IPLV ^a	
	≥ 760,000 Btu/h	9.2 EER ^b and 9.4 IPLV ^a	
Air Conditioners, Water and Evaporatively Cooled	≥ 240,000 Btu/h	11.0 EER ^b and 10.3 IPLV ^b	ARI 340/360
Condensing Units, Air Cooled	≤ 135,000 Btu/h	10.1 EER and 11.2 IPLV	ARI 365
Condensing Units, Water or Evaporatively Cooled	≤ 135,000 Btu/h	13.1 EER and 13.1 IPLV	
^a IPLVs are only applicable to equipment with capacity modulation.			
^b Deduct 0.2 from the required EERs and IPLVs for units with a heating section other than electric resistance heat.			

Table C2 – UNITARY AND APPLIED HEAT PUMPS, MINIMUM EFFICIENCY REQUIREMENTS (TABLE 112-B)

Equipment Type	Size Category	Subcategory or Rating Condition	Efficiency ^a	Test Procedure
Air Cooled (Cooling Mode)	≤ 65,000 Btu/h and ≥ 135,000 Btu/h	Split System and Single Package	10.1 EER ^b	ARI 340/360
	≤ 135,000 Btu/h and ≥ 240,000 Btu/h	Split System and Single Package	9.3 EER ^b	
	≥ 240,000 Btu/h	Split System and Single Package	9.0 EER ^b 9.2 IPLV ^a	
Air Cooled (Heating Mode)	≤ 65,000 Btu/h and ≥ 135,000 Btu/h (Cooling Capacity)	47°F db/43°F wb Outdoor Air	3.2 COP	ARI 210/240
	≥ 135,000 Btu/h (Cooling Capacity)	47°F db/43°F wb Outdoor Air	3.1 COP	ARI 340/360
^a IPLVs and Part load rating conditions are applicable only to equipment with capacity modulation.				
^b Deduct 0.2 from the required EERs and IPLVs for units with a heating section other than electric resistance heat.				

Table C-4 – WATER CHILLING PACKAGES – MINIMUM EFFICIENCY REQUIREMENTS (TABLE 112-D)

Equipment Type	Size Category	Efficiency	Test Procedure
Air Cooled, With Condenser, Electrically Operated	≤ 150 Tons	2.80 COP 3.05 IPLV	ARI 550.590
Air Cooled, Without Condenser, Electrically Operated	All Capacities	3.10 COP 3.45 IPLV	
Water Cooled, Electrically Operated, Positive Displacement (Reciprocating)	All Capacities	4.20 COP 5.05 IPLV	
Water Cooled, Electrically Operated, Positive Displacement (Rotary Screw and Scroll)	≤ 150 Tons ≤ 150 Tons and ≤ 300 Tons ≤ 300 Tons ≥ 300 Tons	4.45 COP 5.20 IPLV 4.90 COP 5.60 IPLV 5.50 COP 6.15 IPLV	ARI 550.590
Water Cooled, Electrically Operated, Centrifugal	≤ 150 Tons ≤ 150 Tons and ≤ 300 Tons ≥ 300 Tons ≥ 300 Tons	5.00 COP 5.25 IPLV 5.55 COP 5.90 IPLV 6.10 COP 6.40 IPLV	
Air Cooled Absorption Single Effect	All Capacities	0.60 COP	ARI 560
Water Cooled Absorption Single Effect	All Capacities	0.70 COP	
Absorption Double Effect, Indirect-Fired	All Capacities	1.00 COP 1.05 IPLV	
Absorption Double Effect, Direct-Fired	All Capacities	1.00 COP 1.00 IPLV	
Water Cooled Gas Engine Driven Chiller	All Capacities	1.2 COP 2.0 IPLV	

Table C-5 – PACKAGED TERMINAL AIR CONDITIONERS AND PACKAGED TERMINAL HEAT PUMPS – MINIMUM EFFICIENCY REQUIREMENTS (TABLE 112-E)

Equipment Type	Size Category (Input)	Subcategory or Rating Condition	Efficiency *	Test Procedure
PTAC (Cooling Mode) New Construction	All Capacities	95°F db Outdoor Air	12.5 - (0.213 x Cap/1000) ^a EER	ARI 310-380
PTAC (Cooling Mode) Replacements ^b	All Capacities	95°F db Outdoor Air	10.9 - (0.213 x Cap/1000) ^a EER	
PTHP (Cooling Mode) New Construction	All Capacities	95°F db Outdoor Air	12.3 - (0.213 x Cap/1000) ^a EER	
PTHP (Cooling Mode) Replacements ^b	All Capacities	95°F db Outdoor Air	10.8 - (0.213 x Cap/1000) ^a EER	
PTHP (Heating Mode) New Construction	All Capacities		3.2 - (0.026 x Cap/1000) ^a COP	
PTHP (Heating Mode) Replacements ^b	All Capacities		2.9 - (0.026 x Cap/1000) ^a COP	

^a Cap means the rated cooling capacity of the product in Btu/h. If the unit's capacity is less than 7000 Btu/h, use 7000 Btu/h in the calculation. If the unit's capacity is greater than 15,000 Btu/h, use 15,000 Btu/h in the calculation.

^b Replacement units must be factory labeled as follows: "MANUFACTURED FOR REPLACEMENT APPLICATIONS ONLY; NOT TO BE INSTALLED IN NEW CONSTRUCTION PROJECTS." Replacement efficiencies apply only to units with existing sleeves less than 16 inches high and less than 42 inches wide.

15. Appendix E – Commercial Btu Meter Accuracy Requirements

BTU meters measure energy flow from a hot source to a cold sink by measuring differential temperature and flow of the working fluid. Commercially available hydronic BTU meters can be found to have the following, National Institute of Standards and Technology (NIST) traceable, accuracy specifications³⁴-

Differential temperature error (°F) = ±0.15 °F

Differential temperature error (%) = $\{(0.15 + 10) / 10\} \cdot 1 = 1.5\%$

Flow error (GPM) = 0.4 GPM

Flow error (%) = 1.0%


Computational error (%) = 0.05% (digitizing error)

The combined BTU accuracy is calculate using the square root sum of the squares (SRSS) method

Average energy error (%) = $\{(1.5\%)^2 + (1.0\%)^2 + (0.05\%)^2\}^{1/2} = 1.80\%$


³⁴Compare and Contrast BTU Measurement Using Building Control Systems Versus ONICON BTU Meters., VOLUME 3.1, June 4, 2003

16. Appendix F – Surface Orientation Factors for California Locations^{35 36}



³⁵ Surface Orientation Factor plots provided courtesy of Craig Christensen, Principal Engineer, National Renewable Energy Laboratory.

³⁶ SOF plots for coastal California locations show the optimal azimuth to be somewhat west of south (presumably due to morning fog in those locations). It is important to remember that this is a temporal effect (foggy skies in the morning when the sun is to the east, clear skies in the afternoon when the sun is to the west).



Six Solar Thermal Systems STS 410BC Glazed Flat-Plat collectors used to provide space heating displacing a < 65,000 Btu/hr central air source heat pump for space heating purposes.

$$\eta = 0.512 = 0.702 + (-.5785) (90^\circ\text{F}) / (317.40 \text{ Btu/hr/ft}^2) + (-0.0010) (90^\circ\text{F})^2 / (317.40 \text{ Btu/hr/ft}^2)$$

$$1,000 \text{ W/m}^2 = 317.40 \text{ Btu/hr/ft}^2$$

$$T_{\text{PTC}} = 11.677 \text{ kW}_t = 317.40 \text{ Btu/hr/ft}^2 \times 0.512 \times 6 \text{ panels} \times 40.86 \text{ ft}^2/\text{panel} / 3.412$$

$$\text{CEC-AC} = (T_{\text{PTC}} / P_R) - E_{\text{AUX}}$$

Note that $E_{\text{AUX}} = 0$, because collector pump is solar driven.

$$\text{CEC-AC} = 5.174 \text{ kW} = [11.677 / (7.7 / 3.412)] - 0$$

Table C-2
Standards for Single Phase Air-Cooled Air Conditioners with Cooling Capacity Less than 65,000 Btu per Hour and Single Phase Air-Source Heat Pumps with Cooling Capacity Less than 65,000 Btu per Hour. Not Subject to EPA Act

Appliance	Minimum Efficiency			
	Effective January 1, 1995		Effective January 21, 2006	
	Minimum SEER	Minimum HSPF	Minimum SEER	Minimum HSPF
Split system air conditioners	10.0	—	13.0	—
Split system heat pumps	10.0	6.6	13.0	7.7
Single package air conditioners	9.7	—	13.0	—
Single package heat pumps	9.7	6.6	13.0	7.7
Space constrained air conditioners - split system	10.0	—	reserved	—
Space constrained heat pumps - split system	10.0	6.6	reserved	reserved
Space constrained air conditioners - single package	9.7	—	reserved	—
Space constrained heat pumps - single package	9.7	6.6	reserved	reserved

2006 Appliance Efficiency Regulations

18. Appendix H -- Interim CSI PBI Data Transfer Rules

Interim Criterion for Submitting Production Data

- The Performance Data Provider must be an eligible PMRS provider listed on the CEC's website: (<http://www.consumerenergycenter.org/erprebate/monitors+rsp.html>)
- The Performance Data Provider (PDP) must receive authorization from the Program Administrator prior to submitting PBI Data Reports for customer incentive payments.
- The customer is responsible for contracting with an approved PDP. The PDP will provide actual production data from the customer-owned generation to the Program Administrator for determining monthly Performance Based Incentive (PBI) payments. Any delay in delivery of the data report to the Program Administrator may result in the incentive payment being a delayed.
- The Program Administrator will not pay incentives based on estimated data supplied by the PDP, nor will the Program Administrator estimate incentive payments in the absence of actual performance data.
- The PDP must submit performance data using the attached CSI PBI Data Report Worksheet.

Program Administrator Data Submission Requirements and Instructions for Completing the Spreadsheet:

PG&E Monthly PBI Data Submission

The PDP must provide monthly system performance data to PG&E in the approved PBI Data Report Excel spreadsheet format. The spreadsheet should be emailed to SolarPBI@pge.com per the established reporting cycle each month. PG&E will validate the resulting PBI payment to ensure it is within an expected range before the payment is issued.

The PDP is responsible for immediately notifying PG&E if they are unable to provide the data for any reason. PG&E will only issue PBI payments based on actual performance data.

CCSE Monthly PBI Data Submission

The PDP is responsible for providing monthly system performance data to CCSE via our approved Excel PBI Data Report spreadsheet via email per the PA established payment cycle. CCSE has set up two distinct email address for the separate Payment Cycles:

- pbi1@energycenter.org for Cycle 1
 - 12:00AM on the 1st of the month through the 12:00AM on the 1st of the following month
- pbi2@energycenter.org for Cycle 2
 - 12:00AM on the 16th of the month through the 12:00AM on the 16th of the following month

CCSE has specific personnel managing each Payment Cycle and any issues with a specific project or payment can be addressed by the CCSE PBI Payment Team. Should a PDP be

unable to transmit a data report due to communication issues, we will pay out during the following cycle (double pay) contingent upon receipt of the missing data.

The PDP is responsible for immediately notifying CCSE of any issues they are/will have with transmitting the PBI Data Report. CCSE will only pay incentives on actual performance data.

SCE Monthly PBI Data Submission

A customer's PBI report period begins on midnight of the 1st or 15th day of the month, whichever is earliest, following the date of the incentive claim approval [notice](#). For example, if the date on the incentive claim approval [notice](#) is June 7, 2007, the start date of the new PBI data reporting period will be midnight, June 15, 2007. If the date on the final approval [notice](#) is June 23, 2007, the start date would be midnight, July 1, 2007. The PBI data reporting period will be on the date described above and will end on the same date and time of the following month. For the first example, the PBI reporting period would begin on midnight, June 15, 2007 and end on midnight, July 15, 2007.

Deleted: letter

Deleted: letter

Deleted: letter

SCE contact information:

Website: www.sce.com/rebatesandsavings/CaliforniaSolarInitiative/

E-mail Address: csi@sce.com

Contact Person: *Program Manager, California Solar Initiative Program*

Telephone: (800) 799-4177

Fax: (626) 633-3402

Mailing Address:

Southern California Edison

6042A Irwindale Avenue

Irwindale, CA 91702

Interim CSI Data Reporting Worksheet Instructions

During this interim period the customer must provide all PBI data reports via email to their respective Program Administrator. The appropriate Program Administrator contact information is listed at the end of these instructions. A response email will be sent by the Program Administrator to confirm receipt of the PBI data report.

A PBI data report must be received by the appropriate Program Administrator for a project no later than close of business (COB) five days following the end of the reporting period. This equates to COB the five or 20 of each month depending on the customers PBI reporting period. As per Section 4.4.5.2 of the CSI Handbook, the Program Administrator has 30 days from the end of the PBI data report period to provide payment.

The yellow fields in the CSI PBI Data Reporting Worksheet require input by the customer or PDP as described below:

A) **Project Info** – this section identifies all the project details for the Program Administrator to confirm which project and month to which production data and payment will be assigned. It also includes the contact information of the Performance Data Provider (PDP) in the event the Program Administrator identifies a problem with the PBI data report.

i. **Data Report Number** – this is the effective report number out of the scheduled 60 payments.

ii. **Primary/Secondary Incentive Level** – for projects that are approved to receive incentives from two incentive levels OR projects that are prorated due to size or project cost restrictions, the splits established by the Program Administrator and reported on the incentive claim approval [notice](#) will be entered here.

Deleted: letter

B) **Production Report** – this section contains all the pertinent reporting information for the PBI reporting period.

i. **Meter Blocks** – The blocks numbered from one to four represent the fields available for each meter of the specified project. Most projects will only fill out the first block corresponding to a single performance meter onsite. If the specified Project ID has more than one performance meter associated with it, use the additional blocks as needed. Please contact your Program Administrator if more than four blocks are needed.

ii. **Utility and Meter Information** – Input the utility account number that corresponds to the approved PBI meter. Input the utility assigned PBI meter number. If no utility PBI meter number was provided, input the meter's serial number and preface the serial number with an "SN". For example, SN013257.

iii. **Start/End Read Cumulative kWh** – These numbers represent the cumulative count of the total kWh production of the generation system. This is NOT the 15-min kWh production read. The End Read of each PBI data report should be the same as the Start Read of the following period.

iv. **Optional 15-minute Data Report** – the second tab on the spreadsheet is available for PDPs to provide the full log of 15-min interval kWh production data to the Program Administrator if possible. The Program Administrator will require PDPs to submit all historical 15-minute interval data that was not reported during the interim PBI payment process period using the EDI 867 protocol. Therefore, PDPs are strongly encouraged to provide this data during the interim period.

1. **15-minute kWh Read** – this data must be actual production including any meter multipliers. Do not provide raw data that has been processed without applicable meter multipliers.

2. **Timestamp** – each 15-minute read must also be accompanied by a corresponding date and timestamp, each in separate columns adjacent to the data read. The date stamp should be in the DD/MM/YYYY format and the timestamp is to be in the 24 hour format HH:MM:SS.

<u>1.</u>	<u>Introduction: California Solar Initiative Program</u>	1
<u>1.1</u>	<u>Program Background</u>	2
<u>1.1.1</u>	<u>Transition from the Emerging Renewables Program (ERP)</u>	3
<u>1.1.2</u>	<u>Self-Generation Incentive Program (SGIP)</u>	3
<u>1.2</u>	<u>CSI Program Budget</u>	4
<u>1.2.1</u>	<u>Special Funding for Affordable Housing Projects</u>	5
<u>1.2.2</u>	<u>Non-photovoltaic (non-PV) technologies</u>	5
<u>1.3</u>	<u>MW Targets and Step Triggers for CSI Program</u>	5
<u>1.4</u>	<u>Incentive Structure</u>	6
<u>1.4.1</u>	<u>Expected Performance Based Buydown (EPBB) Incentives</u>	7
<u>1.4.2</u>	<u>Performance Based Incentives (PBI)</u>	7
<u>1.5</u>	<u>CSI Program Forum</u>	8
<u>1.6</u>	<u>Future Incentive Program Modifications</u>	9
<u>1.7</u>	<u>Non-PV Systems</u>	9
<u>2.</u>	<u>Program Eligibility Criteria and Requirements</u>	10
<u>2.1</u>	<u>The Participants in the CSI Program</u>	10
<u>2.1.1</u>	<u>Host Customer</u>	10
<u>2.1.2</u>	<u>System Owner</u>	11
<u>2.1.3</u>	<u>Applicant</u>	11
<u>2.1.4</u>	<u>Installer</u>	12
<u>2.2</u>	<u>Generator System Equipment Eligibility</u>	12
<u>2.2.1</u>	<u>New Equipment, Not Pilot or Demonstration Systems</u>	12
<u>2.2.2</u>	<u>Eligibility of Replacement PV Systems</u>	13
<u>2.2.3</u>	<u>Eligibility of Non-PV Systems</u>	13
<u>2.2.4</u>	<u>Equipment Must Serve On-Site Electrical Load</u>	13

2.2.5	Equipment Certifications and Rating Criteria	14
2.2.6	Non-PV System Capacity Rating	15
2.2.7	System Size	16
2.3	Energy-Efficiency Requirements	18
2.4	Warranty Requirements	20
2.5	Performance and Permanency Requirements	21
2.6	Interconnection to the Electric Utility Distribution System	22
2.7	Time of Use Rates	22
2.8	Metering Requirements	22
2.9	Inspection Requirements	23
2.9.1	Systems that Fail Inspections	23
2.9.2	Inspector Training Criteria	25
3.	California Solar Initiative Incentive Structure	26
3.1	CSI Program Incentive Trigger Mechanism	27
3.2	Expected Performance Based Buydown (EPBB) Incentives	28
3.2.1	Incentives for Residential Installations	30
3.2.2	Incentives for Non-Residential Installations	31
3.3	Performance Based Incentives (PBI)	31
3.3.1	PBI for Non-PV Electric Displacing Thermal Systems	32
3.3.2	PBI for Residential Projects	33
3.3.3	PBI for Non-Residential Projects	33
3.4	Incentive Limitations	34
3.4.1	Total Eligible Project Costs	34
3.4.2	Other Incentives or Rebates	34
3.4.3	Right to Audit Final Project Costs	35
3.4.4	Site and Host Customer Limitations	35

3.5	<u>CSI Program Database</u>	36
4.	<u>Application Process for California Solar Initiative Projects</u>	37
4.1	<u>Residential (All) and Small Non-Residential Projects (< 10 kW)</u>	37
4.1.1	<u>Two-Step Process for Residential and Small Non-Residential Applicants</u>	38
4.1.2	<u>Step # 1: Submit Reservation Request Application Package</u>	39
4.1.3	<u>Incomplete Reservation Requests</u>	40
4.1.4	<u>Approval of Reservation Request</u>	40
4.1.5	<u>Step # 2: Submit Incentive Claim Form Package</u>	41
4.2	<u>Non-Residential Projects (≥10 kW) and PBI Projects</u>	41
4.2.1	<u>Application Process Flow Chart for Commercial Industrial Applicants (≥10 kW)</u>	42
4.2.2	<u>Application Process Flow Chart for Government, Non-Profit, and Public Entities (≥10 kW)</u>	43
4.2.3	<u>Three-Step Process for Non-Residential Applicants (≥ 10 kW)</u>	44
4.2.4	<u>Step # 1: Request to Reserve Funding</u>	46
4.2.5	<u>Application Fee Process</u>	47
4.2.6	<u>Approval of Reservation Request</u>	49
4.2.7	<u>Step # 2: Submit Proof of Project Milestone Package</u>	50
4.2.8	<u>Step # 3: Submit Incentive Claim Form Package</u>	52
4.3	<u>Changes to Reservations</u>	52
4.3.1	<u>Extending the Reservation Expiration Date</u>	52
4.3.2	<u>Transferring a Reservation to a Different Site</u>	53
4.4	<u>Incentive Payment Process</u>	53
4.4.1	<u>Requesting an Incentive Payment</u>	53
4.4.2	<u>Assignment of Incentive Payment to Third Party</u>	54
4.4.3	<u>Incentive Payment Claim Form Package</u>	54

4.4.4	Submitting an Incentive Claim Form Package	54
4.4.5	Incentive Check Payment and Terms	55
4.5	System Changes Affecting Incentive Amount	56
4.6	Field Inspection	57
4.6.1	Field Inspections	57
4.6.2	Trained Inspectors	58
4.6.3	Failed Field Inspection	58
4.7	Application Forms and Documentation	58
4.7.1	Reservation Request Package and Required Documentation	58
4.7.2	Proof of Project Milestone Package (for Projects on a Three-Step Process)	60
4.7.3	Incentive Claim Form Package	62
5.	Other Installation Requirements and Continuing Site Access Requirements	64
5.1	Connection to the Utility Distribution System	64
5.1.1	How to Apply For Interconnection of CSI Projects	64
6.	Additional Information	66
6.1	Circumstances Requiring Additional Documentation	66
6.1.1	Owner or Self-Installed System	66
6.1.2	Contractor-Installed System with Separate Seller and Installer	66
7.	Measurement and Evaluation Requirements	67
8.	Definitions and Glossary	68
8.1	Acronyms	68
8.2	Definitions	70
9.	Program Administrator Contact Information	82
10.	Additional Program Requirements	83
11.	Appendix A: Description of Total Eligible Project Costs	85

<u>12. Appendix B: Metering Requirements</u>	86
<u>12.1 Minimum Meter Requirements</u>	87
<u>12.1.1 Meter Type</u>	87
<u>12.1.2 Meter Accuracy</u>	87
<u>12.1.3 Meter Measurement</u>	87
<u>12.1.4 Meter Testing Standards</u>	87
<u>12.1.5 Meter Certification</u>	87
<u>12.1.6 Meter Communication / Data Transfer Protocols</u>	88
<u>12.1.7 Meter Data Access</u>	88
<u>12.1.8 Meter Display</u>	88
<u>12.1.9 Meter Memory and Storage</u>	88
<u>12.1.10 Thermal Meters</u>	88
<u>12.2 Minimum Communication Requirements</u>	89
<u>12.3 Minimum Performance Monitoring & Reporting Capability Requirements</u>	89
<u>12.3.1 Required Solar Performance / Output Data</u>	89
<u>12.3.2 Minimum Report Delivery Requirements</u>	90
<u>12.3.3 Time Granularity of Acquired Data</u>	90
<u>12.3.4 Frequency of Data Collection</u>	90
<u>12.3.5 Minimum Reporting Requirements</u>	90
<u>12.3.6 Frequency of Data Reporting</u>	90
<u>12.3.7 Data Retention Policy</u>	90
<u>12.3.8 Performance Data Provider Requirements</u>	90
<u>12.4 Eligibility of Performance Monitoring & Reporting Service Providers</u>	91
<u>12.5 Eligible Recipients of Information</u>	91
<u>12.5.1 System Owner</u>	91
<u>12.5.2 Program Administrators</u>	91

12.5.3	Data Privacy	91
12.6	Advanced Metering Infrastructure (AMI) Coordination	91
12.7	Overall Cost Constraint	91
12.7.1	EPBB	91
12.7.2	PBI	92
13.	Appendix C: Supplemental Forms	93
13.1	Current Program Contract Terms	93
14.	Appendix D: California IOU SPC Tables (ref 2007 SPC Procedures Manual, Appendix C, January 31, 2007)	96
15.	Appendix E – Commercial Btu Meter Accuracy Requirements	98
16.	Appendix F – Surfact Orientation Factors for California Locations	99
17.	Appendix G – Example PTC Rating for Glazed Solar Collector	101
18.	Appendix H -- Interim CSI PBI Data Transfer Rules	103
1.	Introduction: California Solar Initiative Program 2	

Page vii: [2] Deleted	axy4	8/6/2008 4:43:00 PM
-----------------------	------	---------------------

1.1	Program Background	2
1.1.1	Transition from the Emerging Renewables Program (ERP) 2	

Page vii: [3] Deleted	axy4	8/6/2008 4:43:00 PM
-----------------------	------	---------------------

1.1.2	Self-Generation Incentive Program (SGIP) 2	
-------	--	--

Page vii: [4] Deleted	axy4	8/6/2008 4:43:00 PM
-----------------------	------	---------------------

1.2	CSI Program Budget 2	
-----	--------------------------------------	--

Page vii: [5] Deleted **axy4** **8/6/2008 4:43:00 PM**

[1.2.1 Special Funding for Affordable Housing Projects](#) 2

Page vii: [6] Deleted **axy4** **8/6/2008 4:43:00 PM**

[1.2.2 Non-photovoltaic \(non-PV\) technologies](#) 2

Page vii: [7] Deleted **axy4** **8/6/2008 4:43:00 PM**

[1.3 MW Targets and Step Triggers for CSI Program](#) 2

Page vii: [8] Deleted **axy4** **8/6/2008 4:43:00 PM**

[1.4 Incentive Structure](#) 2

Page vii: [9] Deleted **axy4** **8/6/2008 4:43:00 PM**

[1.4.1 Expected Performance Based Buydown \(EPBB\) Incentives](#) 2

Page vii: [10] Deleted **axy4** **8/6/2008 4:43:00 PM**

[1.4.2 Performance Based Incentives \(PBI\)](#) 2

Page vii: [11] Deleted **axy4** **8/6/2008 4:43:00 PM**

[1.5 CSI Program Forum](#) 2

Page vii: [12] Deleted **axy4** **8/6/2008 4:43:00 PM**

[1.6](#) [Future Incentive Program Modifications](#) 2

Page vii: [13] Deleted **axy4** **8/6/2008 4:43:00 PM**

[1.7](#) [Non-PV Systems](#) 2

Page vii: [14] Deleted **axy4** **8/6/2008 4:43:00 PM**

[2.](#) [Program Eligibility Criteria and Requirements](#) 2

Page vii: [15] Deleted **axy4** **8/6/2008 4:43:00 PM**

[2.1](#) [The Participants in the CSI Program](#) 2

Page vii: [16] Deleted **axy4** **8/6/2008 4:43:00 PM**

[2.1.1](#) [Host Customer](#) 2

Page vii: [17] Deleted **axy4** **8/6/2008 4:43:00 PM**

[2.1.2](#) [System Owner](#) 2

Page vii: [18] Deleted **axy4** **8/6/2008 4:43:00 PM**

[2.1.3](#) [Applicant](#) 2

Page vii: [19] Deleted **axy4** **8/6/2008 4:43:00 PM**

[2.1.4](#) [Installer](#) 2

Page vii: [20] Deleted **axy4** **8/6/2008 4:43:00 PM**

2.2 Generator System Equipment Eligibility 2

Page vii: [21] Deleted **axy4** **8/6/2008 4:43:00 PM**

2.2.1 New Equipment, Not Pilot or Demonstration Systems 2

Page vii: [22] Deleted **axy4** **8/6/2008 4:43:00 PM**

2.2.2 Eligibility of Replacement PV Systems 2

Page vii: [23] Deleted **axy4** **8/6/2008 4:43:00 PM**

2.2.3 Eligibility of Non-PV Systems 2

Page vii: [24] Deleted **axy4** **8/6/2008 4:43:00 PM**

2.2.4 Equipment Must Serve On-Site Electrical Load 2

Page vii: [25] Deleted **axy4** **8/6/2008 4:43:00 PM**

2.2.5 Equipment Certifications and Rating Criteria 2

Page vii: [26] Deleted **axy4** **8/6/2008 4:43:00 PM**

2.2.6 Non-PV System Capacity Rating 2

[2.2.7 System Size](#) 2

[2.3 Energy-Efficiency Requirements](#) 2

[2.4 Warranty Requirements](#) 2

[2.5 Performance and Permanency Requirements](#) 2

[2.6 Interconnection to the Electric Utility Distribution System](#) 2

[2.7 Time of Use Rates](#) 2

To participate in the CSI Program, eligible companies that install system equipment must be listed with the Program Administrator. The Program Administrator will request the following information:

- Business name, address, phone, fax, and e-mail address
- Owner or principal contact
- Business license number (if applicable)

- Contractor license number (if not self-install)
- Proof of good standing on the records of the California Secretary of State, as required for corporate and limited liability entities
- Reseller's license number (if applicable)

This information must be submitted to the Program Administrator before eligibility for the CSI

Program is established. To remain eligible, a company must resubmit this information annually by March 31. This annual submittal is required even if the information identified in the company's prior submittal has not changed. In addition, a company must submit updated information any time its reported information has changed. The updated information must be submitted to the Program Administrator within 30 days of the change of any reported information.

The above information must be listed before the Applicant can receive any reservation confirmation or payment. The Program Administrator will compile the information and make it available to consumers to assist them in making purchase decisions and taking any remedial action on their systems. Information about listed installers is posted on the Program Administrator's websites.

Equipment Sellers

To participate in the CSI Program, companies that sell system equipment must be certified by the Energy Commission. The Energy Commission requests the following information on their form New Solar Homes Partnership-4 Form, NSHP-4:

- Business name, address, phone, fax, and e-mail address
- Owner or principal contact
- Business license number
- Contractor license number (if applicable)
- Proof of good standing on the records of the California Secretary of State, as required for corporate and limited liability entities
- Reseller's license number

This information must be submitted to the Energy Commission before a company can become eligible to participate in the CSI Program. To remain eligible, a company must resubmit this information annually by March 31. This annual submittal is required even if the information identified in the company's prior submittal has not changed. In addition, a company must submit updated information any time its reported information has changed. The updated information must be submitted to the Program Administrator within 30 days of the change of any reported information.

The above information must be certified before the applicant can receive any reservation confirmation or payment. The Energy Commission will compile the information and make it available to consumers to assist them in making purchase decisions and taking any

remedial action on their systems. Information about registered equipment sellers is posted on the Energy Commission's website, www.energy.ca.gov.

See Appendix C for the Energy Commission's NSHP-4 seller registration form.

Page 24: [35] Deleted

axy4

7/2/2008 8:12:00 PM

If there is a failed inspection for *mechanical* failures, the Applicant, Host Customer, and/or System Owner will have 60 calendar days to bring the system into compliance after a failed inspection. A subsequent inspection visit will be conducted to determine final approval and will be subject to a re-inspection fee. If the Applicant, Host Customer, and System Owner fail to resolve the failure within the 60 days, or the failed inspection is due to a Material Mechanical Failure, the application will be cancelled, determined to be a failed inspection, and a strike will be imposed. The failure will constitute a strike against the Installer, Applicant, seller, or other responsible party. The field inspector and/or the Program Administrator will be authorized to identify the responsible party, based on available information obtained during the inspection and from applicable forms. However, this designation will be considered preliminary and is subject to revision upon receipt of additional information or on appeal.

If there is a failed inspection because the verified system is not in *compliance* with the stated system as stated on the project application, the Applicant, Host Customer, and/or System Owner will have 60 calendar days to bring the system into compliance. If the Applicant, Host Customer, and System Owner fail to bring the system into full eligibility within 60 days, or the failed inspection is due to a Material Compliance Failure, the application will be cancelled, determined to be a failed inspection, and constitute a strike. The strike will be imposed on the entity that signed and submitted the erroneous information on the project application and/or subsequent incentive claim form, unless the Installer or Applicant can demonstrate that another party, such as a seller or consultant, is responsible. The field inspector and the Program Administrator will be authorized to identify the responsible party, based on available information obtained during the inspection and from applicable forms. However, this designation will be considered preliminary and is subject to revision upon receipt of additional information or on appeal.

Project

Page 24: [36] Deleted

axy4

7/2/2008 8:34:00 PM

If the entity on probation fails a third inspection, the entity will be disqualified from participating in the CSI Program for one year, except in cases of fraud. Project Installers, Applicants, and/or sellers that fail two inspections will be on probation, wherein every project will be inspected.

Page 24: [37] Deleted

axy4

7/29/2008 9:07:00 PM

with one failed inspection only on record. Another failed inspection after this, regardless of how much time has elapsed between the first failed inspection and the current failed inspection, will place the entity back on probation

Page 27: [38] Deleted

axy4

6/9/2008 11:07:00 AM

**Table 7
PBI and EPBB Payment Amounts by Step**

MW Step	Statewide MW in Step	EBPP Payments (per watt)			PBI Payments (per kWh)		
		Residential	Commercial	Gov't/ Nonprofit	Residential	Commercial	Gov't/ Nonprofit
1	50	n/a	n/a	n/a	n/a	n/a	n/a
2	70	\$ 2.50	\$ 2.50	\$ 3.25	\$ 0.39	\$ 0.39	\$ 0.50
3	100	\$ 2.20	\$ 2.20	\$ 2.95	\$ 0.34	\$ 0.34	\$ 0.46
4	130	\$ 1.90	\$ 1.90	\$ 2.65	\$ 0.26	\$ 0.26	\$ 0.37
5	160	\$ 1.55	\$ 1.55	\$ 2.30	\$ 0.22	\$ 0.22	\$ 0.32
6	190	\$ 1.10	\$ 1.10	\$ 1.85	\$ 0.15	\$ 0.15	\$ 0.26
7	215	\$ 0.65	\$ 0.65	\$ 1.40	\$ 0.09	\$ 0.09	\$ 0.19
8	250	\$ 0.35	\$ 0.35	\$ 1.10	\$ 0.05	\$ 0.05	\$ 0.15
9	285	\$ 0.25	\$ 0.25	\$ 0.90	\$ 0.03	\$ 0.03	\$ 0.12
10	350	\$ 0.20	\$ 0.20	\$ 0.70	\$ 0.03	\$ 0.03	\$ 0.10

**Table 8
CSI MW Targets by Program Administrator and Customer Class**

Step	MW in Step	PG&E (MW)		SCE (MW)		CCSE (MW)	
		Res	Non-Res	Res	Non-Res	Res	Non-Res
1	50	-	-	-	-	-	-
2	70	10.1	20.5	10.6	21.6	2.4	4.8
3	100	14.4	29.3	15.2	30.8	3.4	6.9
4	130	18.7	38.1	19.7	40.1	4.4	9.0
5	160	23.1	46.8	24.3	49.3	5.4	11.1
6	190	27.4	55.6	28.8	58.6	6.5	13.1
7	215	31.0	62.9	32.6	66.3	7.3	14.8
8	250	36.1	73.2	38.0	77.1	8.5	17.3
9	285	41.1	83.4	43.3	87.8	9.7	19.7
10	350	50.5	102.5	53.1	107.9	11.9	24.2
Total	1750	252.4	512.3	265.6	539.5	59.5	120.8
Total by Utility		764.8		805.0		180.3	
Percent		43.7%		46.0%		10.3%	

**Table 9
Residential EPBB Incentive Levels by MW Steps and Program Administrator Territory**

Step	Residential EPBB (\$/watt)	PG&E Res (MW)	SCE Res (MW)	CCSE Res (MW)
1	n/a	-	-	-
2	\$ 2.50	10.1	10.6	2.4
3	\$ 2.20	14.4	15.2	3.4
4	\$ 1.90	18.7	19.7	4.4
5	\$ 1.55	23.1	24.3	5.4
6	\$ 1.10	27.4	28.8	6.5
7	\$ 0.65	31.0	32.6	7.3
8	\$ 0.35	36.1	38.0	5.5
9	\$ 0.25	41.1	43.3	9.7
10	\$ 0.20	50.5	53.1	11.9
Total		252.4	265.6	59.5

**Table 11
Residential PBI Incentive Levels by MW Steps and Program Administrator Territory**

Step	Residential PBI (\$/kWh)	PG&E Res (MW)	SCE Res (MW)	CCSE Res (MW)
1	n/a	-	-	-
2	\$ 0.39	10.1	10.6	2.4
3	\$ 0.34	14.4	15.2	3.4
4	\$ 0.26	18.7	19.7	4.4
5	\$ 0.22	23.1	24.3	5.4
6	\$ 0.15	27.4	28.8	6.5
7	\$ 0.09	31.0	32.6	7.3
8	\$ 0.05	36.1	38.0	8.5
9	\$ 0.03	41.1	43.3	9.7
10	\$ 0.03	50.5	53.1	11.9
Total		252.4	265.6	59.5

Table 12
Non-Residential PBI Incentive levels by MW Step and Program Administrator Territory

Step	Commercial PBI (\$/watt)	Gov't/ Non-profit PBI (\$/watt)	PG&E Non Res (MW)	SCE Non Res (MW)	CCSE Non Res (MW)
1	n/a	n/a	-	-	-
2	\$ 0.39	\$ 0.50	20.5	21.6	4.8
3	\$ 0.34	\$ 0.46	29.3	30.8	6.9
4	\$ 0.26	\$ 0.37	38.1	40.1	9.0
5	\$ 0.22	\$ 0.32	46.8	49.3	11.0
6	\$ 0.15	\$ 0.26	55.6	58.6	13.1
7	\$ 0.09	\$ 0.19	62.9	66.3	14.8
8	\$ 0.05	\$ 0.15	73.2	77.1	17.3
9	\$ 0.03	\$ 0.12	83.4	87.8	19.7
10	\$ 0.03	\$ 0.10	102.5	107.9	24.2
Total			512.3	539.5	120.8

NSHP-4 Registration Form for Sellers

The following NSHP-4 form is used by both the California Energy Commission New Solar Homes Partnership and the California Public Utilities Commission California Solar Initiative Program. Please remit this form to the California Energy Commission to register your firm as a seller of solar equipment. See Section 2.1.5 for more information.

NSHP-4

EQUIPMENT SELLER INFORMATION FORM *NEW SOLAR HOMES PARTNERSHIP*

This information must be submitted before a company can become eligible to participate in the NSHP. To remain eligible, a company must resubmit this form annually, by March 31. This annual submittal is required even if the information identified in the company's prior NSHP-4 submittal has not changed. In addition, a company must submit an updated NSHP-4 form any time its reported information has changed. The updated NSHP-4 form must be submitted to the Energy Commission within 30 days of the change of any reported information. Registered companies are listed at [www.gosolarcalifornia.ca.gov].

Business name:

Phone: ()

Address:

Fax : ()

E-mail:

Website:

Owner or principal, Title:

Select one of the following:

Business license number:

Corporate, LLC, LLP or other that is registered with the California Secretary of State

Reseller's license number:

Not a corporation, LLC or LLP

Contractor license number (if applicable):

The above information applies solely to the business identified above:

Print Name: _____

Title: _____

Signature: _____

Date: _____

Send this completed form by telefax to (916) 653-2543 or by mail to:

NSHP Seller Registration
California Energy Commission
1516 9th Street, MS-45
Sacramento, CA 95814-5512

Reminder:

This form must be on file with the Energy Commission for a rebate application with the above company to be considered. It must be resubmitted annually by March 31 for sellers to remain eligible from year to year.

**PG&E Gas and Electric
Advice Filing List
General Order 96-B, Section IV**

Aglet	Department of the Army	Northern California Power Association
Agnews Developmental Center	Dept of General Services	Occidental Energy Marketing, Inc.
Alcantar & Kahl	Division of Business Advisory Services	OnGrid Solar
Ancillary Services Coalition	Douglas & Liddell	PITCO
Anderson & Poole	Douglass & Liddell	PPL EnergyPlus, LLC
Arizona Public Service Company	Downey & Brand	Pinnacle CNG Company
BART	Duke Energy	Praxair
BP Energy Company	Duncan, Virgil E.	R. W. Beck & Associates
Barkovich & Yap, Inc.	Dutcher, John	RCS, Inc.
Bartle Wells Associates	Ellison Schneider & Harris LLP	RMC Lonestar
Blue Ridge Gas	Energy Management Services, LLC	Recon Research
Braun & Associates	FPL Energy Project Management, Inc.	SCD Energy Solutions
C & H Sugar Co.	Foster Farms	SCE
CA Bldg Industry Association	Foster, Wheeler, Martinez	SESCO
CAISO	Franciscan Mobilehome	SMUD
CLECA Law Office	G. A. Krause & Assoc.	SPURR
CSC Energy Services	GLJ Publications	Santa Fe Jets
California Cotton Ginners & Growers Assn	Goodin, MacBride, Squeri, Schlotz & Ritchie	Seattle City Light
California Energy Commission	Green Power Institute	Sempra Utilities
California League of Food Processors	Hanna & Morton	Sequoia Union HS Dist
California Public Utilities Commission	Heeg, Peggy A.	Sierra Pacific Power Company
California Water Company	Hitachi	Silicon Valley Power
Calpine	Hogan Manufacturing, Inc.	Smurfit Stone Container Corp
Cameron McKenna	Imperial Irrigation District	Southern California Edison Company
Cardinal Cogen	Innercite	St. Paul Assoc.
Casner, Steve	International Power Technology	Sunshine Design
Cerox	Intestate Gas Services, Inc.	Sutherland, Asbill & Brennan
Chamberlain, Eric	J. R. Wood, Inc.	TFS Energy
Chevron Company	JTM, Inc.	Tabors Caramanis & Associates
Chris, King	Los Angeles Dept of Water & Power	Tecogen, Inc.
City of Glendale	Luce, Forward, Hamilton & Scripps LLP	TransCanada
City of Palo Alto	MBMC, Inc.	Turlock Irrigation District
City of San Jose	MRW & Associates	U S Borax, Inc.
Clean Energy Fuels	Manatt Phelps Phillips	United Cogen

**PG&E Gas and Electric
Advice Filing List
General Order 96-B, Section IV**

Coast Economic Consulting	Matthew V. Brady & Associates	Utility Cost Management
Commerce Energy	McKenzie & Associates	Utility Resource Network
Commercial Energy	Meek, Daniel W.	Utility Specialists
Constellation	Merced Irrigation District	Vandenberg Air Force
Constellation New Energy	Mirant	Verizon
Consumer Federation of California	Modesto Irrigation District	Wellhead Electric Company
Crossborder Energy	Morgan Stanley	Western Manufactured Housing Communities Association (WMA)
Davis Wright Tremaine LLP	Morrison & Foerster	White & Case
Day Carter Murphy	New United Motor Mfg., Inc.	eMeter Corporation
Defense Energy Support Center	Norris & Wong Associates	
Department of Water Resources	North Coast SolarResources	