

**PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans Discovery 2022
Data Response**

PG&E Data Request No.:	CalAdvocates_015-Q01		
PG&E File Name:	WMP-Discovery2022_DR_CalAdvocates_015-Q01		
Request Date:	March 11, 2022	Requester DR No.:	CalAdvocates-PGE-2022WMP-15
Date Sent:	March 16, 2022	Requesting Party:	Public Advocates Office
PG&E Witness:		Requester:	Holly Wehrman

The following questions relate to your 2022 WMP Update submission.

PG&E's responses to Data Request CalAdvocates-PGE-2022WMP-10, Questions 1-3, are summarized in the following table:

QUESTION 01

	Tree Attachments Existing as of 2/1/2022	Tree Attachments Remediated in 2021	Tree Attachments to be removed in 2022
HFTD	19,214	247	588
Non-HFTD	749	139	245

- a) Of the tree attachments PG&E remediated in 2021, approximately 36% were outside the HFTD. Please explain why PG&E selected these non-HFTD locations for remediation.
- b) Of the tree attachments PG&E plans to remediate in 2022, approximately 29% are outside the HFTD. Please explain why PG&E selected these non-HFTD locations for remediation.
- c) Please explain how PG&E determines where to remediate tree attachments.

ANSWER 01

- a) PG&E selects tree attachment locations for remediation based on the condition of the tree and facilities it is supporting. Trees that are dead are prioritized over trees that are declining or green. Similarly, if the tree is supporting facilities that are degraded, broken or have another non-conforming condition, remediation of these trees is prioritized over trees without non-conforming conditions.
- b) See response to part a above.
- c) See response to part a above.