

**PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans Discovery 2022
Data Response**

PG&E Data Request No.:	OEIS_007-Q22		
PG&E File Name:	WMP-Discovery2022_DR_OEIS_007-Q22		
Request Date:	March 28, 2022	Requester DR No.:	Data Request OEIS-PG&E-22-007
Date Sent:	March 30, 2022	Requesting Party:	Office of Energy Infrastructure Safety
PG&E Witness:		Requester:	Kevin Miller

SUBJECT: MATURITY GRANULARITY

QUESTION 22

Regarding PG&E's response to Maturity Survey question B.IIc:

- a. Please describe what PG&E needs to do to improve weather data granularity to the span-based level.

ANSWER 22

We interpret this question as asking about weather data collection in the field from weather stations. To collect weather data at a span-based level, PG&E would have to install a weather station on every single pole or tower to collect weather data on each span.