

PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigations Plans Discovery 2026-2028
Data Response

PG&E Data Request No.:	OEIS_005-Q001
PG&E File Name:	WMP-Discovery2026-2028_DR_OEIS_005-Q001
Request Date:	April 22, 2025
Requester DR No.:	OEIS-P-WMP-2025-PG&E-005
Requesting Party:	Office of Energy Infrastructure Safety
Requester:	Nathan Poon
Date Sent:	April 25, 2025

SUBJECT: REGARDING DISTRIBUTION DETAILED INSPECTIONS AND FINDINGS

QUESTION 001

- a. Provide the following data related to detailed distribution inspections:
- The number of detailed distribution inspections performed in the HFRA/HFTD 2020, 2021, 2022, 2023 and 2024.
 - The number of level 1 work orders that resulted from distribution detailed inspections in the HFRA/HFTD in 2020, 2021, 2022, 2023 and 2024.
 - The number of level 1 work orders originating from distribution detailed inspections closed in the HFRA/HFTD 2020, 2021, 2022, 2023, and 2024.
 - The number of level 2 work orders that resulted from distribution detailed inspections in the HFRA/HFTD in 2020, 2021, 2022, 2023 and 2024.
 - The number of level 2 work orders originating from distribution detailed inspections closed in the HFRA/HFTD in 2020, 2021, 2022, 2023 and 2024.

ANSWER 001

Please see the table below for the requested information. Notes 1 and 2 below help explain the data in the table.

Metric Number	Metric Name	2020	2021	2022	2023	2024
Q01(a)(i)	Total Inspections Performed in HFTD-HFRA	352,057	449,645	395,968	235,265	10,197
Q01(a)(ii)	HFTD-HFRA Level 1 Work Orders	1,200	855	896	1,138	23

Metric Number	Metric Name	2020	2021	2022	2023	2024
	resulting from inspection					
Q01(a)(iii)	Level 1 Work orders closed	1,015	999	894	1,324	69
Q01(a)(iv)	HFTD-HFRA Level 2 Work Orders resulting from inspection	56,596	64,275	80,654	72,294	1,240
Q01(a)(v)	Level 2 Work orders closed	12,478	35,722	35,135	41,231	52,633

1. PG&E understands “detailed distribution inspections” to mean “detailed overhead inspections” conducted by ground inspectors in accordance with General Order (GO) 165. Therefore, Wildfire Safety Inspection Program (WSIP) and aerial inspections or notifications are not included in these tables. Please note that PG&E also conducted 216,796 aerial inspections in HFTD/HFRA in 2024. These aerial inspections were not conducted in accordance with GO 165 and therefore are not included in the table above.
2. Level 1 closure dates reflect the date at which an A priority notification was completely repaired. Please note that the date of complete repair may be different than the date of temporary repair.