

**PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigations Plans Discovery 2026-2028
Data Response**

PG&E Data Request No.:	SPD_003-Q005
PG&E File Name:	WMP-Discovery2026-2028_DR_SPD_003-Q005
Request Date:	April 24, 2025
Requester DR No.:	SPD-PGE-WMP2026- 003
Requesting Party:	Safety Policy Division
Requester:	Henry Sweat
Date Sent:	April 29, 2025

SUBJECT: DATA REQUESTS RELATED TO THE 2026-2028 WMP (SPD-PGE-WMP2026-003)

QUESTION 005

Compute the as-built conversion factor for projects in 2023 and 2024 between overhead lines to underground lines. Provide an explanation of the computation. See the computation provided in PG&E's response to "WMP-Discovery2023_DR_SPD_005-Q006" for an example.

ANSWER 005

Please see attachment "*WMP-Discovery2026-2028_DR_SPD_003-Q005Atch01.xlsx*". This includes undergrounding subprojects 100% completed in 2023 and 2024. Note, this is the same subset of data provided in response to "*WMP-Discovery2026-2028_DR_TURN_003-Q004Atch01.xlsx*", and with the conversion factor appended.

The primary overhead miles removed and replaced by undergrounding reflect actual overhead miles removed on undergrounding subprojects, where data is available; otherwise, where data is not yet available, we used the adopted¹ overhead to undergrounding conversion factor of 1 mile of overhead to 1.25 miles of undergrounding.

¹ D.23-11-069, Findings of Fact 102.