

**PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigations Plans Discovery 2026-2028
Data Response**

PG&E Data Request No.:	SPD_003-Q014
PG&E File Name:	WMP-Discovery2026-2028_DR_SPD_003-Q014
Request Date:	April 24, 2025
Requester DR No.:	SPD-PGE-WMP2026- 003
Requesting Party:	Safety Policy Division
Requester:	Henry Sweat
Date Sent:	April 29, 2025

SUBJECT: DATA REQUESTS RELATED TO THE 2026-2028 WMP (SPD-PGE-WMP2026-003)

QUESTION 014

For each vegetation management program in the 2026-2028 WMP, specify if the Quality Assurance and Quality Controls assessments include verification of the height and distance to the conductor of each strike vegetation point specified for removal, and each vegetation strike point noted as an inventory tree.

ANSWER 014

Quality Assurance and Quality Controls assessments do NOT include verification of the height and distance to the conductor of each strike vegetation point specified for removal, and each vegetation strike point noted as an inventory tree.