

**PACIFIC GAS AND ELECTRIC COMPANY**  
**Wildfire Mitigations Plans Discovery 2026-2028**  
**Data Response**

<b>PG&amp;E Data Request No.:</b>	SPD_013-Q002
<b>PG&amp;E File Name:</b>	WMP-Discovery2026-2028_DR_SPD_013-Q002
<b>Request Date:</b>	August 11, 2025
<b>Requester DR No.:</b>	CONF-SPD-PGE-WMP2026-013
<b>Requesting Party:</b>	Safety Policy Division
<b>Requester:</b>	Edwin Schmitt
<b>Date Sent:</b>	August 21, 2025

**SUBJECT: WORK ORDER DATA (SPD-PGE-WMP2026-013)**

**QUESTION 002**

“WMP-Discovery2026-2028\_DR\_SPD\_001-Q019Atch01.xlsx” reports 5185 Priority As associated with “patrol inspections” or “detailed inspections” in 2023. However, PG&E’s response titled “WMP-Discovery2023-2025\_DR\_SPD\_014-Q005Rev02Supp01.pdf” reports 1,419 Priority As created from patrols and detailed inspections. Additionally, “WildfireMitigationPlansDiscovery2023\_DR\_OEIS\_023-Q001” appears to show a separate set of value of Level 1 (Priority As) from inspections. Explain the differences between the documents and correct as necessary.

**ANSWER 002**

Table 1

Document 1	WMP-Discovery2026-2028_DR_SPD_001-Q019Atch01.xlsx
Document 2	WMP-Discovery2023-2025_DR_SPD_014-Q005Rev02Supp01.pdf
Document 3	WildfireMitigationPlansDiscovery2023_DR_OEIS_023-Q001

PG&E’s response regarding patrol inspection A-priority (Level 1) findings is consistent across the three documents. Table 2 and its footnotes below demonstrate this consistency.

PG&E’s response regarding detailed inspection A-priority (Level 1) findings in Document 2 (WMP-Discovery2023-2025\_DR\_SPD\_014-Q005Rev02Supp01.pdf) is incorrect. The correct value as of August 20, 2025 is 4,817, not 1,319<sup>1</sup>.

---

<sup>1</sup> Please note that Document 2 reports 1,319 A-priority tags associated with Detailed Ground Inspections (WMP 2023-2025 §8.1.3.2.1).

Document 2 provided an incorrect value with regard to detailed inspection A-priority (Level 1) findings because of the methodology used to identify overhead tags. The value provided above uses the correct methodology used in Documents 1 and 3. PG&E plans to resubmit Document 2 (WMP-Discovery2023-2025\_DR\_SPD\_014-Q005Rev02Supp01.pdf) with corrected values by September 1, 2025. Full 2024 values will be provided rather than the year-to-date values provided in the July 2024 data response.

Table 2<sup>1</sup>

Inspection Program	Document 1 A-Priority (Level 1) Conditions Identified in 2023	Document 2 A-Priority (Level 1) Conditions Identified in 2023	Document 3 A-Priority (Level 1) Conditions Identified in 2023 <sup>4</sup>
Patrol Inspection	368	N/A <sup>3</sup>	368
Detailed Inspection <sup>2</sup>	4,817	<del>4,319</del> 4,817	4,817

Table Notes:

1. A-priority (Level 1) notifications that match QDR Methodology used for Document 1. Value includes notifications cancelled subsequently as part of work planning and execution processes.
2. Detailed inspection refers to detailed inspections conducted by PG&E's ground inspection plan. Any values reported exclude the aerial pilot program and aerial inspection programs.
3. Patrol inspection information was not provided in Document 2.
4. Document 3 presents data as find rates, which are the number of findings divided by the number of inspections. For patrol, the 0.04% find rate in the data response was derived from dividing 368 findings by 917,767 patrols. For inspections, the 0.88% find rate in the data response was derived from dividing 4,817 findings by 544,492 inspections.