

PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigations Plans Discovery 2026-2028
Data Response

PG&E Data Request No.:	SPD_013-Q005
PG&E File Name:	WMP-Discovery2026-2028_DR_SPD_013-Q005
Request Date:	August 11, 2025
Requester DR No.:	CONF-SPD-PGE-WMP2026-013
Requesting Party:	Safety Policy Division
Requester:	Edwin Schmitt
Date Sent:	August 14, 2025

SUBJECT: WORK ORDER DATA (SPD-PGE-WMP2026-013)

QUESTION 005

Identify any ignitions from 2014-2024 associated with assets where PG&E had an existing corrective notification at the time of the ignition which PG&E attributes as causally connected to the ignition in the same format as “WMP-Discovery2026-2028_DR_SPD_001-Q014Atch01.xlsx”

- a. Include one additional column that includes the existing corrective notification
- b. Include one additional column which identifies the FDA associated with the ignition.
- c. Include one additional column which identifies the priority of the tag.
- d. Include one additional column which identifies the creation date of the tag.

ANSWER 005

Please note that PG&E did not collect data regarding tags related to ignitions prior to 2020. Accordingly, PG&E is providing the requested data from 2020-2024.

PG&E has identified 19 CPUC-reportable ignitions where the failure mode associated with the fire was specifically captured in the scope of an EC or LC corrective notification created prior to, and still open at, the ignition event. Please see “WMP-Discovery2026-2028_DR_SPD_013-Q005Atch01.xlsx.” Please note that PG&E has determined that the conditions identified by the provided corrective notifications are likely related to the failure mode of an ignition event but cannot definitively determine causality.