

**PACIFIC GAS AND ELECTRIC COMPANY**  
**Wildfire Mitigations Plans Discovery 2026-2028**  
**Data Response**

|                                   |  |
|-----------------------------------|--|
| <b>PG&amp;E Data Request No.:</b> | SPD_013-Q006                           |
| <b>PG&amp;E File Name:</b>        | WMP-Discovery2026-2028_DR_SPD_013-Q006 |
| <b>Request Date:</b>              | August 11, 2025                        |
| <b>Requester DR No.:</b>          | CONF-SPD-PGE-WMP2026-013               |
| <b>Requesting Party:</b>          | Safety Policy Division                 |
| <b>Requester:</b>                 | Edwin Schmitt                          |
| <b>Date Sent:</b>                 | August 21, 2025                        |

**SUBJECT: WORK ORDER DATA (SPD-PGE-WMP2026-013)**

**QUESTION 006**

Provide an updated version of “WMP-Discovery2026-2028\_DR\_SPD\_001-Q016Atch01.xlsx” which includes data from 2020-2024.

- a. Include one additional column which includes the creation date of original tag.
- b. Include one additional column which includes the FDA of the original tag. If the tag has additional FDAs, include these FDAs in a second additional column.
  - i. If in all cases, the FDAs matches the FDA in Question 1e, confirm this in the response, and this column may be omitted.

**ANSWER 006**

Please see attachment “*WMP-Discovery2026-2028\_DR\_SPD\_013-Q006Atch01.xlsx*” for 2020-2024 Level 1 corrective notifications associated with overhead distribution assets where PG&E had an existing corrective notification at the time of failure. The following 4 columns of data have been added per request and to match the data presented in response to Question 007: corrective notification date, corrective notification primary FDA, correction notification other FDAs, and Level 1 (A-tag) date.

Due to the volume of data, the method used to derive this data defines “causally connected” as having a Level 1 (emergency) tag, attributed to an equipment failure associated with the primary indicator on the same electric facility as a non-compliance (primary or otherwise) in the open maintenance tag. As this is a data pull and each event has not been desktop reviewed, there may be cases where the associated notification was not causal—for example, an instance in which a pole with two crossarms and an open tag on crossarm 1 experiences a failure of crossarm 2. Similarly, there may be cases where causally connected notifications are excluded—for example, an instance in which a pole fails due to a broken/damaged guy which had an existing notification. Details on the filtering procedure are included in “*WMP-Discovery2026-2028\_DR\_SPD\_013-Q006Atch01.xlsx*”.