

**PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigations Plans Discovery 2026-2028
Data Response**

PG&E Data Request No.:	SPD_001-Q013
PG&E File Name:	WMP-Discovery2026-2028_DR_SPD_001-Q013
Request Date:	April 15, 2025
Requester DR No.:	SPD-PGE-WMP2026-001
Requesting Party:	Safety Policy Division
Requester:	Edwin Schmitt
Date Sent:	April 25, 2025

SUBJECT: OUTAGES, PRIORITY A, MITIGATION EFFECTIVENESS AND WBCA (SPD-PGE-WMP2026-001)

QUESTION 013

Identify any ignitions in 2024 associated with assets where PG&E had an existing corrective notification at the time of the ignition. Provide a spreadsheet listing each such ignition (as rows) in the same format as that provided to the CPUC in the annual CPUC Fire Ignition Data (see this website for the publicly available version: Wildfire and Wildfire Safety).

- a. Include one additional column that includes the corrective notification (i.e., work order or tag).

Answer 013

- a. PG&E observed 166 CPUC-reportable ignition events in 2024 associated with equipment failure. We were able to identify 20 CPUC-reportable ignitions where the suspected cause was equipment failure, and the support structure associated with the location of the fire had an open EC or LC notification at the time of the ignition event.

Please see “*WMP-Discovery2026-2028_DR_SPD_001-Q013Atch01.xlsx*” for the information associated with those 20 fires.