

# EV Customer Application Requirements

## PRE-ASSESSMENT

\*Engineering Advance (EA) is \$3,500 per site/city block

### Attachments and/or information needed are:

- Application Number
- Project Address
- Panel size and voltage
- Map of meter location and transformer location
- Loading information (including electrical load per charger, number of chargers, and ramp up schedule, if applicable)
- Cut sheets of chargers
- Provide photos if available*

## ESTIMATE

### Attachments and/or information needed are:

**Site Plan (AutoCAD)** - The items below are required information that must be visible in the site plan.

- Water Line
- Sewer Line
- Grease Traps
- Drainage (including bio-swales)
- Phone Lines
- Streetlight(s)
- Any Existing Utility Facilities
- Any Existing Easements
- Private Electrical Circuits
- Irrigation Line
- Landscape Improvement eg. trees
- Proposed improvements that will change any of the items listed above
  - Single line diagram
- Provide the Requested Design Completion Date