

**PACIFIC GAS AND ELECTRIC COMPANY**  
**Wildfire Mitigation Plans**  
**Rulemaking 18-10-007**  
**Data Response**

PG&E Data Request No.:	CalAdvocates_038-Q09		
PG&E File Name:	WildfireMitigationPlans_DR_CalAdvocates_038-Q09		
Request Date:	February 16, 2021	Requester DR No.:	CalAdvocates-PGE-2021WMP-04
Date Sent:	February 19, 2021	Requesting Party:	Public Advocates Office
PG&E Witness:		Requester:	Tyler Holzschuh

The following questions relate to PG&E's 2021 wildfire mitigation plan (WMP).

**QUESTION 09**

- a) Is the Girvan circuit (associated with the Zogg Fire) a single-grounded distribution line or a multigrounded distribution line?
- b) Please provide the time-current curves for the two reclosers upstream of the Zogg Fire ignition site

**RESPONSE 09**

- a) The Girvan circuit is a 3-wire distribution circuit that is uni-grounded (single) at the substation.
- b) Please see WildfireMitigationPlans\_DR\_CalAdvocates\_038-Q09-Atch01 and WildfireMitigationPlans\_DR\_CalAdvocates\_038-Q09-Atch02.