



**CONNECTORS FOR INSULATED CABLES
UNDERGROUND DISTRIBUTION SYSTEMS**

015251

Asset Type: Electric Distribution **Function:** Design and Construction

Issued by: Lisseth Villareal (LDV2) *Lisseth Villareal* **Date:** 08-15-17

Rev. #06: This document replaces PG&E Document 015251, Rev. #05. For a description of the changes, see Page 39.

Purpose and Scope

This document provides application and ordering information for cable connectors and terminals for use in underground distribution systems.

General:

This document applies to connectors for copper-to-copper, copper-to-aluminum, and aluminum-to-aluminum conductors. The use of aluminum conductors and the necessity of splicing aluminum-to-copper presents some specific problems as follows.

1. All connectors shall meet the requirements of **ANSI C119 Class A**.

2. Oxide Film

Unlike copper, aluminum is normally covered with a thin, hard film of invisible aluminum oxide. This film is a good insulator and forms immediately whenever aluminum is exposed to air. Therefore, aluminum connectors must meet the following requirements.

- A. Connectors should exert sufficient pressure on the cable to break through the oxide film.
- B. Connectors should exert approximately equal pressures on all strands.

3. Thermal Expansion and Plastic Flow

The difference in the thermal expansion of copper and aluminum must be addressed. Aluminum expands and contracts approximately 38% more than copper with the same temperature change. Copper connectors and copper cables expand together as do aluminum connectors and aluminum cables.

If copper connectors are used on aluminum cables, the aluminum cable expands more than the copper connector. As the temperature rises this causes the aluminum to extrude out of the connector. When the joint cools, the copper connector cannot shrink to fit the reduced diameter of the aluminum conductor. This cycle, repeated over time, results in loose connections and high resistance joints. Therefore, it is important to use connectors that have the same coefficient of expansion as the cable. For example, copper connectors with copper cable and aluminum connectors with aluminum cable.

Aluminum-to-copper connections must be made with special aluminum connectors designed to run cooler than the copper conductor and compensates for the difference in the coefficient of expansion. These connectors have a larger mass than standard aluminum connectors.

4. Corrosion

- A. **Electrolysis:** The third characteristic of aluminum that affects connectors is not peculiar to aluminum alone but is common to all metals. Aluminum in contact with another metal in the presence of moisture will have an electrolysis action.

This problem exists in the connection of aluminum-to-copper, and the electrolysis action causes corrosion of the anode material (aluminum), leaving the cathodic material (copper) undamaged.

- B. **Chemical:** Moisture in the absence of air reacts with aluminum forming aluminum hydroxide, which, in a very short time, will seriously corrode the aluminum material.

It is of extreme importance that aluminum conductors and connectors installed underground be free of moisture. Special care must be used to prevent moisture from entering into underground splices by using an inhibitor, and carefully and correctly taping or sealing splices.

**Connectors for Insulated Cables
Underground Distribution Systems**

5. General Rules for Battery Presses.

- A. A 6-ton in-line or pistol grip battery-powered press is equivalent to the older mechanical hand tools used for pressing connectors - for example, the Burndy MD6-8 tool.
- B. A 6-ton tool uses the same dies and the same number of compressions that the mechanical hand tool does.
- C. If the connector is stamped with a die designation of HYD, it means a 12-ton tool is necessary with a U die. In the past only 12-ton presses were hydraulic. Examples:
 - A Kearney 303 connector shows “HYD O DIE”. This means a 12-ton tool with a U-O die (with 1 compression) is required. An O die in a 6-ton tool is not sufficient.
 - A Kearney 308 connector shows “HYD D OR D3 DIE”. This means a 12-ton tool with a U-D or U-D3 die (with 1 compression) is required.
- D. If the connector is stamped with a die designation of HAND or MEC, it means a 6-ton tool can be used with a W die. Example:
 - A Kearney 302 connector shows “HYD B – MEC K”. This means a 6-ton tool with a W-KK die (with 3 compressions) can be used or a 12-ton tool with a U-B die (with 1 compression) can be used. The 6-ton tool is much lighter than the 12-ton tool and is preferred for ergonomics.

6. For information on multi-tap splices for 600V insulated cable refer to [Document 036640](#)

7. All information for field drilling connectors has been removed in this revision (16). Use range taking connectors (shearbolt) when dealing with non-standard cable sizes.

8. Ground terminal connector has been replaced with a more robust design. See Table 10 on page 14.

Application

1. There are four general types of connectors: solder sweated, bolted, compression, and shear-bolt. The advantages, disadvantages, and normal application of these four types of connectors are described in Table 1.
2. Compression tap connectors, Pages 15 through 18, are the preferred connectors for residential and light commercial installations.

Table 1 UG Connector Comparison

Connector Type	Application	Advantages	Disadvantages
Solder Sweated Split Tinned Copper ¹	For Copper-to-Copper Straight Connections (Page 13)	<ul style="list-style-type: none"> • Inexpensive • Excellent Electrical Connection 	<ul style="list-style-type: none"> • Special Tool Required • Must Be Sweated on (increasing time and labor) • Limited to Copper Cables
Bolted	Terminals and Tap Connections Rated Less Than 600 V (Pages 14, 28, 30, 32, and 36 - 37)	<ul style="list-style-type: none"> • Fast and Easy Install • Wide Range of Sizes • No Special Tools Required • Low Cost 	<ul style="list-style-type: none"> • More Difficult to Seal
Compression (preferred)	Straight and Tap Connections for Copper and Aluminum Cables (Pages 8 - 12, 17 - 27, 33 - 35, and 38)	<ul style="list-style-type: none"> • Preferred Electrical Connection • Ease of Installation 	<ul style="list-style-type: none"> • Requires Specific Tools and Dies
Shearbolt	Straight and Y & H Cold-Shrink Splices	<ul style="list-style-type: none"> • Range Taking • Excellent Electrical Connection • Ease of Installation • No Special Tool Required 	<ul style="list-style-type: none"> • More Expensive

1. Use only with paper-insulated lead-covered (PILC) Cable.

Connectors for Insulated Cables Underground Distribution Systems










References	Location	Document
Joints for 15 kV Three-Conductor Paper-Insulated Lead-Covered Cable for Use on 12 kV Circuits	UG-2: Splices	022709
Method of Terminating 15 kV Paper Insulated Lead-Covered Cable	UG-2: Terminations	022820
Splice for Leaded to Non-Leaded Cable	UG-2: Splices	022824
Splice for 5 kV and 15 kV Type RO&N Cable Single Conductor Shielded	UG-2: Splices	022827
Method of Terminating 5 kV Single Conductor Non-Leaded Rubber-Type Cable	FRO: UG-1 Terminations	022828A
Method of Terminating 15 kV and 22 kV Single Conductor XLPE-PVC and EPR-PVC Cables (compound filled pothead)	FRO: UG-1 Terminations	022829A
Street Light Cable Splices	UG-2: Splices	022830
Method of Terminating Single Conductor Non-Leaded Varnished Cambric Insulated Cables	FRO: UG-1 Terminations	022831A
Splice for Varnished Cambric Insulated Cable With Flameproof Jacket	UG-2: Splices	022832
Installation of Cable Risers on Wood Poles	OH: Risers/UG-1 Terminations	027742
Current Transformers	ELS	028114
Distribution Transformer Requirements for Vault Installation	FRO: UG-2: Transformers	030362B
Installation of Single-Phase 12 kV Pad-Mounted Transformer Underground Residential Areas	FRO: UG-1 Transformers	032768A
Joints for 15 kV & 25 kV Single Conductor Paper Insulated Lead-Covered Cable for Use on 12 kV & 22 kV Circuits	UG-2: Splices	033585
10 Arrangement 12 kV Switch and Bus Cells	ELS	033701
Distribution Transformer Requirements, Single-Phase and Three-Phase, Overhead-Type	OH: Transformers	034963
Installation of Single-Phase 7,200 V Pad-Mounted Transformer Underground Residential Areas	FRO: Transformers	034978A
Single-Phase, Subsurface, Round Transformers	UG-1: Transformers	035313
Installation of Subsurface, Load-Break, and Dead-Break Primary Junction	UG-1: Switches	035380
Multi-Tap Splice for 600-Volt Insulated Cables	UG-1: Splices	036640
Installation of 200-Amp, Subsurface Sectionalizing Switches	UG-1: Switches	039954
Cables for Underground Distribution	UG-1: Cable	039955
Compression-Type Connectors for Overhead Distribution and Transmission	OH: Conductors	041010
Splices for 15 kV and 22 kV XLP-PVC and EPR-PVC Cable Single-Conductor Shielded	ELS	041583
Termination for 15 and 22 kV XLP-PVC, EPR-PVC, and XLP-CONC-PVC Cables Single Conductor Shielded	ELS	041584
Installation of Live-Front, Low-Profile, Single-Phase, Pad-Mounted Transformers	UG-1: Transformers	042762
Installation of Low Profile Single-Phase 6.9 kV Pad Mounted Transformer Underground Residential Systems	ELS	042765
Installation of Three-Phase, Radial-Style, Pad-Mounted Transformers	UG-1: Transformers	043817
Splices for 15 kV and 22 kV Concentric-Type Cable (PE-CONC, XLP-CONC and XLP-CONC-PVC)	ELS	043901

**Connectors for Insulated Cables
Underground Distribution Systems**

References (continued)	Location	Document
Method of Terminating 15 KV and 22KV I/O & Smaller Concentric Type Cable – XLP-CONC-PVC & XLP-CONC	ELS	043902
Installation of Loop-Style, Three-Phase, Pad-Mounted Transformers	UG-1: Transformers	045291
Installation of Three-Phase, 600-Amp, Subsurface Sectionalizing Switches	UG-1: Switches	050859
Straight and Tap Splice for 600 Volt Insulated Cable	UG-1: Splices	051034
600-Amp Separable Insulated Connectors	UG-1: Terminations	051071
Premolded 600-Amp Splices for Primary Underground Cables	UG-1: Splices	053732
Pad-Mounted Transformers Installed Indoors	UG-1: Transformers/Greenbook/EMWP	057521
Single-Phase, Dead-Front, and Duplex, Pad-Mounted Transformer Installations	UG-1: Transformers	064308
Cold Shrink 600-Amp Splices for Primary Underground Cable	UG-1: Splices	066204
Fired Wedge Connectors for Primary and Secondary Distribution Lines	OH: Conductors	066194
24 kV 1/0 Cable Joint for Use on 22 kV Circuits, PILC Cables	ELS	306644
Straight Cold Shrink™ 15 KV Transition Splices	ELS	072152
Cold-Shrinkable Trifurcating 600-Amp 15KV Transition Splice	ELS	076245
Cold-Shrinkable Straight 600-Amp 15 KV Transition Splice	ELS	076246
Medium Voltage Y and H Splices for Manhole Applications	UG-2: Splices	076261
Grounding of Tape Shield and Flat Strap Neutral Cables	UG-1: General	076264

**Connectors for Insulated Cables
Underground Distribution Systems**












Table 2 Connectors – Pictorial Index

Connector	Type		Page	Application	
				Cable	Document ¹
	Straight Connectors	Compression	8 to 9	Copper-to-Aluminum	022824 022827 022830 041583
			10 & 15	Aluminum-to-Aluminum	043901 051034
			11 to 13	Copper-to-Copper	022709 022824 022827 022830 022832 033585 041583 043901 051034
		Shearbolt	2	Bi-Metal Copper or Aluminum	066204 072152 076245 076246
	Split Connectors	Solder	13	Copper-to-Copper	022709 022824 022827 022830 022832 033585 041583 043901 051034
	Tap Connectors	Bolted	14	Copper-to-Copper (San Francisco and Oakland Network only)	051034
		Compression	15 to 20	Aluminum-to-Aluminum or Aluminum-to-Copper (for secondary conductors)	
			19 to 21	Copper-to-Copper (for secondary conductors)	
	Terminal Connectors		22 to 27	Aluminum-to-Copper (for transformer spade terminals)	032768A 034978A 042762 042765 043817 045291

¹ For a description of the application document, see “References” on Page 3.

Connectors for Insulated Cables Underground Distribution Systems

Table 2 Connectors – Pictorial Index (continued)

Connector	Type		Page	Application	
				Cable	Document ¹
	Terminal	Compression	4	Bi-Metal Copper or Aluminum	051071
		Shearbolt	4		076261
	Terminal Connectors	Bolted	28 to 31	Copper (for transformer spade terminals, non-preferred)	028114 030362B 033701
	Terminal Connectors	Bolted	32	Copper (transformer terminals)	028114 030362B 033701
	Ground Terminal	Bolted	14	Copper (equipment tank grounds and primary concrete enclosures)	035313 035380 039954 050859
	Tap Connectors	Bolted	32	Copper-to-Copper	022828A 022829A 022831A
			32	Copper-to-Aluminum	042762 042765
		Compression	33	Aluminum-to-Aluminum Copper-to-Aluminum Copper-to-Copper	041583 043901
	Slip-Fit Connectors	Bolted	36	Aluminum or Copper	064308
	Multiple Transformer Terminal	Bolted	37	Aluminum or Copper	043817 045291
	Pin Terminals	Compression	38 – 39	Aluminum or Copper	027742 041584 043902
Tool and Die Information	Compression	7	Copper Cables Aluminum Cables	-	
		8			

¹ For a description of the application document, see “References” on Page 3.

Connectors for Insulated Cables Underground Distribution Systems

Applications of Straight Connectors Compression-Type (copper-to-aluminum)

Notes

1. Circular dies should be used on all primary and secondary splices. In these small sizes, the indent-type dies seriously distort the connector.
2. Tool index numbers may be applied to in-line cable-to-cable limiters.
3. For the correct number of crimps, see the appropriate numbered document or the manufacturer's instructions on the package. When the information is not available, make as many non-overlapping crimps as possible without going over the outer end.
4. Pages 8 through 14 and 17 through 22 show compression-type connectors used to connect copper conductors to aluminum conductors. These connectors may also be used to connect aluminum-to-aluminum conductors.
5. Table 3 on Page 8 and Table 4 on Page 9 show compression splice connectors which accommodate specific conductor sizes.
6. Use a clean wire brush to remove oxides from the conductors prior to installing the connectors.
7. After the connector has been pressed on, insulating and sealing of pressed connections is accomplished in the same manner as shown in [Document 051034](#). Special attention must be given to the following:
 - A. Both ends of the aluminum connector should contain oxide inhibitor. Connectors shown in Table 3 on Page 8 and Table 4 on Page 9 are prefilled with inhibitor. See [Document 028852](#) for approved oxide inhibitors.
 - B. After the connector has been pressed on the cable, excess oxide inhibitor must be wiped from the connector and conductor surface.
 - C. Use special care to ensure a moisture-proof splice.
8. Solder-type connectors must not be used on aluminum conductors. This type of connection is only allowed on PILC cable.
9. If several insulated aluminum conductors are to be connected to one insulated copper conductor, each aluminum conductor must first be spliced to a short length of copper conductor so that the multiple connection can be made with all copper conductors. This multiple connection may be a tee tap (or several tee taps) as shown in [Document 051034](#).
10. Special care must be used to prevent moisture from entering through the copper strands when connecting a bare stranded copper conductor to an insulated aluminum conductor (e.g., copper-to-aluminum neutral connection). See Figure 1 below for these connections.




Figure 1
Connection Between Bare and Insulated Conductor

Connectors for Insulated Cables Underground Distribution Systems

Straight Connectors Compression-Type (predrilled) Copper-to-Aluminum




Figure 2
Overall Dimensions




Figure 3
View After Connector Installation
(for Figure 2)

Table 3 Compression-Type Connectors – Predrilled

Conductor Size – AWG or kcmil		Connector Dimensions (inches)				Manufacturer and Catalog Numbers			6-Ton Tool Die # ⁵ 12-Ton Tool Die # 15-Ton Tool Die #	Connector Code
A ¹ (Cu or Al)	B (Al)	AA	BB	L ²	OD	Burdny	Richards	Homac		
4	2	1.03	1.03	2.75	0.65	See Document 028852			W-BG U-BG U-BG ⁴	305558 ³
2	2					YR1CA2CCAG1	ALCR 8-7	SAC1R2		305559 ³
2	1/0					See Document 028852				305569
2	2/0	1.56	1.56	4.00	0.91	YR26A2CCAG1	ALCR 10-7	SAC2/0 R2	W249 U249 U249 ⁴	305571
2/0	2/0					YS26UG2	ALC 10	SAC2/0		305581
2/0	3/0					YR27A26CAG1	ALCR 11-10	SAC3/0 R2/0		305582
2/0	4/0					YR28A26CAG1	ALCR 12-10	SAC4/0 R2/0		305585

¹ Maximum copper conductor size.

² These dimensions may vary slightly among the various suppliers.

³ These connectors are overhead-type insulated service sleeves. The insulation on these sleeves does not provide an adequate seal for underground application. These sleeves must be insulated and sealed as shown in [Document 051034](#) as if they were bare.

⁴ A U-die adapter must be used when utilizing U-dies in a 15-Ton press.

⁵ Within this column, the first entry corresponds to a 6-ton press tool, the second entry corresponds to a 12-ton press tool, and the third entry corresponds to a 15-ton press tool.

**Connectors for Insulated Cables
Underground Distribution Systems**

Straight Connectors Compression-Type (predrilled) Copper-to-Aluminum (continued)

Table 4 Compression-Type Connectors – Predrilled

Conductor Size – AWG or kcmil		Dimensions (inches)				Manufacturer and Catalog Numbers			6-Ton Tool-Die # ⁴ 12-Ton Tool Die # 15-Ton Tool Die #	Connect- or Code
A ¹ (Cu or Al)	B (Al)	AA	BB	L ²	OD	Burdny	Richards	Homac		
250	250	1.86	1.86	4.62	1.12	YS29UG1	ALC 13	SACB250	– U31ART U31ART ³	305586
250	300					YR30A29CAG1	ALCR 14-13	SAC300R250		305602
250	350					YR31A29CA	ALCR 15-13	SAC350R250		305127
250	400	2.55	2.55	6.19	1.62	YR32A29CAG1	ALCR 16-13	SACL400R250	– UI39ART P39ART	305604
500/600	500					YS34APGE	ALC 18	SACL500		305108
500	600					YR36A34CA	ALCR 20-18	SAC600R500		305129
500	700, 750					YR39A34CA	ALCR 25-18	SAC750R500		305107
500	800	2.91	2.91	7.16	1.84	YR40A34CAG1	ALCR 24-18	SACF800R500	– – P44ART	305606
750	1,000					YR44AG3	ALCR 28-23	SAC1000R750		305023
For Circuits Above 5 kV										
4	2	1.50	1.50	3.57	0.65	YR2CA4CCATG1	OATCR7-5	SAC2R4	W-BG U-BG U-BG ³	305607
2	2					YS2CUTG1	OATC 7	SAC2		305608
2	1/0					YR25A2CCATG3	OATCR9-7	SAC1/0R2		305609
2/0	4/0	2.08	2.08	4.82	0.91	YR28A26CATG2	OATC 12-10	SAC4/0R2/0	W249 U249 U249 ³	305610
250	350	2.61	2.96	6.66	1.12	YR31A29CAT	OATC15-13	SAC350R250	– U31ART U31ART ³	305143
500/600	700, 750	3.75	4.19	9.41	1.62	YR39A34CAT	OATC23-18	SAC750R500	– U39ART P39ART	305403
750	1,000	4.10	4.10	9.09	1.84	YR44ATG1	OATC28-13	SAC1000R750	– – P44ART	305611

¹ Maximum copper conductor size.

² These dimensions may vary slightly among the various suppliers.

³ A U-die adapter must be used when utilizing U-dies in a 15-Ton press tool.

⁴ Within this column, the first entry corresponds to a 6-ton press tool, the second entry corresponds to a 12-ton press tool, and the third entry corresponds to a 15-ton press tool.

Notes

1. Connectors shall be pre-filled with an approved oxide inhibitor.
2. All connectors shall have an oil stop.

Connectors for Insulated Cables Underground Distribution Systems

Straight Connectors Compression-Type (aluminum-to-aluminum)




Table 5 Dimensions and Ordering Information – Aluminum-to-Aluminum (Figure 4)

Conductor Size AWG or kcmil	Refer to	Dimensions (inches)			Manufacturer and Catalog Number			6-Ton Tool Die # ⁴ 12-Ton Tool Die # 15-Ton Tool Die #	Code
		L	B	OD	Burndy	Richards	Homac		
2	Figure 5 On Page 11	2.75	1.18	0.65	See Document 028852			W-BG	305559 ¹
1/0		2.75	1.18	0.65				U-BG	305563 ¹
4/0		3.30 ²	1.54 ²	0.91	YS28AG9	ALC12	AC4/0	W249 U249 U249 ³	305616
350		6.97	3.38	1.12	YS31AY	ALC15	AC350	– U31ART U31ART ³	305148
700/750		8.28	4.00	1.62	YS39AY	ALC23	AC750	– – U39ART P39ART	305150
1,000		10.81	5.25	1.84	YS44AY	ALC28	AC1000	– – P44ART	305618

¹ These connectors are overhead-type insulated service sleeves (see [Document 028852](#)). The insulation on these sleeves will not provide an adequate seal for underground application. These sleeves must be insulated and sealed as shown in [Document 051034](#) as if they were bare.

² For Burndy & Richards, Dimension L = 2.34", B = 1.09".

³ A U-die adapter must be used when utilizing u-dies with 15-Ton press.

⁴ Within this column, the first entry corresponds to a 6-ton press tool, the second entry corresponds to a 12-ton press tool, and the third entry corresponds to a 15-ton press tool

Notes

1. Connectors shall be pre-filled with an oxide inhibitor.
2. Connectors shown in Table 5 above are not suitable substitutes for the compression connectors supplied in the 3M pre-molded splice kits. The connector ODs supplied in the splice kits are larger than normal to provide a heat sink and facilitate sliding the pre-molded housing back and forth.
3. These connectors are aluminum unplated finished and must be used only with aluminum cables.

**Connectors for Insulated Cables
Underground Distribution Systems**

Straight Connectors Compression-Type (copper-to-copper)




Figure 5

Table 6 Straight Connectors – Compression-Type – Copper-to-Copper (Figure 4)

Conductor Size AWG or kcmil	Dimensions (inches)		Manufacturer and Catalog Number				6-Ton Tool Die # ⁴ 12-Ton Tool Die # 15-Ton Tool Die #	Code
	Length (L)	OD	Burndy	Richards	Homac	Dossert		
4	2.38	0.34	YSP4CT	OCC5	PC-4	DPCP 4	W4CRT U4CRT U4CRT ³	305164 ¹
2 ²	2.62	0.42	YSP2CT	OCC7	PC-2	DPCP 6	W2CRT U2CRT UWCRT ³	305165 ¹
2/0	2.21	0.56	YS26T	CC10	TC-2/0	DPC 13-T	W26RT U26RT	305283
2/0	3.13	0.56	YSP26T	OCC10	PC-2/0	DPCP 13	U26RT ³	305167 ¹
4/0	2.39	0.69	YS28T	CC12	C-4/0	DPC 21-T	W28RT U28RT U28RT ³	305285
250	3.38	0.75	YSP29T	OCC13	PC-250	DPCP 25	– U29RT	305429 ¹
250	3.38	0.75	YS29	CC13	C-250	DPC 25	U29RT ³	305202
500	4.62	1.06	YSP34T	OCC18	PC-500	DPCP 50	– U34RT	305428 ¹
500	4.63	1.06	YS34	CC18	C-500	DPC 50	U34RT ³	305203
750	4.23	1.3	Y39T	CC23	TC-750	DPC 75-T	– U39RT U39RT ³	305488
1,000	6.13	1.50	YS44	CC28	C-1000	DPC 100	– – P44RT	305480
1,500	6.5	1.84	YS46	CC30	C-1500	DPC 150	– – P46RT	305511

¹ These connectors have oil stops. These are more costly connectors and should only be used for splicing P&L cable to rubber or polyethylene insulated cables.

² For #2 Solid, use Burndy 162 die index. Refer to Table 20 on Page 19 for Die ordering information.

³ A U-die adapter must be used when utilizing u-dies with 15-Ton press.

⁴ Within this column, the first entry corresponds to a 6-ton press tool, the second entry corresponds to a 12-ton press tool, and the third entry corresponds to a 15-ton press tool.

Straight Connectors Compression-Type (copper-to-copper)(continued)

Notes

1. For material and finish information refer to “Specifications for Straight Compression Type Connectors for Insulated Copper Conductors”.
2. Connectors shown in Figure 5 on Page 11 are to be used to connect cables of up to 35 kV rating or lower, and can be used on bare cables where such cables will not be subjected to tension.
3. An indentor type compression die (clacker) should not be used on #4 or #2 AWG size connectors because it excessively distorts the connector.
4. Round the sector cable with rounder tool.

**Connectors for Insulated Cables
Underground Distribution Systems**

Straight Connectors Solder-Type (copper-to-copper)




Figure 6

Table 7 Straight Connectors – Split Tinned-Type – Copper-to-Copper, All Voltages (Figure 6)

Cable Size AWG or Kcmil (round or compact sector)	Nominal Dimensions – Inches					Standard Package	Burdly Part Number	Richards	Code
	A ID	B OD	C (wall thickness)	D (slot width)	E (length)				
8	5/32	3/16	1/32	1/32	1-1/2	200	SS8C8C	RSS2	305041
6	3/16	1/4	1/32	1/32	1-1/2	200	SS6C6C	RSS3	305042
4	7/32	5/16	1/32	1/32	2	100	SS4C4C	RSS5	305043
2	9/32	3/8	1/32	1/32	2	100	SS2C2C	RSS7	305044
1/0	3/8	1/2	1/16	1/16	2	100	SS2525	RSS9	305045
2/0	13/32	9/16	1/16	1/16	2	100	SS2626	RSS10	305046
3/0	15/32	5/8	1/16	1/16	2	100	SS2727	RSS11	305059
4/0	17/32	23/32	1/16	1/16	2-1/2	50	SS2828	RSS12	305047
250	9/16	25/32	3/32	1/8	2-1/2	50	SS2929	RSS13	305048
350	11/16	29/32	3/32	1/8	2-1/2	20	SS3131	RSS15	305324
400	23/32	31/32	1/8	1/8	3	10	SS3232	RSS16	305049
500	13/16	1-3/32	1/8	1/8	3	10	SS3434	RSS18	305050
600	29/32	1-3/16	1/8	5/32	3-1/2	10	SS3636	RSS20	305051
750	1-1/32	1-11/32	5/32	5/32	3-1/2	10	SS3939	RSS23	305052
1,000	1-5/32	1-9/16	3/16	7/32	4-1/2	1	SS4444	RSS28	305053
1,500	1-7/16	1-29/32	7/32	9/32	5	1	SS4646	RSS30	305054
2,000	1-21/32	2-7/32	1/4	9/32	6	1	SS4848	RSS32	305055

Notes

1. For material and finish refer to “Edison Electric Institute Specification TD 160 “Specifications for Solder-Sweated Split Tinned Copper Connectors”.
2. When splicing cables of different sizes, cut a sector from one half of the connector.
3. When tinning and sweating the connector onto the conductors:
 - A. Protect the insulation.
 - B. Wipe smooth, removing all sharp solder points.
4. Round the sector cable with a rounder tool.

Application

These connectors must be used only to tap splices 5,000 V and above on copper cable in sizes larger than #2 AWG.

Connectors for Insulated Cables Underground Distribution Systems

Bolted Connectors for Underground Network Systems

A. These copper alloy connectors are for making copper-to-copper current carrying connections on underground network secondary systems in San Francisco and Oakland.




Figure 7

Table 8 Split Bolt Connectors For Copper-to-Copper Connections (Figure 7)

Conductor Size AWG or kcmil		Nut Size D	Torque Inch-lbs. (ft./ lbs)	Code	Manufacturer and Catalog Number			
Solid	Stranded				Blackburn	Burndy	Penn-Union	Homac
10	10	7/16"	80 (7)	305026	9H	KS90	S-10-S	-
8	8	1/2"	80 (7)	305027	8H	KS15	S-8-S	E-8
6	8	11/16"	-	305028	6H	KS17	S-6-PGE	E-6
4	6	3/4"	-	305029	4H	KS20	S-4-PGE	E-4
2	4	7/8"	-	305030	2H	KS22	S-3-PGE	E-2
1	2	7/8"	-	305031	1H	KS23	S-2-S	-
2/0	1/0	1"	-	305032	10H	KS25	S-1/0-S	E-1/0
3/0	2/0	1-1/18"	385 (32)	305033	20H	KS26	S-2/0-S	E-2/0
4/0	3/0, 4/0, 250	1-5/16"	650 (54)	305034	40H	KS29	S-250-PGE	E-250




Figure 8

Table 9 Two Bolt Connectors for Copper-to-Copper Connections (Figure 8)

Conductor Size AWG or kcmil		Code	Manufacturer and Catalog Number					
Main Run	Min. Tap		Anderson	Blackburn	Burndy	Penn-Union	Dossert	Homac
4/0	6	305431	K-3	2B40	KVS28	VT-2	DSU21	-
250 to 350	1/0	305432	K-4	2B350	KVS31	VT-3	DSU35	TBC 350
400 to 500	2/0	305433	K-5	2B500	KVS34	VT-4	DSU50	TBC 500
600 to 750	4/0	305434	K-6	2B800	KVS40	VT-5	DSU80	TBC 800
800 to 1,000	4/0	305435	K-7	2B1000	KVS44	VT-6	DSU100	TBC 1,800

Notes

1. Connectors shown in Table 8 and Table 9 are for use on unshielded insulated cables rated 600 V or lower.
2. Connectors shown in Table 8 may also be used to connect unshielded streetlighting cable.
3. If necessary, double back on small size tap wires to obtain a tight fit.
4. The connectors described on this page can be used on bare cables where such cables will not be subjected to tension.
5. These connectors shall not be used in overhead applications.

Ground Terminal





Figure 9

Table 10 Ground Terminal (Figure 9)

Conductor Size AWG	Manufacturer and Catalog Number		Code
	Hubbell	H - J	
#4 Str. - 2/0	GC-208	AS1372-002	M301546

**Connectors for Insulated Cables
Underground Distribution Systems**

Tap Connectors Compression-Type (#6 through 400 kcmil aluminum-to-aluminum or aluminum-to-copper)



**Figure 10
H-Type Connector**

Table 11 Tap Connectors – Compression-Type – Aluminum-to-Aluminum or Aluminum-to-Copper (Figure 10) ¹

Conductor Size AWG or kcmil		Tap																	
		#6 Sol.	#4 Sol.	#4 Str.	#2 Sol.	#1 Sol.	#2 Str.	1/0 Sol.	1/0 Str.	2/0 Str.	3/0 Str.	4/0 Str.	250	266.8 Str.	336.4 Str.	350	397.5	400	
Run	#6 Sol.	Code 305507				-		-		-		-							
	#4 Sol.																		
	#4 Str.																		
	#2 Sol.																		
	#1 Sol.	Code 305509						-		-									
	#2 Str.																		
	1/0 Sol.																		
	1/0 Str.	Code 305519						-											
	2/0 Str.									Code 305510									
	3/0 Str.	Code 305830		Code 305831															
	4/0 Str.					Code 305520													
	250	-								Code 305833		Code 305834							
	266.8 Str.																		
	336.4 Str.							Code 305832											
350																			
397.5																			
Run	400	Code 305832						Code 305833		Code 305834									

¹ For required number of compressions, Refer to Table 13 on Page 16.

Table 12 Aluminum Compression Connectors for Secondary Connections to Streetlight Conductors

Conductor Size (AWG)		Tap	
		#10 Sol.	#8 Sol.
Run	#2 Str.	Code 305842	
	1/0 Str.		
	2/0 Str.		
	3/0 Str.	Code 305843	
	4/0 Str.		

**Connectors for Insulated Cables
Underground Distribution Systems**

Tap Connectors Compression-Type (#6 through 400 kcmil aluminum-to-aluminum or aluminum-to-copper) (continued)

Note

The material for these connectors is aluminum alloy.

Application

These connectors are used for straight splice or tap, residential and light commercial.

Table 13 Aluminum H-Type Compression Connectors

Tools and Dies Data				
Connector Code 1	6-Ton Tool		12-Ton Tool	
	Die	Required # of Compressions	Die	Required # of Compressions
305507	W-O	4	U-O	2
305509		5 ¹		
305510	W-D	5 ¹	U-D	2
305519				
305520				
305830		7		3
305831	-	-	U-N	2
305832				3
305833				
305834				
Connectors for Connection to Secondary Streetlight Conductors				
305842	W-O	4	U-O	2
305843	W-D	4	-	-

¹ These connectors are the same tap connectors shown in [Document 041010](#).

Note


1. Do not use the N Die with UT-15 tools
2. Use U-die adapter with U-dies when a 15-ton press tool is utilized.

**Connectors for Insulated Cables
Underground Distribution Systems**

**Tap Connectors Compression-Type for Secondary Conductors
(2/0 through 1000 kcmil aluminum-to-aluminum or aluminum-to-copper)**


Table 14 Tap Connectors – Compression-Type for Secondary Conductors

Conductor Size AWG or kcmil	Tap															
	2/0	3/0	4/0	250	268.8	300	397.5	500	600	636	700	715.5	750	900	1000	
Run	397.5	See Table 11 Page 15						Code 305522			-					
	500	Code 305521						Code 305522			-					
	600	Code 305521						Code 305522			-					
	636	Code 305524						Code 305526			Code 305537					
	700	Code 305524						Code 305526			Code 305537					
	715.5	Code 305524						Code 305526			Code 305537					
	750	Code 305524						Code 305526			Code 305537					
	900	Code 305524						Code 305526			Code 305537					
1,000	Code 305804		Code 305875			Code 305976					Code 305538					



Marking on Connector for Compression with R Die

**Figure 11
Order of Compression Sequence**



Position of Z Die on R Die Compression Markings

**Figure 12
Installation Instructions for Z Die**

Table 15 Ordering Data for Z Die for Use in UT-15 Hydraulic Tool

Die Designation	Code	Manufacturer and Catalog Number
Z	216248	Homac 15 CZ ¹

¹ T&B equivalent 15620.

Notes

1. The material of these connectors is aluminum alloy.
2. Two dies can be used for compressing the aluminum H-Type connectors listed in above Table 14. These are the R and Z dies. Some manufacturers refer to both dies while others designate only the R die on their connectors. Homac, the supplier of the UT-15 hydraulic head, has standardized on the Z die. Since this tool is standard on the System, the Homac Z die catalog number 15 CZ, has been specified for use in the UT-15 head for compressing all connectors listed in above Table 14. The Z die is slightly wider than the R die and will overlap the R die guide markings on the connectors.
3. When using the Z die on connectors which require three compressions, make the first compression in the center. The Z die will overlap the crimp location markings on the connector since these markings are based on the narrower R die. Then make a compression on each side of the center compression, keeping the die even with the outside edge of the connector and overlapping the previously made center compression.

When using the Z die on connectors which require four compressions, make the first two compressions in the center portion of the connector, overlapping the centerline of the connector on each compression as shown in Figure 12. Then complete a compression on each end, overlapping the previously completed center compression sufficiently to maintain the outer edge of the die flush with the end of the conductor.

Application

These connectors are used for straight splice or tap, residential and light commercial.

**Connectors for Insulated Cables
Underground Distribution Systems**

Tap Connectors Compression-Type for Secondary Conductors (copper-to-copper)

Table 16 YP-C-Tap (Figure-6 Type) (Figure 13) Copper Connectors



**Figure 13
Burndy YP-C-Tap Type**

Conductor Size AWG or kcmil		Tap											
		#6 Sol.	#4 Sol.	#4 Str.	#2 Sol.	#1 Sol.	#2 Str.	1/0 Sol.	1/0 Str.	2/0 Str.	3/0 Str.	4/0 Str.	
Run	#6 Sol.	Code 305844						-		Code 012086			
	#4 Sol.												
	#4 Str.												
	#2 Sol.												
	#1 Sol.												
	#2 Str.												
	1/0 Sol.	Code 305845						-					
	1/0 Str.												
	2/0 Str.												
	3/0 Str.												
	4/0 Str.												
	250												

Table 17 Die Information for YP-C (Figure-6 Type) Connectors (Figure 13)

Manufacture and Catalog Numbers		Die 1, 2	Connector Code	Required Number of Compressions
Brundy	Dossert	Die		
YP2C2	DC6	U-O	305844	1
YP29C26	DC25-13	U-D3	305845	1
YP28C28	-	U-D3	012086	1


¹ These dies use a 12-ton press tool.

² Refer to Table 24 on Page 21 for Die ordering information.

**Connectors for Insulated Cables
Underground Distribution Systems**

**Tap Connectors Compression Type for Secondary Conductors (copper-to-copper)
(continued)**

**Table 18 Blackburn, Homac, Kearney and Penn-Union H-Tap
Copper Connectors (Figure 14)**



**Figure 14
Blackburn, Kearney,
Homac, Penn-Union
H-Tap Type**

Conductor Size AWG or kcmil	Tap										
	#6 Sol.	#4 Sol.	#4 Str.	#2 Sol.	#1 Sol.	#2 Str.	1/0 Sol.	1/0 Str.	2/0 Str.	3/0 Str.	4/0 Str.
Run	#6 Sol.	Code									
	#4 Sol.	305243									
	#4 Str.	Code									
	#2 Sol.	305244									
	#1 Sol.	Code				Code					
	#2 Str.	305245				305246					
	1/0 Sol.										
	1/0 Str.										
	2/0 Str.										
	3/0 Str.			Code		Code		Code		Code	
4/0 Str.	-		3052147 ¹		305249		305846				

¹ Only the Kearney connector is currently approved for use with #6 solid using a U-D die

Table 19 Blackburn, Kearney, and Penn-Union Connectors

Connector Code	Blackburn Part No.	Kearney Part No.	6-Ton Tool		12-Ton Tool	
			Die	Required Number of Compressions	Die	Required Number of Compressions
305243 ¹	CF-44-1	301-82	W-KB	3	-	-
305244 ¹	CF-22-1	302-82	W-KK	3	-	-
305245	CF-102-1	304-82	-	-	U-O	1
305246	CF-1010-1	303-82	-	-	U-O	1
305247 ¹	CF-402-1	309-82	-	-	U-D	1
305249	CF-4010-1	308-82	-	-	U-D, D3	1
305846	CF-4040-1	307-82	-	-	U-D, D3	1

¹ Do not use with W-BG die for the connectors under M305243 and M305244 codes.

² Only the Kearney connector is currently approved for use with #6 solid using a U-D die.

Table 20 Ordering Data for 6-Ton Press Tool

Burndy Catalog Number	Die Code ¹	Burndy Catalog Number	Die Code ²
W-KB	202240	-	-
W-KK	202241	-	-
W-161	1208088	U-161	2791549
W-162	1208089	U-162	2702336
W-163	1208100	U-163	2755406

¹ These dies use 6-ton press tool.

² These dies use 12-ton press tool.

³ These dies are only available for purchase in SRM. The codes shown on this table are the SRM part number.

Notes

The material for connectors are on Pages 20 and 21 is copper alloy

Connectors for Insulated Cables Underground Distribution Systems

Application

Connectors are on Pages 20 and 21 are used for straight splice or tap.

Connectors for Splicing and Tapping Concentric Wires

Table 21 For Splicing and Tapping of XLP-Conc-PVC Cable Concentric Neutrals ²

Primary Cable Size AWG or kcmil Document 039955 ¹	2/0 Cu 1/0 Al 4/0 Al	350 Al	#2 Al	#4 Cu 250 Cu	#2 Cu	700 Al	500 Cu	1,000 Al
Conc. Size	8 – #14	9 – #14	10 – #14	11 – #14	17 – #14	18 – #14	13 – #12	16 – #12
2/0 Cu 1/0 Al 4/0 Al	8 – #14	Code 305244		Code 305245	Code 305246			Code 305247
350 Al	9 – #14							
#2 Al	10 – #14							
#4 Cu 250 Cu	11 – #14	Code 305245						
#2 Cu	17 – #14							
700 Al	18 – #14							
500 Cu	13 – #12							
1,000 Al	16 – #12	Code 305247						
-	#2 Str. Cu	Code 305245			Code 305246			Code 305249
-	#2 Solid Cu	Code 305244						Code 305247

¹ For extension or splicing out of concentric neutral wires, see [Document 051071](#) or [Document 066204](#).

² This cable design is no longer approved for purchase.

Table 22 Connectors for Splicing and Tapping EPR Cable Concentric Neutrals ¹

Primary Cable Size AWG or kcmil Document 039955 ² (AL)	#2 1/0 600	1,100
#2 1/0 600	Concentric Size	10-#14
1,100	12-#14	Code 305244
		Code 305255
		Code 305245

¹ This cable design is our current standard.

² For extension or splicing out of concentric neutral wires, see [Document 051071](#) or [Document 066204](#).

Table 23 Connectors for Splicing and Tapping EPR-Cable Flat Strap Neutral ¹

Primary Cable Size AWG or kcmil Document 039955 ² (Cu)	#2	350 500	750
#2	305244		
350		305246	-
500	-		
700	-	-	305247

¹ This cable design is used in special application.

² For extension or splicing out of concentric neutral wires, see [Document 051071](#) or [Document 076264](#).

**Connectors for Insulated Cables
Underground Distribution Systems**

Connectors for Splicing and Tapping Concentric Wires (continued)

Table 24 Dies Ordering Data for 12-Ton Press Tool

Die	Kearney Catalog Number	Burndy Catalog Number	Die Code ^{1, 2}
U-O	-	U-O	216083
U-D	-	U-D	2811758
U-D3	-	U-D3	216084
U-N	-	UN-C	216085
U-BKT	36832	U-KBKTT	216133

¹ Code includes one complete set of dies consisting of two half-sections.

² These dies are only available for purchase in SRM. The codes shown on this table are the SRM part number.




Table 25 Equivalent Conductor Size for Concentric Neutrals ¹

Equivalent Size	Concentric Size
#4 Approximate	8 – #14
	9 – #14
	10 – #14
#2 Approximate	11 – #14
	12 – #14
	17 – #14
1/0 Approximate	18 – #14
	13 – #12
	16 – #12

¹ To connect these concentric conductors to conductors other than #2, use the equivalent conductor size and select a connector from Table 21 – 25 on Page 20.

**Connectors for Insulated Cables
Underground Distribution Systems**

**Terminal Connectors Compression-Type
(aluminum cable for flat bar or transformer spade terminals)**



**Figure 17
4-Hole Pad**

Table 26 Specifications for Terminal Connectors – Aluminum Cable-to-Flat Bar (Figure 15 and Figure 16) ⁷

Cable Size AWG or kcmil	Refer to	Approved for Purchase					Connector Code	6-Ton Too Dies # ⁷ 12-Ton Tool Dies # 15-Ton Tools Dies #
		Approximate Dimensions (inches)						
		B	C ¹	L ¹	T ¹	OD		
4	Figure 15	1.24	1.25	4.92	0.25	0.65	303829	W-BG U-BG
2		1.10	0.91	5.62	0.25	0.65	303761	U-BG
1/0		1.10	0.91	5.62	0.25	0.65	303760	U-BG
2/0		1.60	1.25	5.43	0.25	0.91	303830	W249 U249
4/0		1.60	1.25	5.75	0.30	0.91	303759	U249
250		1.96	1.25	5.88	0.25	1.12	303831	-
350		1.91	1.62	6.84	0.38	1.12	303758	U31ART U31ART
500/600		2.62	1.62	6.78	0.38	1.62	303832	-
700/750 ²		2.65	1.62	8.22	0.62	1.62	303833	U39ART P39ART
1,000 ²		2.97	1.62	8.88	0.62	1.84	303834	-
1,250 ³	Figure 16/ Figure 17	2.58	2.60	7.53	0.51	1.84	303835	- P44ART
1,500 ³		3.19	3.09	8.59	0.81	2.26	303836	L46ART ⁶
1,750 ³		3.69	3.33	8.38	0.86	2.46	303837	L47ART ⁶
2,000 ³		3.69	3.57	8.50	0.94	2.60	303838	L48ART ⁶
6 ⁵	Figure 16 ^{4, 5} (stacking terminals)	1.50	0.87	5.25	0.21	0.62	303732	-
2 ⁵		1.10	0.91	5.62	0.25	0.65	303731	W-BG U-BG
1/0 ⁵		1.10	0.91	5.62	0.25	0.65	303730	U-BG
4/0 ⁵		1.52	1.17	6.20	0.30	0.91	303729	W249 U249 U249
250		1.90	1.62	6.6	0.38	1.0	301283	- - -

**Connectors for Insulated Cables
Underground Distribution Systems**

**Table 26 Specifications for Terminal Connectors – Aluminum Cable-to-Flat Bar (Figure 16 and Figure 17)
(Continued)**

Cable Size AWG or kcmil	Refer to	Approved for Purchase					Connector Code	6-Ton Tool Dies # ⁷ 12-Ton Tool Dies # 15-Ton Tool Dies #
		Approximate Dimensions (inches)						
		B	C ¹	L ¹	T ¹	OD		
350 ⁵	Figure 16 ^{4, 5} (stacking terminals)	2.25	1.62	6.84	0.38	1.12	303728	– U31ART U31ART
700/750 ^{2, 5}		2.65	1.62	8.22	0.62	1.62	303839	– U39ART P39ART
1,000 ^{2, 5}		2.97	1.62	8.88	0.62	1.84	303840	– – P44ART

¹ These dimensions may vary slightly among the various suppliers.
² These connectors shall be designed to fit side by side on a standard NEMA spade terminal (see Figure 24 on Page 29).
³ To order 4-hole terminals larger than 1,000 kcmil, select the Burndy or Homac terminal for the proper cable size and substitute 4 for 2 in the catalog number. Example: YA45A-4NTN or Homac AL-750-4NTN. See Figure 17 on Page 22.
⁴ If it is necessary to stack copper conductors, use aluminum stacking connectors.
⁵ These connectors shall be capable of being stacked on any straight terminal of equal or larger size (up to and including 1,000 kcmil).
⁶ These Die require a 60-ton press tool.
⁷ Within this column, the first entry corresponds to a 6-ton press tool, the second entry corresponds to a 12-ton press tool, and the third entry corresponds to a 15-ton press tool.

**Connectors for Insulated Cables
Underground Distribution Systems**

**Terminal Connectors Compression-Type
(aluminum cable-to-flat bar for transformer spade terminals)(continued)**

Table 27 Terminal Connectors (aluminum cable-to-flat bar)(continued)

Cable Size AWG or kcmil	Approved for Purchase		
	Manufacturer and Catalog Number		Connector Code
	Homac	Burndy	
4	SA4NTN	YAR4U2NTN	303829
2	SA2NTN	YAR2U2NTN	303761
1/0	AL1/0-NTN	YAK25A-2GA	303760
2/0	SA2/0-NTN	YAR2/0U2NTN	303830
4/0	AL4/0-NTN	YA4/0A2NTN	303759
250	SAB4/0-NTN	YA250A2NTN	303831
350	AL350-NTN	YA350A2NTN	303758
500	SAL500-NTN	YA500A2NTN	303832
700/750 ¹	AL750-NTN	YA750A2NTN	303833
1,000 ¹	AL1000-NMS	YA1000A2NTN	303834
1,250 ²	AL1250-NTN	YA1250A2NTN	303835
1,500 ²	AL1500-NTN	YA1500A2NTN	303836
1,750 ²	AL1750-NTN	YA1750A2NTN	303837
2,000 ²	AL2000-NTN	YA2000A2NTN	303838
Stacking Terminal			
6 ^{3, 4}	ASL 6-NTN	YARSO6U2NTN	303732
2 ^{3, 4}	ASL 386-N	YARSO2U2NTN	303731
1/0 ^{3, 4}	ASL1/0-NTN	YARSO1/0U2NTN	303730
4/0 ^{3, 4}	ASL4/0-NTN	YASO4/0A2NTN	303729
250	ASL250-NTN	YASO250A2NTN	301283
350 ^{3, 4}	ASL350-NTN	YASO350A2NTN	303728
700/750 ^{1, 3, 4}	ASL750-NTN	YASO750A2NTN	303839
1,000 ^{1, 3, 4}	ASL1000-SSNTN	YASO1000A2NTN	303840

- ¹ These connectors shall be designed to fit side by side on a standard NEMA spade terminal (see Page 27).
- ² To order 4-hole terminals larger than 1,000 kcmil, select the Burndy or Homac terminal for the proper cable size and substitute 4 for 2 in the catalog number. Example: YA45A-4NTN or Homac AL-750-4NTN.
- ³ If it is necessary to stack copper conductors, use aluminum stacking connectors.
- ⁴ These connectors shall be capable of being stacked on any straight terminal of equal or larger size (up to and including 1,000 kcmil).

Notes

- 1. The material for these connectors, is tinned aluminum alloy, tubular.
- 2. Attach terminal connectors using Everdur bolts and washers shown on page 28. For ordering Everdur Bolts refer to Table 29 on Page 28.
- 3. Partially filled with oxide inhibitor and sealed. For ordering Everdur bolts refer to Table 30 On Page 28.
- 4. Connections of copper-to-copper, tinned aluminum-to-copper, and tinned aluminum-to-tinned aluminum require no special precautions other than a clean surface. Any combination involving an untinned aluminum surface requires the application of oxide inhibitor to the surface. Wire brush the surface through the compound thoroughly. Brushing through this inhibitor prevents the oxide from reforming. If in doubt as to the materials or tinning, applying inhibitor will do no harm

**Connectors for Insulated Cables
Underground Distribution Systems**

**Terminal Connectors Compression-Type
(copper cable-to-flat bar for transformer spade terminals)**




Figure 18

Table 28 Specifications for Terminal Connectors – Copper Cable-to-Flat Bar (Figure 18)

Cable Size AWG or kcmil	Manufacture and Catalog Number		Approved for Purchase							Bolt Size	Connector Code	6-Ton Tool ¹ Dies # 12-Ton Tool Dies # 15-Ton Tool Dies #
			Dimensions (inches)									
			Romac	Burndy	B	C	D	L	N			
4	L4N	YA4C-2N	1-1/8	13/16	3	4-1/2	5/8	1/8	1/2	303916	W4CRT ² U4CRT ² U4CRT ²	
2 ²	L2N	YA2C-2N	1-1/4	13/16	3	4-23/32	5/8	1/8	1/2	303221	W2CRT U2CRT U2CRT	
1	L1N	YA1C-2N	1-3/8	13/16	3	4-7/8	5/8	1/8	1/2	303804	W1CRT U1CRT U1CRT	
1/0	L1/0N	YA25-2N	1-3/8	13/16	3	4-29/32	5/8	1/8	1/2	303209	W26RT U26RT U26RT	
2/0	L2/0N	YA26-2N	1-1/2	13/16	3	4-29/32	5/8	1/8	1/2	303220	W27RT U27RT U27RT	
3/0	L3/0N	YA27-2N	1-1/2	29/32	3	4-15/16	5/8	1/8	1/2	303219	U28RT U28RT U28RT	
4/0	L4/0N	YA28-2N	1-5/8	1	3	5-1/16	5/8	9/64	1/2	303917	- U29RT U29RT	
250	L250-N	YA29-2N	1-5/8	1-3/32	3	5-5/32	5/8	5/32	1/2	303092	- U30RT U30RT	
300	L300-N	YA30-2N	2	1-11/16	3	5-3/4	5/8	5/32	1/2	303451	- U31RT U31RT	
350	L350-N	YA31-2N	2	1-25/32	3	5-11/16	5/8	3/16	1/2	303452	- U32RT U32RT	
500	L500-N	YA34-2N	2-1/4	1-17/32	3	5-15/16	5/8	15/64	1/2	303093	- U36RT U36RT	

**Connectors for Insulated Cables
Underground Distribution Systems**

***Terminal Connectors Compression-Type
(copper cable-to-flat bar for transformer spade terminals)(preferred)***

**Table 28 Specifications for Terminal Connectors – Copper Cable-to-Flat Bar (Figure 18 on Page 25)
(Continued)**

Cable Size AWG or kcmil	Manufacture and Catalog Number		Approved for Purchase							6-Ton Tool Dies # ¹ 12-Ton Tool Dies # 15-Ton Tool Dies #	
			Dimensions (inches)						Bolt Size		Connector Code
	Romac	Burndy	B	C	D	L	N	T			
600 ^{3, 4}	L600-N	YA36-2N	2-11/16	1-1/2	3	6-5/8	5/8	17/64	1/2	303454	– U37RT U37RT
750 ^{3, 4}	L750-N	YA39-2NN1	2-7/8	1-3/4	3	6-3/4	5/8	17/64	1/2	303296	– – P44RT
1,000 ²	L1000N	YA44-2NG10	3	1-3/4	3	6-15/16	5/8	21/64	1/2	303461	1000C

¹ Within this column, the first entry corresponds to a 6-ton press tool, the second entry corresponds to a 12-ton press tool, and the third entry corresponds to a 15-ton press tool

² For #2 Solid, use Burndy 162 die index. For Die ordering information refer to Table 20 on Page 19

³ Dimension C shall not exceed 1-3/4”.

⁴ To order 4-hole terminals, select the Homac or Burndy terminal for the proper cable size and substitute 4 for 2 in the catalog number. For example: YA39-4NNT, for Burndy L750-4N for Homac

Notes

1. Attach using Everdur bolts and washers as shown on Table 30 on Page 28.
2. Connections of copper-to-copper, tinned aluminum-to-copper, and tinned aluminum-to-tinned aluminum pads require no special precautions other than a clean surface. Any combination involving an untinned aluminum surface requires the application of oxide inhibitor to the surface. Wire brush the surface through the compound thoroughly. Brushing through this inhibitor prevents the oxide from reforming. If in doubt as to the materials or tinning, application of the inhibitor will do no harm.

Connectors for Insulated Cables
Underground Distribution Systems

Applications of Compression-Type Terminal Connectors (preferred)






Figure 19




Figure 20

Notes

1. Where the transformer spade does not provide sufficient space for cables to be connected, it may be extended with a short length of 1/4" x 4" copper bus bar, 3.86 pounds per foot, **Code M156024**. The current carrying capacity of the bus bar, when insulated with tape is as follows:
1,200 amps for one 1/4" x 4" bus bar.
2,200 amps for two 1/4" x 4" bus bars (one on each side of the spade).
The spade itself has capacity sufficient for the rating of the transformer.
2. Where large size or a large number of cables are attached to secondary spade, they should be supported to prevent excessive strain on the secondary bushings.
3. Installations shown in this document **cannot** be used for aluminum cables 1,250 kcmil and larger, or copper cables 750 kcmil and larger, as the flat portion of the connector is wider than the hole spacing provided on the transformer spade.

**Connectors for Insulated Cables
Underground Distribution Systems**

**Terminal Connectors Bolted-Type
(copper cable-to-flat bar for transformer spade terminals)(non-preferred)**




Figure 21




Figure 22

Table 29 Connectors (copper cable eye bolt-to-flat bar type) ¹

Use for Cable Range (AWG-kcmil)	Manufacturer and Catalog Number						Code
	Refer to	A.E. Corp. ²	Burdny	So. States	Royal	Dossert	
2/0-500	Figure 21	TLD-62	QQGF34-G6	UNNS-4656T	12222	T2L-50E	303169
600-1,000	Figure 22	TLDN-86	QQGFL44-G4	UNNS-5666T	19599	T2L-50E	303286

¹ Connectors shown in Figure 21 and Figure 22 have two cable clamping elements and require a minimum of space and taping. The recommended tightening force for the 1/2" eye bolt on these connectors is 25-40 foot-pounds.

² Formerly Anderson Brass Works.

Note

1. See Pages 24 to 29 for preferred compression connectors for this application.

Table 30 Bolts, Nuts, and Washers (Figure 21 above, Figure 26 on Page 30, Figure 36 on Page 37) ^{1, 2, 3}

Item	Description	Code
1	Screw, Cap (bolt) Everdur, Hex. Head 1/2" x 1-1/2" ^{1, 2}	193023
2	Screw, Cap (bolt) Everdur, Hex. Head 1/2" x 2" ^{1, 2}	193025
3	Screw, Cap (bolt) Everdur, Hex. Head 1/2" x 2-1/2" ^{1, 2}	193177
4	Nut, Bolt, Everdur, Hex. 1/2" ¹	195013
5	Washer, Round, Everdur, 1/2"	195252
6	Washer, Lock, Everdur, 1/2"	195193
7	Screw, Cap (bolt), Steel, CDPL, Hex. HD 1/2" x 1-1/2"	193271
8	Screw, Cap (bolt), Steel, CDPL, Hex. HD. 1/2" x 2"	193272
9	Screw, Cap (bolt), Steel, CDPL, Hex. HD. 1/2" x 2-1/2"	193273
10	Screw, Cap (bolt), Steel, CDPL, Hex. HD. 1/2" x 3"	193274
11	Nut, Bolt, Steel, CDPL, Hex. 1/2"	195449
12	Washer, Round, Steel, CDPL 1/2"	195450
13	Washer, Lock, Steel, CDPL 1/2"	195451

¹ The recommended tightening force for a 1/2" Everdur bolt is 40 foot-pounds. Normally, the use of an 8" wrench will give this range of torque.

² Everdur cap screws are low silicon bronze, Spec 651 per ASTM F468 with Class 2A threaded.

³ Use Items 1 - 6 as shown in Figure 23 on Page 29 and Figure 36 on Page 37. Use Items 7 - 13 as shown in Figure 26 on Page 30.

**Connectors for Insulated Cables
Underground Distribution Systems**

**Terminal Connectors Bolted-Type
(copper cable-to-flat bar for transformer spade terminals)(non-preferred) (continued)**




Figure 23

Table 31 Connectors – Bolted Tongue-to-Copper Cable Type ¹ (Figure 23)


Use for Cable Range (kcmil)	Manufacturer and Catalog Number			Dimensions (inches) ²				Connector Code
	Burndy	Royal	Dossert	L	W	H	T	
400-500	QA34-2N	18726	HL 50-2N	4-11/16	1-3/8	1-15/16	5/16	303188
600-800	QA40-2N	18727	HL 80-2N	4-13/16	1-5/8	2-5/16	3/8	303298
850-1,000	QA44-2N	18728	HL 100-2N	4-15/16	1-7/8	2-1/2	1/2	303189

¹ Bolt on these connectors is 40 foot-pounds of applied torque.

² Dimensions shown are for Burndy connectors; others may vary slightly.

Notes

- Figure 24 Below shows standard transformer spade terminals per Electronic Edison Institute (EEI) Specification.



**Figure 24
Standard Transformer Spade Terminals (EEI-NEMA)**

**Connectors for Insulated Cables
Underground Distribution Systems**

**Terminal Connectors Bolted-Type
(copper cable-to-flat bar for transformer spade terminals)(non-preferred)(continued)**







Table 32 Connectors – Copper Cable Eyebolt-to-Flat Bar Type (Figure 25 and Figure 26)

Cable Range (AWG or kcmil) Min – Max	Manufacturer and Catalog Number			Approximate Dimensions (inches) ¹				Code
	Figure 26	Figure 26	Figure 25	H	J	L	W	
	Burndy	Royal	Dossert					
2 – 350	QGFL-31B1	12208	QL35	2-3/4	1/2	1-3/4	1-7/16	303165
1/0 – 500	QGFL-34B1	12209	QL50	3-3/16	1/2	2-1/4	1-13/16	303233
750 – 1,000	QGFL-44B1	12212	QL100	3-1/2	1/2	2-1/4	2-3/16	303179

¹ The recommended tightening force for the 1/2" eye bolt on these connectors is 40 foot-pounds of applied torque.

² Dimensions shown are for Burndy connectors; others may vary slightly.

Terminal Connectors Bolted-Type (copper cable-to-flat bar for current transformer terminals only)

Table 33 Connectors – Cable-to-Flat Bar-to-Copper Cable Type (Figure 25 and Figure 26)

Cable Range (AWG or kcmil) Min – Max	Manufacturer and Catalog Number				Approximate Dimensions (inches) ¹					Code
	Figure 25	Figure 26	Figure 25	Figure 26	C	H	K (min.)	L	W	
	A.E. Corp.	Burndy	Royal	Dossert						
3/0 – 4/0	ITE024-A	QA28-B3	18723	HL 21-1-50	1	1-7/16	9/16	2-1/4	1/4	303297
250 – 350	ITE035-A	QA31-B	18724	HL 35-1	1-3/16	1-11/16	17/32	2-11/16	5/16	303182
400 – 500	ITE050-A	QA34-B	18725	HL 50-1	1-3/8	2	17/32	3-3/16	5/16	303112
600 – 800	ITE080-A	QA40-B	19600	HL 75-1	1-5/8	2-3/8	11/16	3-11/16	3/8	303122
850 – 1,000	ITE100-A	QA44-B	19601	HL 100-1	1-7/8	2-1/2	11/16	3-15/16	1/2	303121

¹ Dimensions shown are for Burndy connectors; others may vary slightly.

Notes

1. Connectors shown in Table 32 on Page 30 are less costly than those shown in Table 33 and should be used when connecting one cable to bar-type primary terminal.
2. Use connectors shown in Table 32 on Page 30 to connect two cables to bar-type primary terminal by placing them back-to-back as shown in Figure 25 and Figure 26.
Where severe corrosive conditions exist, use Everdur cap screws, nuts, and washers shown in Table 30 on Page 28.

**Connectors for Insulated Cables
Underground Distribution Systems**

Tap Connectors for Cable Termination (copper or aluminum cable) Pad-Mounted Transformers




Figure 27




Figure 28





Table 34 Tap Connectors – Tee-Type (copper-to-copper, for circuits 5,000 V or lower)

Cable Size AWG or kcmil		Approved for Purchase									6-Ton Tool Dies # ¹ 12-Ton Tool Dies # 15-Ton Tool Dies #	
Run	Tap	Refer to	Dimensions (inches)						Burdny Catalog Number	Dossert Catalog Number	Code	
			B	C	E	H	J	L				
6 to 2/0	2	Figure 27	1-11/32	1-5/8	2-17/32	1-13/16	-	3-7/32	VYT262CG 1	UTDK 13-6	305638	W2CRT U2CRT U2CRT
6 to 2/0	2/0		1-17/32	1-5/8	2-23/32	1-13/16	-	3-13/32	VYT2626G 1	UTDK 13-13	305639	W26RT U26RT U26RT
1/0 to 300	2	Figure 28	1-11/32	1-3/8	2-3/4	1-27/32	7/16	3-23/32	VYT302C	UTSK 30-6	305640	W2CRT U2CRT U2CRT
1/0 to 300	2/0		1-17/32	1-3/8	3-1/16	1-27/32	7/16	4	VYT3026	UTSK 30-13	305641	W26RT U26RT U26RT
1/0 to 300	250		1-21/32	1-3/8	3-1/4	1-27/32	7/16	4-7/32	VYT3029	UTSK 30-25	305642	U29RT U29RT
1/0 to 300	500		2-9/32	1-3/8	3-1/16	1-27/32	7/16	5	VYT3034	UTSK 30-50	305643	U34RT U34RT

¹ Within this column, the first entry corresponds to a 6-ton press tool, the second entry corresponds to a 12-ton press tool, and the third entry corresponds to a 15-ton press tool.

Notes

1. If Tee Connectors, shown in Figure 27 and Figure 28 are to be attached to an aluminum overhead conductor run, use a short length of bare copper conductor between the connector and the aluminum conductor, and attach it with a fired wedge per [Document 066194](#).
2. If the desired connector size is not shown, special sizes may be acquired by ordering a connector similar to the connector shown.

**Connectors for Insulated Cables
Underground Distribution Systems**

Tap Connectors for Cable Termination (copper or aluminum cable) Pad-Mounted Transformers (continued)




Figure 29




Figure 30
Blackburn Catalog Number PGH3, Code 305997

Application: Tap clamp for live-front loop-style, 3-phase pad-mounted transformer. [Document 045291](#) and [Document 057521](#) conductor range #2 AWG to 2/0.

Application

See “Low Profile” Single-Phase 6.9 and 12 kV pad-mounted transformer, [Document 042762](#) and [Document 042765](#).

Table 35 Tap Connectors for Cable Termination in “Low-Profile” Pad-Mounted Transformers (Figure 29)

Connector Size AWG or kcmil	Manufacturer and Catalog Number	6-Ton Tool Dies # ¹	Connector Code
	Kortick	12-Ton Tool Dies # 15-Ton Tool Dies #	
4 Cu	PMT-401	W4CRT UCRT UCRT ²	305057
2 Cu	PMT-201	W2CRT U2CRT U2CRT ²	305058
2 Al	PMTA-201	W2CART U2CART U2CART ²	305153
1/0 Al	PMTA-1001	- U25ART U25ART ²	305264

¹ Within this column, the first entry corresponds to a 6-ton press tool, the second entry corresponds to a 12-ton press tool, and the third entry corresponds to a 15-ton press tool.

² A U-die adapter must be used when utilizing u-dies in a 15-ton press.

**Connectors for Insulated Cables
Underground Distribution Systems**

**Primary T-Connectors, Compression-Type, 5 kV or Above
Aluminum-to-Aluminum, Copper-to-Aluminum, or Copper-to-Copper**




Figure 31




Figure 32

Table 36 Primary T-Connectors, Compression-Type - Aluminum-to-Aluminum or Copper-to-Aluminum (refer to Figure 31)

Conductor Size AWG or kcmil		Approved for Purchase					6-Ton Tool Die # 12-Ton Tool Die # 15-Ton Tool Die #
		Dimension (inches)		Manufacturer and Catalog Number		Connector Code	
		A		Burndy	Dossert		
Run	Tap	Burndy	Mac				
2	2	1-21/32	1-7/8	YST2CU2CUT	CVT6-6-S-AA	305266	See Table 38 on Page 35
4	2	1-21/32	1-7/8	YST4CU2CUT	CVT4-6-S-AA	305268	
1/0	1/0	1-3/4	1-7/8	YST25U25UT	CVT10-10-S-AA	305270	
1/0	2	1-3/4	1-7/8	YST25U2CUT	CVT10-6-S-AA	305271	
#2-4/0	#2-4/0	3-3/32	-	YST28TG1	CVT6-6-S-AA	305380	
4/0-250	#2-250	3-5/8	-	YST29TG1	CVT21-6-S-AA	305384	
350-500	#2-500	4-9/32	-	YST34TG1	CVT35-6-S-AA	305386	
700-1,000 ¹	#2-700 ¹	4-25/32	-	YST39TG1	CVT70-6-S-AA	305398	

¹ Maximum conductor size for aluminum only. Maximum copper size is 750 kcmil for run and 500 kcmil for tap.

**Connectors for Insulated Cables
Underground Distribution Systems**

**Primary T-Connectors, Compression-Type, 5kV and Above
Aluminum-to-Aluminum, Copper-to-Aluminum, or Copper-to-Copper (continued)**

Table 37 Primary T-Connectors, Compression-Type - Copper-to-Copper (refer to Table 32 on Page 30)

Conductor Size AWG or kcmil		Dimensions (inches)						Manufacturer and Catalog Number			Connector code	6-Ton Tool Die # 12-Ton Tool Die # 15-Ton Tool Die #
		A	AA	H	T	OD		Burndy	Homac	Dossert		
Run	Tap					Run	Tap					
2	2	1.23	1.23	2.16	4.31	0.42	0.42	YSTP2C2CT	2T2	CVT6-6	305808	W2CRT U2CRT U2CRT ²
2	4	1.23	1.09	2.04	4.31	0.42	0.34	YSTP2C4CT	2T4	CVT6-4	305809	
4	4	1.09	1.09	1.84	3.88	0.34	0.34	YSTP4C4CT	4T4	CVT4-4	305810	

¹ Within this column, the first entry corresponds to a 6-ton press tool, the second entry corresponds to a 12-ton press tool, and the third entry corresponds to a 15-ton press tool.

² A U-die adapter must be used when utilizing u-dies in a 15-ton press.

Notes

1. The material of these connectors is aluminum or copper with a tinplated finish.
2. Barrels are factory drilled to accommodate the minimum conductor OD.
3. Connectors shall be filled with oxide inhibitor and sealed

Application

Tap splices for above 5,000 V, see [Document 041583](#) and [Document 043901](#)

**Connectors for Insulated Cables
Underground Distribution Systems**

**Primary T-Connectors, Compression-Type,
Aluminum-to-Aluminum, Copper-to-Aluminum or Copper-to-Copper (continued)**

Table 38 Tooling from Table 36 on Page 33


Connector Code	6-Ton Tool Dies # ¹ 12-Ton Tool Dies # 15-Ton Tool Dies #	
	Run	Tap
305266	- U25ART U25ART	- U25ART U25ART ²
305268	W2CART U2CABT U2CABT	
305270	W27ART U27ART U27ART	W27ART U27ART U27ART ²
305271		- U25ART U25ART ²
305380	- U31ART U31ART	- U31ART U31ART ²
305384	- U39RT U39ART	- U39ART U39ART ²
305386	- U39ART U39ART	- U39ART P39ART
305398	- - P44ART	

¹ Within this column, the first entry corresponds to a 6-ton press tool, the second entry corresponds to a 12-ton press tool, and the third entry corresponds to a 15-ton press tool.

² A U-die adapter must be used when utilizing u-dies in a 15-ton press.

Connectors for Insulated Cables Underground Distribution Systems

Slip-Fit Connector Installation, Aluminum or Copper Cable



Scope

This page shows slip-fit connectors for single-phase, dead-front transformer, low voltage, secondary installations (see [Document 064308](#)).

Notes

1. All set screws to be 5/16" Allen head drive.
2. The bar is rated in excess of 1,600 amps, which exceeds the maximum allowable transformer load.
3. Connectors may be used for aluminum or copper conductors.
4. Never combine conductors in one port.
5. Connector is designed to slip onto the stud even though the terminal is threaded.
6. Secondary cover, see Figure 35, is a tool to be used when required to insulate the energized secondary slip-fit connectors.

Instructions


1. Remove any jam nuts from transformer studs.
2. Slide the connector onto the transformer stud, position the connector to allow a straight, smooth cable entry, mesh the threads together, and tighten the setscrews to lock the connector in place.
3. To prepare the cable, remove the insulation, wire brush the conductor, and apply inhibitor.
4. Insert the conductor in the port and tighten the setscrew.
5. After completing work on the secondary connectors, make sure all connections are tightened as indicated in Table 39.

Table 39 Conductor/Torque

Conductor	Torque (ft/lbs)
#6 – 350 and Transformer Stud	25
500 – 1,000	40

**Connectors for Insulated Cables
Underground Distribution Systems**

Multiple Transformer Terminal Aluminum or Copper Cable



**Figure 36
8-Way Terminal Illustrated (1,000 kcmil)**

**Table 40 EZ Keeper Lay-In Terminals for Copper or Aluminum Conductors (600 V or lower)
(refer to Figure 36)**

Conductor Range	Ampacity (minimum)	Number of Conductors	Dimensions – Approximate (inches)			Mounting Hole Diameter	Code
			L	W	H		
1/0 – 1,000	3100	4	7.0	6.25	1-7/8	9/16"	301281
	5100	8	13.75	6.25			301282

Scope

These connectors are for use in connecting service cables from 1/0 to 1,000 kcmil to the spade of three-phase, pad-mounted transformers ([Document 043817](#) and [Document 045291](#)). Cable-to-flat bars are replaced in this design by set screws and a removable lay-in connection. If needed to terminate a #2 neutral onto one of these bars, it is necessary to splice a piece of 1/0 tail for insertion into the lay-in port.

Notes

1. Connectors may be used for copper or aluminum conductors.
2. Never put more than one cable in a port.
3. Install the lower (X_0 and X_2) connectors first, then the higher (X_1 and X_3). Use as many bolts as there are holes in the spade.
4. If transformer spades are not supported, install a secondary cable support kit (see [Document 045291](#)).
5. To prepare the cable, remove the insulation, wire brush the conductor, and apply inhibitor.
6. Make sure all set screws are tightened as indicated in Table 39 on Page 36. (Torque them to the specified value, wait 5 minutes, and make the final torque).
7. See Table 30 on Page 28 for bolts, nuts, and washers.

Connectors for Insulated Cables Underground Distribution Systems

Pin Terminals




Table 41 Specifications for Aluminum Pin Terminal ¹

Copper/ Al. Cable Size	Copper Stud Equivalent	Approved for Purchase									Code	6-Ton Tool Die # ¹ 12-Ton Tool Die # 15-Ton Tool Die #
		Manufacturer and Catalog Number		Dimension (inches)								
		Homac	Brundy	A	B	OD	E Approx.	L Approx.	P			
6	8	SAPT-6-26	YE6R-40	0.250	1.75	0.65	3.25	9.25	6.00	303843	W-BG U-BG U-BG ²	
2	4	SAPT-2-26	TE2R-40	0.250	1.75	0.65	3.25	9.25	6.00	303844		
1/0	2	SAPT-1/0-26	YE25R-60	0.250	1.75	0.65	3.25	9.25	6.00	303845		
4/0	2/0	SAPT-4/0-206	YE28R-60	0.375	1.54	0.91	3.50	10.9	6.00	303846	W249 U249 U249 ²	
350	4/0	PTB-350-6	YE31AG3	0.460	2.25	1.12	4.70	10.7	6.00	303554	– U31ART U31ART ²	
500/600	500	PTM-500-346	YE34AP- GE	0.750	2.56	1.57	6.30	12.3	6.00	300013	– U34ART ³ U34ART ^{2 3}	
700	500	PTL-750	YE39AGB	0.750	2.56	1.60	6.30	12.3	6.00	303555	– U39ART P39ART	
1,000	700	PTF-1000-346	YE44AG7	0.750	2.56	1.60	6.30	12.3	6.00	033757	– – P44ART	

¹ Within this column, the first entry corresponds to a 6-ton press tool, the second entry corresponds to a 12-ton press tool, and the third entry corresponds to a 15-ton press tool.

² A U-die adapter must be used when utilizing U-dies in 15-ton press tool.

³ Homac equivalent of this die is 106A.

Notes

1. The material for the pin terminals is on Table 41. Copper Rod-Soft Drawn, Tinned, Aluminum Connector EC Grade, Untinned
2. Connector is supplied pre-filled with inhibitor and sealed.
3. Connector is supplied pre-filled with inhibitor and sealed.
4. Pin terminals connected to copper secondary conductors use a copper connector. Pin terminals connected to aluminum secondary conductors use a fired wedge or h-tap.

Application

1. To make straight connections of insulated aluminum secondary neutral to bare copper neutral, see Note 10 Page 7.
2. To connect aluminum primary stress cone termination to terminal tap connector or cutout.
3. To make watertight termination for secondary risers.

Connectors for Insulated Cables Underground Distribution Systems

Pin Terminals (continued)

Table 42 Color Coding

Color Coding Requirements for Plastic End Plugs in Pin Terminals	
Conductor Size	Plug Color
#6	Blue
#2	Red
1/0	Yellow
4/0	Pink
350	Brown
700	Purple

Table 43 Specifications and Ordering Information for Copper Pin Terminal

Cu Cable Size	Cu Stud Size	Manufacturer and Catalog Number			Dimensions (inches)						6-Ton Tool Die # ¹ 12-Ton Tool Die # 15-Ton Tool Die #	Code
		Dossert	Mac Prod Co.	Brundy	A	B	OD	E	L	P		
2	2	SDP 6-PG	CAS2-2	YE2CLH128	0.25	1.25	0.415	2.25	9.00	6.00	W2CRT U2CRT U2CRT ²	303847

¹ Within this column, the first entry corresponds to a 6-ton press tool, the second entry corresponds to a 15-ton press tool.

² A U-die must be used when utilizing u-dies 15-ton press tool.

Notes

- The material for the pin terminals on Table 43 is copper rod-soft-drawn, tinned.
- Rod may be bent for installation convenience. It is recommended that bending take place 1/2" beyond the copper sleeve.

Application

- To make straight connections of insulated aluminum secondary neutral to bare copper neutral, see Note 10 Page 7.
- To connect bare copper secondary neutral to aluminum bar connector using Thermofit boot, see [Document 036640](#).
- To make watertight termination for secondary risers.

Revision Notes

Revision 06 has the following changes:

- Major changes throughout the entire document.

