

POSTING REQUIREMENTS FOR FERC STANDARDS OF CONDUCT PACIFIC GAS AND ELECTRIC COMPANY

FERC Standards of Conduct, Section 358.7(a): If a transmission provider discloses non-public transmission function information, other than information identified in paragraph (a)(2) of this section, in a manner contrary to the requirements of § 358.6, the transmission provider must immediately post the information that was disclosed on its Internet website.

In preparation for a potential Public Safety Power Shutoff (PSPS) event that is forecasted to commence the morning of 11/20/2019, on 11/19/2019 Pacific Gas and Electric Company (PG&E) notified potentially affected customers that the transmission lines identified below may be de-energized during the PSPS event.

Transmission Lines that may be de-energized:

FULTON-LAKEVILLE-IGNACIO	230
APPLE HILL #1 TAP	115
APPLE HILL #2 TAP	115
CARIBOU-PALERMO	115
DRUM PH #2 TAP	115
DRUM-HIGGINS	115
DRUM-RIO OSO #1	115
DRUM-RIO OSO #2	115
DRUM-SUMMIT #1	115
DRUM-SUMMIT #2	115
DUTCH FLAT #2 TAP	115
EAGLE ROCK-CORTINA	115
EAGLE ROCK-REDBUD	115
EL DORADO-MISSOURI FLAT #1	115
EL DORADO-MISSOURI FLAT #2	115
WOODLEAF-PALERMO	115
COLGATE-ALLEGHANY	60
COLGATE-CHALLENGE	60
COLGATE-GRASS VALLEY	60
COTTONWOOD-BENTON #2	60
DEER CREEK-DRUM	60
DESABLA-CENTERVILLE	60
DRUM-GRASS VALLEY-WEIMAR	60
DRUM-SPAULDING	60
FORKS OF THE BUTTE TAP	60
FULTON-CALISTOGA	60

GOLD HILL #1	60
KONOCTI-EAGLE ROCK	60
MIDDLE FORK #1	60
MONTE RIO-FORT ROSS	60
MONTE RIO-FULTON	60
ORO FINO TAP	60
OXBOW TAP	60
ROLLINS TAP	60
VOLTA-DESCHUTES	60
WEIMAR #1	60
BRUNSWICK #1-115KV TAP	115
BRUNSWICK #2-115KV TAP	115
KANAKA 115KV TAP	115
LOWER LAKE-HOMESTAKE 115KV LINE	115
SLY CREEK 115KV TAP	115
FORBESTOWN 115KV TAP	115
CAPE HORN 60KV TAP	60
MIDDLETOWN-KONOCTI 60KV LINE	60
FITCH MOUNTAIN #1-60KV TAP	60
WOHLER 60KV TAP	60
KILARC-CEDAR CREEK	60
VOLTA-SOUTH	60
VOLTA-DESCHUTES	60
CLOVER CREEK TAP	60

Posted: 11/20/2019