

PUBLIC UTILITIES COMMISSION  
505 Van Ness Avenue  
San Francisco CA 94102-3298



**Pacific Gas & Electric Company**  
**ELC (Corp ID 39)**  
**Status of Advice Letter 6363E**  
**As of November 30, 2021**

Subject: Modifications to Electric Rule 21 Pursuant to Decision 20-09-035 Ordering Paragraphs 5 and 8

Division Assigned: Energy

Date Filed: 10-15-2021

Date to Calendar: 10-20-2021

Authorizing Documents: D2009035

<b>Disposition:</b>	<b>Accepted</b>
<b>Effective Date:</b>	<b>03-17-2022</b>

Resolution Required: No

Resolution Number: None

Commission Meeting Date: None

CPUC Contact Information:

[edtariffunit@cpuc.ca.gov](mailto:edtariffunit@cpuc.ca.gov)

AL Certificate Contact Information:

Kimberly Loo

415-973-4587

[PGETariffs@pge.com](mailto:PGETariffs@pge.com)

**PUBLIC UTILITIES COMMISSION**  
505 Van Ness Avenue  
San Francisco CA 94102-3298



To: Energy Company Filing Advice Letter

From: Energy Division PAL Coordinator

Subject: Your Advice Letter Filing

The Energy Division of the California Public Utilities Commission has processed your recent Advice Letter (AL) filing and is returning an AL status certificate for your records.

The AL status certificate indicates:

- Advice Letter Number
- Name of Filer
- CPUC Corporate ID number of Filer
- Subject of Filing
- Date Filed
- Disposition of Filing (Accepted, Rejected, Withdrawn, etc.)
- Effective Date of Filing
- Other Miscellaneous Information (e.g., Resolution, if applicable, etc.)

The Energy Division has made no changes to your copy of the Advice Letter Filing; please review your Advice Letter Filing with the information contained in the AL status certificate, and update your Advice Letter and tariff records accordingly.

All inquiries to the California Public Utilities Commission on the status of your Advice Letter Filing will be answered by Energy Division staff based on the information contained in the Energy Division's PAL database from which the AL status certificate is generated. If you have any questions on this matter please contact the:

Energy Division's Tariff Unit by e-mail to  
**[edtariffunit@cpuc.ca.gov](mailto:edtariffunit@cpuc.ca.gov)**

October 15, 2021

**Advice 6363-E**

(Pacific Gas and Electric Company ID U 39 E)

Public Utilities Commission of the State of California

**Subject: Modifications to Electric Rule 21 Pursuant to Decision 20-09-035  
Ordering Paragraphs 5 and 8.**

**Purpose**

Pursuant to California Public Utilities Commission (CPUC, Commission) Decision (D.) 20-03-035 (the Working Group 2 & 3 Decision in Rulemaking 17-07-007) Ordering Paragraphs (OP) 5 and 8, Pacific Gas and Electric Company (PG&E) submits this Tier 2 advice letter to make these additional modifications to its Electric Rule 21 - *Generating Facility Interconnections*. OP 5 and OP 8 were originally addressed in the following advice letters:

- 1) Advice 5915-E – *Advice Letter Modifying Electric Rule 21 Pursuant to Decision 20-09-035 for Working Group 2 and 3 (due 120 Days from Issuance) for Ordering Paragraphs 5, 6, 8 and 11 - January 28, 2021*
- 2) Advice 5915-E-A – *Supplemental: Advice Letter Modifying Electric Rule 21 Pursuant to Decision 20-09-035 for Working Group 2 and 3 (due 120 Days from Issuance) for Ordering Paragraphs 5, 6, 8 and 11 - September 3, 2021 (which replaced AL 5915-E in its entirety).*

This advice letter is submitted under the guidance of Energy Division and replaces OP 5 and OP 8 from AL 5915-E-A in its entirety.

**Background****Rulemaking 17-07-007**

On July 13, 2017, The Commission adopted Order Instituting Rulemaking (R.) 17-07-007 to consider refinements to Electric Tariff Rule 21 of Pacific Gas and Electric Company (PG&E), San Diego Gas & Electric Company (SDG&E), and Southern

California Edison Company (SCE) (jointly, Utilities) regarding the interconnection of distributed energy resources.<sup>1</sup>

### **ACR Scoping Memo**

On October 2, 2017, the Commission issued Scoping Memo of Assigned Commissioner and Administrative Law Judge (Scoping Memo) set forth the scope and schedule of the proceeding. It established the working group process, whereby resolution of the technical issues of the proceeding would be proposed by Working Groups One through Six. In addition, four issues were assigned to the Smart Inverter Working Group, including issues 5 and 8.<sup>2</sup>

### **Working Group 2**

On February 14, 2018, a Ruling directed that Working Group Two would begin on March 15, 2018 and required that it subsequently file its recommendations report on September 15, 2018. The Ruling also reassigned Issue 6 to Working Group Two.

On August 15, 2018, the Administrative Law Judge issued a Ruling allowing additional time for Working Group Two to resolve issues, including sub-issues encountered, and delaying the filing of the recommendations report to October 31, 2018.

On October 31, 2018, the Working Group 2 final report was issued.<sup>3</sup>

On November 7, 2018, the Administrative Law Judge facilitated a workshop to discuss the recommendations provided in the Working Group 2 Final Report.

On December 7, 2018, in response to the November 7, 2018, workshop on the Working Group Two Report, and parties were directed to respond to questions on the report.

On February 1, 2019, responses to the questions, along with comments on the Working Group Report, were filed by the various parties.

On February 22, 2019, replies were filed by the various parties.

---

<sup>1</sup> The Rule 21 tariff describes the interconnection, operating, and metering requirements for certain generating and storage facilities seeking to connect to the electric distribution system. Rule 21 provides customers access to the electric grid to install generating or storage facilities while protecting the safety and reliability of the distribution and transmission systems at the local and system levels. (See R.17-07-007 at p2.)

<sup>2</sup> The Smart Inverter Working Group (SIWG) grew out of a collaboration between the Commission and the California Energy Commission in early 2013. The collaboration identified the development of advanced inverter functionality as an important strategy to mitigate the impact of high penetrations of distributed energy resources. [as explained in footnote 2 in D. 20-09-035]

<sup>3</sup> Working Group Two Final Report filed jointly by the Utilities.

**Amended Scoping Memo and Working Group 3**

On November 16, 2018, a Scoping Memo and Ruling (Amended Scoping Memo) delayed the start of Working Group Three until December 1, 2018 and required Working Group Three to file its recommendations report on June 14, 2019. The Amended Scoping Memo also decreased the number of working groups and redistributed issues across two working groups and the Interconnection Discussion Forum<sup>4</sup> such that Working Group Three was assigned issues 12, 15, 16, 20, 22, 23, 24, 27, 28, and New Issues A and B.

On June 13, 2019, the Working Group Three Final Report<sup>5</sup> was issued followed by a workshop.

A November 27, 2019 Ruling directed parties to respond to questions on the Working Group Three Report.

On January 13, 2020, the various parties filed responses to the questions contained in the November 27, 2019, ruling, along with comments to the Working Group Three Report.

On January 27, 2020, various parties filed replies to the responses and Working Group Three Report comments.

**Working Group 2 & 3 Decision 20-09-035**

On August 20, 2020, a proposed decision was issued on Working Groups Two and Three. On September 9, 2020 comments were received. On September 22, 2020, replies were received.

On September 24, 2020, the Commission voted out D.20-09-035.<sup>6</sup> D.20-09-035 addressed the recommendations of Working Groups Two and Three and the Vehicle-to-Grid Alternating Current Interconnection Subgroup (V2G AC Subgroup).

**Decision 21-01-027**

On January 21, 2021, the CPUC issued D. 21-01-027<sup>7</sup> Correcting Errors in Decision 20-09-035. It corrected various ordering paragraph numbering in D. 20-09-035, but OPs 5 and 8 were not affected.

---

<sup>4</sup> In Resolution Administrative Law Judge-347, the Commission established the Interconnection Discussion Forum (formerly known as the Rule 21 Working Group) as a venue to encourage discussion and collaboration between the Utilities and developers. [as explained in footnote 3 in D. 20-09-035]

<sup>5</sup> Working Group Three Final Report filed by SDG&E

<sup>6</sup> [Decision 20-09-035](#) - *Decision Adopting Recommendations from Working Groups Two, Three, and Subgroup* - Date of Issuance 9/30/2020

<sup>7</sup> [Decision. 21-01-027](#) - *Order Correcting Errors in Decision 20-09-035* – issued January 21, 2021.

**AL 5915-E**

On January 28, 2021, PG&E submitted the original advice letter AL 5915-E<sup>8</sup> 120 days after the issuance of D.20-09-035, as ordered by that decision. That advice letter was subsequently protested. It addressed OPs 5, 6, 8, and 11.

**ALs 6014-E and 6014-E-A**

On November 30, 2020, AL 6014-E- *Advice Letter Modifying Electric Rule 21 Pursuant to Decision 20-09-035 for Working Group 2 and 3 (due 60 Days from Issuance)*. It was protested. It addressed OPs 1, 2, 3, 4, 12 17, 18, 24, 30, 32, 33, 37, 38, 40, and 45 (as corrected).

Subsequently, on June 25, 2021, AL 6014-E-A *Supplemental: Advice Letter Modifying Electric Rule 21 Pursuant to Decision 20-09-035 for Working Group 2 and 3 (due 60 Days from Issuance)* - was submitted. It addressed OPs 1, 3, 4, 17, 18, 23, 24, 30, 32, 33, 37, 38, 40, and 45 (as corrected). OPs 2, 12, and 23 were addressed in an AL 5915-E-A.

The version of Rule 21 attached includes pending changes from AL 6014-E-A.

**AL 6287-E**

AL 6287-E<sup>9</sup> was submitted on August 6, 2021, based on Energy Division's initial guidance, and AL 6287-E addressed the remaining issues in the above two advice letters, AL 5915-E and AL 6014-E-A. It addressed OPs 2, 5, 6, 8, 11, 12, and 23.<sup>10</sup> However, subsequent additional feedback from Energy Division requested PG&E to withdraw AL 6287-E and instead submit it as a supplemental advice letter to AL 5915-E.

**AL 5915-E-A & Protest**

On September 3, 2021, Supplemental AL 5915-E-A<sup>11</sup> was submitted replacing AL 6287-E.

---

<sup>8</sup> [AL 5915-E](#) - *Advice Letter Modifying Electric Rule 21 Pursuant to Decision 20-09-035 for Working Group 2 and 3 (due 120 Days from Issuance) for Ordering Paragraphs 5, 6, 8 and 11* – submitted January 28, 2021.

<sup>9</sup> [AL 6287-E](#) - *Modifications to Electric Rule 21 Pursuant to Decision 20-09-035 Addressing Remaining Ordering Paragraph Issues in Working Group 2 and 3* – submitted August 6, 2021; withdrawal request submitted by PG&E August 25, 2021; with disposition letter issued approving the withdrawal, dated August 30, 2021.

<sup>10</sup> Some of the OPs included in AL 6287-E replaced by 5915-A, were from AL 6014-E-A. *Supplemental: Advice Letter Modifying Electric Rule 21 Pursuant to Decision 20-09-035 for Working Group 2 and 3 (due 60 Days from Issuance of D.20-09-035)*. This was based on Energy Division Guidance.

<sup>11</sup> [Advice 5915-E-A](#) – *Supplemental: Advice Letter Modifying Electric Rule 21 Pursuant to Decision 20-09-035 for Working Group 2 and 3 (due 120 Days from Issuance) for Ordering Paragraphs 5, 6, 8 and 11*.

On September 10, 2021, AI 5915-E-A was protested by the Interstate Renewable Energy Council, Inc. (IREC).<sup>12</sup>

On September 17, 2021, PG&E submitted joint reply comments<sup>13</sup> to the IREC protest.

Subsequently on October 10, 2021, PG&E received guidance from Energy Division on the next steps for the above advice letter. Pursuant to their October 10 email:

“...For OP 5: Screen F and Adding Screen F1

1. IREC notes SDG&E omits the word “circuit.” And **SDG&E** agrees to add the word “circuit” in a supplemental advice letter.

Screen F: Is the Short **Circuit** Current Contribution Ratio within acceptable limits?

2. IREC indicates that in the Screen F “significance” note, PG&E uses “Distribution System’s” while SCE and SDG&E use “Distribution Provider’s Distribution System.” The language should be identical across the three utilities. **PG&E agrees to use language consistent with that of SCE and SDG&E in a supplemental advice letter.**
3. In Screen F1, the Utilities use different language in their footnotes. IREC recommends that the footnote to Screen F1 read:

“The protection limit is one of the components of the ICA Value that pertains to sensing faults on the grid.”

The Utilities agree to adopt IREC’s proposed language as a footnote in a supplemental advice letter.

For OP 8: – Modify Screen L to Include Transmission Overvoltage and Anti-islanding Tests (PG&E only)

PG&E proposed the modify Screen L as follow in AL 5915-E-A and IREC did not comment in its protest.

I. Screen L: Transmission Dependency, and **Transmission Stability**, **Ground Fault** Overvoltage, and / **Anti-Islanding Tests**

---

<sup>12</sup> IREC’s Protest to San Diego Gas & Electric’s Advice Letter 3677-E-A, Pacific Gas & Electric’s Advice Letter 5915-E-A, and Southern California Edison’s Advice Letter 4561-E – Proposed Modifications to the Electric Rule 21 Interconnection Application Process Pursuant to Decision 20-09-035.

<sup>13</sup> Pacific Gas and Electric Company (PG&E), Southern California Edison Company (SCE), and San Diego Gas & Electric Company’s (SDG&E) Joint Reply to the Protest from Interstate Renewable Energy Council, Inc. to PG&E Advice 5915-E-A, SCE Advice 4561-E, and SDG&E Advice 3677-E-A.

*Is the Interconnection Request for an area where:*

*(i) there are known, or posted, transient/dynamic stability limitations, or*

*(ii) the proposed Generating Facility has interdependencies, known to Distribution Provider, with earlier-queued Transmission System interconnection requests, or*

*(iii) islanding conditions are possible based on PG&E's currently adopted and published screening policies with respect to antiislanding screening, or*

*(iv) transmission ground fault overvoltage is possible based on PG&E's currently adopted and published screening policies with respect to overvoltage screening.*

*Where (i) or (ii) or (iii) or (iv) above are met, the impacts of this Interconnection Request to the Transmission System may require further Detailed Study.*

- If Yes (fail), Supplemental Review is required.*
- If No (pass), continue to Screen M.*

*Significance: Special consideration must be given to those areas identified as having current or future (due to currently-queued interconnection requests) grid stability concerns.*

*PG&E will temporarily apply anti-islanding tests until the resolution of Issue 18\* in R. 17-07-007, Working Group Four Report made effective in PG&E's tariffs.*

*\* Issue 18 is "Should the Commission adopt changes to anti-islanding screen parameters to reflect research on islanding risks when using UL 1741-certified inverters in order to avoid unnecessary mitigations? If yes, what should those changes entail?"*

*Therefore, each IOU please file a supplemental AL to*

1) **remove OPs 5 and 8<sup>14</sup> from the original ALs** (SDG&E AL 3677-E-A, SCE AL 4561-E, and PG&E AL 5915-E-A) and

2) *implement all language that the IOUs are in agreements with IREC into the Electric Rule 21 tariff.*

Also, each IOU please **submit a new AL only for OPs 5 & 8<sup>14</sup>** with the above agreed language. This AL should have a 10-day protest period.  
[bold added – red text in original]

This advice letter resubmits this advice letter specifically for OPs 5 and 8, which require:

5. *Proposal 8f1 is adopted. Pacific Gas and Electric Company, San Diego Gas & Electric Company, and Southern California Edison Company shall include a new Screen in the Interconnection Rule 21 process, to be named Screen F1, which will determine whether a generating system's short circuit contribution exceeds 1.2 per unit.*

8. *Option C of Proposal 8k<sup>15</sup> is adopted on an interim basis until resolution of Issue 18<sup>16</sup> in Working Group Four. Pacific Gas and Electric Company shall:*

*modify Screen L in Interconnection Rule 21 to include the transmission overvoltage and transmission anti-islanding tests currently in Screen M.*

PG&E submits this advice letter based on the guidance from Energy Division.

## **Tariff Revisions**

### **1) For OP 5:**

A) For the Screen F “significance” note, PG&E agrees to use language consistent with that of SCE and SDG&E in a supplemental advice letter. However, PG&E’s “significance” language in fact already aligned, so no redlines were needed, but on the cover advice letter PG&E had a typo (a deletion) that might

---

<sup>14</sup> In the original email this was “OP 6” but later it was clarified to be “OP 8”. It was explicitly requested that OP 6 not be addressed in this advice letter.

<sup>15</sup> Proposal 8k – See D. 20-09-035 Section 4.2.9 p26: Proposal 8k, involving Screen L, and comprises three options. Option C, which modifies the Screen to temporarily allow application of anti-islanding tests until Issue 18 can be resolved in Working Group Four was adopted Option C as a temporary solution until Issue 18 is resolved (Also see Conclusion of Law 10 p201 )

<sup>16</sup> Issue 19 See D. 20-09-035 p44. It asks whether the Commission should adopt changes to anti-islanding screen parameters. Issue 18 is being taken up in Working Group 4.

have given the impression we had different language. (PG&E regrets the typo.)

B) In Screen F1, PG&E agrees to use IREC recommended language (in BLUE) in the footnote to Screen F1 to read:

*“The protection limit is one of the components of the ICA Value that pertains to sensing faults on the grid.”*

## G. ENGINEERING REVIEW DETAILS (Cont'd.)

### 1. INITIAL REVIEW SCREENS (Cont'd.)

- e. Screen E: Does the Single-Phase Generator cause unacceptable imbalance? (Cont'd.)

Significance: Generating Facilities connected to a single-phase transformer with 120/240 V secondary voltage must be installed such that the aggregated gross output is as balanced as practicable between the two phases of the 240 volt service. When Distribution Provider's analysis determines a transformer change is required. Distribution Provider will furnish the customer with an explanation of why the change is needed.

- f. Screens F and F1:

**Screen F:** Is the Short Circuit Current Contribution Ratio within acceptable limits?

- If Yes (pass), continue to Screen **G-F1**.
- If No (fail), continue to Screen **G-F1** pursuant to Section G.1.

Note: This Screen does not apply to Generating Facilities with a Gross Rating of 11 kVA or less.

When measured at primary side (high side) of the Dedicated Distribution Transformer serving a Generating Facility, the sum of the Short Circuit Contribution Ratios of all Generating Facilities connected to Distribution Provider's Distribution System circuit that serves the Generating Facility must be less than or equal to 0.1.

Significance: If the Generating Facility passes this **S**screen, it can be expected that it will have no significant impact on Distribution Provider's Distribution System's short circuit duty, fault detection sensitivity, relay coordination or fuse-saving schemes.

**Screen F1:** Is the per unit Short Circuit Current Contribution under allowable levels?

Is the short circuit current contribution less than or equal to 1.2 per unit or is the Generating Facility Gross Nameplate Rating multiplied by its per unit contribution less than the Protection Integrated Capacity Analysis (ICA) Value<sup>1</sup> multiplied by 1.2 per unit?

- If Yes to either (pass), continue to Screen G.
- If No to both (fail), continue to Screen G pursuant to Section G.1.

Significance: Generating systems with a per unit short circuit contribution of 1.2 or less can bypass this screen and directly use the ICA because ICA calculations assume that Generating Facilities have a per unit short circuit contribution of 1.2. For Generating Facilities with a per unit short circuit contribution greater than 1.2, the Distribution Provider will use the protection ICA Value at the point of interconnection in conjunction with the Generating Facility's per unit short circuit contribution to determine whether the facility passes Screen F1.

<sup>1</sup>The protection limit is one of the components of the ICA Value that pertains to sensing faults on the grid.

*“The protection limit is one of the components of the ICA Value that pertains to sensing faults on the grid.”*

## 2) For OP 8:

Based on the guidance noted from Energy Division above, PG&E modifies Screen L as shown below.

### G. ENGINEERING REVIEW DETAILS (Cont'd.)

#### 1. INITIAL REVIEW SCREENS (Cont'd.)

##### I. Screen L: Transmission Dependency, and ~~Transmission~~ Stability, ~~Overvoltage, and Islanding~~ Tests

Is the Interconnection Request for an area where: (i) there are known, or posted, transient/~~dynamic~~ stability limitations, or (ii) the proposed Generating Facility has interdependencies, known to Distribution Provider, with earlier-queued Transmission System interconnection requests, ~~or (iii) islanding conditions are possible based on PG&E's currently adopted and published screening policies with respect to antiislanding, or (iv) transmission ground fault overvoltage is possible based on PG&E's currently adopted and published screening policies with respect to overvoltage screening.~~ Where (i) or (ii) ~~or (iii) or (iv)~~ above are met, the impacts of this Interconnection Request to the Transmission System may require ~~Detailed further~~ Study.

- If Yes (fail), Supplemental Review is required.
- If No (pass), continue to Screen M.


Significance: Special consideration must be given to those areas identified as having current or future (due to currently-queued interconnection requests) grid stability concerns.

PG&E will temporarily apply anti-islanding tests until the resolution of Issue 18\* in R. 17-07-007, Working Group Four Report made effective in PG&E's tariffs.

\* Issue 18 is "Should the Commission adopt changes to anti-islanding screen parameters to reflect research on islanding risks when using UL 1741-certified inverters in order to avoid unnecessary mitigations? If yes, what should those changes entail?"

### 3) Technical Framework Update

PG&E also makes changes to technical screen flowchart with updates consistent with the changes above. Specifically, PG&E modifies Screen M to be consistent with OP 8 changes above. And for clarity, it combines the two existing footnotes for (\*) and referenced in screen I into a single footnote (\*).



4) **Other**

PG&E also updates the table of contents to reflect the addition of Screen F1 for OP 5 above.

This submittal would not increase any current rate or charge, cause the withdrawal of service, or conflict with any rate schedule or rule.

**Protests**

**\*\*\*Due to the COVID-19 pandemic, PG&E is currently unable to receive protests or comments to this advice letter via U.S. mail or fax. Please submit protests or comments to this advice letter to [EDTariffUnit@cpuc.ca.gov](mailto:EDTariffUnit@cpuc.ca.gov) and [PGETariffs@pge.com](mailto:PGETariffs@pge.com)\*\*\***

Anyone wishing to protest this submittal may do so by letter sent via U.S. mail, facsimile or E-mail, no later than October 25, 2021, which is 10 days after the date of this submittal. This shortened protest period has been approved by Energy Division. Protests must be submitted to:

CPUC Energy Division  
ED Tariff Unit  
505 Van Ness Avenue, 4<sup>th</sup> Floor  
San Francisco, California 94102

Facsimile: (415) 703-2200  
E-mail: [EDTariffUnit@cpuc.ca.gov](mailto:EDTariffUnit@cpuc.ca.gov)

Copies of protests also should be mailed to the attention of the Director, Energy Division, Room 4004, at the address shown above.

The protest shall also be sent to PG&E either via E-mail or U.S. mail (and by facsimile, if possible) at the address shown below on the same date it is mailed or delivered to the Commission:

Sidney Bob Dietz II  
Director, Regulatory Relations  
c/o Megan Lawson  
Pacific Gas and Electric Company  
77 Beale Street, Mail Code B13U  
P.O. Box 770000  
San Francisco, California 94177

Facsimile: (415) 973-3582  
E-mail: [PGETariffs@pge.com](mailto:PGETariffs@pge.com)

Any person (including individuals, groups, or organizations) may protest or respond to an advice letter (General Order 96-B, Section 7.4). The protest shall contain the following information: specification of the advice letter protested; grounds for the protest; supporting factual information or legal argument; name, telephone number, postal address, and (where appropriate) e-mail address of the protestant; and statement that the protest was sent to the utility no later than the day on which the protest was submitted to the reviewing Industry Division (General Order 96-B, Section 3.11).

### **Effective Date**

Pursuant to General Order (GO) 96-B, Rule 5.2 and D.20-09-035 OP 55 (as corrected), and based on Energy Division guidance on OPs 5 and 8 of D.20-09-035, this advice letter is submitted with a Tier 2 designation. PG&E requests that this advice submittal become effective 180 to 240 days after it is approved, to allow to time to implement the Screen M ICA changes and related screen L changes, train staff and notify applicants of the changes.

### **Notice**

In accordance with General Order 96-B, Section IV, a copy of this advice letter is being sent electronically and via U.S. mail to parties shown on the attached list and the parties on the service list for R.17-07-007. Address changes to the General Order 96-B service list should be directed to PG&E at email address PGETariffs@pge.com. For changes to any other service list, please contact the Commission's Process Office at (415) 703-2021 or at Process\_Office@cpuc.ca.gov. Send all electronic approvals to PGETariffs@pge.com. Advice letter submittals can also be accessed electronically at: <http://www.pge.com/tariffs/>.

\_\_\_\_\_  
/S/

Sidney Bob Dietz II  
Director, Regulatory Relations

### **Attachments:**

Attachment 1: Tariffs  
Attachment 2: Redline Tariff Revisions

cc: Service List R.17-07-007



# ADVICE LETTER SUMMARY

## ENERGY UTILITY



MUST BE COMPLETED BY UTILITY (Attach additional pages as needed)

Company name/CPUC Utility No.: Pacific Gas and Electric Company (ID U39E)

Utility type:

- ELC       GAS       WATER  
 PLC       HEAT

Contact Person: Kimberly Loo

Phone #: (415)973-4587

E-mail: PGETariffs@pge.com

E-mail Disposition Notice to: KELM@pge.com

EXPLANATION OF UTILITY TYPE

ELC = Electric      GAS = Gas      WATER = Water  
 PLC = Pipeline      HEAT = Heat

(Date Submitted / Received Stamp by CPUC)

Advice Letter (AL) #: 6363-E

Tier Designation: 2

Subject of AL: Modifications to Electric Rule 21 Pursuant to Decision 20-09-035 Ordering Paragraphs 5 and 8

Keywords (choose from CPUC listing): Compliance, Rule 21

AL Type:  Monthly  Quarterly  Annual  One-Time  Other:

If AL submitted in compliance with a Commission order, indicate relevant Decision/Resolution #: D.20-09-035

Does AL replace a withdrawn or rejected AL? If so, identify the prior AL: No

Summarize differences between the AL and the prior withdrawn or rejected AL:

Confidential treatment requested?  Yes  No

If yes, specification of confidential information:

Confidential information will be made available to appropriate parties who execute a nondisclosure agreement. Name and contact information to request nondisclosure agreement/ access to confidential information:

Resolution required?  Yes  No

Requested effective date:

No. of tariff sheets: 9

Estimated system annual revenue effect (%): N/A

Estimated system average rate effect (%): N/A

When rates are affected by AL, include attachment in AL showing average rate effects on customer classes (residential, small commercial, large C/I, agricultural, lighting).

Tariff schedules affected: See Attachment 1

Service affected and changes proposed<sup>1</sup>: N/A

Pending advice letters that revise the same tariff sheets: 6014-E-A, 6286-E, 5915-E-A

<sup>1</sup>Discuss in AL if more space is needed.

**Protests and all other correspondence regarding this AL are due no later than 20 days after the date of this submittal, unless otherwise authorized by the Commission, and shall be sent to:**

CPUC, Energy Division  
Attention: Tariff Unit  
505 Van Ness Avenue  
San Francisco, CA 94102  
Email: [EDTariffUnit@cpuc.ca.gov](mailto:EDTariffUnit@cpuc.ca.gov)

Name: Sidney Bob Dietz II, c/o Megan Lawson  
Title: Director, Regulatory Relations  
Utility Name: Pacific Gas and Electric Company  
Address: 77 Beale Street, Mail Code B13U  
City: San Francisco, CA 94177  
State: California Zip: 94177  
Telephone (xxx) xxx-xxxx: (415)973-2093  
Facsimile (xxx) xxx-xxxx: (415)973-3582  
Email: [PGETariffs@pge.com](mailto:PGETariffs@pge.com)

Name:  
Title:  
Utility Name:  
Address:  
City:  
State: District of Columbia Zip:  
Telephone (xxx) xxx-xxxx:  
Facsimile (xxx) xxx-xxxx:  
Email:

Cal P.U.C. Sheet No.	Title of Sheet	Cancelling Cal P.U.C. Sheet No.
51650-E	ELECTRIC RULE NO. 21 GENERATING FACILITY INTERCONNECTIONS Sheet 6	50812-E
51651-E	ELECTRIC RULE NO. 21 GENERATING FACILITY INTERCONNECTIONS Sheet 145	50415-E
51652-E	ELECTRIC RULE NO. 21 GENERATING FACILITY INTERCONNECTIONS Sheet 151	50421-E
51653-E*	ELECTRIC RULE NO. 21 GENERATING FACILITY INTERCONNECTIONS Sheet 152	50422-E
51654-E	ELECTRIC RULE NO. 21 GENERATING FACILITY INTERCONNECTIONS Sheet 153	50423-E
51655-E	ELECTRIC RULE NO. 21 GENERATING FACILITY INTERCONNECTIONS Sheet 159	50826-E
51656-E	ELECTRIC RULE NO. 21 GENERATING FACILITY INTERCONNECTIONS Sheet 160	50827-E
51657-E	ELECTRIC TABLE OF CONTENTS Sheet 1	51615-E
51658-E*	ELECTRIC TABLE OF CONTENTS Sheet 20	51480-E



**ELECTRIC RULE NO. 21**  
**GENERATING FACILITY INTERCONNECTIONS**

Sheet 6

TABLE OF CONTENTS (Cont'd.)

G.	ENGINEERING REVIEW DETAILS (Cont'd.)		
1.	INITIAL REVIEW SCREENS (Cont'd.)		
	d. Screen D: Is the transformer or secondary conductor rating exceeded?	150	
	e. Screen E: Does the Single-Phase Generator cause unacceptable imbalance?	150	
	f. Screen F: Is the Short Circuit Current Contribution Ratio within acceptable limits?	151	
	Screen F1: Is the per unit Short Circuit Current Contribution under allowable levels?	152	(N)
	g. Screen G: Is the Short Circuit Interrupting Capability Exceeded?	152	(N)
	h. Screen H: Is the line configuration compatible with the Interconnection type?	153	
	i. Screen I: Will power be exported across the PCC?	154	
	j. Screen J: Is the Gross Rating of the Generating Facility 11 kVA or less?	158	
	k. Screen K: Is the Generating Facility a Net Energy Metering (NEM) Generating Facility with nameplate capacity less than or equal to 500kW?	158	
	l. Screen L: Transmission Dependency and Transmission Stability Test	159	
	m. Screen M: Is the aggregate Generating Facility capacity on the Line Section less than 15% of Line Section peak load for all line sections bounded by automatic sectionalizing devices?	159	

(Continued)





**ELECTRIC RULE NO. 21**  
**GENERATING FACILITY INTERCONNECTIONS**

Sheet 151

**G. ENGINEERING REVIEW DETAILS (Cont'd.)**

**1. INITIAL REVIEW SCREENS (Cont'd.)**

- e. Screen E: Does the Single-Phase Generator cause unacceptable imbalance? (Cont'd.)

Significance: Generating Facilities connected to a single-phase transformer with 120/240 V secondary voltage must be installed such that the aggregated gross output is as balanced as practicable between the two phases of the 240 volt service. When Distribution Provider's analysis determines a transformer change is required. Distribution Provider will furnish the customer with an explanation of why the change is needed.

- f. Screens F and F1: (T)

Screen F: Is the Short Circuit Current Contribution Ratio within acceptable limits? (N)  
(N)

- If Yes (pass), continue to Screen F1. (T)

- If No (fail), continue to Screen F1 pursuant to Section G.1. (T)

Note: This Screen does not apply to Generating Facilities with a Gross Rating of 11 kVA or less.

When measured at primary side (high side) of the Dedicated Distribution Transformer serving a Generating Facility, the sum of the Short Circuit Contribution Ratios of all Generating Facilities connected to Distribution Provider's Distribution System circuit that serves the Generating Facility must be less than or equal to 0.1.

Significance: If the Generating Facility passes this screen, it can be expected that it will have no significant impact on Distribution Provider's Distribution System's short circuit duty, fault detection sensitivity, relay coordination or fuse-saving schemes. (T)

(Continued)



**ELECTRIC RULE NO. 21**  
**GENERATING FACILITY INTERCONNECTIONS**

Sheet 152

**G. ENGINEERING REVIEW DETAILS (Cont'd.)**

**1. INITIAL REVIEW SCREENS (Cont'd.)**

**f. Screens F and F1 (Cont'd):**

Screen F1: Is the per unit Short Circuit Current Contribution under allowable levels?

Is the short circuit current contribution less than or equal to 1.2 per unit or is the Generating Facility Gross Nameplate Rating multiplied by its per unit contribution less than the Protection Integrated Capacity Analysis (ICA) Value<sup>1</sup> multiplied by 1.2 per unit?

- If Yes to either (pass), continue to Screen G.
- If No to both (fail), continue to Screen G pursuant to Section G.1.

Significance: Generating systems with a per unit short circuit contribution of 1.2 or less can bypass this screen and directly use the ICA because ICA calculations assume that Generating Facilities have a per unit short circuit contribution of 1.2. For Generating Facilities with a per unit short circuit contribution greater than 1.2, the Distribution Provider will use the Protection ICA Value at the point of interconnection in conjunction with the Generating Facility's per unit short circuit contribution to determine whether the facility passes Screen F1.

**g. Screen G: Is the Short Circuit Interrupting Capability Exceeded?**

Does the proposed Generating Facility, in aggregate with other Generating Facilities on the distribution circuit, cause any distribution protective devices and equipment (including, but not limited to, substation breakers, fuse cutouts, and line reclosers), or Interconnection Request equipment on the system to exceed 87.5 % of the short circuit interrupting capability; or is the Interconnection proposed for a circuit that already exceeds 87.5 % of the short circuit interrupting capability?

- If Yes (fail) continue to Screen H pursuant to Section G.1.
- If No (pass), continue to Screen H

<sup>1</sup>The protection limit is one of the components of the ICA Value that pertains to sensing faults on the grid.

(N)  
-----  
(N)

(L)  
(L)  
(L)  
(N)

(Continued)



**ELECTRIC RULE NO. 21  
GENERATING FACILITY INTERCONNECTIONS**

Sheet 153

**G. ENGINEERING REVIEW DETAILS (Cont'd.)**

**1. INITIAL REVIEW SCREENS (Cont'd.)**

- g. Screen G: Is the Short Circuit Interrupting Capability Exceeded? (Cont'd)

(L)

Note: This Screen does not apply to Generating Facilities with a Gross Rating of 11 kVA or less.

Significance: If the Generating Facility passes this screen, it can be expected that it will not cause any of Distribution Provider's equipment to be overstressed.

(L)

- h. Screen H: Is the line configuration compatible with the Interconnection type?

- If Yes (pass), continue to Screen I.
- If No (fail), continue to Screen I pursuant to Section G.1.

Note: This Screen does not apply to Generating Facilities with a Gross Rating of 11 kVA or less

Line Configuration Screen: Identify primary distribution line configuration that will serve the Generating Facility. Based on the type of Interconnection to be used for the Generating Facility, determine from Table G.1 if the proposed Generating Facility passes the Screen.

**Table G-1  
Type of Interconnection**

Primary Distribution Line Type Configuration	Type of Interconnection to be made to Primary Distribution Line	Result/Criteria
Three-phase, three-wire	Any type	Pass Screen
Three-phase, four-wire	Single-phase, line-to-neutral	Pass Screen
Three-phase, four-wire (For any line that has such a section OR mixed three-wire & four-wire)	All others	To pass, aggregate Generating Facility nameplate rating must be less than or equal to 10% of Line Section peak load

(Continued)

Advice 6363-E  
Decision D.20-09-035

Issued by  
**Robert S. Kenney**  
Vice President, Regulatory Affairs

Submitted  
Effective  
Resolution

October 15, 2021



**ELECTRIC RULE NO. 21**  
**GENERATING FACILITY INTERCONNECTIONS**

Sheet 159

**G. ENGINEERING REVIEW DETAILS (Cont'd.)**

**1. INITIAL REVIEW SCREENS (Cont'd.)**

I. Screen L: Transmission Dependency, and Stability, Overvoltage, and Islanding Tests (T)  
(T)

Is the Interconnection Request for an area where: (i) there are known, or posted, transient/dynamic stability limitations, or (ii) the proposed Generating Facility has interdependencies, known to Distribution Provider, with earlier-queued Transmission System interconnection requests, or (iii) islanding conditions are possible based on PG&E's currently adopted and published screening policies with respect to antiislanding, or (iv) transmission ground fault overvoltage is possible based on PG&E's currently adopted and published screening policies with respect to overvoltage screening. Where (i) or (ii) or (iii) or (iv) above are met, the impacts of this Interconnection Request to the Transmission System may require further Study. (T)  
(N)  
(N)  
(T)

- If Yes (fail), Supplemental Review is required.
- If No (pass), continue to Screen M.

Significance: Special consideration must be given to those areas identified as having current or future (due to currently-queued interconnection requests) grid stability concerns.

PG&E will temporarily apply anti-islanding tests until the resolution of **Issue 18\*** in R. 17-07-007, Working Group Four Report made effective in PG&E's tariffs. (N)  
(N)

\* Issue 18 is "Should the Commission adopt changes to anti-islanding screen parameters to reflect research on islanding risks when using UL 1741-certified inverters in order to avoid unnecessary mitigations? If yes, what should those changes entail?" (N)  
(N)

(Continued)



**ELECTRIC RULE NO. 21**  
**GENERATING FACILITY INTERCONNECTIONS**

Sheet 160

**G. ENGINEERING REVIEW DETAILS (Cont'd.)**

**1. INITIAL REVIEW SCREENS (Cont'd.)**

m. Screen M: Is the aggregate Generating Facility capacity on the Line Section less than 15% of Line Section peak load for all line sections bounded by automatic sectionalizing devices? <sup>ii</sup> (L)

- If Yes (pass), Initial Review is complete.
- If No (fail), Supplemental Review is required.

Significance:

1. Low penetration of Generating Facility capacity will have a minimal impact on the operation and load restoration efforts of Distribution Provider's Distribution System. (L)
2. The operating requirements for a high penetration of Generating Facility capacity may be different since the impact on Distribution Provider's Distribution System will no longer be minimal, therefore requiring additional study or controls.

The purpose of this Screen is solely to identify if the Generating Facility needs additional study and is not intended as justification for limiting the penetration of generation on a line section.

**2. SUPPLEMENTAL REVIEW SCREENS**

The Supplemental Review consists of Screens N through P. If any of the Screens are not passed, a quick review of the failed Screen(s) will determine the requirements to address the failure(s) or that Detailed Studies are required. In certain instances, Distribution Provider may be able to identify the necessary solution and determine that Detailed Studies are unnecessary. Some examples of solutions that may be available to mitigate the impact of a failed Screen are:

1. Replacing a fixed capacitor bank with a switched capacitor bank.
2. Adjustment of line regulation settings.
3. Simple reconfiguration of the distribution circuit.

<sup>ii</sup> Inadvertent Export systems that meet the requirements specified in Section Mm are processed under Screen M as described in Section Mm.

(Continued)



**ELECTRIC TABLE OF CONTENTS**

Sheet 1

**TABLE OF CONTENTS**

<b>SCHEDULE</b>	<b>TITLE OF SHEET</b>	<b>CAL P.U.C. SHEET NO.</b>	
Title Page.....		<b>51657-E</b>	(T)
Rate Schedules.....	51611,51612,51579,49701,50627,50628,50657,49654,49184-E		
Preliminary Statements.....	49185,48878,50629,50630,49682,50058,51616-E		
Rules.....	51617,50633,	<b>51658*-E</b>	(T)
Maps, Contracts and Deviations.....		50635-E	
Sample Forms.....	50636,50671,50672,50638,50639,50673,		
.....	50640,50641,51254,51487,49309,49310,49311-E		

(Continued)

Advice 6363-E  
Decision D.20-09-035

Issued by  
**Robert S. Kenney**  
Vice President, Regulatory Affairs

Submitted  
Effective  
Resolution

October 15, 2021



## Attachment 2

### Redline Tariff Revisions

For convenience of the reader, PG&E has included redline revisions in Attachment 2. Where Electric Rule 21 has been revised, the affected sheets are included in Attachment 1.

In this advice letter and accordance to CPUC General Order 96B, Section 9.5.3, PG&E has implemented the use of the “(P)” symbol to signify material subject to change under a pending advice letter. The redlines in Attachment 2 are color coded to the specific advice letter. The color coding is as follows:

Redline Text Color	Advice Letter	Subject	Comments
	6014-E-A	Supplemental: Advice Letter Modifying Electric Rule 21 Pursuant to Decision 20-09-035 for Working Group 2 and 3 (due 60 Days from Issuance)	Pending Approval
	6363-E	Modifications to Electric Rule 21 Pursuant to Decision 20-09-035 Ordering Paragraphs 5 and 8.	In this advice letter, revisions are made according to OP 5 and OP 8 of D.20-09-035.



**ELECTRIC RULE NO. 21**  
**GENERATING FACILITY INTERCONNECTIONS**

Sheet 6

TABLE OF CONTENTS (Cont'd.)

G.	ENGINEERING REVIEW DETAILS (Cont'd.)		
1.	INITIAL REVIEW SCREENS (Cont'd.)		
	d. Screen D: Is the transformer or secondary conductor rating exceeded?	150	
	e. Screen E: Does the Single-Phase Generator cause unacceptable imbalance?	150	
	f. Screen F: Is the Short Circuit Current Contribution Ratio within acceptable limits?	151	
	<u>Screen F1: Is the per unit Short Circuit Current Contribution under allowable levels?</u>	<u>152</u>	(N) (N)
	g. Screen G: Is the Short Circuit Interrupting Capability Exceeded?	152	
	h. Screen H: Is the line configuration compatible with the Interconnection type?	153	
	i. Screen I: Will power be exported across the PCC?	154	
	j. Screen J: Is the Gross Rating of the Generating Facility 11 kVA or less?	158	
	k. Screen K: Is the Generating Facility a Net Energy Metering (NEM) Generating Facility with nameplate capacity less than or equal to 500kW?	158	
	l. Screen L: Transmission Dependency and Transmission Stability Test	159	
	m. Screen M: Is the aggregate Generating Facility capacity on the Line Section less than 15% of Line Section peak load for all line sections bounded by automatic sectionalizing devices?	159	


(Continued)



**ELECTRIC RULE NO. 21**  
**GENERATING FACILITY INTERCONNECTIONS**

**G. ENGINEERING REVIEW DETAILS**

ADD FLOWCHART BELOW:



(T) [Vertical dashed line] (T)


(Continued)



**ELECTRIC RULE NO. 21**  
**GENERATING FACILITY INTERCONNECTIONS**

Sheet 145

DELETE FLOWCHART BELOW:



\* Non-Export AC/DC Converter installations that have a complete and valid Interconnection Request will be eligible to bypass screens B through D and F through M. If the Generating Facility meets the conditions in Screen I below (Section G.1.i), skip Screens K, L, and M.

(P)  
 (P)

(Continued)



**ELECTRIC RULE NO. 21**  
**GENERATING FACILITY INTERCONNECTIONS**

Sheet 151

G. ENGINEERING REVIEW DETAILS (Cont'd.)

1. INITIAL REVIEW SCREENS (Cont'd.)

- e. Screen E: Does the Single-Phase Generator cause unacceptable imbalance? (Cont'd.)

Significance: Generating Facilities connected to a single-phase transformer with 120/240 V secondary voltage must be installed such that the aggregated gross output is as balanced as practicable between the two phases of the 240 volt service. When Distribution Provider's analysis determines a transformer change is required. Distribution Provider will furnish the customer with an explanation of why the change is needed.

- f. Screens F and F1: (T)

Screen F: Is the Short Circuit Current Contribution Ratio within acceptable limits? (T)

- If Yes (pass), continue to Screen F1G. (T)

- If No (fail), continue to Screen G-F1 pursuant to Section G.1. (T)

Note: This Screen does not apply to Generating Facilities with a Gross Rating of 11 kVA or less.

When measured at primary side (high side) of the Dedicated Distribution Transformer serving a Generating Facility, the sum of the Short Circuit Contribution Ratios of all Generating Facilities connected to Distribution Provider's Distribution System circuit that serves the Generating Facility must be less than or equal to 0.1.

Significance: If the Generating Facility passes this sScreen, it can be expected that it will have no significant impact on Distribution Provider's Distribution System's short circuit duty, fault detection sensitivity, relay coordination or fuse-saving schemes. (T)

(Continued)



**ELECTRIC RULE NO. 21**  
**GENERATING FACILITY INTERCONNECTIONS**

G. ENGINEERING REVIEW DETAILS (Cont'd.)

1. INITIAL REVIEW SCREENS (Cont'd.)

f. Screens F and F1 (Cont'd):

(N)

Screen F1: Is the per unit Short Circuit Current Contribution under allowable levels?

Is the short circuit current contribution less than or equal to 1.2 per unit or is the Generating Facility Gross Nameplate Rating multiplied by its per unit contribution less than the Protection Integrated Capacity Analysis (ICA) Value<sup>1</sup> multiplied by 1.2 per unit?

- If Yes to either (pass), continue to Screen G.
- If No to both (fail), continue to Screen G pursuant to Section G.1.

Significance: Generating systems with a per unit short circuit contribution of 1.2 or less can bypass this screen and directly use the ICA because ICA calculations assume that Generating Facilities have a per unit short circuit contribution of 1.2. For Generating Facilities with a per unit short circuit contribution greater than 1.2, the Distribution Provider will use the protection ICA Value at the point of interconnection in conjunction with the Generating Facility's per unit short circuit contribution to determine whether the facility passes Screen F1.

(N)

g. Screen G: Is the Short Circuit Interrupting Capability Exceeded?

Does the proposed Generating Facility, in aggregate with other Generating Facilities on the distribution circuit, cause any distribution protective devices and equipment (including, but not limited to, substation breakers, fuse cutouts, and line reclosers), or Interconnection Request equipment on the system to exceed 87.5 % of the short circuit interrupting capability; or is the Interconnection proposed for a circuit that already exceeds 87.5 % of the short circuit interrupting capability?

- If Yes (fail) continue to Screen H pursuant to Section G.1.
- If No (pass), continue to Screen H

<sup>1</sup>The protection limit is one of the components of the ICA Value that pertains to sensing faults on the grid.

(N)  
(N)

(Continued)



**ELECTRIC RULE NO. 21**  
**GENERATING FACILITY INTERCONNECTIONS**

G. ENGINEERING REVIEW DETAILS (Cont'd.)

1. INITIAL REVIEW SCREENS (Cont'd.)

g. Screen G: Is the Short Circuit Interrupting Capability Exceeded? (Cont'd)

(L)

Note: This Screen does not apply to Generating Facilities with a Gross Rating of 11 kVA or less.

Significance: If the Generating Facility passes this screen, it can be expected that it will not cause any of Distribution Provider's equipment to be overstressed.

(L)

h. Screen H: Is the line configuration compatible with the Interconnection type?

- If Yes (pass), continue to Screen I.
- If No (fail), continue to Screen I pursuant to Section G.1.

Note: This Screen does not apply to Generating Facilities with a Gross Rating of 11 kVA or less

Line Configuration Screen: Identify primary distribution line configuration that will serve the Generating Facility. Based on the type of Interconnection to be used for the Generating Facility, determine from Table G.1 if the proposed Generating Facility passes the Screen.

**Table G-1**  
**Type of Interconnection**

Primary Distribution Line Type Configuration	Type of Interconnection to be made to Primary Distribution Line	Result/Criteria
Three-phase, three-wire	Any type	Pass Screen
Three-phase, four-wire	Single-phase, line-to-neutral	Pass Screen
Three-phase, four-wire (For any line that has such a section OR mixed three-wire & four-wire)	All others	To pass, aggregate Generating Facility nameplate rating must be less than or equal to 10% of Line Section peak load

(Continued)



**ELECTRIC RULE NO. 21**  
**GENERATING FACILITY INTERCONNECTIONS**

Sheet 159

G. ENGINEERING REVIEW DETAILS (Cont'd.)

1. INITIAL REVIEW SCREENS (Cont'd.)

I. Screen L: Transmission Dependency<sub>1</sub> and ~~Transmission~~ Stability<sub>1</sub> (T)  
Overvoltage, and Islanding Tests (T)

Is the Interconnection Request for an area where: (i) there are known, or posted, transient/dynamic stability limitations, or (ii) the proposed Generating Facility has interdependencies, known to Distribution Provider, with earlier-queued Transmission System interconnection requests, or (iii) islanding conditions are possible based on PG&E's currently adopted and published screening policies with respect to antiislanding, or (iv) transmission ground fault overvoltage is possible based on PG&E's currently adopted and published screening policies with respect to overvoltage screening. Where (i) or (ii) or (iii) or (iv) above are met, the impacts of this Interconnection Request to the Transmission System may require Detailed-further Study. (T)

- If Yes (fail), Supplemental Review is required.
- If No (pass), continue to Screen M.

Significance: Special consideration must be given to those areas identified as having current or future (due to currently-queued interconnection requests) grid stability concerns.

PG&E will temporarily apply anti-islanding tests until the resolution of Issue 18\* in R. 17-07-007, Working Group Four Report made effective in PG&E's tariffs. (N)  
(N)

\* Issue 18 is "Should the Commission adopt changes to anti-islanding screen parameters to reflect research on islanding risks when using UL 1741-certified inverters in order to avoid unnecessary mitigations? If yes, what should those changes entail?" (N)  
(N)

(Continued)



**PG&E Gas and Electric  
Advice Submittal List  
General Order 96-B, Section IV**

AT&T  
Albion Power Company

Alta Power Group, LLC  
Anderson & Poole

Atlas ReFuel  
BART

Barkovich & Yap, Inc.  
California Cotton Ginners & Growers Assn  
California Energy Commission

California Hub for Energy Efficiency  
Financing

California Alternative Energy and  
Advanced Transportation Financing  
Authority  
California Public Utilities Commission  
Calpine

Cameron-Daniel, P.C.  
Casner, Steve  
Cenergy Power  
Center for Biological Diversity

Chevron Pipeline and Power  
City of Palo Alto

City of San Jose  
Clean Power Research  
Coast Economic Consulting  
Commercial Energy  
Crossborder Energy  
Crown Road Energy, LLC  
Davis Wright Tremaine LLP  
Day Carter Murphy

Dept of General Services  
Don Pickett & Associates, Inc.  
Douglass & Liddell

East Bay Community Energy Ellison  
Schneider & Harris LLP Energy  
Management Service  
Engineers and Scientists of California

GenOn Energy, Inc.  
Goodin, MacBride, Squeri, Schlotz &  
Ritchie

Green Power Institute  
Hanna & Morton  
ICF

IGS Energy  
International Power Technology

Intertie

Intestate Gas Services, Inc.  
Kelly Group  
Ken Bohn Consulting  
Keyes & Fox LLP  
Leviton Manufacturing Co., Inc.

Los Angeles County Integrated  
Waste Management Task Force  
MRW & Associates  
Manatt Phelps Phillips  
Marin Energy Authority  
McKenzie & Associates

Modesto Irrigation District  
NLine Energy, Inc.  
NRG Solar

OnGrid Solar  
Pacific Gas and Electric Company  
Peninsula Clean Energy

Pioneer Community Energy

Public Advocates Office

Redwood Coast Energy Authority  
Regulatory & Cogeneration Service, Inc.  
SCD Energy Solutions  
San Diego Gas & Electric Company

SPURR  
San Francisco Water Power and Sewer  
Semptra Utilities

Sierra Telephone Company, Inc.  
Southern California Edison Company  
Southern California Gas Company  
Spark Energy

Sun Light & Power  
Sunshine Design  
Tecogen, Inc.  
TerraVerde Renewable Partners  
Tiger Natural Gas, Inc.

TransCanada  
Utility Cost Management  
Utility Power Solutions  
Water and Energy Consulting Wellhead  
Electric Company  
Western Manufactured Housing  
Communities Association (WMA)  
Yep Energy