PUBLIC UTILITIES COMMISSION

505 VAN NESS AVENUE SAN FRANCISCO, CA 94102-3298



October 1, 2008

Advice Letter 3270-E

Brian K. Cherry Vice President, Regulatory Relations Pacific Gas and Electric Company 77 Beale Street, Mail Code B10C P.O. Box 770000 San Francisco, CA 94177

Subject: Submits Notice of Construction, Pursuant to General Order 131-D, for the Gold Hill-Clarksville 115 kV and Gold Hill #1 60 kV Reconductoring Project in the Cities of Folsom and El Dorado Hills

Dear Mr. Cherry:

Advice Letter 3270-E is effective June 15, 2008.

Sincerely,

Kenneth Lewis, Acting Director

Energy Division



Brian K. Cherry Vice President Regulatory Relations Pacific Gas and Electric Company 77 Beale St., Mail Code B10C P.O. Box 770000 San Francisco, CA 94177

Fax: 415.973.7226

May 16, 2008

Advice 3270-E (Pacific Gas and Electric Company ID U 39E)

Public Utilities Commission of the State of California

Subject: Submits Notice of Construction, Pursuant to General Order 131-D,

for the Gold Hill-Clarksville 115kV and Gold Hill #1 60k\
Reconductoring Project in the Cities of Folsom and El Dorado Hills

Pacific Gas and Electric Company (the Company) hereby submits notice pursuant to General Order (G.O.) 131-D, Section XI, Subsection B.4, of the construction of facilities that are exempt from a Permit to Construct.

Purpose

This advice letter provides a copy of the Notice of Proposed Construction (Attachment I) and the Notice Distribution List, which comply with the noticing requirements found in G.O. 131-D, Section XI.

Background

In order to maintain service reliability and meet increasing electric load demands in El Dorado County, Pacific Gas and Electric Company (PG&E) is proposing to reconductor (replace the existing wires with new wires) the existing Gold Hill-Clarksville 115kV and Gold Hill#1 60kV power lines, which are co-located on the same tubular steel poles and wood poles in this location. The project will consist of replacing the existing wires with new wires (replacement of existing facilities) on the existing tubular steel poles and wood poles in the same alignment (existing public utility easement) between Gold Hill Substation in the City of Folsom and Clarksville Substation in the City of El Dorado Hills, a distance of approximately 6 miles. To meet existing standards for the new conductor, 15 wood poles will be replaced with approximately 5-10' taller self-weathering light-duty steel poles. Construction is scheduled to begin in September 2008 or as soon thereafter as possible, with completion in approximately eight months or as soon as possible after construction begins.

 This project qualifies as exempt from Permit to Construct filing requirements, pursuant to G.O. 131-D, Section III, Subsection B.1., which exempts, "The replacement of existing power line facilities or supporting structures with equivalent facilities or structures" and "Power line facilities or substations to be located in an existing franchise, road widening setback easement, or public utility easement; or in a utility corridor designated, precisely mapped and officially adopted pursuant to law by federal, state, or local agencies for which a final Negative Declaration or EIR finds no significant unavoidable environmental impacts."

Additionally, G.O. 131-D requires utilities to employ "no cost" and specified "low cost" measures to reduce public exposure to electric and magnetic fields (EMFs) in accordance with CPUC Decision 06-01-042 and the "EMF Guidelines for Electrical Facilities." The following measures are proposed for this project:

• Optimize phase configuration by "cross-phasing" individual circuits to cancel magnetic fields.

Protests

Anyone wishing to protest this filing may do so by letter sent via U.S. mail, by facsimile or electronically, any of which must be received no later than **June 5, 2008**, which is 20 days after the date of this filing. Protests should be mailed to:

CPUC Energy Division
Tariff Files, Room 4005
DMS Branch
505 Van Ness Avenue
San Francisco, California 94102

Facsimile: (415) 703-2200

E-mail: ini@cpuc.ca.gov and mas@cpuc.ca.gov

Copies of protests also should be mailed to the attention of the Director, Energy Division, Room 4004, at the address shown above.

The protest also should be sent via U.S. mail (and by facsimile and electronically, if possible) to PG&E at the address shown below on the same date it is mailed or delivered to the Commission:

David T. Kraska
Attorney, Law Department
Pacific Gas and Electric Company
P.O. Box 7442
San Francisco, California 94120

Facsimile: (415) 973-0516

Brian K. Cherry
Vice President, Regulatory Relations
Pacific Gas and Electric Company
77 Beale Street, Mail Code B10C
P.O. Box 770000
San Francisco, California 94177

Facsimile: (415) 973-7226 E-mail: PGETariffs@pge.com

Persons or groups may protest the proposed construction if they believe that the Company has incorrectly applied for an exemption or that the conditions set out in Section III.B.2 of G.O. 131-D exist.

Effective Date

The Company requests that this advice filing become effective on **June 15, 2008**, which is 30 calendar days after the date of filing. (In accordance with G.O. 131-D, construction will not begin until 45 days after notice is first published.)

Notice

In accordance with G.O. 96-B, Section IV, a copy of this advice letter is being sent electronically and via U.S. mail to parties shown on the attached list, including the parties listed in G.O. 131-D, Section XI, Paragraphs B.1 and B.2. These parties are identified in the "Notice Distribution List" included in Attachment I. Address changes to the General Order 96-B service list should be directed to Rose de la Torre at (415) 973-4716. Send all electronic approvals to PGETariffs@pge.com. Advice letter filings can also be accessed electronically at: http://www.pge.com/tariffs.

Vice President, Regulatory Relations

Brian Cherry / Oni

Attachments

cc: Parties Listed in G.O. 131-D, Paragraphs B.1 and B.2

CALIFORNIA PUBLIC UTILITIES COMMISSION

ADVICE LETTER FILING SUMMARY ENERGY UTILITY

MUST BE COMPLETED BY UTILITY (Attach additional pages as needed)				
Company name/CPUC Utility No. Pacific Gas and Electric Company (ID U39 M)				
Utility type: Con		Contact Person: Linda Tom-Martinez		
☑ ELC ☑ GAS Phone #:		Phone #: (415) 973-46	one #: (415) 973-4612	
□ PLC	□ HEAT □ WATER	E-mail: lmt1@pge.com		
EXPLANATION OF UTILITY TYPE			(Date Filed/ Received Stamp by CPUC)	
ELC = Electric $GAS = Gas$			(
PLC = Pipeline HEAT = Heat WATER = Water				
Advice Letter (AL) #: 3270-E Subject of AL: Gold Hill-Clarksville 115kV and Gold Hill #1 60kV Reconductoring Project (Cities of Folsom and El Dorado Hills)				
Keywords (choose from CPUC listing): <u>Power Lines</u>				
AL filing type: ☐ Monthly ☐ Quarterly ☐ Annual ☑ One-Time ☐ Other				
If AL filed in compliance with a Commission order, indicate relevant Decision/Resolution #:				
Does AL replace a withdrawn or rejected AL? If so, identify the prior AL: No				
Summarize differences between the AL and the prior withdrawn or rejected AL1:				
Is AL requesting confidential treatment? If so, what information is the utility seeking confidential treatment for:				
Confidential information will be made available to those who have executed a nondisclosure agreement: \square Yes \square No				
Name(s) and contact information of the person(s) who will provide the nondisclosure agreement and access to the confidential information:				
Resolution Required? □ Yes ☑ No				
Requested effective date: <u>June 15, 2008</u>			No. of tariff sheets: N/A	
Estimated system annual revenue effect (%): N/A				
Estimated system average rate effect (%): <u>N/A</u>				
When rates are affected by AL, include attachment in AL showing average rate effects on customer classes (residential, small commercial, large C/I, agricultural, lighting).				
Tariff schedules affected: <u>N/A</u>				
Service affected and changes proposed ¹ : <u>N/A</u>				
Pending advice letters that revise the same tariff sheets: $\underline{N/A}$				
Protests, dispositions, and all other correspondence regarding this AL are due no later than 20 days after the date of this filing, unless otherwise authorized by the Commission, and shall be sent to:				
CPUC, Energy			c Gas and Electric Company	
Tariff Files, Ro	oom 4005		Attn: Brian K. Cherry Vice President, Regulatory Relations	
DMS Branch	A vo		ale Street, Mail Code B10C	
505 Van Ness A San Francisco,	· ·	P.O. 1	Box 770000	
			rancisco, CA 94177 il: PGETariffs@pge.com	

NOTICE OF PROPOSED CONSTRUCTION

PROJECT NAME: GOLD HILL-CLARKSVILLE 115kV AND GOLD HILL #1 60kV RECONDUCTORING PROJECT (CITIES OF FOLSOM AND EL DORADO HILLS)

ADVICE LETTER NUMBER: 3270-E

Proposed Project: In order to maintain service reliability and meet increasing electric load demands in El Dorado County, Pacific Gas and Electric Company (PG&E) is proposing to reconductor (replace the existing wires with new wires) the existing Gold Hill-Clarksville 115kV and Gold Hill #1 60kV power lines, which are co-located on the same tubular steel poles and wood poles in this location. The project will consist of replacing the existing wires with new wires (replacement of existing facilities) on the existing tubular steel poles and wood poles in the same alignment (existing public utility easement) between Gold Hill Substation in the City of Folsom and Clarksville Substation in the City of El Dorado Hills, a distance of approximately 6 miles. To meet existing standards for the new conductor, 15 wood poles will be replaced with approximately 5-10' taller self-weathering light-duty steel poles. Construction is scheduled to begin in September 2008 or as soon thereafter as possible, with completion in approximately eight months or as soon as possible after construction begins.

Electric and Magnetic Fields (EMF): Pacific Gas and Electric Company will employ "no cost" and specified "low cost" measures to reduce public exposure to EMF in accordance with California Public Utilities Commission (CPUC) Decision 06-01-042 and Pacific Gas and Electric Company's "EMF Design Guidelines for Electrical Facilities." The following measures are proposed for this project::

Optimize phase configuration by "cross-phasing" individual circuits to cancel magnetic fields.

Exemption from CPUC Permit Requirement: CPUC General Order 131-D, Section III, B.1, exempts projects meeting specific conditions from the CPUC's requirement to file an application requesting authority to construct. Pacific Gas and Electric Company believes this project qualifies for the following exemption:

- The replacement of existing power line facilities or supporting structures with equivalent facilities or structures.
- Power line facilities or substations to be located in an existing franchise, road-widening setback easement, or public utility easement; or in a
 utility corridor designated, precisely mapped and officially adopted pursuant to law by federal, state, or local agencies for which a final Negative
 Declaration or EIR finds no significant unavoidable environmental impacts.

Public Review Process: Persons or groups may protest the proposed construction if they believe that Pacific Gas and Electric Company has incorrectly applied for an exemption or that the conditions set out in Section III.B.2 of General Order 131-D exist;

- a. There is reasonable possibility that the activity may have an impact on an environmental resource of hazardous or critical concern where designated, precisely mapped and officially adopted pursuant to law by federal, state, or local agencies; or
- b. The cumulative impact of successive projects of the same type in the same place, over time, is significant; or
- c. There is a reasonable possibility that the activity will have a significant effect on the environment due to unusual circumstances.

Protests should include the following:

- 1. Your name, mailing address and daytime telephone number.
- 2. Reference to the CPUC Advice Letter Number and Project Name.
- 3. A clear description of the reason for the protest.
- 4. Whether you believe that evidentiary hearings are necessary to resolve factual disputes.

Protests for this project must be filed by June 5, 2008 at the following address:

Director, Energy Division California Public Utilities Commission 505 Van Ness Avenue, Fourth Floor San Francisco, California 94102

With a copy mailed to:

David Kraska, Law Department Pacific Gas and Electric Company P.O. Box 7442 San Francisco, California 94120

Pacific Gas and Electric Company must respond within five business days of receipt and serve copies of its response on each protestant and the Energy Division. Within 30 days after Pacific Gas and Electric Company has submitted its response, the Executive Director of the CPUC will send you a copy of an Executive Resolution granting or denying the request and stating the reasons for the decision.

Assistance in Filing a Protest: For assistance in filing a protest, contact the CPUC Public Advisor in San Francisco at (415) 703-2074 or 1-866-849-8390 (toll-free) or TTY (415) 703-5258 or public.advisor@cpuc.ca.gov.

Additional Project Information: To obtain further information on the proposed project, please call Pacific Gas and Electric Company's Project Information Line at (415) 973-5530.

Notice Distribution List

GOLD HILL-CLARKSVILLE 115kV AND GOLD HILL #1 60kV RECONDUCTORING PROJECT (CITIES OF FOLSOM AND EL DORADO HILLS)

Advice 3270-E

Energy Commission

Ms. Melissa Jones, Executive Director California Energy Commission 1516 Ninth Street, Mail Stop 39 Sacramento, California 95814

Mr. Terry O'Brien, Deputy Director California Energy Commission 1516 Ninth Street, Mail Stop 39 Sacramento, California 95814

El Dorado Hills Community Services District

Dianna Hillyer Planning Director 1021 Harvard Way El Dorado Hills, CA 95762 (916) 614-3210

City of Folsom

David Miller Community Development Director 50 Natoma Street Folsom, CA 95630 (916) 355-7224

Newspaper

The Mountain Democrat 1360 Broadway P.O. Box 1088 Placerville, CA 95667 (530) 622-1255

The Sacramento Bee 2100 Q Street P.O. Box 15779 Sacramento, Ca 95816 (916) 321-1000

PG&E Gas and Electric Advice Filing List General Order 96-B, Section IV

ABAG Power Pool Accent Energy

Aglet Consumer Alliance
Agnews Developmental Center

Ahmed, Ali Alcantar & Kahl

Ancillary Services Coalition
Anderson Donovan & Poole P.C.
Applied Power Technologies
APS Energy Services Co Inc

Arter & Hadden LLP

Avista Corp

Barkovich & Yap, Inc.

BART

Bartle Wells Associates

Blue Ridge Gas

Bohannon Development Co BP Energy Company Braun & Associates C & H Sugar Co.

CA Bldg Industry Association

CA Cotton Ginners & Growers Assoc.

CA League of Food Processors

CA Water Service Group
California Energy Commission
California Farm Bureau Federation
California Gas Acquisition Svcs

California ISO Calpine Calpine Corp

Calpine Gilroy Cogen

Cambridge Energy Research Assoc

Cameron McKenna
Cardinal Cogen
Cellnet Data Systems
Chevron Texaco

Chevron USA Production Co.

City of Glendale
City of Healdsburg
City of Palo Alto
City of Redding
CLECA Law Office
Commerce Energy
Constellation New Energy

CPUC

Cross Border Inc
Crossborder Inc
CSC Energy Services
Davis, Wright, Tremaine LLP
Defense Fuel Support Center
Department of the Army

Department of Water & Power City

DGS Natural Gas Services

Douglass & Liddell

Downey, Brand, Seymour & Rohwer

Duke Energy

Duke Energy North America

Duncan, Virgil E.

Dutcher, John

Dynegy Inc.

Ellison Schneider

Energy Law Group LLP

Energy Management Services, LLC

Exelon Energy Ohio, Inc Exeter Associates Foster Farms

Foster, Wheeler, Martinez Franciscan Mobilehome

Future Resources Associates, Inc

G. A. Krause & Assoc

Gas Transmission Northwest Corporation

GLJ Energy Publications

Goodin, MacBride, Squeri, Schlotz &

Hanna & Morton Heeg, Peggy A.

Hitachi Global Storage Technologies

Hogan Manufacturing, Inc

House, Lon

Imperial Irrigation District

Integrated Utility Consulting Group International Power Technology Interstate Gas Services, Inc. IUCG/Sunshine Design LLC

J. R. Wood, Inc JTM, Inc

Luce, Forward, Hamilton & Scripps

Manatt, Phelps & Phillips

Marcus, David

Maynor, Donald H.

Matthew V. Brady & Associates

MBMC, Inc.
McKenzie & Assoc
McKenzie & Associates
Meek, Daniel W.
Mirant California, LLC
Modesto Irrigation Dist
Morrison & Foerster

Morse Richard Weisenmiller & Assoc.

Navigant Consulting
New United Motor Mfg, Inc
Norris & Wong Associates
North Coast Solar Resources
Northern California Power Agency
Office of Energy Assessments

OnGrid Solar

Palo Alto Muni Utilities

PG&E National Energy Group Pinnacle CNG Company

PITCO Plurimi. Inc.

PPL EnergyPlus, LLC

Praxair, Inc. Price. Rov

Product Development Dept R. M. Hairston & Company R. W. Beck & Associates

Recon Research

Regional Cogeneration Service

RMC Lonestar

Sacramento Municipal Utility District

SCD Energy Solutions Seattle City Light

Sempra

Sempra Energy

Sequoia Union HS Dist

SESCO

Sierra Pacific Power Company

Silicon Valley Power

Smurfit Stone Container Corp Southern California Edison

SPURR

St. Paul Assoc

Sutherland, Asbill & Brennan Tabors Caramanis & Associates

Tecogen, Inc TFS Energy Transcanada

Turlock Irrigation District

U S Borax, Inc United Cogen Inc. URM Groups

Utility Resource Network
Wellhead Electric Company

White & Case

WMA