

PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans
Rulemaking 18-10-007
Data Response

PG&E Data Request No.:	CalAdvocates_041-Q09		
PG&E File Name:	WildfireMitigationPlans_DR_CalAdvocates_041-Q09		
Request Date:	February 19, 2021	Requester DR No.:	CalAdvocates-PGE-2021WMP-07
Date Sent:	February 24, 2021	Requesting Party:	Public Advocates Office
PG&E Witness:		Requester:	Alan Wehrman

SUBJECT: NON-SPATIAL DATA TABLES

The following questions relate to the attachment “Attachment 1 - All Data Tables Required by 2021 WMP Guidelines.xlsx.” For the purposes of these questions, the term “high-priority findings” refers to the combined number of Level 1 and Level 2 findings.

QUESTION 09

Per Table 1, the number of high-priority findings per distribution mile inspected in the HFTD averaged 0.05 for 2015 to 2018, then rose to 0.29 in 2019 and 0.17 in 2020. Please explain the causes or reasons for the increase in the last two years.

ANSWER 09

In 2019 PG&E implemented Enhanced Inspections. These inspections were above and beyond our normal GO165 requirements, which resulted in an increase of findings.