

**PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans Discovery 2023
Data Response**

PG&E Data Request No.:	CalAdvocates_009-Q011		
PG&E File Name:	WMP-Discovery2023_DR_CalAdvocates_009-Q011		
Request Date:	April 4, 2023	Requester DR No.:	CalAdvocates-PGE-2023WMP-09
Date Sent:	April 7, 2023	Requesting Party:	Public Advocates Office
DRU Index #:		Requester:	Holly Wehrman

Grid Design and System Hardening

QUESTION 011

P. 969 of PG&E's WMP states, "on average, it takes 1.25 UG install miles to replace 1 OH mile. However, at times, this multiplier can be 2-3 times greater."

Does PG&E's target of 10,000 miles of undergrounding refer to the number of OH circuit-miles to be moved underground, or the number of underground circuit-miles to be installed?

ANSWER 011

The 10,000 mile target refers to the number of miles of underground conductor and aligned with the assumption of removing approximately 8,100 overhead circuit miles.